

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8901030059      DOC. DATE: 88/12/27      NOTARIZED: NO      DOCKET #  
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315  
 AUTH. NAME      AUTHOR AFFILIATION  
 ALEXICH, M.P.      Indiana Michigan Power Co. (formerly Indiana & Michigan Ele  
 RECIP. NAME      RECIPIENT AFFILIATION  
                                  Document Control Branch (Document Control Desk)

SUBJECT: Forwards addl info re operability of sys w/Copes-Vulcan valves, per NRC 881221 telcon.

DISTRIBUTION CODE: A001D      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 4  
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES		
	ID CODE/NAME	LTR	ENCL		
	PD3-1 LA	1	0		
	STANG, J	1	1		
INTERNAL:	ARM/DAF/LFMB	1	0		
	NRR/DEST/CEB 8H	1	1		
	NRR/DEST/MTB 9H	1	1		
	NRR/DEST/SICB	1	1		
	NRR/PMAS/ILRB12	1	1		
	OGC/HDS1	1	0		
	RES/DSIR/EIB	1	1		
	PD3-1 PD	2	2		
	NRR/DEST/ADS 7E	1	1		
	NRR/DEST/ESB 8D	1	1		
	NRR/DEST/RSB 8E	1	1		
	NRR/DOEA/TSB 11	1	1		
	NUDOCS-ABSTRACT	1	1		
	<u>REG FILE</u> 01	1	1		
EXTERNAL:	LPDR	1	1		
	NSIC	1	1		
	NRC PDR	1	1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 20 ENCL 17

R  
I  
D  
S  
/  
A  
D  
D  
S  
  
R  
I  
D  
S  
/  
A  
D  
D  
S

Indiana Michigan  
Power Company  
P.O. Box 16631  
Columbus, OH 43216



AEP:NRC:1084A

Donald C. Cook Nuclear Plant Unit 1  
Docket No. 50-315  
License No. DPR-58  
OPERABILITY OF SYSTEMS WITH COPES-VULCAN VALVES

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D. C. 20555

Attn: A. B. Davis

December 27, 1988


Dear Mr. Davis:

A conference call was held among NRC Region III, NRR and AEPSC representatives on December 21, 1988. The purpose of the call was to address the basis for continued operation of Donald C. Cook Nuclear Plant, Unit 1, due to concerns related to the recent discrepancies found in both weight and center of gravity of Copes-Vulcan air operated valves installed on small-bore diameter piping systems. The enclosure to this letter provides the information requested during the conference call.

In addition, the plant walkdowns conducted to date and the preliminary analytical results have yielded no evidence that the systems affected by the valves are incapable of performing their safety related functions. Initial computer runs on the first seventeen (17) valves indicate that we are within the NRC approved 2.0 Sy interim acceptance criteria. As we have previously committed in our December 9, 1988 letter, we expect to complete our evaluation of the associated Problem Report regarding the subject valves by January 3, 1989.

This document has been prepared following Corporate procedures that incorporate a reasonable set of controls to ensure its accuracy and completeness prior to signature by the undersigned.

Sincerely,

  
M. P. Alexich  
Vice President

8901030059 881227  
PDR ADOCK 05000315  
P PDC

A001  
11



5 2 3

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100

101 102 103 104 105 106 107 108 109 110 111 112 113 114 115 116 117 118 119 120 121 122 123 124 125 126 127 128 129 130 131 132 133 134 135 136 137 138 139 140 141 142 143 144 145 146 147 148 149 150

151 152 153 154 155 156 157 158 159 160 161 162 163 164 165 166 167 168 169 170 171 172 173 174 175 176 177 178 179 180 181 182 183 184 185 186 187 188 189 190 191 192 193 194 195 196 197 198 199 200

201

202

203

204

205

206

207

208

209

210

Mr. A. B. Davis

-2-

AEP:NRC:1084A

MPA/eh

Attachment

cc: D. H. Williams, Jr.  
W. G. Smith, Jr. - Bridgman  
R. C. Callen  
G. Charnoff  
G. Bruchmann  
NRC Resident Inspector - Bridgman

The following information provides the basis for our engineering judgment to continue operating Cook Nuclear Plant, Unit 1, while the analytical efforts continue regarding the impact of discrepancies found in both the weight and location of the center of gravity for installed small-bore (3/4", 1" and 2" diameter) Copes-Vulcan air operated valves.

#### FUNCTION OF AFFECTED PIPING SYSTEMS

The thirty-eight (38) fail closed Copes-Vulcan valves in Unit 1 are installed in piping systems that require no flow through to fulfill their safety related function but which must retain the pressure boundary integrity of the safety related systems to which they are connected. Twenty-six (26) of these valves are normally closed during power operation and function as fill, drain, flush, and test lines for the ECCS and Accumulator systems. Nine (9) of these valves are in the CVCS letdown system, which is isolated to maintain RCS inventory upon activation of the safety injection system. The remaining three (3) valves, which automatically close on a safety injection signal, are in the line that continuously circulates the Boron Injection Tank contents during power operation.

#### LOW EARTHQUAKE PROBABILITY

As indicated in Chapter 2.5 of the Updated Final Safety Analysis Report, the Cook Nuclear Plant is located in the Michigan tectonic plate, historically a low seismicity basin. The seismic history and known tectonics in the region reveal that no major earthquake epicenter has occurred within four hundred (400) miles of the Cook Nuclear Plant site and no shocks have occurred within fifty (50) miles of the Cook Nuclear Plant site of sufficient magnitude to cause significant structural damage. Based on this historical data, the probability of a damaging earthquake at the Cook Nuclear Plant is considered to be extremely low.

#### SUPPORTS IN THE VICINITY OF THE VALVES

Our Alternate Analysis criteria, the simplified approach to supporting small-bore (less than or equal to 2-inch nominal diameter) piping systems, required supporting of concentrated loads, such as valves. Review of available photographs has confirmed the existence of pipe supports in the vicinity of the valves.

STRENGTH OF PIPING

Based on the inherent safety margins in the codes and our own power plant experience, piping systems are more robust than would be predicted by rigorous code analyses. Also, recent studies have indicated that piping system failures occur due to seismic anchor movements and not due to the seismic inertia loads. Most of the piping systems in question are within the same building and are at the same general elevation. Furthermore, the differential displacements under seismic conditions between the safety-related buildings are not significant; therefore, we believe that the piping systems that run through the containment to the auxiliary building would not be adversely affected in the unlikely event of a seismic disturbance.

OPERATING EXPERIENCE

The affected piping systems have functioned for over twelve (12) years of operation in Unit 1. During the recent walkdown to obtain as-built design information, the personnel involved were instructed to note any physical signs of distress in the piping system and supports. No adverse findings were noted in the field walk of the accessible valves, demonstrating that the affected piping systems can withstand normal operating loads.