



Indiana Michigan  
Power Company  
Cook Nuclear Plant  
One Cook Plant  
Bridgman, MI 49106  
616 465 5901



May 20, 1999

United States Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Operating License DPR-58  
Docket No. 50-315

Document Control Manager:

In accordance with the criteria established by 10 CFR 50.73 entitled Licensee Event Report System, the following report is being submitted:

LER 315/99-012-00, "Auxiliary Building ESF Ventilation System may not be Capable of Maintaining ESF Room Temperatures Post-Accident"

The following commitment has been identified in this submittal:

- A comprehensive action plan is being developed to establish the normal, shutdown, and post-accident design temperatures for each auxiliary building room required to be maintained by the auxiliary building ventilation systems. In addition, a single failure analysis for the AES ventilation system will be performed to identify failures which could prevent the system from performing its design and safety function. Based on the results of the completed evaluation, additional information regarding safety significance, and corrective and preventive actions will be provided in an update to this LER.

Sincerely,

A handwritten signature in cursive script, appearing to read 'M. W. Rencheck'.

M. W. Rencheck  
Vice President - Nuclear Engineering

/bwo  
Attachment

c: J. E. Dyer, Region III  
P. A. Barrett  
D. F. Kunsemiller  
R. Whale  
D. Hahn  
Records Center, INPO  
NRC Resident Inspector

1/1  
IE22

9905260271 990520  
PDR ADOCK 05000315  
S PDR