

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9501230218      DOC. DATE: 95/01/12      NOTARIZED: YES      DOCKET #  
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana M 05000315  
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana M 05000316  
 AUTH. NAME      AUTHOR AFFILIATION  
 FITZPATRICK, E.      Indiana Michigan Power Co. (formerly Indiana & Michigan Ele  
 RECIP. NAME      RECIPIENT AFFILIATION  
                          Document Control Branch (Document Control Desk)

SUBJECT: Responds to 951205 request for addl info re responses to  
 GL 93-04, "Rod Control Sys Failure & Withdrawal Of Rod  
 Cluster Control Assemblies."

DISTRIBUTION CODE: A030D      COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3  
 TITLE: Generic Ltr-93-04-Rod Control System Failure & Withdrawal of Rod Cont

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	HICKMAN, J	1    1		
INTERNAL:	<del>FILE CENTER</del> 01 NRR/DRPW/PDIV-1	1    1 1    1	NRR/DRCH/HICB NRR/DSSA/SRXB	1    1 1    1
EXTERNAL:	NRC PDR	1    1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL  
 DESK, ROOM P1-37 (EXT. 504-2083 ) TO ELIMINATE YOUR NAME FROM  
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR    6    ENCL    6

P  
R  
I  
O  
R  
I  
T  
Y  
  
1  
  
D  
O  
C  
U  
M  
E  
N  
T

Indiana Michigan  
Power Company  
P.O. Box 16631  
Columbus, OH 43216



AEP:NRG:1190B  
GL 93-04

Donald C. Cook Nuclear Plant Units 1 and 2  
Docket Nos. 50-315 and 50-316  
License Nos. DPR-58 and DPR-74  
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO GENERIC  
LETTER 93-04, "ROD CONTROL SYSTEM FAILURE AND WITHDRAWAL OF ROD  
CONTROL CLUSTER ASSEMBLIES"

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

January 12, 1995

Dear Mr. Russell:

This letter is in response to your staff's December 5, 1994, request for additional information pertaining to our responses to Generic Letter 93-04, "Rod Control System Failure and Withdrawal of Rod Cluster Control Assemblies." Specifically, your staff has requested us to either commit to implement Westinghouse's recommended current order timing modification and surveillance test, or provide an alternative long-term plan. Also stated in the request was that the modification and surveillance should be implemented during the next refueling outage. Your staff, in a letter to the WOG, dated November 10, 1994, approved the following documents: (1) WCAP-13864, Rev. 1, "Rod Control System Evaluation Program," (2) Westinghouse Technical Bulletin NSD-TB-94-05-RO, "Rod Control CRDM Timing Change," and (3) "WOG Recommended Rod Control System Surveillance Test." Your staff found that the WOG's response, as discussed in the above Westinghouse documents, was an acceptable long-term resolution to Generic Letter 93-04.

We will implement the current order timing modification, as described in Westinghouse Technical Bulletin NSD-TB-94-05-RO, during the next refueling outage for each unit. The WOG's Recommended Rod Control System Surveillance Test (submitted by the WOG to the NRC, July 12, 1994) will be used to develop a post-modification acceptance test to be performed upon initial installation and a surveillance test to be performed during each refueling outage. The Unit 1 refueling outage is scheduled for the third quarter of 1995.


9501230218 950112  
PDR ADOCK 05000315  
P PDR

AD30

The Unit 2 refueling outage is scheduled for the first quarter of 1996. As requested by your staff, we will inform you upon the successful implementation of the modifications and completion of the surveillance tests.

This letter is submitted pursuant to 10 CFR 50.54(f) and, as such, an oath statement is attached.

Sincerely,



E. E. Fitzpatrick  
Vice President

eh

Attachment

cc: A. A. Blind  
G. Charnoff  
J. B. Martin - Region III  
NFEM Section Chief  
NRC Resident Inspector - Bridgman  
J. R. Padgett

STATE OF OHIO)  
COUNTY OF FRANKLIN)

E. E. Fitzpatrick, being duly sworn, deposes and says that he is the Vice President of licensee Indiana Michigan Power Company, that he has read the forgoing RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO GENERIC LETTER 93-04 and knows the contents thereof; and that said contents are true to the best of his knowledge and belief.

E. E. Fitzpatrick

Subscribed and sworn to before me this 12<sup>th</sup>  
day of January, 19 95.

Rita D. Hill  
NOTARY PUBLIC

RITA D. HILL  
NOTARY PUBLIC, STATE OF OHIO  
MY COMMISSION EXPIRES 6-28-99

10-10-10

10-10-10

10-10-10