

Docket No. 50-315

June 28, 1985

DISTRIBUTION

Docket File	NRC PDR
LPDR	ORB#1 Rdg
GrayFile	HThompson
OELD	EJordan
BGrimes	JPartlow
DWigginton	CParrish
ACRS 10	

Mr. John Dolan, Vice President
 Indiana and Michigan Electric Company
 c/o American Electric Power Service Corporation
 1 Riverside Plaza
 Columbus, Ohio 43216

Dear Mr. Dolan:

By letter dated May 17, 1985, the Indiana & Michigan Electric Company requested relief from the pressure test inspection requirements of the ASME B&PV Code Section XI, subsections IWB-5000 and IWC-5000. This relief was required for sections of four groups of pipe in which code specified pressure tests were determined to be impractical without extensive modification of valves and substantial radiation exposure to plant personnel. We have completed our review and the Safety Evaluation is enclosed.

In accordance with Technical Specification 4.0.5, written relief may be granted by the Commission pursuant to 10 CFR 50.55a(g)(6)(i). Our review has determined that the code requirements for the specified systems are impractical and the granting of the relief is authorized by law and will not endanger life or property or the common defense and security and is otherwise in the public interest, giving due consideration to the burden upon the licensee that could result if the requirements were imposed on the facility. Therefore, the systems for which relief has been requested will be tested at 2280 psig at a temperature of 100°F during Mode 3 while the reactor coolant system pressure is at 2280 psig and temperature greater than or equal to 500°F. These piping systems are detailed in the enclosure and include the accumulator discharge piping, reactor letdown and charging piping, and safety injection system piping. The relief is granted.

Sincerely,

/s/SVarga

Steven A. Varga, Chief
 Operating Reactors Branch #1
 Division of Licensing

Enclosure:
 As stated

cc w/enclosure:
 See next page

8507110602 850628
 PDR ADDCK 05000315
 Q PDR

*See previous white for concurrence			
ORB#1:DL*	ORB#1:DL	BC-ORB#1:DL*	OELD*
CParrish	DWigginton;ps	SVarga	
6/20/85	6/20/85	6/20/85	6/25/85



10/10/10

2

1. The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that this is essential for ensuring the integrity of the financial statements and for providing a clear audit trail. The document also notes that this practice is a key component of good financial management and is required by law in many jurisdictions.

2. The second part of the document outlines the specific procedures that should be followed when recording transactions. It details the steps from identifying the transaction to entering it into the accounting system. The document stresses the importance of double-checking all entries to ensure accuracy and consistency. It also provides examples of how to handle common types of transactions, such as sales, purchases, and transfers.

3. The third part of the document discusses the role of the accounting system in providing information to management. It explains how the system can be used to generate reports that show the company's financial performance over time. The document also notes that the accounting system can be used to identify areas where costs can be reduced and revenues can be increased. This information is crucial for making informed decisions about the company's future.

4. The final part of the document concludes by reiterating the importance of accurate record-keeping and the role of the accounting system. It encourages the reader to take the time to understand the system and to use it effectively. The document also provides a list of resources for further information, including books, articles, and websites.

Docket No. 50-315

DISTRIBUTION

Docket File	NRC PDR
LPDR	ORB#1/Rdg
GrayFile	HThompson
OELD	EJordan
BGrimes	JPartlow
DWigginton	CParrish
ACRS 10	

Mr. John Dolan, Vice President
Indiana and Michigan Electric Company
c/o American Electric Power Service Corporation
1 Riverside Plaza
Columbus, Ohio 43216

Dear Mr. Dolan:

By letter dated May 17, 1985, the Indiana & Michigan Electric Company requested relief from the pressure test inspection requirements of the ASME B&PV Code Section XI, subsections IWB-5000 and IWC-5000. This relief was required for sections of four groups of pipe in which code specified pressure tests were determined to be impractical without extensive modification of valves and substantial radiation exposure to plant personnel. We have completed our review and the Safety Evaluation is enclosed.

In accordance with Technical Specification 4.0.5, written relief may be granted by the Commission pursuant to 10 CFR 50.55a(g)(6)(i). Our review has determined that the code requirements for the specified systems are impractical and the granting of the relief is authorized by law and will not endanger life or property or the common defense and security and is otherwise in the public interest. Therefore, the systems for which relief has been requested will be tested at 2280 psig at a temperature of 100°F during Mode 3 while the reactor coolant system pressure is at 2280 psig and temperature greater than or equal to 500°F. These piping system are detailed in the enclosure and include the accumulator discharge piping, reactor letdown and charging piping, and safety injection system piping. The relief is granted.

Sincerely,

Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

*See previous white for concurrence
 ORB#1:DL* ORB#1:DL BC-ORB#1:DL
 CParrish DWigginton;ps SVarga
 6/20/85 6/29/85 6/25/85

OELD
 SCJunk
 6/25/85 (Changes w/Red)

Docket No. 50-315

DISTRIBUTION

Docket File	NRC PDR
LPDR	ORB#1 Rdg
GrayFile	HThompson
OELD	EJordan
BGrimes	JPartlow
DWigginton	CParrish
ACRS 10	

Mr. John Dolan, Vice President
 Indiana and Michigan Electric Company
 c/o American Electric Power Service Corporation
 1 Riverside Plaza
 Columbus, Ohio 43216

Dear Mr. Dolan:

By letter dated May 17, 1985, the Indiana & Michigan Electric Company requested relief from the pressure test inspection on requirements of the ASME B&PV Code Section XI, subsections IWB-5000 and IWC-5000. This relief was required for sections of four groups of pipe in which code specified pressure tests were determined to be impractical without extensive modification of valves and substantial radiation exposure to plant personnel. We have completed our review and the Safety Evaluation is enclosed.

In accordance with Technical Specification 4.0.5, written relief may be granted by the Commission pursuant to 10 CFR 50.55a(g)(6)(i). Our review has determined that the code requirements for the specified systems are impractical and the granting of the relief is authorized by law and will not endanger life or property or the common defense and security and is otherwise in the public interest. Therefore, the systems for which relief has been requested will be tested at 2280 psig at a temperature of 100°F during Mode 3 while the reactor coolant system pressure is at 2280 psig and temperature greater than or equal to 500°F. These piping system are detailed in the enclosure and include the accumulator discharge piping, reactor letdown and charging piping, and safety injection system piping. The relief is granted.

Sincerely,

Steven A. Varga, Chief
 Operating Reactors Branch #1
 Division of Licensing

Enclosure:
 As stated

cc w/enclosure:
 See next page

ORB#1:DL
 CParrish
 6/29/85

ORB#1:DL
 DWigginton;ps
 6/28/85

BC-ORB#1:DL
 SVarga
 6/ /85

OELD
 6/ /85

Mr. John Dolan
Indiana and Michigan Electric Company

Donald C. Cook Nuclear Plant

cc:
Mr. M. P. Alexich
Vice President
Nuclear Operations
American Electric Power Service
Corporation
1 Riverside Plaza
Columbus, Ohio 43215

The Honorable John E. Grotberg
United States House of Representatives
Washington, DC 20515

James G. Keppler
Regional Administrator - Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Attorney General
Department of Attorney General
525 West Ottawa Street
Lansing, Michigan 48913

J. Feinstein
American Electric Power
Service Corporation
1 Riverside Plaza
Columbus, Ohio 43216

Township Supervisor
Lake Township Hall
Post Office Box 818
Bridgman, Michigan 49106

W. G. Smith, Jr., Plant Manager
Donald C. Cook Nuclear Plant
Post Office Box 458
Bridgman, Michigan 49106

U.S. Nuclear Regulatory Commission
Resident Inspectors Office
7700 Red Arrow Highway
Stevensville, Michigan 49127

Gerald Charnoff, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, DC 20036

Mayor, City of Bridgeman
Post Office Box 366
Bridgman, Michigan 49106

Special Assistant to the Governor
Room 1 - State Capitol
Lansing, Michigan 48909

Nuclear Facilities and Environmental
Monitoring Section Office
Division of Radiological Health
Department of Public Health
3500 N. Logan Street
Post Office Box 30035
Lansing, Michigan 48909