LICENSEE EVENT REPORT

CONTROL BLOCK: |__|__|__|__|__|__| (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

| 0 | 1 | M | I | D | C | C | 2 | (2) | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | (3) | 4 | 1 | 1 | 1 | 1 | (4) | | | (5) |

LICENSEE CODE ... LICENSE NUMBER ... LICENSE TYPE ... CAT

CON'T
| 0 | 1 | REPORT SOURCE | |_| (6) | 0 | 5 | 0 | 0 | 0 | 3 | 1 | 6 | (7) | 0 | 1 | 2 | 9 | 8 | 0 | (8) | 0 | 2 | 2 | 8 | 8 | 0 | (9) |

DOCKET NUMBER ... EVENT DATE ... REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0	2	DURING A SURVEILLANCE TEST ON PRESSURIZER PRESSURE PROTECTION SET 3, BISTABLE
0	3	2 PB-457D WAS FOUND TO TRIP AT A VALUE CORRESPONDING TO 1887.4 PSIG. THIS EXCEEDS
0	4	THE REQUIRED VALUE SPECIFIED IN T.S. TABLE 3.3-4 ITEM 1.D.
0	5	
0	6	
0	7	
0	8	

| 0 | 9 | SYSTEM CODE S H (11) | CAUSE CODE E (12) | CAUSE SUBCODE E (13) | COMPONENT CODE I N S T R U (14) | COMP. SUBCODE S (15) | VALVE SUBCODE Z (16) |

(17) LER/RO REPORT NUMBER | EVENT YEAR 8 0 | SEQUENTIAL REPORT NO. 0 0 6 | OCCURRENCE CODE 0 3 | REPORT TYPE L | REVISION NO. 0

ACTION TAKEN E (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. Y (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER F 1 8 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1	0	THE BISTABLE WAS IMMEDIATELY SET TO WITHIN ALLOWABLE VALUES AND RETURNED TO SERVICE.
1	1	THE NEXT DAY A RECHECK OF THE BISTABLE TRIP VALUE INDICATED THAT THERE WAS NO
1	2	INHERENT PROBLEMS WITH THE BISTABLE. THIS BISTABLE WAS MANUFACTURED BY FOXBORO
1	3	MODEL NUMBER 63 U-BC-OHEA-F. THE CAUSE OF THIS EVENT IS ATTRIBUTED TO INSTRUMENT
1	4	DRIFT. NO FURTHER ACTION IS PLANNED.

| 1 | 5 | FACILITY STATUS E (28) | % POWER 0 9 0 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) SURVEILLANCE TEST |

| 1 | 6 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA |

| 1 | 7 | PERSONNEL EXPOSURES NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA |

| 1 | 8 | PERSONNEL INJURIES NUMBER 0 0 0 (40) | DESCRIPTION (41) NA |

| 1 | 9 | LOSS OF OR DAMAGE TO FACILITY (43) TYPE Z (42) | DESCRIPTION NA |

| 2 | 0 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY |

8008040534

NAME OF PREPARER __Jack Rischling__ PHONE: __616-465-5901__