

Wicket

DECEMBER 28 1979

Docket Nos. 50-315  
and 50-316

Mr. John Dolan, Vice President  
Indiana and Michigan Electric Company  
Post Office Box 18  
Bowling Green Station  
New York, New York 10004

Dear Mr. Dolan:

SUBJECT: INADVERTENT SAFETY INJECTION DURING COOLDOWN

The Division of Operating Reactors has completed a generic bounding review on this subject and concludes that no further licensing action is necessary at this time since it is likely that a facility could withstand more than fifty inadvertent ECCS actuations. We have concluded, however, that it would be prudent, should a facility experience more than twenty-five such injections, for you to consider a plant specific analysis for that facility which would identify more precisely the additional number of actuations that can be safely accommodated at that facility.

A copy of our Safety Evaluation Report is enclosed.

Sincerely,

Original signed by

A. Schwencer, Chief  
Operating Reactors Branch #1  
Division of Operating Reactors

Enclosure:  
Safety Evaluation

cc: w/enclosure  
See next page

8003060626 60

OFFICE	DOR:OPB1	DOR:OPB1				
SURNAME	DWigginton:jb	ASchwencer				
DATE	12/18/79	12/30/79				

DECEMBER 8 1973

Original signed by

12-11-73