(7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1	M I D C C 2 (2)	LICENSEE CODE	0 0 - 0 0 0 0 0 - 0 0 (3)	LICENSE NUMBER	4 1 1 1 1 (4)	LICENSE TYPE	(5)	CAT

CON'T

0 1	REPORT SOURCE	L (6)	0 5 0 0 0 3 1 6 (7)	DOCKET NUMBER	0 2 2 3 8 0 (8)	EVENT DATE	0 3 2 1 8 0 (9)	REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 WHILE PERFORMING THE WEEKLY TURBINE STOP AND CONTROL VALVE TESTING A

0 3 REDUCTION IN THE REACTOR COOLANT SYSTEM PRESSURE OCCURRED. THE PRESSURE

0 4 DROPPED TO 2215 PSIA WHICH IS 5 PSI BELOW THE MINIMUM PRESSURE LIMIT

0 5 SPECIFIED IN TECHNICAL SPECIFICATION 3.2.5.b. THE PRESSURE RECOVERED

0 6 RAPIDLY AND THERE WAS NO THREAT TO THE PUBLIC HEALTH AND SAFETY.

0 7

0 8

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
0 9	Z Z (11)	E (12)	A (13)	C K T B R K (14)	A (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 0	—	0 1 1	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
Z (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	N (24)	L (25)	C 7 7 C (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 INVESTIGATION FOUND THAT 6 OF 78 PRESSURIZER HEATERS WERE INOPERABLE DUE TO

1 1 TRIPPED SUPPLY BREAKERS. THE BREAKERS WERE RESET AND THE HEATERS HAVE BEEN

1 2 FUNCTIONING NORMALLY SINCE. THIS CONDITION HAS BEEN REVIEWED WITH ALL

1 3 LICENSED OPERATORS, IN CASE A SIMILIAR SITUATION SHOULD OCCUR.

1 4

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
1 5	E (28)	1 0 0 (29)	NA	(31)	OPERATOR OBSERVATION

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
1 6	Z (33)	Z (34)	NA	NA

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
1 7	0 0 0 (37)	Z (38)	NA

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
1 8	0 0 0 (40)	NA

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
1 9	Z (42)	NA

PUBLICITY

	ISSUED	DESCRIPTION (45)	NRC USE ONLY
2 0	N (44)	NA	

8004010461

NAME OF PREPARER C. E. MURPHY PHONE: 465-5901 X-316

GPO 917-926