NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | MIDCC1 (2) | 0000000000 (3) | 4 1 1 1 1 (4) | (5)
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
01 | REPORT SOURCE L (6) | 05000315 (7) | 032480 (8) | 041880 (9)
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 DURING THE PERFORMANCE OF A SURVEILLANCE TEST ON THE UNIT 1 650 FOOT ELEVATION
03 AIRLOCK DOOR A LEAKAGE OF 130 CFH WAS FOUND. THIS CONDITION IS NON CONSERVATIVE
04 WITH RESPECT TO T.S. 4.6.1.3b.
05
06
07
08
7 8 9 80

09
7 8 SYSTEM CODE SD (11) | CAUSE CODE X (12) | CAUSE SUBCODE Z (13) | COMPONENT CODE PENETR (14) | COMP. SUBCODE A (15) | VALVE SUBCODE Z (16)
9 10 11 12 13 18 19 20

(17) LER/RO REPORT NUMBER: EVENT YEAR 80 | — | SEQUENTIAL REPORT NO. 006 | / | OCCURRENCE CODE 03 | REPORT TYPE L | — | REVISION NO. 0
21 22 23 24 26 27 28 29 30 31 32

ACTION TAKEN X (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0000 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER A (25) | COMPONENT MANUFACTURER W302 (26)
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 AN INSPECTION OF THE DOOR SEAL FOLLOWING THE SURVEILLANCE TEST INDICATED THE
11 SEAL WAS CLEAN AND IN GOOD CONDITION. A RETEST WAS THEN PERFORMED AND THE
12 LEAK RATE WAS LESS THAN 20 CFH. NO CAUSE FOR THE LEAK COULD BE FOUND AND
13 NO FURTHER ACTION IS PLANNED. THE ACTION REQUIREMENT FOR T.S. 4.6.1.3b WAS
14 FULFILLED.
7 8 9 80

15
7 8 FACILITY STATUS E (28) | % POWER 100 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) SURVEILLANCE TEST
9 10 12 13 44 45 46 80

16
7 8 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA
9 10 11 44 45 80

PERSONNEL EXPOSURES
17
7 8 NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA
9 11 12 13 80

PERSONNEL INJURIES
18
7 8 NUMBER 000 (40) | DESCRIPTION (41) NA
9 11 12 80

LOSS OF OR DAMAGE TO FACILITY (43)
19
7 8 TYPE Z (42) | DESCRIPTION NA
9 10 80

8004230447

PUBLICITY
20
7 8 ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY
9 10 68 69 80

NAME OF PREPARER S. D. DELONG PHONE: 616-465-5901

GPO 917-926