

DMB
016


DISTRIBUTION

- Dockets
- NRC PDR
- L PDR
- TERA
- NSIC
- ORB#1 Rdg
- DEisenhut
- OELD
- IE-3
- ACRS-10
- SVarga
- SMiner
- CParrish
- DChaney
- Gray File

JUN 09 1981

Docket Nos. 50-315
and 50-316

Mr. John Dolan, Vice President
Indiana and Michigan Electric Company
Post Office Box 18
Bowling Green Station
New York, New York 10004



Dear Mr. Dolan:

The NRC staff has completed an interim review of the Westinghouse Owners Group submittal for Action Plan item I.C.1, Guidance for the Evaluation and Development of Procedures for Transients and Accidents. We have identified the following deficiencies in the Owners Group proposal:

1. Proposed guidelines do not provide smooth transitions from the event procedures to direct the operator if subsequent multiple or consequential failures occur.
2. The proposed schedule for completing the program does not appear responsive to NUREG-0737, Item I.C.1 and we believe that additional work is necessary.
3. The staff has serious doubts that the full range of initiating events and subsequent failures can be addressed within the proposed event specific framework.

A copy of our letter to the Owners Group is enclosed for your information.

Sincerely,
Original signed by:
S. A. Varga

Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

MA
4

Enclosure:
As stated

cc: Service List

8107060157 810609
PDR ADOCK 05000315
PDR

OFFICE	ORB#1:DL	ORB#1:DL					
SURNAME	SMiner, ds	SVarga					
DATE	6/9/81	6/9/81					

[Faint, illegible text, possibly bleed-through from the reverse side of the page]

12/21

DISTRIBUTION

Dockets
NRC PDR
L PDR
TERA
NSIC
ORB#1 Rdg
DEisenhut
OELD
IE-3
ACRS-10
SVarga
SMiner
CParrish
DChaney
Gray File

Docket Nos. 50-315
and 50-316

Mr. John Dolan, Vice President
Indiana and Michigan Electric Company
Post Office Box 18
Bowling Green Station
New York, New York 10004

Dear Mr. Dolan:

The NRC staff has completed an interim review of the Westinghouse Owners Group submittal for Action Plan item I.C.1, Guidance for the Evaluation and Development of Procedures for Transients and Accidents. We have identified the following deficiencies in the Owners Group proposal:

1. Proposed guidelines do not provide smooth transitions from the event procedures to direct the operator if subsequent multiple or consequential failures occur.
2. The proposed schedule for completing the program does not appear responsive to NUREG-0737, Item I.C.1 and we believe that additional work is necessary.
3. The staff has serious doubts that the full range of initiating events and subsequent failures can be addressed within the proposed event specific framework.

A copy of our letter to the Owners Group is enclosed for your information.

Sincerely,

Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Enclosure:
As stated

cc: Service List

OFFICE	...ORB#1:DL...	...ORB#1:DL...						
SURNAME	...SMiner:ds	...SVarga						
DATE	...6/.../81...	...6/.../81...						



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

June 9, 1981

Docket Nos. 50-315
and 50-316

Mr. John Dolan, Vice President
Indiana and Michigan Electric Company
Post Office Box 18
Bowling Green Station
New York, New York 10004


Dear Mr. Dolan:

The NRC staff has completed an interim review of the Westinghouse Owners Group submittal for Action Plan item I.C.1, Guidance for the Evaluation and Development of Procedures for Transients and Accidents. We have identified the following deficiencies in the Owners Group proposal:

1. Proposed guidelines do not provide smooth transitions from the event procedures to direct the operator if subsequent multiple or consequential failures occur.
2. The proposed schedule for completing the program does not appear responsive to NUREG-0737, Item I.C.1 and we believe that additional work is necessary.
3. The staff has serious doubts that the full range of initiating events and subsequent failures can be addressed within the proposed event specific framework.

A copy of our letter to the Owners Group is enclosed for your information.

Sincerely,


Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Enclosure:
As stated

cc: Service List

Dolan

Mr. John Dolan
Indiana and Michigan Electric Company

cc: Mr. Robert W. Jurgensen
Chief Nuclear Engineer
American Electric Power
Service Corporation
2 Broadway
New York, New York 10004

Gerald Charnoff, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D. C. 20036

Maude Preston Palenske Memorial
Library
500 Market Street
St. Joseph, Michigan 49085

Mr. D. Shaller, Plant Manager
Donald C. Cook Nuclear Plant
P. O. Box 458
Bridgman, Michigan 49106

U. S. Nuclear Regulatory Commission
Resident Inspectors Office
770 Red Arrow Highway
Stevensville, Michigan 49127

William J. Scanlon, Esquire
2034 Pauline Boulevard
Ann Arbor, Michigan 48103