

July 29, 1985

Docket Nos. 50-315
and 50-316

DISTRIBUTION

Docket File

L PDR
Gray File
OELD
BGrimes
DWigginton
ACRS 10

NRC PDR
ORB#1 Rdg
HThompson
EJordan
JPartlow
CParrish
JKudrick

Mr. John Dolan, Vice President
Indiana and Michigan Electric Company
c/o American Electric Power Service Corporation
1 Riverside Plaza
Columbus, Ohio 43216

Dear Mr. Dolan:

By letter dated March 29, 1985, the Indiana and Michigan Electric Company provided, among other things, an analysis of the Donald C. Cook Nuclear Plant substation and AEP grid system in regards to the need for backup power for the containment hydrogen ignitors. We have completed a qualitative analysis of this information and a comparison of the Cook system to the Sequoyah system which we have approved. Our analysis and assessment is enclosed. On the basis of our review to date, we have determined that it is reasonable to conclude that D. C. Cook need not provide at this time any additional supplies for their hydrogen ignitor system.

If there are any questions on this matter, please let us know.

Sincerely,

/s/SVarga

Steven A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Enclosure:
As stated

cc w/enclosure:
See next page

ORB#1:DL
CParrish
7/1/85

ORB#1:DL
DWigginton;ps
7/2/85

CSB
JKudrick
7/1/85

BC-ORB#1:DL
SVarga
7/2/85

8508080688 850729
PDR ADDCK 05000315
PDR

Mr. John Dolan
Indiana and Michigan Electric Company

Donald C. Cook Nuclear Plant

cc:

Mr. M. P. Alexich
Vice President
Nuclear Operations
American Electric Power Service
Corporation
1 Riverside Plaza
Columbus, Ohio 43215

The Honorable John E. Grotberg
United States House of Representatives
Washington, DC 20515

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Attorney General
Department of Attorney General
525 West Ottawa Street
Lansing, Michigan 48913

J. Feinstein
American Electric Power
Service Corporation
1 Riverside Plaza
Columbus, Ohio 43216

Township Supervisor
Lake Township Hall
Post Office Box 818
Bridgman, Michigan 49106

W. G. Smith, Jr., Plant Manager
Donald C. Cook Nuclear Plant
Post Office Box 458
Bridgman, Michigan 49106


U.S. Nuclear Regulatory Commission
Resident Inspectors Office
7700 Red Arrow Highway
Stevensville, Michigan 49127

Gerald Charnoff, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, DC 20036

Mayor, City of Bridgeman
Post Office Box 366
Bridgman, Michigan 49106

Special Assistant to the Governor
Room 1 - State Capitol
Lansing, Michigan 48909

Nuclear Facilities and Environmental
Monitoring Section Office
Division of Radiological Health
Department of Public Health
3500 N. Logan Street
Post Office Box 30035
Lansing, Michigan 48909



ENCLOSURE

I. Background

The Indiana and Michigan Electric Company (IMEC) in a letter dated March 29, 1985, provided information on the American Electric Power (AEP) grid and the Donald C. Cook Nuclear Plant substation as justification for not providing backup power for the containment hydrogen ignitors.

Considering that IMEC has not developed a quantitative assessment of the probability of loss of all AC power at D. C. Cook and the ongoing work on USI A-44 on the topic of station blackout, the staff performed a qualitative design comparative assessment of the D. C. Cook to the Sequoyah power supply system. This was to help determine whether further consideration should be given to a backup power supply for the hydrogen ignition system in the event of degraded core accidents in conjunction with a station blackout. The Sequoyah plant already has an installed hydrogen control system without additional power sources beyond that provided by existing emergency onsite diesels which has been approved.

II. Qualitative Analysis

Recognizing the fact that an electric power system's capability to withstand disturbances resulting in total losses of AC power for the station is to a large degree a function of the system design features, a comparison of the D. C. Cook to the Sequoyah electric system design was made to determine on a qualitative basis how the D. C. Cook design related to the previously accepted Sequoyah design. Presently estimated power requirements from the hydrogen control system for both plants are as follows:

	<u>D. C. Cook</u>	<u>Sequoyah</u>
type	glow plug	igniter
voltage/power consumption	12-14V AC/100W	120V AC/500W
approximate number	70	80
power requirement	7 kW	40 kW

The basis for comparison of the two plants is that both D. C. Cook and Sequoyah have the following comparable power system capability and similar inplant design features.

	<u>D. C. Cook</u>	<u>Sequoyah</u>
no. of diesel/capacity (ea.)	4/3500 kW	4/4000 kW
LOCA load requirement	2760 kW	3537 kW
capability to intertie between units	Yes	Yes

Comparison of Offsite Power System Designs

	<u>D. C. Cook</u>		<u>Sequoyah</u>	
	<u>Unit 1</u>	<u>Unit 2</u>	<u>Unit 1</u>	<u>Unit 2</u>
<u>Switchyard¹</u>				
No. of offsite lines to switchyards (switchyard voltage)	8(345kV)	2(765kV)	4(500kV)	10 (161kV)
<u>Interconnection</u>				
Between the onsite and the switchyard (excluding step up X-formers)	1 - 765 kV 1 - 345 kV 1 - 69 kV		2 - 161 kV	
<u>Switchyard Breaker Configuration</u>	breaker and a half scheme		bus transfer scheme	
<u>Distribution Transformers</u>				
(A) Step up	2		2	
(B) Common station service (startup)	6 ²		2	
(C) Unit station service, or unit auxiliary	4		4	

¹ Both plants include a transformer which connects between units (i.e., 765/345 kW for D. C. Cook and 500/161 kV for Sequoyah) as an offsite source.

² This includes two 69/4.16 kV transformers which can be connected from one 69 kV offsite power source.

III. Comparison

- A. The D. C. Cook switchyard design employs a breaker and a half scheme which provides a simpler and more reliable isolation capability for a certain faults (e.g. transmission line faults, bus faults, and stuck breaker cases) with no or minimal disruption to the offsite power availability. In case of Sequoyah, the switchyard design has a similar capability, but requires a series of breaker operations for its transfer scheme to work and also may involve time delays. Thus, the D. C. Cook switchyard design is less susceptible to failure as a result of system transients.
- B. Upon unit trip, both Sequoyah and D. C. Cook require a transfer scheme to isolate the main generator from the offsite power system which establishes the offsite power source to supply inplant safety equipment through common station service transformers for Sequoyah and from the preferred offsite power source through transformer no. 4 for D. C. Cook. In contrast to the offsite power supply design for Sequoyah which actually feeds from one 161 kV switchyard, the offsite power from D. C. Cook is available from three different switchyards, namely, 69 kV, 345 kV, and 765 kV which undoubtedly reduces the potential for total loss of offsite power. This, in turn, increases the availability of offsite power.
- C. Although both designs provide two diesel generators per unit, manual crossties exist in both plants, which make it possible to use one of the diesels from the other units, to supply emergency loads should both diesels be lost on one unit. In addition, D. C. Cook has an additional 69 kV offsite power source which can be connected manually to emergency buses, which is not present on Sequoyah.

IV. Conclusion

By considering all the above design features such as immediate, multiple accessibility to the offsite power source, instantaneous isolation capability of the breaker and a half arrangement and an additional 69 kV power source, the staff concludes that qualitatively D. C. Cook's AC power supply system reliability is somewhat better than that of Sequoyah. Therefore, on the basis that Sequoyah was not required to provide additional power supplies beyond the existing emergency sources for the hydrogen ignition system, it is reasonable to conclude that D. C. Cook need not provide any additional supplies for their hydrogen ignition system.