## REGULATORY NFORMATION DISTRIBUTION STEM (RIDS)

ACCESSION NBR: 8602240382 DOC. DATE: 86702719 NOTARIZED: NO DOCKET # FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316

AUTH. NAME AUTHOR AFFILIATION

ALEXICH, M. P. Indiana & Michigan Electric Co.

RECIP. NAME RECIPIENT AFFILIATION

DENTON, H. R. Office of Nuclear Reactor Regulation, Director (post 851125

SUBJECT: Summarizes planned actions, per 851219 meeting, re Attachments 1 & 2 to NUREG-0737, Sections II. B. 3 & II. F. 1, including post-accident sampling sys, location of main steam gas

post-accident sampling sys, location of main steam gas effluent radiation detectors & eberline monitoring sys.

DISTRIBUTION CODE: A046D COPIES RECEIVED: LTR ENCL SIZE: TITLE: OR Submittal: TMI Action Plan Rgmt NUREG-0737 & NUREG-0660

## NOTES:

	RECIPIENT COPIES			RECIPIENT		COPIES		
	ID CODE/NAME		LTTR E	NCL	ID CODE/	NAME	LTTR	ENCL
	PWR-A ADTS		1 :	4	PWR-A PD4	PD 01	5	₽
	PWR-A EB		1 :	ıll	PWR-A EICS	B	1	i i
	PWR-A FOB		1 :	ď	WIGGINGTON	, D	1	ji j
	PWR-A PSB		1		PWR-A RSB		1	#
INTERNAL:	ADM/LFMB		1 (		ELD/HDS3		1	b
	IE/DEPER DIR	33	1 :	i	IE/DEPER/E	PB	3	13
	NRR BWR ADTS		1	Ħ	NRR PAULSO	N, W.	1	ļ.
	NRR PWR-A ADT	rs	1	Ų.	NRR PWR-B	ADTS	1	1
_	NERADHET		1 :	ij	NRR/ORAS	18	3	13
	REG FILE	04	1 :	1	Rena		1	
EXTERNAL:	24X		1 :	1	LPDR	03	2	þ
	NRC PDR	02	1 :	4	NSIC	05	1	Į.

3 . g ji t

TO AND A

The state of the s

त्र । विकास ५५ ते विकासी विकास १५ व मार्थ व १ विकास विकास

The state of the s

The state of the s

The state of the s

The state of the s

1. 1868 1. 1864 1. 1865 1. 186

## INDIANA & MICHIGAN ELECTRIC COMPANY

P.O. BOX 16631 COLUMBUS, OHIO 43216

> February 19, 1986 AEP:NRC:0678S

Donald C. Cook Nuclear Plant Unit Nos. 1 and 2 Docket Nos. 50-315 and 50-316 License Nos. DPR-58 and DPR-74 NUREG-0737, SECTIONS II.B.3 and II.F.1

Mr. Harold R. Denton, Director Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Washington, D.C. 20555

Dear Mr. Denton:

On December 19, 1985, Indiana & Michigan Electric Company held a meeting with your staff to discuss Technical Specifications for NUREG-0737, Section II.B.3 and II.F.1, Attachments 1 and 2. The following is a brief summary of the actions we currently plan to take as a result of that meeting.

I. Post-Accident Sampling System (PASS):

After the NUS Corporation has completed their testing program, and a reevaluation of the PASS is completed, we will be submitting to your staff a complete detailed description of the PASS system relative to the requirements of the NUREG-0737, Section II.B.3.

- II. Location of the Main Steam Noble Gas Effluent Radiation

  Detectors: Questions have been raised concerning the present
  locations of our main steam effluent detectors and whether
  they meet the intent of NUREG-0737, Section II.F.1, Attachment
  1. We are currently evaluating our position on this issue and
  will advise you accordingly.
- III. Eberline SPING 3 and 4 Monitoring System: At the present time, AEP and Eberline are in the process of developing a technical information data package which will be submitted to your staff for review. The purpose of this data package is to discuss the current Eberline system at the Donald C. Cook Nuclear Plant with respect to NUREG-0737, Section II.F.1, Attachment 1 for the following areas: detector sensitivity/response, detector linearity, maximum range capability and acceptable range overlap between the low, mid and high ranges.

B602240382 860219 PDR ADDCK 05000315 PDR ADDCK 05000315 A046

The state of the s

g gradien was de gradien de gradi

O.

1. yz

The American Brown Brown Brown

The state of the s

- IV. Radiation Source Terms for the Main Steam System: Source terms are being evaluated for the Steam Jet Air Ejector (SJAE) and the Gland Seal Condenser Exhaust (GSCE) systems. After these source terms are fully developed, they will be submitted to your staff for approval.
- V. Continuous Sampling: Because of moisture problems in the SJAE and GSCE systems it is difficult to have continuous sampling that is representative for iodine and particulates.

  Therefore, an alternative method, which is more conservative, is being evaluated. It is our intention to submit our methodology for sampling these two systems and request an exemption from continuous sampling of the SJAE and GSCE systems.

We currently anticipate submitting the above information no later than September, 1986. If our schedule should change significantly, we will advise you at that time.

This document has been prepared following Corporate procedures which incorporate a reasonable set of controls to insure its accuracy and completeness prior to signature by the undersigned.

Very truly yours,

M. P. Alexich

MPA/cm

cc: John E. Dolan

W. G. Smith, Jr. - Bridgman

R. C. Callen

G. Bruchmann

G. Charnoff

NRC Resident Inspector - Bridgman

A CONTRACTOR OF THE STATE OF TH

> **6**

٠,