

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8811230391 DOC. DATE: 88/11/07 NOTARIZED: NO DOCKET #

FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315

50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316

AUTH. NAME AUTHOR AFFILIATION

MENGE, R.C. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele

RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: NPDES noncompliance notificatio: on 881031, prefilter backwash discharge indicated TSS concentration of 138 mg/l.

DISTRIBUTION CODE: IE23D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1

TITLE: Environmental Event Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES	LTR	ENCL	RECIPIENT ID CODE/NAME	COPIES	LTR	ENCL
	PD3-1 LA	1		0	PD3-1 PD	1		1
	SCOTT, W	1		1				
INTERNAL:	AEOD/DSP/TPAB	1		1	AEOD/PTB	1		1
	NRR/DEST/ADE 8H	1		1	NRR/DOEA/EAB 11	1		1
	NRR/DREP/EPB 10	1		1	NRR/DREP/RPB 10	1		1
	NRR/PMAS/ILRB12	1		1	NRR/PMAS/PTSB12	1		1
	NUDOCS-ABSTRACT	1		1	OGC/HDS1	1		1
	<u>REG FILE</u>	1		1	RGN3 FILE 01	1		1
	RGN2/DRSS/EPRPB	1		1				
EXTERNAL:	LPDR	1		1	NRC PDR	1		1
	NSIC	1		1				

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR. 19 ENCL 18

R
I
D
S
/
A
D
D
S
/
A
D
S
/
A
D
S

Environ. 1/91


Indiana Michigan
Power Company
One Summit Square
P.O. Box 60
Fort Wayne, IN 46801
219 425 2111

DMB



INDIANA
MICHIGAN
POWER

Paul D. Zugger, Executive Secretary
Michigan Water Resources Commission
Stevens T. Mason Building, P.O. Box 30026
Lansing, Michigan 48909



November 7, 1988

Dear Mr. Zugger:

RE: Donald C. Cook Nuclear Plant
NPDES Permit No. MI 0005827
Prefilter Backwash Limitations

A sample taken on October 31, 1988 of the prefilter backwash discharge (Outfall OOF) indicated a suspended solids (TSS) concentration of 138 mg/l. The average TSS for the month of October was 59 mg/l. The operating log showed that the prefilter backwash unit was operating normally at that time. Rough lake conditions appear to have suspended lake bottom sediments in the plant's intake water.

By copy of this letter, the Nuclear Regulatory Commission is notified pursuant to the requirements of Appendix B, Part II, Nonradiological Environmental Protection Plan, Section 3.2.

Very truly yours,

Richard C. Menge

Richard C. Menge
Senior Vice President

RCM/df

c: Valdas Adamkus - USEPA, Region V
~~XXXXXXXXXXXXXXXXXXXX~~
Fred Morley - MDNR, Plainwell

I certify under penalty of law that I have personally examined and am familiar with the information submitted on this and all attached documents; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

Richard C. Menge
Richard C. Menge

EX-105
1523
110

NOV 10 1988

8811230391 881107
PDR ADOCK 05000315
S PDC