

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8811300572 DOC. DATE: 88/11/18 NOTARIZED: NO DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316
 AUTH. NAME AUTHOR AFFILIATION
 MENGE, R.C. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 RECIP. NAME RECIPIENT AFFILIATION
 ZUGGER, P.D. Michigan, State of

SUBJECT: NPDES noncompliance notification: on 881114, prefilter
backwash effluent for suspended solids was 171 mg/l.

DISTRIBUTION CODE: IE23D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: Environmental Event Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES
		LTR	ENCL		LTR
	PD3-1 LA	1	0	PD3-1 PD	1
	SCOTT, W	1	1		1
INTERNAL:	AEOD/DSP/TPAB	1	1	AEOD/PTB	1
	NRR/DEST/ADE 8H	1	1	NRR/DOEA/EAB 11	1
	NRR/DREP/EPB 10	1	1	NRR/DREP/RPB 10	1
	NRR/PMAS/ILRB12	1	1	NRR/PMAS/PTSBL2	1
	NUDOCS-ABSTRACT	1	1	OGC/HDS1	1
	<u>REG FILE</u>	1	1	RGN3 FILE 01	1
	RGN2/DRSS/EPRPB	1	1		
EXTERNAL:	LPDR	1	1	NRC PDR	1
	NSIC	1	1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 19 ENCL 28

E. P. W.

Indiana Michigan
Power Company
One Summit Square
P.O. Box 60
Fort Wayne, IN 46801
219 425 2111

DMB



Paul D. Zuger, Executive Secretary
Michigan Water Resources Commission
Stevens T. Mason Building, P.O. Box 30026
Lansing, Michigan 48909

November 18, 1988

PRIORITY ROUTING	
First	Second
RA	
ORA	
DRP	
DRS	
DRSS	
DRM	

FILE *DM*

Dear Mr. Zuger:

RE: Donald C. Cook Nuclear Plant
NPDES Permit No. MI 0005827
Prefilter Backwash Limitations

A sample of the prefilter backwash effluent (Outfall 00F) taken on November 14, 1988 was analyzed for suspended solids and indicated 171 mg/l. The backwash unit was operating normally at that time. Rough lake conditions appear to have stirred bottom sediments coming into the plant's intake water.

By copy of this letter, the Nuclear Regulatory Commission is notified pursuant to the requirements of Appendix B, Part II, Nonradiological Environmental Protection Plan, Section 3.2.

Very truly yours,

Richard C. Menge
Richard C. Menge
Senior Vice President

RCM/df
cc: Valdas Adamkus - USEPA, Region V
~~B. DAVIS - NRC, Region III~~
Fred Morley - MDNR, Plainwell

I certify under penalty of law that I have personally examined and am familiar with the information submitted on this and all attached documents; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

Richard C. Menge
Richard C. Menge

IEES
IEES
NOV 21 1988
/0

8811300572 881118
PDR ADOCK 05000315
S PNU

November 18, 1988

Paul D. Zegger

Page 2

bc: A. J. Ahern/T. E. Webb/M. R. Robida - Columbus
M. P. Alexich - Columbus
P. A. Barrett - Columbus
C. E. Hawk - Columbus
K. D. Mack - Columbus
W. E. Walters/D. L. Baker/J. L. Hughey - Fort Wayne

A. A. Blind/J. R. Sampson - Cook Plant
NRC Resident Inspector - Cook Plant
PNSRC - Cook Plant
W. G. Smith, Jr. - Cook Plant
J. T. Wojcik/D. M. Fitzgerald - Cook Plant

G. Charnoff/R. E. Zahler - Shaw, Pittman, Potts & Trowbridge

T. E. Murley - Nuclear Reactor Regulations