

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8904200392 DOC. DATE: 89/04/13 NOTARIZED: NO DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315
 AUTH. NAME AUTHOR AFFILIATION
 CREED, J. Region 3, Ofc of the Director
 GREGER, R. Region 3, Ofc of the Director
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: PNO-III-89-026: on 890409 & 10, potential equipment tampering.

DISTRIBUTION CODE: IE34D COPIES RECEIVED: LTR 0 ENCL 1 SIZE: 1
 TITLE: Preliminary Notification-Occurrence/Non-Routine Event/Safeguards Even

NOTES:

	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTR	ENCL		LTR	ENCL
INTERNAL:	ACRS/SIESS	1	1	AEOD/DSP/TPAB	1	1
	NRC OP CNTR	1	1	NRR/DRIS/SGB 9A	1	1
	NRR/DRIS/SIB.9A	1	1	NRR/DRIS/VIB	1	1
	NRR/PMAS/ILRB12	1	1	NUDOCS-ABSTRACT	1	1
	OE LIEBERMAN, J	1	1	<u>REG FILE</u> 02	1	1
	RES BROOKS, B	1	1	RES-DEPY	1	1
	RES FILE	1	1	RES/DE	1	1
	RES/DRA	1	1	RES/DSIR	1	1
	RES/DSIR/EIB	1	1	RES/DSR DEPY	1	1
	RES/PMPDAS	1	1	RGN3 FILE 01	1	1
EXTERNAL:	DOE BARBER EV34	1	1	LPDR	1	1
	NRC PDR	1	1	NSIC	1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 24 ENCL 24

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE PNO-III-26 Date April 13, 1989

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region III staff on this date.

Facility: Indiana Michigan Power Co.
D. C. Cook, Unit 1
Stevensville, MI 49127

Docket No. 50-315

Licensee Emergency
Classification:
 Unusual Event
 Alert
 Site Area Emergency
 General Emergency
 Not Applicable

Subject: POTENTIAL EQUIPMENT TAMPERING

On April 9 and 10, 1989, the licensee conducted a surveillance test on the Unit 1 diesel generator. During this time, the two circuit breakers on the CD Diesel Generator Invertor were verified to be in the closed position (the invertor supplies power to diesel generator control functions).

About 20 minutes after the verification, an alarm was received in the control room indicating that the breakers had opened. The opened breakers had no direct effect on the operation of the diesel or the surveillance test; however, had the diesel generator been in the standby mode, the generator may not have operated properly if called upon.

The licensee has been investigating this event. On April 12, the licensee conducted trip tests on the circuit breakers and concluded that neither mechanical failure or previously reported electrical fluctuations could have caused the breakers to open. The breakers are three position breakers ("on, trip, off"). The test showed that when the breakers trip, they go into the "trip" position, and not to the "off" position in which they were found.

The licensee's investigation is continuing and additional security actions are being taken. Site access has been limited for the individuals who were in the room when the breakers tripped. The FBI also is onsite reviewing this event.

Two Region III (Chicago) physical security inspectors are onsite monitoring the licensee's course of action. The NRC's Information Assessment Team has been briefed.

The State of Michigan will be notified.

Region III was notified of the updated information at 2:30 p.m. (CDT), April 12, 1989. This information is current as of 11:30 a.m. (CDT), April 13, 1989.

CONTACT: *J. Creed*
J. Creed (FTS 388-5643)

R. Greger
R. Greger (FTS 388-5644)

DISTRIBUTION:

<u>WHITE FLINT NORTH 1</u>	<u>MNBB</u>	<u>REGIONS</u>	<u>FAX TO:</u>
Chairman Zech CA	AEOD	RI	INPO 3:23
Comm. Roberts OGC	ARM	RII	NSAC 3:39
Comm. Carr OI	OIA	RIV	Licensee 3:40
Comm. Rogers EDO		RV	NRC Ops Ctr 3:21
Comm. Curtiss NRR	NL	<u>MAIL TO:</u>	PDR (8/634-3343) 3:30
SECY NMSS	RES	DCS (Orig.)	
GPA/SLITP/PA ACRS		DOT (Trans. Only)	

IE34
0/1

Rev. 03/01/89