

RTT File
DCL

SEP 22 1989

Docket No. 50-315
Docket No. 50-316

Indiana Michigan Power Company
ATTN: Mr. Milton P. Alexich
Vice President
Nuclear Operations Division
1 Riverside Plaza
Columbus, OH 43216

Gentlemen:

Thank you for your letter dated July 21, 1989, in response to our June 15, 1989 letter concerning an allegation pertaining to construction and maintenance practices by an Indiana Michigan Power Company contractor: Catalytic Industrial Maintenance Company.

In our letter, we requested that you examine the circumstances surrounding the allegations, take all actions deemed necessary to resolve the issues, and submit the results of your investigation to the NRC.

Your response indicated that an extensive investigation was conducted into each of the concerns by the American Electric Power Service Corporation Quality Assurance Division. Interviews with specified supervisors and randomly selected maintenance workers were conducted, welder test records were reviewed, and component installation packages were reviewed to identify the facts involved. Your investigation revealed only one minor procedural violation related to improper change to the mounting bolt layout for a junction box. Your assessment stated that this did not create a safety problem for the D. C. Cook Nuclear Plant. We found your investigation to be sufficient to support your conclusions and have no additional questions regarding this matter.

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter will be placed in the NRC Public Document Room.

Your cooperation is appreciated.

Sincerely,

Original signed by W. L. Forney

Edward G. Greenman, Director
Division of Reactor Projects

8910040005 890922
PDR ADOCK 05000315
P PNU

See Attached Distribution

[Handwritten signature]
IE01

Indiana Michigan Power
Company

2

SEP 22 1989

Distribution

cc: A. A. Blind, Plant Manager
DCD/DCB (RIDS)
Licensing Fee Management Branch
Resident Inspector, RIII
Ronald Callen, Michigan
Public Service Commission
EIS Coordinator, USEPA Region 5
Michigan Department of
Public Health

RIII
MOT
Farber/cs
9/21/89

RIII
MOT
Burgess
9/21/89

RIII
MOT
Axelson
9/21

RIII
MOT
Forney
9/22

RIII
MOT
Greenman
9/22