



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

May 4, 1990

Docket Nos. 50-315/316

Mr. Milton Alexich
Indiana Michigan Power Company
c/o American Electric Power
Service Corporation
1 Riverside Plaza
Columbus, Ohio 43216

Dear Mr. Alexich:

SUBJECT: MEETING WITH INDIANA MICHIGAN POWER COMPANY TO DISCUSS CYCLE 8
RELOAD ANALYSIS FOR D. C. COOK UNIT 2.

On April 19, 1990, the staff met with Indiana Michigan Power Company (IMPC) to discuss the proposed Technical Specification (TS) amendments related to the D. C. Cook Unit 2 Cycle 8 reload. A list of attendees is provided as Attachment 1. A copy of the slides (all non-proprietary) is provided as Attachment 2.


IMPC has submitted three technical specification amendment applications to support Cycle 8 for D. C. Cook Unit 2: (1) an amendment that reflects revised accident analyses for Cycle 8, (2) an amendment that would allow receipt of fuel assemblies with higher enrichment into the spent fuel pool and new fuel storage vault, and (3) an amendment that would allow cycle specific parameters to be removed from technical specifications and placed in a Core Operating Limits Report. The staff informed IMPC that safety evaluations for items 2 and 3 were complete and that TS should be issued within the next month.

IMPC currently estimates that Unit 2 will enter a refueling outage toward the beginning of July and commence Cycle 8 at the end of August. The transition core designed for Cycle 8 will include 77 new Westinghouse 17 x 17 Vantage 5 fuel assemblies plus 116 of the previously utilized Advanced Nuclear Fuels 17 x 17 fuel assemblies.

Changes from previous analyses include revised set points or response times for some reactor protection system and engineered safety features actuations, a decrease in shutdown margin (to 1.6%), an increase in minimum boric acid storage tank volume, an increase in allowable rod drop time, and relaxed accumulator volume and pressure limits. The proposed amendment would also modify some current transition mode requirements. For example, shutdown margin requirements would be added for modes 4 and 5 such that an operator would have sufficient time (at least 15 minutes) to respond to a postulated boron dilution transient.

9005160226 900504
PDR ADOCK 05000315
P PDC

27



IMPC still plans to submit information related to incomplete modelling of the feedwater regulating valves, in addition to some corrected TS pages and other information requested by the staff. IMPC requested NRC response relative to the shutdown margin requirement in mode 4 and 5 by June 29th and approved TS by August 15th.

Sincerely,

A handwritten signature in black ink, appearing to read "J. G. Gitter", with a flourish at the end.

Joseph G. Gitter, Project Manager
Project Directorate III-1
Division of Reactor Projects - III,
IV, V & Special Projects
Office of Nuclear Reactor Regulation

Attachments:
As stated

cc: See next page

IMPC still plans to submit information related to incomplete modelling of the feedwater regulating valves, in addition to some corrected TS pages and other information requested by the staff. IMPC requested NRC response relative to the shutdown margin requirement in mode 4 and 5 by June 29th and approved TS by August 15th.

Sincerely,

Original signed by

Joseph G. Gitter, Project Manager
Project Directorate III-1
Division of Reactor Projects - III,
IV, V & Special Projects
Office of Nuclear Reactor Regulation

Attachments:
As stated

cc: See next page

DISTRIBUTION
Docket File 3
NRC & Local PDRs
FMiraglia
PD31 Reading
DDianni
JGitter
OGC
EJordan
ACRS(10)
JClifford
JPartlow

MMA
LA/PD31:DRSP
MRShuttleworth
05/3 /90

PD/PD31:DRSP
BSzpanky
05/31 /90

JGD
(A)D/PD31:DRSP
DDianni
05/3 /90

RF01
11

1944

1. The first part of the report deals with the general situation of the country and the progress of the war. It is a very interesting and informative account of the events of the year.

2. The second part of the report deals with the economic situation of the country and the progress of the war. It is a very interesting and informative account of the events of the year.

CONCLUSION

The report is a very interesting and informative account of the events of the year. It is a very interesting and informative account of the events of the year.

The report is a very interesting and informative account of the events of the year. It is a very interesting and informative account of the events of the year.

Mr. Milton Alexich
Indiana Michigan Power Company

Donald C. Cook Nuclear Plant

cc:
Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Mr. S. Brewer
American Electric Power
Service Corporation
1 Riverside Plaza
Columbus, Ohio 43216

Attorney General
Department of Attorney General
525 West Ottawa Street
Lansing, Michigan 48913

Township Supervisor
Lake Township Hall
Post Office Box 818
Bridgman, Michigan 49106

Al Blind, Plant Manager
Donald C. Cook Nuclear Plant
Post Office Box 458
Bridgman, Michigan 49106

U.S. Nuclear Regulatory Commission
Resident Inspectors Office
7700 Red Arrow Highway
Stevensville, Michigan 49127

Gerald Charnoff, Esquire
Shaw, Pittman, Potts and Trowbridge
2300 N Street, N.W.
Washington, DC 20037

Mayor, City of Bridgman
Post Office Box 366
Bridgman, Michigan 49106

Special Assistant to the Governor
Room 1 - State Capitol
Lansing, Michigan 48909

Nuclear Facilities and Environmental
Monitoring Section Office
Division of Radiological Health
Department of Public Health
3500 N. Logan Street
Post Office Box 30035
Lansing, Michigan 48909

ATTACHMENT 1

MEETING WITH D. C. COOK TO DISCUSS

UNIT 2, CYCLE 8 RELOAD ANALYSIS

APRIL 19, 1990

<u>NAME</u>	<u>AFFILIATION</u>	<u>TITLE</u>
Thomas A. Georgantis	AEPSC-NF&A	Engineer
Vance Vanderburg	AEPSC-NF&A	Scientist
Steve Brewer	AEPSC-NS&L	Manager
Shamul Abedin	Westinghouse/NS	Sr. Engineer
Donald H. Behuki	Westinghouse/Nuc Sof	Sr. Engineer
Juan M. Nieto	AEPSC-NS&L	Sr. Engineer
Bert Svensson	Indiana Michigan Power	Lic. Coord.
Doug Malin	AEPSC-Nuclear Fuels	Manager
Harry Balukjian	NRR/RSB	Reactor Engineer
Daniel Fieno	NRR/SRXB	Sr. Reactor Physicist
Joseph G. Giitter	NRR/DRSP	Project Manager
Laubros Lois	NRR/DST	Sr. Nuclear Engineer
Scott R. Griffith	Westinghouse/Nuc Safety	Engineer
Michael A. Emery	Westinghouse/Nuc Safety	Engineer
Bernard W. Gergos	Westinghouse/CNFD	Sr. Engineer
Mark Caruso	NRR/SRXB	Section Chief
Dominic DiIanni	NRR/DRSP	Acting Project Director




DONALD C. COOK NUCLEAR PLANT

UNIT 2 CYCLE 8

Presentation to NRC Staff

April 19, 1990



DONALD C. COOK NUCLEAR PLANT

UNIT 2 CYCLE 8

- Currently Projected Outage Schedule
 - End of Cycle 7 29Jun90
 - Mode 5 Cycle 8 22Aug90
 - Mode 4 Cycle 8 27Aug90

- Transition Core
 - 77 Westinghouse 17 x 17 V-5 Assemblies
 - 116 Advanced Nuclear Fuels 17 x 17 Assemblies


- Vantage 5 Fuel
 - Integral Fuel Burnable Absorber
 - Intermediate Flow Mixers
 - Reconstitutible Top Nozzle
 - Extended Burnup
 - Axial Blankets
 - Debris Filter Bottom Nozzle

Cycle 8 Submittals

- Unit 2 Cycle 8 Reload Analyses
(AEP:NRC:1071E,1071H)
- Unit 2 Cycle 8 Criticality Analyses
(AEP:NRC:1071F,1071G)
- Unit 2 Core Operating Limits Report
(AEP:NRC:1077A)

UNIT 2 CYCLE 8 RELOAD ANALYSES

- Unit 2 Licensing Basis
- Proposed T/S Changes



PURPOSES OF CYCLE 8 T/S CHANGES

- Support Mixed Core Operation
 - ANF 17x17 Fuel
 - Westinghouse 17x17 V-5 Fuel
- Gain Operational Flexibility
- Remove Non-Standard Transition Mode Requirements
- Similar Changes to Unit 1 Where Justifications Are Similar

ORGANIZATION OF CYCLE 8 RELOAD ANALYSES SUBMITTAL

- Cover Letter
- Eleven Attachments

Attachments

1. Description and 50.92 Evaluation
2. Proposed T/S Changes
3. Summary

4. Westinghouse Analyses and Evaluations
5. Westinghouse Analysis of M&E Release Inside Containment
6. Westinghouse Evaluation to Support Pressurizer Operability at 92% Level

7. Draft Cycle 8 COLR

8. Unit 2 Licensing Basis 50.92 Evaluation
9. Letter from NRC Staff Discussing Previous Cycle 8 Meeting

10. Part B of WCAP 10217-A, Fq Surveillance Technical Specification
11. Major Analytical Assumptions from WCAP 11908, "Containment Integrity Analysis for Donald C. Cook Plant Units 1 and 2"

ATTACHMENT 3 TO AEP:NRC:1071E

SUMMARY DESCRIPTIONS FOR DONALD C. COOK NUCLEAR PLANT
UNIT 2 CYCLE 8 PROPOSED T/Ss

Page	Section	+	#	Description	Remarks
3/4 1-3b	Figure 3.1-3	2	033	Remove Figure 3.1-3	The shutdown margin requirements for Mode 4 and Mode 5 when operating on RHR were added to the Unit 2 T/Ss by Amendment 82. This requirement ensures the operator has adequate time to respond to dilution transients when operating on RHR. We propose to address this concern administratively. See Attachment 1; T/S Change Group 2b
3/4 1-16	3.1.2.8	1	034	Item a1; the required volume of the 20,000 ppm boration source is increased to 7715 gallons	The new value is a value which is expected to accommodate uprating to a core thermal power of 3588 MWt, fuel of increased enrichment for increased cycle length, and changes in vendor methodology. This change is indicated in Attachment 4, Table 6.1 and Attachment 4, Appendix A.
		4	035	Mathematical symbols replaced with words	Administrative change
3/4 1-23	3.1.3.4	1	036	The rod drop time requirement is changed to less than or equal to 2.7 seconds	The pressure drop is larger in V5 than other fuel types requiring an increase in rod drop time to 2.7 seconds. See Attachment 4, Section 5.1.2; Attachment 4, Appendix B, Section B.2.4; and Attachment 4, Appendix C, Table C.3.2-1.
		4	037	Mathematical symbols replaced with words	Administrative change

NEW ANALYSES FOR UNIT 2 CYCLE 8

- Uncontrolled RCCA Bank Withdrawal From A Subcritical Condition
- Uncontrolled RCCA Bank Withdrawal At Power
- Rod Cluster Control Assembly Misalignment
- Rod Cluster Control Assembly Drop
- Uncontrolled Boron Dilution



NEW ANALYSES FOR UNIT 2 CYCLE 8 (CONTINUED)

- Loss of Forced Reactor Coolant Flow
(Including Locked Rotor)
- Loss of External Electric Load or Turbine Trip
- Loss of Normal Feedwater
- Excessive Heat Removal Due to Feedwater System
Malfunctions
- Excessive Load Increase
- Loss Of Offsite Power to the Station
Auxiliaries



NEW ANALYSES FOR UNIT 2 CYCLE 8 (CONTINUED)

- Rupture of a Steamline
- Rupture of a Control Rod Drive Mechanism Housing
- Major Rupture of Main Feedwater Pipe
- Large Break LOCA
- Small Break LOCA
- Post LOCA Long Term Cooling
- Combined Seismic LOCA Analysis

T/S CHANGE GROUPS

- Changes Based on Analyses
- Transition Mode Requirements
- Changes Previously Made for Unit 1
- Administrative
- Delta Flux Surveillance
- Parallel Changes to Unit 1 T/S

CHANGES FROM ANALYSES

- New Safety Limit Curves
- New OPDT/OTDT Setpoints
- Increase Design Flow to
to 91,600 gpm/loop
- Decrease SDM to 1.6%
- Increase Minimum BAST Volume
- Increase Allowable Rod Drop Time
to 2.7 Seconds
- New Mode 1 Operating Window:
 - $543.9^{\circ}\text{F} \leq T_{\text{avg}} \leq 578.7^{\circ}\text{F}$
 - Pressurizer Pressure ≥ 2200 psig
 - RCS Total Flow $\geq 366,400$ gpm

Note: Design Flow = 366,400 gpm / 4

CHANGES FROM ANALYSES

(Continued)

- Revise Fp Penalty
- Add Protection Response Time
 - Pressurizer Level
- Relax Response Times
 - Pressurizer Pressure, Low and High
 - Low Flow, One and Two Loops
 - Steam Generator Level, Low-Low
 - Undervoltage RCPs
- New High Steam Flow Setpoints
- Add Safeguards Response Times
 - Containment Pressure High
 - Steam Generator Level, High-High

CHANGES FROM ANALYSES (Continued)

- Relax Accumulator Volume and Pressure Limits
 - 921 to 971 Cubic Feet
 - 585 to 658 psig
- Relax Permissible SI and RHR Pump Degradation
- Relax Boron Injection Flow Imbalance
- Related Bases Changes

TRANSITION MODE REQUIREMENTS

- SDM in Modes 4 & 5 for Boron Dilution Transient
- Protection for Increased Steam Load Transient in Mode 3
- DNB Protection in Modes 2, 3, 4 & 5
- \$ Footnote for Steam Generator High-High Level Safeguards Actuation

PROPOSED UNIT 2 T/S CHANGE
PREVIOUSLY APPROVED FOR UNIT 1

- OPERABILITY LEVEL FOR
PRESSURIZER

PROPOSED UNIT 1 CHANGES SIMILAR TO PROPOSED UNIT 2 CHANGES

- SDM In Modes 4 & 5 For Boron Dilution Transient
- Delta Flux Surveillance
- SI and RHR Pump Degradation

DELTA FLUX SURVEILLANCE AFTER RESTORING MONITOR OPERABILITY

- 24 Hour Monitoring Requirement
Based on Inability to Update
Time Out of Target Band
- Not Needed If Known Delta Flux
Not Out of Target Band

FEEDWATER SYSTEM MALFUNCTION ZERO POWER CASE

- One Open Item Remains from AEP:NRC:1071E Submittal: Incomplete Modelling of Feedwater Regulating Valve in Original Analysis
- Analysis Redone
- All Acceptance Criteria Are Met
- NRC Submittal: May 1990



COLR PARAMETERS

- MTC: -38.0 pcm/oF for HFP Tavg = 574.0 oF
- 300 ppm Acceptance Criterion:
Approximately -32 pcm/oF (1)
- ARO: 228 Steps
- Rod Insertion Limits
- Delta Flux Wings
- F(Q): 2.33 for Westinghouse Fuel
2.10 for ANF Fuel
- K(Z)
- F Delta H: 1.56 for Westinghouse Fuel
1.49 for ANF Fuel
- V(Z) (1)

(1) : To Be Calculated

Unit 2 Cycle 8 Reload Submittal
Assumes COLR Submittal Approval



Handwritten scribbles and marks in the top right corner.

CONCLUSIONS

- Standard Westinghouse Fuel Product in Westinghouse NSSS
- No Challenge to Health, Safety, and Welfare of the Public
- Reviewed Submittal with NRC
- Unit 2 COLR - Under Staff Review
- Unit 2 Criticality - Under Staff Review
- AEP to Provide Final Documentation for Feedwater Malfunction in May
- Need NRC Response to Modes 4 & 5 SDM by June 29
- Need NRC Final Approval by August 15

