

UNITED STATES NUCLEAR REGULATORY COMMISSIONINDIANA MICHIGAN POWER COMPANYDOCKET NO. 50-315NOTICE OF ISSUANCE OF AMENDMENT TOFACILITY OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (Commission) has issued Amendment No. 151 to Facility Operating License No. DPR-58, issued to the Indiana Michigan Power Company, (the licensee), which revised the Technical Specifications (TS) for operation of the Donald C. Cook Nuclear Plant, Unit No. 1, located in Berrien County, Michigan. The amendment is effective as of the date of issuance.

The amendment permits the use of approved sleeves to repair defective steam generator tubes. The TS previously required that all defective tubes be plugged and removed from service.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment.

Notice of Consideration of Issuance of Amendment and Opportunity for Hearing in connection with this action was published in the FEDERAL REGISTER on October 19, 1990 (55 FR 42526). No request for a hearing or petition for leave to intervene was filed following this notice.

The Commission has prepared an Environmental Assessment related to the action and has determined not to prepare an environmental impact statement.


9012140102 901205
PDR ADOCK 05000315
P PIC

Based upon the environmental assessment, the Commission has concluded that the issuance of this amendment will not have a significant effect on the quality of the human environment.

For further details with respect to the action see (1) the application for amendment dated June 27, 1990 and supplemented by letter dated October 9, 1990, (2) Amendment No. 151 to License No. DPR-58, (3) the Commission's related Safety Evaluation, and (4) the Commission's Environmental Assessment. All of these items are available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, N.W., Washington, D.C., 20555 and at the Maude Preston Palenske Memorial Library, 500 Market Street, St. Joseph, Michigan 49085. A copy of items (2), (3) and (4) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Director, Division of Reactor Projects III/IV/V.

Dated at Rockville, Maryland this 5th day of December 1990.

FOR THE NUCLEAR REGULATORY COMMISSION



Timothy G. Colburn, Senior Project Manager
Project Directorate III-1
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

