

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9012260154 DOC. DATE: 90/12/21 NOTARIZED: YES DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316
 AUTH. NAME AUTHOR AFFILIATION
 ALEXICH, M. P. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 RECIP. NAME RECIPIENT AFFILIATION
 MURLEY, T. E. Document Control Branch (Document Control Desk)

SUBJECT: Forwards response to Generic Ltr 90-06 re Generic Issue 70
 on PORV & block valve reliability & Generic Issue 94 on addl
 low temp overpressure protection for LWRs. Tech Spec change
 will be proposed in early 1991.

DISTRIBUTION CODE: A019D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 8
 TITLE: Generic Ltr 90-06 Resolution of GE 70N94 PORVs & Block Valve Reliabil

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR	ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR	ENCL
	PD3-1 LA	1	1	PD3-1 PD	1	1
	COLBURN, T.	1	1			
INTERNAL:	KIRKWOOD, R. NLS3	1	1	NRR/EMEB	1	1
	NRR/SRXB	1	1	PICKETT, D 13H15	1	1
	REG FILE 01	1	1	RES/DSIR/EIB	1	1
	RES/DSIR/RPSIB	1	1			
EXTERNAL:	NRC PDR	1	1	NUDOCS-ABSTRACT	1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 12 ENCL 12

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S



AEP:NRG:1131

Donald C. Cook Nuclear Plant Units 1 and 2
Docket Nos. 50-315 and 50-316
License Nos. DPR-58 and DPR-74
RESOLUTION OF GENERIC ISSUE 70, "POWER-OPERATED RELIEF VALVE AND
BLOCK VALVE RELIABILITY," AND GENERIC ISSUE 94, "ADDITIONAL LOW-
TEMPERATURE OVERPRESSURE PROTECTION FOR LIGHT-WATER REACTORS,"
PURSUANT TO 10 CFR 50.54(f) (GENERIC LETTER 90-06)

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Attn: T. E. Murley

December 21, 1990

Dear Dr. Murley:

This letter is in response to Generic Letter 90-06 dated June 25, 1990. Enclosure A of the Generic Letter presents the staff position and recommendations for the resolution of Generic Issue 70, "Power-Operated Relief Valves and Block Valve Reliability," applicable to Westinghouse-designed plants with power-operated relief valves (PORVs). Enclosure B of the Generic Letter presents the staff position and recommendations for the resolution of Generic Issue 94, "Additional Low-Temperature Overpressure Protection for Light-Water Reactors," applicable to Westinghouse-designed plants, with or without PORVs and block valves. Cook Nuclear Plant Units 1 and 2 were designed by Westinghouse and have three sets of PORVs and block valves. Our response to these recommendations is provided in the attachment to this letter.

Technical Specifications changes will be proposed for Cook Nuclear Plant in response to Generic Letter 90-06. We propose to submit the changes early in 1991 with the intent to implement them by the end of the 1992 refueling outages.

Once our actions are completed, we will have implemented the staff recommendations with three exceptions, which are discussed in the attachment. One exception concerns incorporating valves in the PORV control air system into the IST Program (see response to Enclosure A, Action Item 2). The second exception concerns the limiting condition for operation for three PORVs and associated block valves in Modes 1, 2, and 3 (see response to Enclosure A, Action Item 3). The third exception concerns the applicability of low temperature overpressure protection (LTOP) in Mode 4 (see response to Enclosure B Action Item).

9012260154 901221
PDR--ADOCK 05000315
PDR

A019
1/1


Dr. T. E. Murley

-2-

AEP:NRC:1131

This letter is submitted pursuant to 10 CFR 50.54(f) and, as such,
an oath is enclosed.

Sincerely,



M. P. Alexich
Vice President

ldp

Attachments

cc: D. H. Williams, Jr.
A. A. Blind
J. R. Padgett
G. Charnoff
A. B. Davis - Region III
NRC Resident Inspector - Bridgman
NFEM Section Chief

STATE OF OHIO)
COUNTY OF FRANKLIN)

Milton P. Alexich, being duly sworn, deposes and says that he is the Vice President of licensee Indiana Michigan Power Company, that he has read the foregoing Response to Generic Letter 90-06 and knows the contents thereof; and that said contents are true to the best of his knowledge and belief.

M. Alexich

Subscribed and sworn to before me this 21st
day of December, 1990.

FILE
NOV 23 1990

Rita D. Hill
NOTARY PUBLIC

RITA D. HILL
NOTARY PUBLIC, STATE OF OHIO
MY COMMISSION EXPIRES 6-28-94



v
v
:

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100
101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200
201
202
203
204
205
206
207
208
209
210
211
212
213
214
215
216
217
218
219
220
221
222
223
224
225
226
227
228
229
230
231
232
233
234
235
236
237
238
239
240
241
242
243
244
245
246
247
248
249
250
251
252
253
254
255
256
257
258
259
260
261
262
263
264
265
266
267
268
269
270
271
272
273
274
275
276
277
278
279
280
281
282
283
284
285
286
287
288
289
290
291
292
293
294
295
296
297
298
299
300
301
302
303
304
305
306
307
308
309
310
311
312
313
314
315
316
317
318
319
320
321
322
323
324
325
326
327
328
329
330
331
332
333
334
335
336
337
338
339
340
341
342
343
344
345
346
347
348
349
350
351
352
353
354
355
356
357
358
359
360
361
362
363
364
365
366
367
368
369
370
371
372
373
374
375
376
377
378
379
380
381
382
383
384
385
386
387
388
389
390
391
392
393
394
395
396
397
398
399
400
401
402
403
404
405
406
407
408
409
410
411
412
413
414
415
416
417
418
419
420
421
422
423
424
425
426
427
428
429
430
431
432
433
434
435
436
437
438
439
440
441
442
443
444
445
446
447
448
449
450
451
452
453
454
455
456
457
458
459
460
461
462
463
464
465
466
467
468
469
470
471
472
473
474
475
476
477
478
479
480
481
482
483
484
485
486
487
488
489
490
491
492
493
494
495
496
497
498
499
500
501
502
503
504
505
506
507
508
509
510
511
512
513
514
515
516
517
518
519
520
521
522
523
524
525
526
527
528
529
530
531
532
533
534
535
536
537
538
539
540
541
542
543
544
545
546
547
548
549
550
551
552
553
554
555
556
557
558
559
560
561
562
563
564
565
566
567
568
569
570
571
572
573
574
575
576
577
578
579
580
581
582
583
584
585
586
587
588
589
590
591
592
593
594
595
596
597
598
599
600
601
602
603
604
605
606
607
608
609
610
611
612
613
614
615
616
617
618
619
620
621
622
623
624
625
626
627
628
629
630
631
632
633
634
635
636
637
638
639
640
641
642
643
644
645
646
647
648
649
650
651
652
653
654
655
656
657
658
659
660
661
662
663
664
665
666
667
668
669
670
671
672
673
674
675
676
677
678
679
680
681
682
683
684
685
686
687
688
689
690
691
692
693
694
695
696
697
698
699
700
701
702
703
704
705
706
707
708
709
710
711
712
713
714
715
716
717
718
719
720
721
722
723
724
725
726
727
728
729
730
731
732
733
734
735
736
737
738
739
740
741
742
743
744
745
746
747
748
749
750
751
752
753
754
755
756
757
758
759
760
761
762
763
764
765
766
767
768
769
770
771
772
773
774
775
776
777
778
779
780
781
782
783
784
785
786
787
788
789
790
791
792
793
794
795
796
797
798
799
800
801
802
803
804
805
806
807
808
809
810
811
812
813
814
815
816
817
818
819
820
821
822
823
824
825
826
827
828
829
830
831
832
833
834
835
836
837
838
839
840
841
842
843
844
845
846
847
848
849
850
851
852
853
854
855
856
857
858
859
860
861
862
863
864
865
866
867
868
869
870
871
872
873
874
875
876
877
878
879
880
881
882
883
884
885
886
887
888
889
890
891
892
893
894
895
896
897
898
899
900
901
902
903
904
905
906
907
908
909
910
911
912
913
914
915
916
917
918
919
920
921
922
923
924
925
926
927
928
929
930
931
932
933
934
935
936
937
938
939
940
941
942
943
944
945
946
947
948
949
950
951
952
953
954
955
956
957
958
959
960
961
962
963
964
965
966
967
968
969
970
971
972
973
974
975
976
977
978
979
980
981
982
983
984
985
986
987
988
989
990
991
992
993
994
995
996
997
998
999
1000

ATTACHMENT TO AEP:NRC 1131

RESPONSE TO ACTIONS REQUESTED IN GENERIC LETTER 90-06

Enclosure A - Section 3.1, Staff Positions Resulting from Resolution of Generic Issue 70, "PORV and Block Valve Reliability"

Action Item 1

"Include PORVs and block valves within the scope of an operational quality assurance program that is in compliance with 10 CFR Part 50, Appendix B. This program should include the following elements:

- a. The addition of PORVs and block valves to the plant operational Quality Assurance List.
- b. Implementation of a maintenance/refurbishment program for PORVs and block valves that is based on the manufacturer's recommendations or guidelines and is implemented by trained plant maintenance personnel.
- c. When replacement parts and spares, as well as complete components, are required for existing non-safety-grade PORVs and block valves (and associated control systems), it is the intent of this generic letter that these items may be procured in accordance with the original construction codes and standards."

Response

This action is already established at Cook Nuclear Plant and includes the following elements, as requested:

- a. The PORVs and block valves are classified as QA-N in the plant Facility Data Base as a result of their pressure retaining function for the reactor coolant pressure boundary. It should be noted that the classification does not necessarily apply to non-pressure retaining components on these valves, as well as actuators, motor operators and associated air and control systems.
- b. Maintenance of the PORVs and block valves has been performed to date, on an as-required basis, in accordance with manufacturer's recommendations and by trained plant personnel. This will be enhanced during 1991 when the PORVs and block valves will be evaluated during the reliability-centered maintenance analysis of the reactor coolant system as part of our preventive maintenance upgrade program.

- c. Pressure retaining components of the PORVs and block valves have been and will continue to be procured in accordance with original construction codes and standards. This practice has not necessarily been applied to non-pressure retaining components, as well as actuators, motor operators and associated air and control systems. In the future, these items will be procured in accordance with original construction codes and standards.

Action Item 2

"Include PORVs, valves in PORV control air systems, and block valves within the scope of a program covered by Subsection IWV, 'Inservice Testing of Valves in Nuclear Power Plants,' of Section XI of the ASME Boiler and Pressure Vessel Code. Stroke testing of PORVs should only be performed during Mode 3 (HOT STANDBY) or Mode 4 (HOT SHUTDOWN) and in all cases prior to establishing conditions where the PORVs are used for low-temperature overpressure protection. Stroke testing of the PORVs should not be performed during power operation. Additionally, the PORV block valves should be included in the licensees' expanded MOV test program discussed in NRC Generic Letter 89-10, 'Safety-Related Motor Operated Valve Testing and Surveillance,' dated June 28, 1989."

Response

The purpose of the IST Program is to provide indication of component reliability. The PORVs and block valves are currently in the Cook Nuclear Plant second 10-year IST Program. A separate test of the valves in the PORV control air system, however, is not presently included in the IST Program. Given the existing configuration of the control air system, separate testing of its components within the IST Program would not be possible without significant system modifications and/or numerous exemptions.

Since current in-service testing of the PORVs already indirectly provides assurance of proper operation of the control air system, we do not intend to separately include the control air system components in the IST Program. Indirect testing will continue to be accomplished by testing the PORVs, on a cold shutdown frequency as covered by the IST Program, in accordance with plant procedures. This will include testing to ensure that the valves stroke using normal and backup air supplies.

Action Item 2 also states that the PORV block valves should be included in the MOV testing program discussed in NRC Generic Letter 89-10, "Safety-Related Motor-Operated Valve Testing and Surveillance." These valves have been included in the MOV testing program.

Action Item 3

"For operating PWR plants, modify the limiting conditions of operation of PORVs and block valves in the technical specifications for Modes 1, 2, and 3 to incorporate the position adopted by the staff in recent guidance. The staff recognizes that some recently licensed PWR plants already have technical specifications in accordance with the staff position. Such plants are already in compliance with this position and need merely state that in their response. These recent technical specifications require that plants that run with the block valves closed (e.g., due to leaking PORVs) maintain electrical power to the block valves so they can be readily opened from the control room upon demand. Additionally, plant operation in Modes 1, 2, and 3 with PORVs and block valves inoperable for reasons other than seat leakage is not permitted for periods of more than 72 hours."

Response

The Cook Nuclear Plant Technical Specifications for Modes 1, 2, and 3 will be modified to agree with those proposed by the staff with one exception. Given that we have three PORVs, we will propose that plant operation in Modes 1, 2, and 3 be permitted with one PORV or block valve inoperable for reasons other than excessive seat leakage. Operation in these modes with more than one PORV or block valve inoperable for reasons other than seat leakage will not be permitted for periods of more than 72 hours. Our proposed Technical Specifications changes, and related justification, to address this issue will be submitted to you separately in early 1991.

Enclosure B - Section 3, Staff Positions Resulting from Resolution of Generic Issue 94, "Additional Low Temperature Overpressure Protection for Light Water Reactors"

Action Item

". . . The current 7-day AOT for a single channel is considered to be too long under certain conditions. The staff has concluded that the AOT for a single channel should be reduced to 24 hours when operating in MODE 5 or 6 when the potential for an overpressure transient is highest."

Response

The Technical Specifications will be revised using the guidance in Attachment B-1 as it specifically applies to Cook Nuclear Plant. Recognizing that we rely on PORVs and the RHR safety valve for low temperature overpressure protection (LTOP) and that the applicability of the LTOP system is limited to temperatures below 170°F for Unit 1 and 152°F for Unit 2, the 7-day AOT for Mode 4 (> 200°F) is not applicable to Cook Nuclear Plant. Proposed Technical Specifications changes will also be addressed as part of the aforementioned submittal to be made in early 1991.