

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9103010095 DOC. DATE: 91/02/25 NOTARIZED: NO DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316
 AUTH. NAME AUTHOR AFFILIATION
 ALEXICH, M.P. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 RECIP. NAME RECIPIENT AFFILIATION
 MURLEY, T.E. Document Control Branch (Document Control Desk)

SUBJECT: Application for amends to Licenses DPR-58 & DPR-74, modifying
 Tech Spec 4.0.3 requirements delayed to permit completion of
 missed surveillance allowable outage time limits of action.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2-1-12
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES		
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL	
	PD3-1 LA		1	1		PD3-1 PD		1	1	
	COLBURN, T.		2	2						
INTERNAL:	NRR/DET/ECMB 9H		1	1		NRR/DET/ESGB		1	1	
	NRR/DOEA/OTSB11		1	1		NRR/DST 8E2		1	1	
	NRR/DST/SELB 8D		1	1		NRR/DST/SICB 7E		1	1	
	NRR/DST/SRXB 8E		1	1		NUDOCS-ABSTRACT		1	1	
	OC/LFMB		1	0		OGC/HDS2		1	0	
	<u>REG FILE</u> 01		1	1		RES/DSIR/EIB		1	1	
EXTERNAL:	NRC PDR		1	1		NSIC		1	1	

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 18 ENCL 16

R
I
D
S
/
A
D
S

R
I
D
S
/
A
D
D
S



AEP:NRG:1036C

Donald C. Cook Nuclear Plant Units 1 and 2
License Nos. DPR-58 and DPR-74
Docket Nos. 50-315 and 50-316
MODIFICATION OF TECHNICAL SPECIFICATION 4.0.3
REQUIREMENTS REGARDING MISSED SURVEILLANCES

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Attn: T. E. Murley

February 25, 1991

Dear Dr. Murley:

This letter and its attachments constitute an application for amendment to the Technical Specifications (T/Ss) for the Donald C. Cook Nuclear Plant Units 1 and 2. Specifically, we are proposing to modify T/S 4.0.3 such that the action requirements of the T/Ss may be delayed for up to 24 hours to permit the completion of a missed surveillance when the allowable outage time limits of the action requirements are less than 24 hours. This modification is consistent with an NRC position provided in Generic Letter 87-09.

We believe the proposed change will not result in (1) a significant change in the types of effluents or a significant increase in the amounts of any effluent that may be released offsite, or (2) a significant increase in individual or cumulative occupational radiation exposure.

The reason for the change and our 10 CFR 50.92 significant hazards analysis are found in Attachment 1. Attachment 2 contains the proposed revised T/Ss pages.

The proposed change has been reviewed by the Plant Nuclear Safety Review Committee and by the Nuclear Safety and Design Review Committee.

In compliance with the requirements of 10 CFR 50.91(b)(1), copies of this letter and its attachments have been transmitted to Mr. J. R. Padgett of the Michigan Public Service Commission and the Michigan Department of Public Health.

9103010095 910225
PDR ADOCK 05000315
PDR

A001
1/11

Dr. T. E. Murley

-2-

AEP:NRC:1036C

This document has been prepared following Corporate procedures that incorporate a reasonable set of controls to ensure its accuracy and completeness prior to signature by the undersigned.

Sincerely,



M. P. Alexich
Vice President

ldp

Attachments

cc: D. H. Williams, Jr.
A. A. Blind - Bridgman
J. R. Padgett
G. Charnoff
A. B. Davis - Region III
NRC Resident Inspector - Bridgman
NFEM Section Chief