

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9103080056 DOC. DATE: 91/03/01 NOTARIZED: NO DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316
 AUTH. NAME AUTHOR AFFILIATION
 TROSKOSKI, W. Ofc of Enforcement (Post 870413)
 LIEBERMAN, J. Ofc of Enforcement (Post 870413)
 RECIPIENT NAME RECIPIENT AFFILIATION

SUBJECT: EN-91-015: on 900306, notice of proposed imposition of civil
 penalty in amount of \$150,000 issued to licensee. Action
 based on inadequate control of plant designs related to post-
 fire shutdown capability.

DISTRIBUTION CODE: IE33F COPIES RECEIVED: LTR 0 ENCL 1 SIZE: 1
 TITLE: Enforcement Notice (EN)

NOTES:

	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID	CODE/NAME	LTR	ENCL	ID	CODE/NAME	LTR	ENCL
INTERNAL:	AEOD/DOA		1	1	AEOD/DSP/TPAB		1	1
	NRR/DOEA/OEAB11		1	1	NRR/DREP/PEPB9D		1	1
	NRR/PMAS/ILRB12		1	1	NUDOCS FULL TXT		1	1
	OE DEF		1	1	OE FILE 01		1	1
	<u>REG FILE</u>	02	1	1				
EXTERNAL:	NRC PDR		1	1	NSIC		1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 21 ENCL 11

R
I
D
S
/
A
D
D
S

DCS

March 1, 1991
EN 91-015

OFFICE OF ENFORCEMENT
NOTIFICATION OF SIGNIFICANT ENFORCEMENT ACTION

Licensee: Indiana Michigan Power Company (EA 90-194)
(D. C. Cook).
Docket No. 50-315 and 50-316

Subject: PROPOSED IMPOSITION OF CIVIL PENALTY - \$150,000

This is to inform the Commission that a Notice of Violation and Proposed Imposition of Civil Penalty in the amount of \$150,000 will be issued on or about March 6, 1991 to Indiana Michigan Power Company. This action is based on inadequate control of plant designs related to post-fire shutdown capability. This resulted in a condition whereby a fire in one of two fire areas could have eliminated all power supplies to Unit 1 local shutdown indication panels and control room indications. No alternative means existed to obtain information related to the lost instrumentation and the likelihood existed that safe shutdown of Unit 1 could not have been achieved and maintained. The base civil penalty was escalated by 100% for prior notice due to NRC 1988 and 1989 inspection concerns related to design controls applied to Appendix R modifications. The civil penalty was escalated an additional 100% based on the added significance of the duration of the violation because the facility was operated outside of regulatory fire protection requirements for four years.

It should be noted that the licensee has not been specifically informed of the enforcement action. The schedule of issuance and notification is:

Mailing of Notice March 6, 1991
Telephone Notification of Licensee March 6, 1991

The State of Indiana will be notified.

The licensee has thirty days from the date of the Notice in which to respond. Following NRC evaluation of the response, the civil penalty may be remitted, mitigated, or imposed by Order.

Contact: W. Troskoski, OE, 23281 J. Lieberman, OE, 20741

Distribution

OWFN <u>4:20</u>	OWFN <u>4:20</u>	MNBB <u>4:20</u>	PHIL <u>4:20</u>	NL <u>4:20</u>
Chairman Carr	EDO	OC	IRM	RES
Comm. Rogers	DEDR	AEOD		
Comm. Curtiss	DEDS	Op Ctr		
Comm. Remick	OE			
	NMSS			
SECY	NRR			
OCA	OI			
GPA	OGC			
SP				

Regional Offices MAIL
 RI 4:20 RIV 4:20 ADM: Doc. Mgt. Br.
 RII 4:20 RV 4:20 PDR ACRS
 RIII 4:20 OIG

PRELIMINARY INFORMATION - NOT FOR PUBLIC DISCLOSURE UNTIL PUBLICLY ANNOUNCED

9103080056 910301
PDR I&E
EN-91-015 PDR

en91-15
IE:33