

DCS



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

APR 23 1991

Dockets No. 50-315; 50-316  
Licenses No. DPR-58 and DPR-74  
EA 90-194

Indiana Michigan Power Company  
ATTN: Mr. E. E. Fitzpatrick  
Vice President  
Nuclear Power Operations Division  
1 Riverside Plaza  
Columbus, Ohio 43216

Dear Mr. Fitzpatrick:

SUBJECT: RESPONSE TO NOTICE OF VIOLATION AND PROPOSED IMPOSITION OF CIVIL  
PENALTY - \$150,000  
(NRC INSPECTION REPORTS NO. 50-315/90018; 50-316/90018)

This will acknowledge receipt of your letter, dated March 26, 1991, and your check for \$150,000 for the civil penalty proposed by the NRC in a letter, dated March 6, 1991. Your corrective actions will be examined during future inspections.

The enclosure to your March 26, 1991, letter provided additional information concerning Example No. 1 of Violation No. II.A, which was not assessed a monetary penalty. We have reviewed the information you provided and after careful consideration we are withdrawing Example No. 1 of Violation No. II.A.

This letter also confirms an April 9, 1991, telephone conversation between Mr. S. J. Brewer, your Manager of Nuclear Safety and Licensing, and Mr. J. M. Ulie of the NRC Region III office. During that conversation, Mr. Brewer agreed that during the summer of 1991 the Indiana Michigan Power Company will conduct a walkdown of the emergency remote shutdown (ERS) procedure, including a review to ensure the adequacy of the illumination provided by the emergency lighting units during use of the ERS procedure.

Please contact Mr. Hubert J. Miller, Director, Division of Reactor Safety, NRC Region III (telephone number (708) 790-5573) should your understanding of the agreement reached during the April 9, 1991, telephone conversation be different than ours.

Sincerely,

A handwritten signature in cursive script, reading "James Lieberman".  
James Lieberman, Director  
Office of Enforcement

cc: A. B. Davis, RIII

9104250058 910423  
PDR ADOCK 05000315  
PDR

IE14  
110

APR 23 1991

Indiana Michigan Power Company

Distribution

DCD/DCB (RIDS)

A. A. Blind, Plant Manager

Resident Inspector, RIII

James R. Padgett, Michigan

Public Service Commission

EIS Coordinator, USEPA,

Region 5 Office

Michigan Department of

Public Health

D. C. Cook LPM, NRR

J. Goldberg, OGC

J. Partlow, NRR

Enforcement Coordinators

RI, RII, RIV, RV

OE:ES

OE:Chron

OE:EA

SLO:RIII

PAO:RIII

IMS:RIII

OE *Wm T*  
WTroskoski  
4/22/91

*Wm T / Wm*  
RIII  
CPederson  
4/22/91

*per memo*

*Wm T*  
OE: D  
JL Teberman  
4/22/91