Docket Nos. 50-315
and 50-316

August 13, 1991

Mr. Gene Fitzpatrick, Vice President
Indiana and Michigan Electric Company
c/o American Electric Power Service Company
1 Riverside Plaza
Columbus, Ohio 43216

Dear Mr. Fitzpatrick

SUBJECT: Donald C.COOK UNITS 1 & 2, SAFETY EVALUATION FOR GENERIC LETTER 83-28, ITEM 1.2 - POST-TRIP REVIEW - DATA AND INFORMATION CAPABILITY (TAC NOS. 53578 AND 53579)

Enclosed is the staff's evaluation for Generic Letter 83-28, Item 1.2 for the Donald C. Cook Nuclear Plant, Unit Nos. 1 and 2. Item 1.2 "Post Trip Review - Data and Information Capability" requires power reactor facilities to have the capability to record, recall, and display data and information to permit diagnosing the causes of unscheduled reactor shutdowns and the proper functioning of safety-related equipment during those events using systematic safety assessment procedures.

We have reviewed your letters dated November 4, 1983, March 30, 1984, and December 17, 1986, and have concluded that the D. C. Cook facilities meet the intent of the review criteria for Generic Letter 83-28, Item 1.2. Therefore, we find that your Post-Trip Review - Data and Information Capability is acceptable. This completes our review of MPA B-85, Salem ATWS Item 1.2, for the Donald C. Cook Nuclear Power Plant, Units 1 and 2.

If you have any questions regarding this action please contact W. Long at (301) 492-3026 or T. Colburn at (301) 492-1341.

Sincerely,

Original signed by

William O. Long, Project Manager
Project Directorate III-1
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosure:
As stated
cc w/enclosure:
See next page
DISTRIBUTION
See attached page

NRC FILE CENTER COPY

OFC	:LA:PD31	:PM:PD31	:PM:PD32	:D:PD31	:	:
NAME	:PShuttleworth	:WLong:sw	:TColburn	:LMarsh	:	:
DATE	:8/13/91	:8/13/91	:8/13/91	:8/13/91	:	

OFFICIAL RECORD COPY
Document Name: LTR FITZPATRICK 73578/79

9108150249 910813
PDR ADOCK 05000315
P PDR

150020

A/A-3
DF01 1/1

cc:

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Mr. S. Brewer
American Electric Power
Service Corporation
1 Riverside Plaza
Columbus, Ohio 43216

Attorney General
Department of Attorney General
525 West Ottawa Street
Lansing, Michigan 48913

Township Supervisor
Lake Township Hall
Post Office Box 818
Bridgman, Michigan 49106

Al Blind, Plant Manager
Donald C. Cook Nuclear Plant
Post Office Box 458
Bridgman, Michigan 49106

U.S. Nuclear Regulatory Commission
Resident Inspectors Office
7700 Red Arrow Highway
Stevensville, Michigan 49127

Gerald Charnoff, Esquire
Shaw, Pittman, Potts and Trowbridge
2300 N Street, N.W.
Washington, DC 20037

Mayor, City of Bridgman
Post Office Box 366
Bridgman, Michigan 49106

Special Assistant to the Governor
Room 1 - State Capitol
Lansing, Michigan 48909

Nuclear Facilities and Environmental
Monitoring Section Office
Division of Radiological Health
Department of Public Health
3500 N. Logan Street
Post Office Box 30035
Lansing, Michigan 48909