



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555

August 10, 1992

Docket Nos. 50-315  
and 50-316

Mr. E. E. Fitzpatrick, Vice President  
Indiana Michigan Power Company  
c/o American Electric Power Service Corporation  
1 Riverside Plaza  
Columbus, OH 43216

Dear Mr. Fitzpatrick:

SUBJECT: NRC BULLETIN 88-08, "THERMAL STRESSES IN PIPING CONNECTED TO REACTOR COOLANT SYSTEMS" (TAC NOS. M69618 AND M69619)

The NRC Bulletin 88-08, "Thermal Stresses in Piping Connected to Reactor Coolant Systems," dated June 22, 1988, requested all licensees to (1) review their reactor coolant system (RCS) to identify any connected unisolable piping that could be subjected to temperature distributions which would result in unacceptable thermal stresses; and (2) take action, where such piping is identified, to ensure that the piping will not be subjected to unacceptable thermal stresses. Following the original Bulletin, three supplements were issued which contained no additional reporting requirements. Supplement 1 issued June 24, 1988, provided information about an event at a foreign plant similar to the event described in the original Bulletin. Supplement 2 dated August 4, 1988, emphasized the need for an enhanced ultrasonic examination with the appropriate expertise when performing Action 2 of the Bulletin. Supplement 3, issued April 11, 1989, informed licensees about a related event at a foreign plant with an initiating mechanism significantly different from that which was discussed in the original Bulletin.

By letters dated September 29, 1988, August 8, and November 1, 1989, Indiana Michigan Power Company (IMPC) provided responses to the requirements of the subject Bulletin for the D. C. Cook Nuclear Plant, Units 1 and 2. The responses did not provide adequate assurances that all unisolable portions of piping connected to the RCS would not be subject to temperature distributions which would result in unacceptable thermal stresses. Specifically, the NRC staff was concerned with the pressurizer auxiliary spray piping. The licensee proposed the use of non-destructive examination each refueling outage to detect the presence of cracks.

By letter dated November 1, 1991, the NRC staff informed IMPC this method was unacceptable as the final resolution to Bulletin 88-08 concerns because the fundamental precept of the Bulletin is to prevent the initiation of cracks in piping; inservice inspection is not an acceptable technique identified in the Bulletin for preventing such cracks. In the November 1, 1991 letter, the NRC staff also provided information to IMPC to assess the adequacy of the D. C. Cook Nuclear Plant, Units 1 and 2, with respect to Action 3 of the Bulletin and Supplement 3.

9208170085 920810  
PDR ADDCK 05000315  
Q PDR

NRC FILE CENTER COPY

DF01 / 0  
A02/P

700061

August 10, 1992

By letter dated January 31, 1992, IMPC committed to install instrumentation on the pressurizer auxiliary spray piping near appropriate welds and bends to take data on Unit 1, which is scheduled for outage in June 1992, to determine if the pressurizer auxiliary spray line is susceptible to thermal stresses and fatigue cracking. Data will be collected for one fuel cycle. At the end of the cycle, if the data provides indications that such high cycle thermal loads exist in the pipe, IMPC has committed to make modifications in both Units 1 and 2 to be in compliance with Bulletin 88-08.

We have reviewed your January 31, 1992, response and find that the data that will be recorded during only one cycle may not be sufficient to capture the effects of valve leakage, since the absence of valve leakage during this cycle does not translate to no valve leakage during future cycles. Accordingly, we find your commitments to be acceptable subject to the following conditions: (1) the data collection period should be of sufficient duration (greater than one cycle if necessary) such that the data collected captures conditions reflecting leakage from an upstream closed isolation valve through the auxiliary spray line, and (2) this data is used to determine whether the resultant thermal cyclic stresses, together with other concurrent cyclic stresses, will initiate fatigue cracking in the main spray or auxiliary spray line during the life of the plant.

Therefore, based on the commitments made by IMPC, and subject to the above conditions, the NRC staff finds that D. C. Cook Nuclear Plant, Units 1 and 2, will meet the requirements of Bulletin 88-08. Within sixty days of the receipt of this letter please provide a final implementation schedule for all modifications required for Bulletin 88-08. This completes our activity on TAC Nos. M69618 and M69619.

Sincerely,

Original signed by

John F. Stang, Project Manager  
Project Directorate III-1  
Division of Reactor Projects -III/IV/V  
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION

Docket-File	JStang
OGC	ACRS(10)
Cook P/F	WShafer RIII
BMozafari 14/B/20	MHartzman 7/E/23
JNorberg 7/E/23	NRC & LPDRs
PD31 Rdg file	BBoger
JZwolinski	LMarsh
MShuttleworth	

OFFICE	LA:PD31	PM:PD31	EMEB	D:PD31	
NAME	MShuttleworth	JStang:jkd	JNorberg	LMarsh	
DATE	8/16/92	8/16/92	8/16/92	8/16/92	1/1

Mr. E. E. Fitzpatrick

- 2 -


August 10, 1992

By letter dated January 31, 1992, IMPC committed to install instrumentation on the pressurizer auxiliary spray piping near appropriate welds and bends to take data on Unit 1, which is scheduled for outage in June 1992, to determine if the pressurizer auxiliary spray line is susceptible to thermal stresses and fatigue cracking. Data will be collected for one fuel cycle. At the end of the cycle, if the data provides indications that such high cycle thermal loads exist in the pipe, IMPC has committed to make modifications in both Units 1 and 2 to be in compliance with Bulletin 88-08.

We have reviewed your January 31, 1992, response and find that the data that will be recorded during only one cycle may not be sufficient to capture the effects of valve leakage, since the absence of valve leakage during this cycle does not translate to no valve leakage during future cycles. Accordingly, we find your commitments to be acceptable subject to the following conditions: (1) the data collection period should be of sufficient duration (greater than one cycle if necessary) such that the data collected captures conditions reflecting leakage from an upstream closed isolation valve through the auxiliary spray line, and (2) this data is used to determine whether the resultant thermal cyclic stresses, together with other concurrent cyclic stresses, will initiate fatigue cracking in the main spray or auxiliary spray line during the life of the plant.

Therefore, based on the commitments made by IMPC, and subject to the above conditions, the NRC staff finds that D. C. Cook Nuclear Plant, Units 1 and 2, will meet the requirements of Bulletin 88-08. Within sixty days of the receipt of this letter please provide a final implementation schedule for all modifications required for Bulletin 88-08. This completes our activity on TAC Nos. M69618 and M69619.

Sincerely,



John F. Stang, Project Manager  
Project Directorate III-1  
Division of Reactor Projects -III/IV/V  
Office of Nuclear Reactor Regulation

cc: See next page



11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100

Mr. E. E. Fitzpatrick  
Indiana Michigan Power Company

Donald C. Cook Nuclear Plant

cc:

Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Mr. S. Brewer  
American Electric Power  
Service Corporation  
1 Riverside Plaza  
Columbus, Ohio 43216

Attorney General  
Department of Attorney General  
525 West Ottawa Street  
Lansing, Michigan 48913

Township Supervisor  
Lake Township Hall  
Post Office Box 818  
Bridgman, Michigan 49106

Al Blind, Plant Manager  
Donald C. Cook Nuclear Plant  
Post Office Box 458  
Bridgman, Michigan 49106

U.S. Nuclear Regulatory Commission  
Resident Inspectors Office  
7700 Red Arrow Highway  
Stevensville, Michigan 49127

Gerald Charnoff, Esquire  
Shaw, Pittman, Potts and Trowbridge  
2300 N Street, N.W.  
Washington, DC 20037

Mayor, City of Bridgman  
Post Office Box 366  
Bridgman, Michigan 49106

Special Assistant to the Governor  
Room 1 - State Capitol  
Lansing, Michigan 48909

Nuclear Facilities and Environmental  
Monitoring Section Office  
Division of Radiological Health  
Department of Public Health  
3423 N. Logan Street  
Post Office Box 30195  
Lansing, Michigan 48909



Handwritten marks and scribbles in the top right corner, possibly including the number '2'.

Handwritten marks at the bottom center of the page, possibly including the number '1'.