

August 24, 1992

Docket Nos. 50-315
and 50-316

Mr. E. E. Fitzpatrick, Vice President
Indiana Michigan Power Company
c/o American Electric Power Service Corporation
1 Riverside Plaza
Columbus, Ohio 43216

Dear Mr. Fitzpatrick:

SUBJECT: RESPONSE TO GENERIC LETTER 91-11, "RESOLUTION OF GENERIC ISSUE 48, 'LCO'S FOR CLASS 1E VITAL INSTRUMENT BUSES,' AND 49, 'INTERLOCKS AND LCO'S FOR CLASS 1E TIE BREAKERS,' PURSUANT TO 10 CFR 50.54 (F)" FOR DONALD C. COOK NUCLEAR PLANT (TAC NOS. M82399 AND 82400)

On July 18, 1991, the NRC issued Generic Letter (GL) 91-11 which contained the staff resolution of Generic Issues 48 and 49. The GL required licensees to certify that procedures exist which contain time limitations and surveillance requirements for vital instrument buses (VIB), inverters or other onsite power sources for VIB, and tie breakers. If procedures do not exist, a justification demonstrating the reasons why the controls are not needed is required.

By letter dated November 4, 1991, you responded to the GL. You indicated that procedures for time limitations and surveillance requirements are in place at your site.

The staff has reviewed your response and finds that it meets the reporting requirements set forth in GL 91-11. This completes the staff's activities on TAC Nos. M82399 and M82400.

Sincerely,

Original signed by
John F. Stang, Project Manager
Project Directorate III-1
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

cc: See next page

OFFICE	LA:PDIII-1	PM:PDIII-1	PD:PDIII-1
NAME	MShuttleworth	JStang	LMarsh
DATE	8/24/92	8/24/92	8/24/92

OFFICIAL RECORD COPY
FILENAME: C082399.LTR

D FOI
110

9209040059 920824
PDR ADOCK 05000315
PDR

NRC FILE CENTER COPY

MA-4
dhp

070084

August 24, 1992

DISTRIBUTION:

Docket file
NRC & Local PDRs
PD 31 reading file
B. Boger
J. Zwolinski
L. Marsh
J. Stang
M. Shuttleworth
OGC
ACRS (10)
Cook plant file
W. Shafer, RIII

cc: Plant Service list

