

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9210260202 DOC. DATE: 92/10/19 NOTARIZED: YES DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana M 05000315
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana M 05000316
 AUTH. NAME AUTHOR AFFILIATION
 FITZPATRICK, E. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Responds to JF Stang 920810 request for final
 implementation schedule for all mods required for NRC
 Bulletin 88-008, "Thermal Stresses in Piping Connected to
 RCS." NDT concluded that no cracks exist in spray line.

DISTRIBUTION CODE: IE16D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 4
 TITLE: Bulletin Response 88-08 - Thermal Stress in Piping to RCS.

NOTES:

	RECIPIENT		COPIES		
	ID CODE/NAME		LTTR	ENCL	
	PD3-1 LA		1	0	
	STANG, J		1	1	
INTERNAL:	AEOD/DOA		1	1	
	NRR HUM, M		1	1	
	NRR/DET/EMEB 7E		1	1	
	NRR/DOEA/OGCB11		1	1	
	NRR/DST/ 8E2		1	1	
	REG FILE 02		1	1	
	RGNS FILE 01		1	1	
EXTERNAL:	NRC PDR		1	1	
		PD3-1 PD	1	1	
		NRR HARTZMAN, M	1	1	
		NRR MOZAFARI, B	1	1	
		NRR/DOEA/OEAB11	1	1	
		NRR/DREP/PEPB9D	1	1	
		NRR/PMAS/ILRB12	1	1	
		RES/DSIR/EIB	1	1	
		NSIC	1	1	

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK.
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 18 ENCL 47 0

R
I
D
S
/
A
D
D
S
/
A
D
S

AO-1
JSP



AEP:NRG:1069F

Donald C. Cook Nuclear Plant Units 1 and 2
Docket Nos. 50-315 and 50-316
License Nos. DPR-58 and DPR-74
NRC BULLETIN NO. 88-08, "THERMAL STRESSES IN PIPING CONNECTED TO
REACTOR COOLANT SYSTEMS"

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Attn: T. E. Murley

October 19, 1992

Dear Mr. Murley:

Reference:

1. Letter, J. F. Stang (NRC) to E. E. Fitzpatrick (AEP), "NRC Bulletin 88-08, "Thermal Stresses in Piping Connected to Reactor Coolant Systems" (TAC NOS M69618 and M69619), dated August 10, 1992.
2. Letter AEP:NRG:1069A, "NRC Bulletin 88-8: Action Item Status," dated August 8, 1989.

This letter responds to an August 10, 1992 letter from J. F. Stang to E. E. Fitzpatrick (Reference 1) which requested that Indiana Michigan Power Company provide a final implementation schedule for all modifications required for Bulletin 88-08. As noted in previous correspondence (Reference 2), lines in three systems that meet the Bulletin's criteria were identified. These are a 3" alternate charging line to the loop 1 cold leg, a 2" auxiliary pressurizer spray line, and four 1 1/2" high pressure emergency core cooling system injection lines (one line to each cold leg). The 3" alternate charging line to the loop 1 cold leg and the four 1 1/2" high-pressure emergency core cooling system injection lines (one to each cold leg), have been modified (Reference 2).

Non-destructive testing has shown that there are no cracks in the remaining line (the pressurizer auxiliary spray line). We have contracted with Westinghouse Electric Corporation to install temperature monitoring equipment on this line in Unit 1 and to evaluate the data. The monitoring equipment was installed on the Unit 1 auxiliary spray line during the 1992 refueling outage under minor modification 01-MM-336. Data will be obtained during the next

9210260202 921019
PDR ADDCK 05000315
Q PDR

TEIG
110


fuel cycle and taken for a further cycle if one cycle of data is not sufficient. It is planned that the data will be recorded as follows:

- a. Modes 3, 4 and 5 - Two-minute intervals
- b. Mode 2 - Two-minute intervals until 100% power (Mode 1) is reached
- c. Mode 1 - Two-minute intervals initially. Data collection intervals may be adjusted after data are evaluated.

The data will be sent to Westinghouse for evaluation on a monthly basis. The NRC will be informed of any required actions resulting from the data evaluation.

This letter is submitted pursuant to 10CFR50.54(f) and, as such, an oath statement is enclosed.

Sincerely,



E. E. Fitzpatrick
Vice President

tjw

- cc: D. H. Williams, Jr.
A. A. Blind - Bridgman
J. R. Padgett
G. Charnoff
NFEM Section Chief
A. B. Davis - Region III
NRC Resident Inspector - Bridgman

Dr. T. E. Murley

- 3 -

AEP:NRC:1069F

bc: S. J. Brewer
D. H. Malin/M. S. Ackerman
M. L. Horvath - Bridgman
J. B. Shinnock
W. G. Smith, Jr.
J. F. Stang, NRC - Washington, D. C.
AEP:NRC:1069F
DC-N-6015.1

(STATE OF OHIO
(COUNTY OF FRANKLIN

E. E. Fitzpatrick, being duly sworn, deposes and says that he is the Vice President of licensee Indiana Michigan Power Company, that he has read the forgoing response to Bulletin 88-08, "Thermal Stresses in Piping Connected to Reactor Coolant Systems," and that said contents are true to the best of his knowledge and belief.

E. E. Fitzpatrick

Subscribed and sworn to before me this 21st
day of October, 19 92.

Lita D. Hill
NOTARY PUBLIC

LITA D. HILL
NOTARY PUBLIC, STATE OF OHIO
MY COMMISSION EXPIRES 6-23-94