NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | MIDCC2 (2) | 0000000000 (3) | 41111 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T 01 | REPORT SOURCE L (6) | 05000316 (7) | 042980 (8) | 052080 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 DURING NORMAL OPERATION WHILE PERFORMING A SURVEILLANCE TEST, IT WAS DISCOVERED
03 THAT THE BISTABLE FOR STEAM GENERATOR WATER LEVEL Hi-Hi ESF SETPOINT (TURBINE
04 TRIP AND FEEDWATER ISOLATION) HAD DRIFTED HIGH EXCEEDING THE LCO VALUE. T.S.
05 TABLE 3.3-4 ITEM 5.a. THE APPLICABLE ACTION REQUIREMENT WAS MET.
06
07
08

09 SYSTEM CODE SH (11) | CAUSE CODE E (12) | CAUSE SUBCODE E (13) | COMPONENT CODE INSTRU (14) | COMP. SUBCODE S (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 80 | — | SEQUENTIAL REPORT NO. 021 | / | OCCURRENCE CODE 03 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN E (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0000 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. Y (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER F180 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 THE BISTABLE WAS RECALIBRATED AND RETURNED TO SERVICE. ON APRIL 30, 1980, THE
11 BISTABLE TRIP POINT WAS AGAIN CHECKED. THE SETPOINT HAD DRIFTED SIGNIFICANTLY AND
12 THE BISTABLE (FOXBORO-MODEL 63 U-BC-OHEM-F) WAS REPLACED. THE NEW BISTABLE WAS
13 CALIBRATED AND PLACED IN SERVICE.
14

15 FACILITY STATUS E (28) | % POWER 100 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) OPERATOR OBSERVATION

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION (41) NA

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION NA 8005270461

20 PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY

NAME OF PREPARER J. L. RISCHLING PHONE: 616-465-5901

GPO 917-926

8 Copies