NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

# LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | MIDCC1 (2) | 000000000000000 (3) | 4111 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T 01 | REPORT SOURCE L (6) | 05000315 (7) | 072080 (8) | 081980 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 DURING A SURVEILLANCE TEST ON THE AUTOMATIC LOAD SEQUENCE TIMING RELAYS, THE TIMER
03 FOR 1E-MDAFP WAS FOUND TO EXCEED THE MAXIMUM ALLOWABLE TIME BY 2.88 SECONDS. THIS
04 IS NON-CONSERVATIVE IN RESPECT TO T.S. 4.8.1.1.2.b.6. PREVIOUS OCCURRENCES INCLUDE
05 050-316/80-54.
06
07
08

09 SYSTEM CODE EG (11) | CAUSE CODE E (12) | CAUSE SUBCODE A (13) | COMPONENT CODE RELAYS (14) | COMP. SUBCODE M (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 80 | — | SEQUENTIAL REPORT NO. 016 | / | OCCURRENCE CODE 03 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN E (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0000 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. Y (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER A109 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 THE TIMER, MANUFACTURED BY AGASTAT MODEL NO. 7012, WAS RESET TO WITHIN ALLOWABLE
11 VALUES AND RETESTED PER THE APPLICABLE SURVEILLANCE TEST PROCEDURE. THIS EVENT IS
12 ATTRIBUTED TO INSTRUMENT DRIFT AND NO FURTHER ACTIONS ARE PLANNED.
13
14

15 FACILITY STATUS H (28) | % POWER 000 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) SURVEILLANCE TEST

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION (41) NA

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) NA

20 PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA

8008260445 NRC USE ONLY

NAME OF PREPARER J. L. Rischling PHONE: 616-465-5901

GPO 917-926