NRC FORM 366 (7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | M I D C C 2 (2) LICENSEE CODE | 0 0 0 0 0 0 0 0 0 0 0 (3) LICENSE NUMBER | 4 1 1 1 1 (4) LICENSE TYPE | (5) CAT

CON'T 0 1 | REPORT SOURCE L (6) | 0 5 0 0 0 3 1 6 (7) DOCKET NUMBER | 0 8 1 4 8 0 (8) EVENT DATE | 0 9 1 2 8 0 (9) REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 DURING NORMAL OPERATION, RADIATION MONITOR R-11 ALARMED, INVESTIGATION

0 3 REVEALED THAT THE R-11 AND R-12 SAMPLE PUMP HAD SEIZED. THIS CONSTITUTED

0 4 AN INOPERABLE RAD. MONITOR SYSTEM PER T.S. 3.3.3.1 AND TABLE 3.3-6.

0 5 THE ACTION REQUIREMENTS WERE MET. EVENT HAS NO PUBLIC HEALTH AND SAFETY

0 6 CONSEQUENCES. SIMILAR EVENTS INCLUDE: RO 80-018/03L-0; 79-04/03L-0;

0 7 80-013/03L-0 AND FOR DOCKET NO. 050-315; 79-012/03L-0 AND 79-048/03L-0.

0 8

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
0 9	B B (11)	E (12)	B (13)	P U M P X X (14)	H (15)	Z (16)

(17) LER/RO REPORT NUMBER

EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
8 0	—	0 3 0	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
C (18)	F (19)	Z (20)	Z (21)	0 0 0 0	N (23)	N (24)	A (25)	W 1 2 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 FAILURE WAS DUE TO WEAR. THE COMPLETE PUMP WAS REPLACED AND THE RAD MONITORS

1 1 WERE RETURNED TO SERVICE. PLANS ARE TO REPLACE THE ENTIRE SYSTEM AS PART OF

1 2 RFC DC 12-2448.

1 3

1 4

1 5 FACILITY STATUS E (28) | % POWER 1 0 0 (29) | OTHER STATUS (30) N/A | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) OPERATOR OBSERVATION

1 6 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) N/A | LOCATION OF RELEASE (36) N/A

PERSONNEL EXPOSURES

1 7 NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) N/A

PERSONNEL INJURIES

1 8 NUMBER 0 0 0 (40) | DESCRIPTION (41) N/A

LOSS OF OR DAMAGE TO FACILITY (43)

1 9 TYPE Z (42) | DESCRIPTION N/A

PUBLICITY

2 0 ISSUED N (44) | DESCRIPTION (45) N/A | NRC USE ONLY

NAME OF PREPARER DAVID G. WIZNER PHONE: 616-465-5901, EXT.1037

8009190522