

ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9309210219 DOC. DATE: 93/09/17 NOTARIZED: YES DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana M 05000315
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana M 05000316

AUTH. NAME AUTHOR AFFILIATION
 FITZPATRICK, E. American Electric Power Service Corp.
 RECIPIENT NAME RECIPIENT AFFILIATION
 MURLEY, T.E. Document Control Branch (Document Control Desk)

SUBJECT: Responds to GL 93-04, "Rod Control Sys Failure & Withdrawal of Rod Control Cluster Assemblies."

DISTRIBUTION CODE: A030D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: S
 TITLE: Generic Ltr-93-04-Rod Control System Failure & Withdrawal of Rod Control

NOTES:

		RECIPIENT	COPIES		RECIPIENT	COPIES	
		ID CODE/NAME	LTR	ENCL	ID CODE/NAME	LTR	ENCL
		NRR/PRPW/PDIV-1	2	2	WETZEL, B	1	1
INTERNAL:		NRR/DRCH/HICB	1	1	NRR/DSSA/SRXB	1	1
		<u>REG FILE</u> 01	1	1			
EXTERNAL:		NRC PDR	1	1			

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 7 ENCL 7

MA-4
dhp

American Electric Power
Service Corporation
1 Riverside Plaza
Columbus, OH 43215
614 223 1000



AEP:NRC:1190A
GL 93-04

Donald C. Cook Nuclear Plant Units 1 and 2
Docket Nos. 50-315 and 50-316
License Nos. DPR-58 and DPR-74
RESPONSE TO GENERIC LETTER 93-04, "ROD CONTROL SYSTEM FAILURE AND
WITHDRAWAL OF ROD CONTROL CLUSTER ASSEMBLIES"

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Attn: T. E. Murley

September 17, 1993

Dear Dr. Murley:

Pursuant to the requirements of 10 CFR 50.54(f), the NRC issued Generic Letter 93-04 on June 21, 1993. Generic Letter 93-04 was addressed to all licensees with the Westinghouse Rod Control System (except Haddam Neck) for action, and to all other licensees for information.

In our letter AEP:NRC:1190, dated August 5, 1993, we provided Indiana Michigan Power Company's (I&M) 45-day Required Response to 1.(b), part two, of Generic Letter 93-04 as it applied to Donald C. Cook Nuclear Plant Units 1 and 2 (Cook Nuclear Plant). The response summarized the compensatory actions taken by I&M in response to the Salem rod control system failure event. It also provided a summary of the results of the generic safety analysis program conducted by the Westinghouse Owners Group (WOG) and its applicability to Cook Nuclear Plant. By using three-dimensional neutronic models for the safety analysis, it was concluded that there is no safety significance for any asymmetric rod control cluster assembly (RCCA) withdrawal event.

The Attachment to this letter is our 90-day Required Response to 1.(a) of Generic Letter 93-04 as it applies to Cook Nuclear Plant. The response concludes that the licensing basis is satisfied for General Design Criteria (GDC) 25. Based on the results of 1.(a), responses to questions 1.(b), part one, and 2 are not required.

20:100

9309210219	930917
PDR	ADOCK 05000315
P	PDR

AD30 11

Dr. T. E. Murley

- 2 -

AEP:NRC:1190A
GL 93-04

This letter is submitted pursuant to 10 CFR 50.54(f) and, as such,
an oath statement is attached.

Sincerely,



E. E. Fitzpatrick
Vice President

dr

Attachment

cc: A. A. Blind
G. Charnoff
J. B. Martin - Region III
NFEM Section Chief
NRC Resident Inspector - Bridgman
J. R. Padgett

STATE OF OHIO)
COUNTY OF FRANKLIN)

E. E. Fitzpatrick, being duly sworn, deposes and says that he is the Vice President of licensee Indiana Michigan Power Company, that he has read the forgoing Response to GENERIC LETTER 93-04 and knows the contents thereof; and that said contents are true to the best of his knowledge and belief.

E E Fitzpatrick

Subscribed and sworn to before me this 17th
day of September, 19 93.



Rita D Hill
NOTARY PUBLIC

RITA D. HILL
NOTARY PUBLIC, STATE OF OHIO
MY COMMISSION EXPIRES 6-28-94

1952
1953
1954
1955
1956
1957
1958
1959
1960
1961
1962
1963
1964
1965
1966
1967
1968
1969
1970
1971
1972
1973
1974
1975
1976
1977
1978
1979
1980
1981
1982
1983
1984
1985
1986
1987
1988
1989
1990
1991
1992
1993
1994
1995
1996
1997
1998
1999
2000
2001
2002
2003
2004
2005
2006
2007
2008
2009
2010
2011
2012
2013
2014
2015
2016
2017
2018
2019
2020
2021
2022
2023
2024
2025
2026
2027
2028
2029
2030
2031
2032
2033
2034
2035
2036
2037
2038
2039
2040
2041
2042
2043
2044
2045
2046
2047
2048
2049
2050
2051
2052
2053
2054
2055
2056
2057
2058
2059
2060
2061
2062
2063
2064
2065
2066
2067
2068
2069
2070
2071
2072
2073
2074
2075
2076
2077
2078
2079
2080
2081
2082
2083
2084
2085
2086
2087
2088
2089
2090
2091
2092
2093
2094
2095
2096
2097
2098
2099
2100

ATTACHMENT TO AEP:NRC:1190A

RESPONSE TO NRC GL 93-04

Assessment of Licensing Basis Compliance [Required Response 1.(a)]

The WOG undertook the following initiatives to support the response to NRC Generic Letter 93-04: conducting Rod Control System testing in the Salem training center, examining the existing Rod Control System Failure Modes and Effects Analysis (FMEA), analyzing the worst-case asymmetric RCCA withdrawal combinations with three-dimensional analytical neutronic methods, and performing an equipment survey of Westinghouse plants to determine the frequency and significance of control system circuit card failures.

After this extensive investigation, it was concluded that GDC 25 continues to be satisfied. However, it is recognized that there are questions as to the interpretation of not only the intent of GDC 25, but also the appropriate definition of the specified acceptable fuel design limit.

The NRC has interpreted the GDC 25 fuel design limit to be the departure from nucleate boiling (DNB) design basis. This is believed to be a conservative definition if applied to all events. The equipment survey conducted by the WOG demonstrated that the failure rate of card failures that could result in the movement of less than a whole group is on the order of 4×10^{-8} /critical reactor hours. This indicates that the likelihood of a Salem-type event is extremely remote. With this in mind, it is apparent that a Condition III (or IV) specified acceptable fuel design limit would be applicable.

Based on the current understanding of GDC 25, the purpose of this criterion is to ensure that the appropriate limits (commensurate with the probability of occurrence) are not violated for a "worst-case" stand-alone single failure. The test program conducted at the Salem training center demonstrated that all the RCCAs within a given group receive the same signals. The corrupted current orders generated by the logic cabinet failures at Salem were transmitted identically to all 8 RCCAs in Shutdown Bank A (SBA). The fact that only one RCCA withdrew in the plant was due to a second unrelated effect. If all the RCCAs in SBA responded as predicted in the existing FMEA, they would have withdrawn uniformly, thus being enveloped by the existing FSAR accident analyses. In addition, existing RCCA motion surveillance requirements would detect the type of RCCA motion failure observed at Salem. Thus, the requirement that one single failure not result in a specified acceptable fuel design limit being exceeded, in this case the DNB design basis, remains satisfied.

Long-term Enhancements

While the assessment indicates that the licensing basis is currently satisfied, the WOG recommended that the utilities choose one of two actions that could be taken by utilities to enhance compliance with GDC 25. One recommended action includes making 'current order timing' adjustments in the Rod Control System logic cabinets and performing an additional plant surveillance to verify the timing is correct. The other recommended action consists of adding a safety analysis to the FSAR covering asymmetric RCCA withdrawal events and again, adding a plant surveillance to verify correct 'current order timing.'

Upon successful demonstration of the 'current order timing' adjustments at an operating plant and receipt of the technical bulletin from Westinghouse, we will evaluate which recommendation is appropriate for Cook Nuclear Plant, and implement it in a timely manner.



11 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100

11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100