N.R.C. OPERATING DATA REPORT

DOCKET NO. 50-315
DATE 03/Nov/93
COMPLETED BY DG TURNER
TELEPHONE 616-465-5901

	RATING STATUS		010 .00 05	-
2. F 3. I 4. N 5. D 6. M	Init Name D. C. Cook Reporting Period Licensed Thermal Power (MWt) Name Plate Rating (Gross MWe) Design Electrical Rating (Net MWe) Naximum Dependable Capacity (GROSS Naximum Dependable Capacity (Net M	OCT 1993 3250 1152 1020 5 MWe) 1056	Corrected UCFs to us MWe Net. 1 02/Nov/93	Retro. 07/91
8. I	f Changes Occur in Capacity Ratin Last Report Give Reasons See note: seasonally adjusted values.	ngs (Items nos above. No	o. 3 through	ng
10.	ower Level To Which Restricted. I Reasons For Restrictions. If Any:	f Any (Net I	1We)	
_				
	•		r. to Date	
11.	Hours in Reporting Period		7296.0	
12.	No. of Hrs. Reactor Was Critical	745.0		
13.	Reactor Reserve Shutdown Hours	0.0	0.0	
	Hours Generator on Line		7296.0	
15.	Unit Reserve Shutdown Hours	0.0	0.0	321.0
16.	Gross Therm. Energy Gen. (MWH)	2410091 .	23357580	358799903
17.	Gross Elect. Energy Gen. (MWH)	778010	. 7544210	116487570
18.	Net Elect. Energy Gen. (MWH)	750796	7277346	112039711
19.	Unit Service Factor	100.0	100.0	74.9
20.	Unit Availability Factor			74.9
21.	Unit Capacity Factor (MDC Net)	100.8	99.7	67.6
22.	Unit Capacity Factor (DER Net)	98.8	97.8	65.8
23.	Unit Forced Outage Rate	0.0		6.1
24.	Shutdowns Scheduled over Next Six	Months (Typ	e,Date,and	Duration):
	Refueling Outage to begin Februar	ry 5, 1994 f	or an estim	ated
	duration of 70 days. If Shut Down At End of Report Per			
26.	Units in Test Status (Prior to Co	mmercial Ope		3 ab i 222 - 2
			Forcast	Achieved

INITIAL CRITICALITY INITIAL ELECTRICITY COMMERCIAL OPERATION

9311160034 931105 PDR ADDCK 05000315 R PDR

AVERAGE DAILY POWER LEVEL (MWe-Net)

DOCKET NO. 50-315
UNIT ONE
DATE 02/Nov/93
COMPLETED BY DG TURNER
TELEPHONE 616-465-5901

MONTH

OCT 1993

DAY	AVERAGE DAILY POWER LEVEL	DAY	AVERAGE DAIL POWER LEVEL
10/01/93	1010	10/17/93	. 1007
10/02/93	1009	10/18/93	1008
10/03/93	1009	10/19/93	1008
10/04/93	1010	10/20/93	1006
10/05/93	1010	10/21/93	1012
10/06/93	1011	10/22/93	1016
10/07/93	1011	10/23/93	1016
10/08/93	1010	10/24/93	1017
10/09/93	1011	10/25/93	1007
10/10/93	1013 [.]	10/26/93	1022
10/11/93	1009	10/27/93	1002
10/12/93	. 1013	10/28/93	1017
10/13/93	· 995	10/29/93	1008
10/14/93	983	10/30/93	998
10/15/93	1005	10/31/93	1016
10/16/93	1015	, ,	

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH: OCTOBER 1993

H: Other (Explain)

UNIT NAME:

D. C. COOK UNIT 1-

DATE: COMPLETED BY: Nov. 4, 1993 R. D. Reynnells (616) 465-5901

TELEPHONE: Page 1 of 1

SHUTTING LICENSEE DURATION DOWN EVENT SYSTEM COMPONENT CAUSE AND CORRECTIVE ACTION NO. DATE TYPE ¹ HOURS REASON ² REACTOR ³ REPORT NO. CODE ⁴ CODE ⁵ TO PREVENT RECURRENCE	DURATION DOWN EVENT SYSTEM CO		
---	-------------------------------	--	--

None

There wer no unit shutdown or significant power reductions from 100% RTP this month.

F: Forced Reason: Method: Exhibit G - Instructions Exhibit I: Same Scheduled A: Equipment Failure (Explain) 1: Manual for preparation of data Source B: Maintenance or Test 2: Manual Scram entry sheets for Licensee C: Refueling Event Report (LER) File 3: Automatic Scram D: Regulatory Restriction (NUREG 1061) 4: Other (Explain) E: Operator Training and License Examination F: Administrative G: Operational Error (Explain)

DOCKET NO.: UNIT NAME: COMPLETED BY: TELEPHONE: DATE: PAGE:

50-315 D.C. Cook Unit 1 R. D. Reynnells (616) 465-5901 Nov 4, 1993 Page 1 of 1

MONTHLY OPERATING ACTIVITIES - OCTOBER 1993

HIGHLIGHTS

The unit entered the reporting period in Mode 1 at 100 % RTP.

The unit exited this reporting period in Mode 1 at 100 % RTP.

There were no challenges to the pressurizer safety valves or power operated relief valves.

Gross Electrical generation for the month of October was 778010 MWH.

DETAILS

10-13-93 1900 Commenced reactor power decrease to 95% RTP for scheduled MTC testing.

2300 Reactor power is at 95% RTP.

10-14-93 1515 Commenced reactor power increase to 100% RTP.

1700 Reactor power is at 100% RTP.

10-29-93 2200 Commenced reactor power decrease to 90% RTP for turbine valve testing.

10-30-93 0020 Reactor power is at 90% RTP.

0400 Commenced reactor power increase to 100% RTP.

0715 Reactor power is at 100% RTP.

DOCKET NO: 50-315

UNIT NAME: D.C. Cook Unit 1

COMPLETED BY: M. E. Russo TELEPHONE: (616) 465-5901 DATE: November 5, 1993

PAGE: 1 of 1

MAJOR SAFETY-RELATED MAINTENANCE - October 1993

No major safety-related maintenance items are included for the month of October.