

ADMINISTRATIVE CONTROLS

6.8 PROCEDURES AND PROGRAMS

6.8.1 Written procedures shall be established, implemented and maintained covering the activities referenced below:

- a. The applicable procedures recommended in Appendix "A" of Regulatory Guide 1.33, Rev. 2, February 1978.
- b. Deleted.
- c. Deleted.
- d. PROCESS CONTROL PROGRAM implementation.
- e. OFFSITE DOSE CALCULATION MANUAL implementation.
- f. Quality Assurance Program for effluent and environmental monitoring using the guidance in Regulatory Guide 1.21, Rev. 1, June 1974, and Regulatory Guide 4.1, Rev. 1, April 1975.

Insert "A"

6.8.2 Each procedure and administrative policy of Specification 6.8.1 above, and changes thereto, including temporary changes, shall be reviewed prior to implementation as set forth in Specification 6.5 above.

6.8.3 A plant program for post-accident sampling shall be established, implemented, and maintained which will ensure the capability to obtain and analyze reactor coolant samples, containment atmosphere noble gas samples, and unit vent gaseous effluent samples for iodines and particulates under accident conditions. The program will include the following:

- a. Training of personnel,
- b. Procedures for sampling and analysis,
- c. Provisions for maintenance of sampling and analysis equipment.

ADMINISTRATIVE CONTROLS

6.8 PROCEDURES AND PROGRAMS

6.8.1 Written procedures shall be established, implemented and maintained covering the activities referenced below:

- a. The applicable procedures recommended in Appendix "A" of Regulatory Guide 1.33, Rev. 2, February 1978.
- b. Deleted.
- c. Deleted.
- d. PROCESS CONTROL PROGRAM implementation.
- e. OFFSITE DOSE CALCULATION MANUAL implementation.
- f. Quality Assurance Program for effluent and environmental monitoring using the guidance in Regulatory Guide 1.21, Rev. 1, June 1974, and Regulatory Guide 4.1, Rev. 1, April 1975.

Insert "A" →

6.8.2 Each procedure and administrative policy of Specification 6.8.1 above, and changes thereto, including temporary changes, shall be reviewed prior to implementation as set forth in Specification 6.5 above.

6.8.3 A plant program for post-accident sampling shall be established, implemented, and maintained which will ensure the capability to obtain and analyze reactor coolant samples, containment atmosphere noble gas samples, and unit vent gaseous effluent samples for iodines and particulates under accident conditions. The program will include the following:

- a. Training of personnel,
- b. Procedures for sampling and analysis,
- c. Provisions for maintenance of sampling and analysis equipment.

"A"

- g. Component Cyclic or Transient Limits program, which provides controls to track the UFSAR cyclic and transient occurrences to ensure that components are maintained within the limits.

ATTACHMENT 2 TO AEP:NRC:0980W

ADDITIONAL REVISED
TECHNICAL SPECIFICATION PAGES

6.0 ADMINISTRATIVE CONTROLS

6.8 PROCEDURES AND PROGRAMS

- 6.8.1 Written procedures shall be established, implemented and maintained covering the activities referenced below:
- a. The applicable procedures recommended in Appendix "A" of Regulatory Guide 1.33, Rev. 2, February 1978.
 - b. Deleted.
 - c. Deleted.
 - d. PROCESS CONTROL PROGRAM implementation.
 - e. OFFSITE DOSE CALCULATION MANUAL implementation.
 - f. Quality Assurance Program for effluent and environmental monitoring using the guidance in Regulatory Guide 1.21, Rev. 1, June 1974, and Regulatory Guide 4.1, Rev. 1, April 1975.
 - g. Component Cyclic or Transient Limits program, which provides controls to track the UFSAR cyclic and transient occurrences to ensure that components are maintained within the limits.
- 6.8.2 Each procedure and administrative policy of Specification 6.8.1 above, and changes thereto, including temporary changes, shall be reviewed prior to implementation as set forth in Specification 6.5 above.
- 6.8.3 A plant program for post-accident sampling shall be established, implemented, and maintained which will ensure the capability to obtain and analyze reactor coolant samples, containment atmosphere noble gas samples, and unit vent gaseous effluent samples for iodines and particulates under accident conditions. The program will include the following:
- a. Training of personnel,
 - b. Procedures for sampling and analysis,
 - c. Provisions for maintenance of sampling and analysis equipment.

6.0 ADMINISTRATIVE CONTROLS

6.8 PROCEDURES AND PROGRAMS

- 6.8.1 Written procedures shall be established, implemented and maintained covering the activities referenced below:
- a. The applicable procedures recommended in Appendix "A" of Regulatory Guide 1.33, Rev. 2, February 1978.
 - b. Deleted.
 - c. Deleted.
 - d. PROCESS CONTROL PROGRAM implementation.
 - e. OFFSITE DOSE CALCULATION MANUAL implementation.
 - f. Quality Assurance Program for effluent and environmental monitoring using the guidance in Regulatory Guide 1.21, Rev. 1, June 1974, and Regulatory Guide 4.1, Rev. 1, April 1975.
 - g. Component Cyclic or Transient Limits program, which provides controls to track the UFSAR cyclic and transient occurrences to ensure that components are maintained within the limits.
- 6.8.2 Each procedure and administrative policy of Specification 6.8.1 above, and changes thereto, including temporary changes, shall be reviewed prior to implementation as set forth in Specification 6.5 above.
- 6.8.3 A plant program for post-accident sampling shall be established, implemented, and maintained which will ensure the capability to obtain and analyze reactor coolant samples, containment atmosphere noble gas samples, and unit vent gaseous effluent samples for iodines and particulates under accident conditions. The program will include the following:
- a. Training of personnel,
 - b. Procedures for sampling and analysis,
 - c. Provisions for maintenance of sampling and analysis equipment.