



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

December 6, 2017

Mr. James J. Hutto  
Regulatory Affairs Director  
Southern Nuclear Operating Company, Inc.  
P.O. Box 1295 / Bin – 038  
Birmingham, AL 35201-1295

SUBJECT: JOSEPH M. FARLEY NUCLEAR PLANT, UNITS 1 AND 2 – REISSUE OF  
CORRECTED TECHNICAL SPECIFICATION PAGE 3.6.6-3

Dear Mr. Hutto:

On June 30, 2017 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML17152A218), the U.S. Nuclear Regulatory Commission issued Amendment No. 212 (Unit 1) and No. 209 (Unit 2) to the Joseph M. Farley Nuclear Plant (FNP) Renewed Operating Licenses. The amendments were consistent with Technical Specifications Task Force (TSTF) Traveler TSTF-545, Revision 3, "TS Inservice Testing Program Removal & Clarify SR Usage Rule Application to Section 5.5 Testing."

Subsequent to the June 30, 2017, amendment, it was identified that the FNP, Unit 1 and Unit 2, Technical Specification (TS) page 3.6.6-3 was missing Surveillance Requirement (SR) 3.6.6.9, issued on February 26, 2016, in Amendment No. 200 (Unit 1) and No. 196 (Unit 2) (ADAMS Accession No. ML15345A131). The inadvertent omission of SR 3.6.6.9 was due to an administrative error in the processing Farley Amendment No. 202 (Unit 1) and No. 198 (Unit 2) on June 10, 2016 (ADAMS Accession No. ML15289A227). The omission of SR 3.6.6.9 was carried over into the June 30, 2017, FNP amendment that revised TS page 3.6.6-3.

Please update TS page 3.6.6-3 with the enclosed corrected page.

Sincerely,

A handwritten signature in cursive script that reads "Shawn Williams".

Shawn A. Williams, Senior Project Manager  
Plant Licensing Branch II-1  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-348, 50-364

Enclosures:  
TS page 3.6.6-3

cc w/enclosure: Listserv

CORRECTION TO ATTACHMENT TO LICENSE AMENDMENT NOS. 212 AND 209

JOSEPH M. FARLEY NUCLEAR PLANT, UNITS 1 AND 2

TO RENEWED FACILITY OPERATING LICENSE NOS. NPF-2 AND NPF-8

DOCKET NOS. 50-348 AND 50-364

Replace the following page of the Appendix "A" Technical Specifications (TSs) with the enclosed page. The revised page is identified by amendment number and contains marginal lines indicating the areas of change.

Remove Page

TS  
3.6.6-3

Insert Page

TS  
3.6.6-3

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.6.6.2	Operate each required containment cooling train fan unit for $\geq 15$ minutes.	In accordance with the Surveillance Frequency Control Program
SR 3.6.6.3	Verify each containment cooling train cooling water flow rate is $\geq 1600$ gpm.	In accordance with the Surveillance Frequency Control Program
SR 3.6.6.4	Verify each containment spray pump's developed head at the flow test point is greater than or equal to the required developed head.	In accordance with the INSERVICE TESTING PROGRAM
SR 3.6.6.5	Verify each automatic containment spray valve in the flow path that is not locked, sealed, or otherwise secured in position, actuates to the correct position on an actual or simulated actuation signal.	In accordance with the Surveillance Frequency Control Program
SR 3.6.6.6	Verify each containment spray pump starts automatically on an actual or simulated actuation signal.	In accordance with the Surveillance Frequency Control Program
SR 3.6.6.7	Verify each containment cooling train starts automatically on an actual or simulated actuation signal.	In accordance with the Surveillance Frequency Control Program
SR 3.6.6.8	Verify each spray nozzle is unobstructed.	In accordance with the Surveillance Frequency Control Program
SR 3.6.6.9	Verify containment spray locations susceptible to gas accumulation are sufficiently filled with water.	In accordance with the Surveillance Frequency Control Program

SUBJECT: JOSEPH M. FARLEY NUCLEAR PLANT, UNITS 1 AND 2 – REISSUE OF  
CORRECTED TECHNICAL SPECIFICATION PAGE 3.6.6-3  
DATED DECEMBER 6, 2017

DISTRIBUTION:

PUBLIC

LPL2-1 R/F

RidsNrrDssStsb Resource

RidsACRS\_MailCTR Resource

RidsNrrLAKGoldstein Resource

RidsRgn2MailCenter Resource

RidsNrrPMFarley Resource

**ADAMS Accession No.: ML17333A079**

**\*via email**

OFFICE	DORL/LPL2-1/PM	DORL/LPL2-1/LA	DORL/LPL2-1/BC	DORL/LPL2-1/PM
NAME	SWilliams	KGoldstein	MMarkley	SWilliams
DATE	12/4/2017	12/4/2017	12/6/2017	12/6/2017

**OFFICIAL RECORD COPY**