

DONALD C. COOK NUCLEAR PLANT UNIT 1 CYCLE 15

CORE OPERATING LIMITS REPORT

Revision 5

February 1996

9603110341 960229  
PDR ADOCK 05000315  
P PDR

COLR for Donald C. Cook Nuclear Plant Unit 1 Cycle 15

2.8 Allowable Power Level - APL (Specification 3.2.6)

$$\text{APL-min over Z for } \frac{\text{CFQ} * \text{K(Z)}}{\text{F}_Q(\text{Z}) * \text{V(Z)} * \text{F}_P}$$

2.8.1 V(Z) is provided in Table 1 for  $\pm 5\%$  AFD target band

2.8.2 CFQ and K(Z) are provided in COLR Sections 2.6.1 and 2.6.2, respectively

2.8.3  $\text{F}_P = 1.02$