



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

INDIANA MICHIGAN POWER COMPANY

DOCKET NO. 50-315

DONALD C. COOK NUCLEAR PLANT, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 211
License No. DPR-58

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Indiana Michigan Power Company (the licensee) dated January 12, 1996, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-58 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 211, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of issuance, with full implementation within 45 days.

FOR THE NUCLEAR REGULATORY COMMISSION



John B. Hickman, Project Manager
Project Directorate III-1
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: August 15, 1996

ATTACHMENT TO LICENSE AMENDMENT NO. 211
TO FACILITY OPERATING LICENSE NO. DPR-58
DOCKET NO. 50-315

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the attached pages. The revised pages are identified by amendment number and contain vertical lines indicating the area of change.

REMOVE

3/4 4-36

INSERT

3/4 4-36

LIMITING CONDITION FOR OPERATION (Continued)

- g. With PORVs and block valves not in the same line inoperable due to causes other than excessive seat leakage, within 1 hour restore the valves to OPERABLE status or close and de-energize the associated block valve and place the associated PORV in manual control in each respective line. Apply the portions of ACTION c or d above, relating to the OPERATIONAL MODE, as appropriate for two or three lines unavailable.
- h. The provisions of Specification 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

- 4.4.11.1 In addition to the requirements of Specification 4.0.5, each PORV shall be demonstrated OPERABLE:
 - a. At least once per 31 days by performance of a CHANNEL FUNCTIONAL TEST, excluding valve operation, and
 - b. At least once per 18 months by operating the PORV through one complete cycle of full travel during MODES 3 or 4, and
 - c. At least once per 18 months by operating solenoid air control valves and check valves in PORV control systems through one complete cycle of full travel, and
 - d. At least once per 18 months by performing a CHANNEL CALIBRATION of the actuation instrumentation.
- 4.4.11.2 Each block valve shall be demonstrated OPERABLE at least once per 92 days by operating the valve through one complete cycle of full travel unless the block valve is closed in order to meet the requirements of ACTION b, c, or d in Specification 3.4.11.
- 4.4.11.3 Deleted.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

INDIANA MICHIGAN POWER COMPANY

DOCKET NO. 50-316

DONALD C. COOK NUCLEAR PLANT, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 196
License No. DPR-74

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Indiana Michigan Power Company (the licensee) dated January 12, 1996, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-74 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 196, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of issuance, with full implementation within 45 days.

FOR THE NUCLEAR REGULATORY COMMISSION



John B. Hickman, Project Manager
Project Directorate III-1
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: August 15, 1996

ATTACHMENT TO LICENSE AMENDMENT NO. 196

FACILITY OPERATING LICENSE NO. DPR-74

DOCKET NO. 50-316

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the attached pages. The revised pages are identified by amendment number and contain vertical lines indicating the area of change.

REMOVE

3/4 4-33

INSERT

3/4 4-33

REACTOR COOLANT SYSTEM

LIMITING CONDITION FOR OPERATION (Continued)

- g. With PORVs and block valves not in the same line inoperable due to causes other than excessive seat leakage, within 1 hour restore the valves to OPERABLE status or close and de-energize the associated block valve and place the associated PORV in manual control in each respective line. Apply the portions of ACTION c or d above, relating to the OPERATIONAL MODE, as appropriate for two or three lines unavailable.
- h. The provisions of Specification 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

- 4.4.11.1 In addition to the requirements of Specification 4.0.5, each PORV shall be demonstrated OPERABLE:
 - a. At least once per 31 days by performance of a CHANNEL FUNCTIONAL TEST, excluding valve operation, and
 - b. At least once per 18 months by operating the PORV through one complete cycle of full travel during MODES 3 or 4, and
 - c. At least once per 18 months by operating solenoid air control valves and check valves in PORV control systems through one complete cycle of full travel, and
 - d. At least once per 18 months by performing a CHANNEL CALIBRATION of the actuation instrumentation.[†]
- 4.4.11.2 Each block valve shall be demonstrated OPERABLE at least once per 92 days by operating the valve through one complete cycle of full travel unless the block valve is closed in order to meet the requirements of ACTION b, c, or d in Specification 3.4.11.
- 4.4.11.3 Deleted.

[†]The provisions of Technical Specification 4.0.8 are applicable.

