

## CATEGORY 1

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9704160052    DOC.DATE:- 97/04/10    NOTARIZED: NO    DOCKET #  
FACIL:50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana M 05000315  
          50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana M 05000316  
  
AUTH.NAME            AUTHOR AFFILIATION  
FITZPATRICK,E.     Indiana Michigan Power Co. (formerly Indiana & Michigan Ele  
RECIP.NAME            RECIPIENT AFFILIATION  
                      Document Control Branch (Document Control Desk)

SUBJECT: Responds to RAI re calculations provided to NRC during recent sys operation performance insp repts 50-315/96-13 & 50-316/96-13.

DISTRIBUTION CODE: IE01D COPIES RECEIVED: LTR    ENCL    SIZE: 200  
TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response


## **NOTES :**

RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL	
PD3-3 PD		1	1	HICKMAN,J		1	1
INTERNAL:	AEOD/SPD/RAB	1	1	AEOD/TTC FILE CENTER		1	1
	DEDRO	1	1	NRR/DRCH/HHFB		1	1
	NRR/DISP/PIPB	1	1	NRR/DRPM/PERB		1	1
	NRR/DRPM/PECB	1	1	OE DIR		1	1
	NUDOCS-ABSTRACT	1	1	RGN3 FILE . 01		1	1
	OGC/HDS2	1	1			1	1
RNAL:	LITCO BRYCE,J H	1	1	NOAC		1	1
	NRC PDR	1	1	NUDOCS FULLTEXT		1	1

**NOTE TO ALL "RIDS" RECIPIENTS:**

NOTE TO ALL "KIDS" RECIPIENTS:  
PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS  
OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL  
DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 18 ENCL 18



Indiana Michigan  
Power Company  
500 Circle Drive  
Buchanan, MI 49107 1395



April 10, 1997

AEP:NRC:1238F1  
10 CFR 2.201

Docket Nos.: 50-315  
50-316

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk.  
Washington, D.C. 20555

Gentlemen:

Donald C. Cook Nuclear Plant Units 1 and 2  
NRC INSPECTION REPORTS NO. 50-315/96013 (DRS) AND 316/96013 (DRS)  
REPLY TO REQUEST FOR ADDITIONAL INFORMATION

This letter is in response to a letter from G. E. Grant, dated February 4, 1997, that requested additional information regarding calculations that were provided to the NRC during the recent system operation performance inspection (SOPI). The requested information is described in attachments A and B to the inspection report.

Specifically, additional information was requested on calculation ENSM 961213AF, revision 0, "Allowable Centrifugal Charging Pump Degradation", and calculation RD-96-02, revision 0, "Offsite and Control Room Thyroid Doses From Containment Bypass Associated With a Charging Pump in ECCS Mode".

The additional information requested is provided in the attachments to this letter.

Sincerely,

A handwritten signature in black ink that appears to read "E. E. Fitzpatrick".

E. E. Fitzpatrick  
Vice President

vlb

Attachments


cc: A. A. Blind  
A. B. Beach  
MDEQ - DW & RPD  
NRC Resident Inspector  
J. R. Padgett

150063

9704160052 970410  
PDR ADDCK 05000315  
Q PDR




Tel 01



ATTACHMENT 1 TO AEP:NRC:1238F1

RESPONSE FOR ADDITIONAL INFORMATION REGARDING  
CALCULATION ENSM 961213AF



Introduction

During the system operation performance inspection (SOPI), inspectors reviewed the capability for boration from the refueling water storage tank (RWST). A concern was expressed regarding the ability of the centrifugal charging pumps (CCPs) to supply 120 gpm of 2400 ppm boron from the RWST, which had been determined equivalent to the technical specification (T/S) required boration flow rate of 10 gpm of 20,000 ppm boron, based on an analysis by Westinghouse in 1988. Inspectors were concerned that acceptance limits had not been incorporated into the inservice testing (IST) program which ensured this capability could be met. A calculation was completed to determine the allowable degradation these pumps could undergo without compromising their ability to perform this function. This calculation was provided to inspectors at the SOPI exit meeting.

As a point of information, noted in our response to the SOPI inspection report (AEP:NRC:1238F), the original analysis by Westinghouse which calculated the 120 gpm required flowrate contained a very conservative assumption regarding a step increase in power to 100% while at peak xenon. A reanalysis has been performed using a more realistic ramp rate of 10%/hr which is a limitation contained in plant procedures. This reanalysis indicated that the boration flow requirements of the T/Ss could be satisfied by as little as 60.1 gpm of 2400 ppm boron, instead of the 120 gpm previously defined. We are in the process of recalculating the allowable degradation of the CCPs given this new boration flowrate requirement. The revised calculation will be completed and verified by May 30, 1997.

The following responses are offered to the questions on the original calculation contained in attachment A to the SOPI report:

1. Please provide the basis for the assumption that the CCP miniflow paths are isolated when the suction is aligned to the RWST.

Response

The original calculation assumed that when the CCP suction source was switched from the volume control tank to the refueling water storage tank, the operators would close the miniflow path to provide maximum charging flow to the reactor coolant system (RCS). Subsequent review of the operating procedures for each unit indicated that no specific guidance is provided regarding the position of the miniflow valves. Therefore, it is conservative to assume they are kept open. As noted above, a revision to the subject calculation is being performed to reflect the 60.1 gpm boration flow requirement instead of the previous 120 gpm requirement. This revision will also reflect that the miniflow path is open.

2. Please provide the basis for the assumption that control valves QRV-200 and QRV-251 are fully open.

Response:

Control valves QRV-200 (charging to regenerative heat exchanger flow control valve) and QRV-251 (CCPs discharge flow control valve) are assumed fully open to assure maximum flow through the normal and alternate charging flow paths.

During normal operation, the 32 gpm supplied to the reactor coolant pump (RCP) seals is maintained automatically by valves QRV-200 and QRV-251. QRV-251 controls the charging flowrate to the RCS as required to maintain pressurizer level. QRV-200 maintains sufficient backpressure in the charging header to ensure adequate flow of seal injection water to the RCP seal injection system.

Guidance in operating procedures OHP 4021.005.007, "Operation of the Emergency Boration Flow Paths", directs the operators to "adjust charging and letdown flow to ~120 gpm." Therefore, this assumption reflects that they will adjust control valves QRV-200 and QRV-251 to the full open position, if necessary, to achieve the desired flow. Since the subject calculation was performed to confirm the capability to supply the required flow, it is reasonable to assume the operators will configure the system to supply maximum capability, consistent with their procedure guidance.

3. Although this calculation accounts for pressurizer pressure instrument uncertainty, it does not appear to account for the uncertainty in the instruments used to record the data. Please provide additional information regarding this issue.

Response:

Besides pressurizer pressure instrumentation, other instruments relevant to this calculation include pressurizer level instrumentation, and instrumentation used to determine operability of the centrifugal charging pumps within the IST program. A discussion of the effect of pressurizer level instrument uncertainty was included in the original calculation. The impact of pressurizer level instrument uncertainty on the calculation results was determined to be very minor, approximately 2 psi compared to a CCP developed head of approximately 2500 psid, and therefore was not included in the calculation.

Instrumentation associated with IST of the CCPs includes the suction and discharge pressure gauges, and the charging pumps discharge flow gauge. Our IST program for pumps is based on the code for operation and maintenance of nuclear plants (ASME OM Code-1990). The ASME code recognizes that instrument inaccuracy exists, and includes provisions for a +/- 2% accuracy for pressure and flow instruments. Instruments used for inservice testing of pumps at Cook Nuclear Plant are included in both a calibration program and the "as-found reportable", (AFR) program, which provides for evaluation of instruments found out of calibration. The AFR program includes provisions for assessing the significance of instruments found to be out of calibration on the results of previous operability tests to determine equipment operability from a historical perspective, and also reportability. Since the instruments used to test the CCPs are periodically calibrated, and provisions exist to evaluate the significance of instruments found out of calibration tolerances with respect to previous test results, CCP test instrument error was not included in the original calculation to determine allowable degradation of the CCPs. However, we will include this inaccuracy in the revised calculation to add additional conservatism.

4. Please provide the unit 2 pre-1990 operability review results.

Response:

Although the equivalent boration flow requirement of 120 gpm of 2400 ppm boron was calculated and transmitted to Cook Nuclear Plant by Westinghouse in 1988, the technical specification clarification which implemented this equivalent flow rate was not issued until November 5, 1990. Therefore, since there was no reliance on this equivalent boration flow source prior to late 1990, there is no need to assess operability prior to 1990.

5. Please provide additional information regarding piping configuration input into the Proto-Flo code.

Response:

The Proto-Flo code is used to perform steady-state analyses of thermal-hydraulic systems. The code has been approved for use in safety related applications under the company's quality assurance program. Proto-Flo allows multiple evaluations of systems for a variety of cases considering flow path variations, pump combinations, heat exchanger capability, valve throttling, etc.

The piping configuration parameters utilized by Proto-Flo are obtained from the isometric drawings and other design documents. These parameters include pipe lengths, pipe diameters and elevations, as well as the existence of fittings such as elbows and valves. Equipment characteristics and fluid parameters are also required inputs. These include performance characteristics of heat exchangers and pumps, and physical parameters such as known pressures and temperatures. Proto-Flo uses this information to determine the friction losses, flow distribution, pump operating points, and temperature changes.

6. Please provide additional information regarding fluid viscosity inputs into the Proto-Flo code.

Response:

Fluid temperature is a required input parameter. Proto-Flo uses this information in determining the fluid's properties used in thermal-hydraulic calculations. The fluid properties are determined through Proto-Flo's computer codes. Proto-Flo determines the fluid's density, dynamic viscosity, vapor pressure, specific heat, and thermal conductivity.

7. Please provide additional information regarding initial RWST level assumptions.

Response:

The original calculation assumed that the refueling water storage tank was at a level corresponding to minimum volume of 350,000 gals required by the T/Ss. During normal plant operation, administrative limits ensure that RWST level is maintained above the T/S minimum volume. This assumption regarding RWST level was considered reasonable. However, the revised calculation being performed for the new boration flow

rate of 60.1 gpm will assume the RWST level has been reduced to the centerline of the outlet pipe, for consistency with other similar calculations.

8. Please discuss the sensitivity of flowrate to developed head and how this was factored into the calculation.

Response:

The performance curve (developed head versus flow) for the CCPs is characteristically flat near the point of operation under study in the calculation. For example, the curve exhibits little change in the developed head from 0 gpm (5880 ft. of head) to approximately 150 gpm (5840 ft. of head). Therefore, the flowrate has a relatively high sensitivity to developed head in this region of the pump curve. Given that there is a relatively high sensitivity of flowrate to developed head, it is critical to ensure that developed head is determined in a conservative manner, such that the corresponding flow is not overstated.

Centrifugal pumps characteristically operate at the intersection of their head-capacity curve and the system curve which shows the head required (i.e., developed head) to make the liquid flow through the system of piping, valves, and components. The head in a typical system is made up of three components: 1) static head, 2) pressure head, and 3) friction losses.

Static head, defined for this calculation by the elevation difference between the RWST level and the pressurizer level, is a relatively minor contributor to system head. As noted in the response to question 7, the original calculation conservatively assumed that the level in the RWST was at the technical specification minimum level. Additional conservatism will be added by assuming the RWST level is at the centerline of the outlet pipe in the calculation revision under development. As noted in the response to question 3, pressurizer level instrument uncertainty was also evaluated and the impact on the calculation results was determined to be negligible.


Pressure head (RCS system pressure) is the dominant contributor to system head for the case considered. As noted in question 3, pressurizer pressure instrumentation uncertainty was included in the calculation. This conservatively results in a higher RCS pressure against which the CCPs must deliver flow.

Friction losses are calculated using standard hydraulic analysis methods/practices. The software used for these calculations has been approved under the company's quality assurance program, and results predicted by the model have been observed to be consistent with actual plant parameters. Therefore, there is a high degree of confidence that the friction losses are being accurately calculated.

Therefore, considering the three components of system head, the calculation approach results in a system head which is conservatively high. Although it is recognized that there is a relatively high sensitivity of flowrate to developed head, the calculation methodology ensures that developed head is not underestimated, and therefore, that flowrate is not overstated. Finally, as noted above, the required boration flow value has also been recalculated using more realistic assumptions. The required flowrate is now 60.1 gpm of 2400 ppm boron, instead of the 120 gpm originally calculated. This provides additional assurance that the CCPs can provide the required flows.

ATTACHMENT 2 TO AEP:NRC:1238F1

RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION  
REGARDING CALCULATION RD-96-02



Introduction

Calculation RD-96-02 was performed during the SOPI and provided to the inspection team at the exit meeting. The calculation determined the offsite and control room thyroid doses associated with the potential failure of the CCP emergency leak-off valve to close. (Failure of these valves to isolate during a loss-of-coolant accident could result in diversion of emergency core cooling system (ECCS) recirculation fluid outside containment.)

The following responses are offered to the questions on this calculation contained in attachment B to the SOPI inspection report:

1. Please provide the basis for the assumption that the leak persists for four hours.

Response:

We assumed that within four hours the operator would recognize the problem and take some action to correct it, such as shut off the pump. Even if the leak was assumed to persist for 30 days, the dose to the control operators would still have been within the GDC-19 limits. Using the same values of filtered and unfiltered control room inleakage assumed in calculation RD-96-02, the dose with no action taken by operators and a leak of 70 gpm for 30 days would be 25.32 rem to the thyroid. (This result was determined in calculation RD-97-02, which is included as attachment 3 to this letter.)

2. Please provide additional documentation which supports the chosen operating point of filtered and unfiltered control room inleakage used in the calculation.

Response:

The information was based on previous test results. Test results from the last test prior to the SOPI are attached (see attachment 4 to this letter). A margin was added to the previous test results to allow for degradation.

3. Please provide additional discussion of the purpose and effect of doubling the "LEAKRATE" term in the code.

Response:

The purpose of doubling the "LEAKRATE" term was to correct an error in the modeling of the ECCS leakage component of the operator dose. Thyroid dose to the operator is attributable to two components, iodine leaking from the containment and iodine coming out of solution in the ECCS recirculation fluid leaking outside of the containment. Per the UFSAR, the containment leakage portion assumes 25% of the core iodines are available for leakage from the containment atmosphere, and 50% of the core iodines are resident in the ECCS recirculation fluid. The previous calculation (RD-88-01, rev. 2) assumed 25% core iodines for both of these sources. Doubling the "LEAKRATE" term had the same effect as doubling the percentage of iodine in the ECCS recirculation fluid, and

thus corrected the error. The effect of the doubling was small. For example, for the base case of 10 gpm ECCS leakage the dose went from 17.3 rem to 17.9 rem for an assumed filtered inleakage of 1,000 cfm and an unfiltered inleakage of 30 cfm.

4. Please discuss whether the contribution from ESF leakage was included in the control room thyroid dose calculation.

Response:

Contributions from the engineered safety features (ESF) leakage were included in the calculation. In the calculation, the leakrate from the ESF systems is considered to be 70 gpm for the first four hours of the accident and 10 gpm for the remainder of the accident. See the response to item 1 for additional information.

5. Please provide RD-94-01, "Offsite Doses Due to ECCS Leakage."


Response:

The requested calculation is included as attachment 5 to this letter.

6. Please provide RD-88-01, Revision 2, "Control Room Dose to Operators Following a LOCA."


Response:

The requested calculation is included as attachment 6 to this letter.



ATTACHMENT 3 TO AEP:NRC:1238F1

CALCULATION NO. RD-97-02  
"CALCULATION OF THYROID DOSE TO OPERATORS ASSUMING A  
70 GPM ECCS LEAK FOR 30 DAYS"



American Electric Power  
Nuclear Generation Group

Regulatory Affairs  
Calculation Cover Sheet

Calculation No. RD-97-02 Rev. 0  
Subject : Calculation of thyroid dose to operators assuming a 70 gpm ECCS leak for 30 days  
Safety Related System Yes X No     
Supersedes Calc. No.                 

Plant Cook Nuclear Plant Unit: Both  
Company American Electric Power  
Calculated By W.T. MacRae 3/14/97  
Verified/Checked By Analyst  
Method of Verification Review of source code, comparison to pic river  
Approved By S. J. Miller 3/13/97

Problem Description:

This calculation is a "what-if" analysis of RD-96-02. In RD-96-02, the dose to the thyroid of the operators was calculated for an ECCS leakrate of 70 GPM for 4 hours. This calculation is to take the same assumptions and methodology but assume that the 70 GPM will not be isolated for the 30 days the accident is assumed to occur.


D  
Design Basis Or References:

1. Calculation Number RD-96-02, Rev 0, "Offsite Thyroid Doses and Control Room Thyroid Doses", W T. MacRae, 12/12/96.

Executive Summary:

The dose to the control room operators is still within the limit of 30 rem to the thyroid for typical filtered and unfiltered inleakages. Using the same filtered and unfiltered inleakage points for this calculation as for RD-96-02 the dose to the operators would be 25.32 rem.

Superseded By Calculation No: \_\_\_\_\_ Dated \_\_\_\_\_  
Reason: \_\_\_\_\_



*Calculation  
3/12/97*

Calculation Number: RD-97-01  
Date: March 11, 1997  
Page 2 of 3

## Introduction

This calculation was done as a "what-if" analysis of a previous calculation to determine the 30 day dose to the thyroid of the control operators. In Calculation Number RD-96-02, the control room operator doses were calculated with an ECCS leakrate of 70 GPM for 4 hours. This calculation is the same calculation with one change. The ECCS leakrate is considered to continue for 30 days.

## Statement of Purpose

The purpose of this calculation is to determine the dose to the control room operators after 30 days assuming that there is an ECCS leakrate of 70 GPM for 30 days following an accident.

## Assumptions

The data for this calculation and the methodologies used are from a past calculations, RD-96-02. The assumptions used in that calculation is considered to apply to this calculation. The only change to the assumptions is that the leak rate that in RD-96-02 that was 70 gpm for 4 hours was changed to 70 gpm for 30 days. RD-96-02 assumed that actions would be taken within 4 hours to stop 60 GPM of the leakage. For this calculation it is assumed that no action would successfully isolate the flow and that it would continue for 30 days.


## Analysis

The analysis was a recalculation using a FORTRAN computer code. The code from RD-96-02 was changed in one place to take out the step that made the leakrate 70 GPM for times less than 4 hours and it was set to always be 70 GPM. Attachment 1 contains a printout of the code THY9702.FOR. The change is on page 2 in the step numbered 31.

## Results

The program was run for filtered intake rates of 900 to 1500 CFM and unfiltered inleakage rates of 10 to 50 CFM. The result for a filtered intake of 1000 CFM and an unfiltered inleakage of 30 CFM is 25.32 rem. The values of 1000 CFM and 30 CFM were the same values used in RD-96-02. These values bound the current conditions. The complete output from the program is in Attachment 2. The results for 100 CFM filtered intake and 30 CFM unfiltered inleakage can be found on page 16 of Attachment 2. The dose of 25.32 rem is within the limit of 30 rem allowed for the thyroid dose.

*X note: Stopping within 4 hrs of leakage restores  
leakage to within the 10 gpm period  
analyzed (see calc RD-96-02 pg. 2)*



*ut math*  
3/12/97

Calculation Number: RD-97-01

Date: March 11, 1997

Page 3 of 3


### Verification

The verification was done by comparing the output for this calculation with the output from RD-96-02. RD-96-02 has been verified. This code was verified by comparing the output for the first 2 hours from each calculation. Attachment 3 is the output sheet for the computer code ran for RD-96-02. It is the output for the point of concern 100 CFM filtered intake and 30 CFM unfiltered inleakage. Attachment 4 is the same point for this calculation.

To verify the output for this calculation, it was compared to the output of RD-96-02 for time steps .5 hours, 1 hour and 2 hour. Each of the values for the different forms of the iodine isotopes compared exactly.

### Conclusion

The dose to the control room operators for 1000 CFM filtered intake and 30 CFM unfiltered inleakage is 25.32 rem. The dose to the control room operators is still within the limit of 30 rem to the thyroid.



*3/12/97*


Calculation Number RD-97-02

Attachment 1

Page 1 of 3

March 11, 1997

REAL\*8 ILAMB(5),IDCF(5),PFACT(3),LEAKRT,LPART,  
1 SF,ICI(5),BREATH,F1,F2,F3,F30,ETA(3),IPF(3),  
2 DOSE,DOSET(7),T,DELTAT,XQF(4),S,DOSE05,LEAKFACT,  
3 DOSE10,DOSE20,DOSE80,DOSE96,TFLOW,XQ,F10  
CHARACTER\*4 NAME(5)  
DATA DELTAT/1.0/  
DATA NAME/'I131','I132','I133','I134','I135'/  
DATA ILAMB/0.00359, 0.301, 0.0333, 0.791, 0.105/  
DATA ICI/ 2.5E+07,3.7E+07,5.0E+07,5.5E+07,4.8D+07/  
DATA IDCF/1.07E+06,6.29E+03,1.81E+05,1.07E+03,3.14E+04/  
DATA XQF/6.17D-9,3.64D-9,1.42D-9,4.07D-10/  
DATA BREATH/44.1/  
DATA LPART/6.7/  
DATA ETA/0.95,0.95,0.99/  
DATA PFACT/0.955,0.02,0.025/  
OPEN (UNIT = 6, FILE = 'I:\NSL\MSA\CTRLROOM\THY9702.OUT')  
C VENTILATION SYSTEM FLOWRATE  
TFLOW=5400.0D0  
C LOOP TO USE VARIOUS FILTERED INTAKE RATES  
DO 130 I2=1,8  
F1=800.0D0  
IF(I2.EQ.2) F1=900.0D0  
IF(I2.EQ.3) F1=1000.0D0  
IF(I2.EQ.4) F1=1100.0D0  
IF(I2.EQ.5) F1=1200.0D0  
IF(I2.EQ.6) F1=1300.0D0  
IF(I2.EQ.7) F1=1400.0D0  
IF(I2.EQ.8) F1=1500.0D0  
F10=4200.0  
F2=TFLOW-F1  
C LOOP TO USE VARIOUS UNFILTERED INLEAKAGE RATES  
DO 120 I3=1,6  
F3=0.0D0  
IF(I3.EQ.2) F3=10.0D0  
IF(I3.EQ.3) F3=20.0D0  
IF(I3.EQ.4) F3=30.0D0  
IF(I3.EQ.5) F3=40.0D0  
IF(I3.EQ.6) F3=50.0D0  
F30 = F3 + 200  
DOSET(I3) = 0.0D0  
WRITE (6,290)  
290 FORMAT('INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR')  
WRITE (6,295)  
295 FORMAT('OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT')  
WRITE (6,297)  
297 FORMAT('NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT,  
1 CORRECTED I-135 ')  
WRITE(6,12) F2,F1,F3  
12 FORMAT ('1',4X,'RECIRCULATION FLOW FROM CONTROL ROOM(CFM)',  
1 E10.4,/,5X,'FILTERED INLEAKAGE(CFM)'E10.4,/,5X,  
2 'UNFILTERED INLEAKAGE(CFM)',E10.4,/,13X,  
3 'ISOTOPE',1X,'.5 HOUR DOSE(REM)',1X,' 1 HOUR DOSE(REM)',



*Mrs. 3/12/97*

Calculation Number RD-97-02

Attachment 1

Page 2 of 3

March 11, 1997

4 1X,'2 HOUR DOSE(REM)',1X,'8 HOUR DOSE(REM)',  
5 1X,'4 DAY DOSE(REM)',1X,'30 DAY DOSE(REM)',/)

C LOOP TO SUM DOSES AND DISTINGUISH ELEMENTAL=1 ORGANIC=2 PART=3  
DO 110 I = 1,3

C LOOP FOR DIFFERENT ISOTOPES OF IODINE  
DO 100 K=1,5  
DOSE = 0.0D0  
T=0.0D0

90 DELTAT = 0.01D0  
IF(T.GE.1.0) DELTAT = 0.1D0  
IF(T.GE.24.0) DELTAT = 1.0D0


C LOOP FOR TIME INCREMENTS TO SUM CONCENTRATIONS AND DOSES  
IF(I.EQ.1) THEN  
SF=125.0  
IF (T.LT.0.100) SF=1.0/DEXP(-17.0\*T)  
IF (T.GT.0.100.AND.T.LT.0.167) SF=5.47/DEXP(-14.3\*(T-0.100))  
IF (T.GT.0.167.AND.T.LT.0.333) SF=14.26/DEXP(-22.5\*(T-0.167))  
GO TO 11  
ENDIF  
IF(I.EQ.2) THEN  
SF=1.0  
GO TO 11  
ENDIF  
IF(I.EQ.3) THEN  
SF=200.0  
IF (T.LT.0.584) SF=1.0/DEXP(-LPART\*T)  
IF (T.GT.0.584.AND.T.LT.2.65) THEN  
SF = 50.0/DEXP((-LPART/10.0)\*(T-0.584))  
ENDIF  
GO TO 11  
ENDIF

C DISPERSION FACTORS  
11 XQ=XQF(1)  
IF(T.GT.8.0) XQ=XQF(2)  
IF(T.GT.24.0) XQ=XQF(3)  
IF(T.GT.96.0) XQ=XQF(4)  
LEAKRT = 1.04D-04  
IF(T.GT.24.0) LEAKRT = 5.21D-05  
IF((ILAMB(K)\*T).LT.100.0) GO TO 31  
S = 0.0D0  
GO TO 32

C THE LEAKFACT TERM BELOW IS MULTIPLIED BY 7 TO CONVERT  
C FROM 10 TO 70 GPM  
31 LEAKFACT=7.0D0\*1.03D-7  
S = ICI(K)\*(DEXP(-ILAMB(K)\*T))\*XQ\*PFACT(I)\*(LEAKRT/SF+  
1 2.0D0\*LEAKFACT)  
IPF(I)=(F1+ETA(I)\*F2+F3)/((1.0-ETA(I))\*F1+F3)  
IF (T.LT.2.00) IPF(I)=(F1+ETA(I)\*F2+F30)/((1.0-ETA(I))\*F1+F30)

C IF (T.LT.2.00) IPF(I)=(F10+F3)/((1.0-ETA(I))\*F10+F3)  
DOSE = DOSE + (IDCF(K)\*BREATH\*S\*DELTAT)/IPF(I)

32 IF(T.LT.0.51.AND.T.GT.0.49) DOSE05=DOSE  
IF(T.LT.1.01.AND.T.GT.0.99) DOSE10=DOSE




Calculation Number RD-97-02

Attachment 1

Page 3 of 3

March 11, 1997

IF(T.LT.2.05.AND.T.GT.1.95) DOSE20=DOSE  
IF(T.LT.8.05.AND.T.GT.7.95) DOSE80=DOSE  
IF(T.LT.96.1.AND.T.GT.95.9) DOSE96=DOSE  
T = T+DELTAT  
34 IF(T.LE,720.0) GO TO 90  
IF(I.NE.1) GO TO 71  
WRITE(6,70) NAME(K),DOSE05,DOSE10,DOSE20,DOSE80,DOSE96,DOSE  
70 FORMAT(' ELEMENTAL ',A4,6(8X,E10.4))  
71 IF(I.NE.2) GO TO 72  
WRITE(6,75) NAME(K),DOSE05,DOSE10,DOSE20,DOSE80,DOSE96,DOSE  
75 FORMAT(' ORGANIC ',A4,6(8X,E10.4))  
72 IF(I.NE.3) GO TO 73  
WRITE(6,74) NAME(K),DOSE05,DOSE10,DOSE20,DOSE80,DOSE96,DOSE  
74 FORMAT(' PARTICULATE ',A4,6(8X,E10.4))  
73 DOSET(I3) = DOSET(I3) + DOSE  
100 CONTINUE  
110 CONTINUE  
WRITE(6,200) DOSET(I3)  
200 FORMAT(' /, 'TOTAL DOSE FOR 30 DAYS ',E10.4//)  
120 CONTINUE  
130 CONTINUE  
WRITE(6,140)  
140 FORMAT(:)  
STOP  
END



INPUT I:\NSL\MSA\CTRLROOM\HY9702.FOR

OUTPUT I:\NSL\MSA\CTRLROOM\HY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT,

CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4600E+04

FILTERED INLEAKAGE(CFM) .8000E+03


UNFILTERED INLEAKAGE(CFM) .0000E+00

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY  
DOSE(REM)

ELEMENTAL	I131	.2344E+01	.2760E+01	.3404E+01	.4125E+01	.6554E+01	.7715E+01
ELEMENTAL	I132	.1993E-01	.2279E-01	.2638E-01	.2797E-01	.2816E-01	.2816E-01
ELEMENTAL	I133	.7912E+00	.9285E+00	.1137E+01	.1347E+01	.1675E+01	.1678E+01
ELEMENTAL	I134	.4861E-02	.5355E-02	.5796E-02	.5863E-02	.5863E-02	.5863E-02
ELEMENTAL	I135	.1310E+00	.1526E+00	.1838E+00	.2085E+00	.2231E+00	.2231E+00
ORGANIC	I131	.3495E+00	.7531E+00	.1379E+01	.2079E+01	.3943E+01	.4643E+01
ORGANIC	I132	.2826E-02	.5603E-02	.9090E-02	.1064E-01	.1082E-01	.1082E-01
ORGANIC	I133	.1174E+00	.2508E+00	.4532E+00	.6573E+00	.9398E+00	.9414E+00
ORGANIC	I134	.6359E-03	.1115E-02	.1544E-02	.1609E-02	.1609E-02	.1609E-02
ORGANIC	I135	.1920E-01	.4019E-01	.7046E-01	.9448E-01	.1082E+00	.1082E+00
PARTICULATE	I131	.1107E+00	.1241E+00	.1400E+00	.1431E+00	.1541E+00	.1595E+00
PARTICULATE	I132	.9267E-03	.1019E-02	.1108E-02	.1115E-02	.1116E-02	.1116E-02
PARTICULATE	I133	.3732E-01	.4175E-01	.4687E-01	.4779E-01	.4925E-01	.4926E-01
PARTICULATE	I134	.2204E-03	.2365E-03	.2476E-03	.2479E-03	.2479E-03	.2479E-03
PARTICULATE	I135	.6156E-02	.6854E-02	.7622E-02	.7731E-02	.7794E-02	.7794E-02

TOTAL DOSE FOR 30 DAYS .1557E+02

LB/21/97



March 11, 1997

INPUT I:\NSL\MSA\CTRLROOM\HY9702.FOR

OUTPUT I:\NSL\MSA\CTRLROOM\HY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT, CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4600E+04

FILTERED INLEAKAGE(CFM) .8000E+03


UNFILTERED INLEAKAGE(CFM) .1000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY  
DOSE(REM)

ELEMENTAL	I131	.2437E+01	.2869E+01	.3542E+01	.4441E+01	.7472E+01	.8920E+01
ELEMENTAL	I132	.2072E-01	.2369E-01	.2744E-01	.2943E-01	.2966E-01	.2966E-01
ELEMENTAL	I133	.8226E+00	.9654E+00	.1183E+01	.1445E+01	.1854E+01	.1857E+01
ELEMENTAL	I134	.5054E-02	.5568E-02	.6028E-02	.6111E-02	.6111E-02	.6111E-02
ELEMENTAL	I135	.1362E+00	.1587E+00	.1912E+00	.2221E+00	.2402E+00	.2402E+00
ORGANIC	I131	.3634E+00	.7831E+00	.1436E+01	.2309E+01	.4635E+01	.5508E+01
ORGANIC	I132	.2938E-02	.5826E-02	.9463E-02	.1139E-01	.1162E-01	.1162E-01
ORGANIC	I133	.1220E+00	.2607E+00	.4720E+00	.7266E+00	.1079E+01	.1081E+01
ORGANIC	I134	.6611E-03	.1160E-02	.1607E-02	.1687E-02	.1688E-02	.1688E-02
ORGANIC	I135	.1997E-01	.4179E-01	.7337E-01	.1033E+00	.1205E+00	.1205E+00
PARTICULATE	I131	.1158E+00	.1299E+00	.1465E+00	.1536E+00	.1782E+00	.1903E+00
PARTICULATE	I132	.9696E-03	.1066E-02	.1160E-02	.1176E-02	.1177E-02	.1177E-02
PARTICULATE	I133	.3904E-01	.4367E-01	.4906E-01	.5113E-01	.5440E-01	.5443E-01
PARTICULATE	I134	.2306E-03	.2475E-03	.2591E-03	.2597E-03	.2597E-03	.2597E-03
PARTICULATE	I135	.6441E-02	.7171E-02	.7977E-02	.8222E-02	.8365E-02	.8365E-02

TOTAL DOSE FOR 30 DAYS .1803E+02

t b / 2 / 1 / 6  
2 / 2 / 4 / 1



INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR  
OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT, CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4600E+04

FILTERED INLEAKAGE(CFM) .8000E+03

UNFILTERED INLEAKAGE(CFM) .2000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY  
DOSE(REM)

ELEMENTAL	I131	.2530E+01	.2978E+01	.3679E+01	.4756E+01	.8386E+01	.1012E+02
ELEMENTAL	I132	.2151E-01	.2460E-01	.2850E-01	.3088E-01	.3115E-01	.3115E-01
ELEMENTAL	I133	.8539E+00	.1002E+01	.1229E+01	.1543E+01	.2033E+01	.2037E+01
ELEMENTAL	I134	.5247E-02	.5780E-02	.6258E-02	.6358E-02	.6358E-02	.6358E-02
ELEMENTAL	I135	.1414E+00	.1647E+00	.1986E+00	.2356E+00	.2573E+00	.2573E+00
ORGANIC	I131	.3773E+00	.8129E+00	.1493E+01	.2539E+01	.5324E+01	.6370E+01
ORGANIC	I132	.3050E-02	.6048E-02	.9835E-02	.1215E-01	.1241E-01	.1241E-01
ORGANIC	I133	.1267E+00	.2706E+00	.4907E+00	.7957E+00	.1218E+01	.1220E+01
ORGANIC	I134	.6863E-03	.1204E-02	.1669E-02	.1766E-02	.1766E-02	.1766E-02
ORGANIC	I135	.2073E-01	.4338E-01	.7628E-01	.1122E+00	.1327E+00	.1327E+00
PARTICULATE	I131	.1209E+00	.1356E+00	.1530E+00	.1640E+00	.2023E+00	.2210E+00
PARTICULATE	I132	.1012E-02	.1113E-02	.1211E-02	.1236E-02	.1239E-02	.1239E-02
PARTICULATE	I133	.4076E-01	.4560E-01	.5124E-01	.5446E-01	.5953E-01	.5958E-01
PARTICULATE	I134	.2407E-03	.2583E-03	.2703E-03	.2715E-03	.2715E-03	.2715E-03
PARTICULATE	I135	.6724E-02	.7486E-02	.8332E-02	.8711E-02	.8933E-02	.8933E-02

TOTAL DOSE FOR 30 DAYS .2048E+02

t b / 2 / 1 / C  
2/24/97

INPUT I:\NSL\MSA\CTRLROOM\HY9702.FOR  
OUTPUT I:\NSL\MSA\CTRLROOM\HY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT. CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4600E+04

FILTERED INLEAKAGE(CFM) .8000E+03

UNFILTERED INLEAKAGE(CFM) .3000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY DOSE(REM)

ELEMENTAL	I131	.2622E+01	.3087E+01	.3816E+01	.5070E+01	.9297E+01	.1132E+02
ELEMENTAL	I132	.2230E-01	.2550E-01	.2955E-01	.3232E-01	.3264E-01	.3264E-01
ELEMENTAL	I133	.8851E+00	.1039E+01	.1274E+01	.1640E+01	.2210E+01	.2215E+01
ELEMENTAL	I134	.5438E-02	.5991E-02	.6488E-02	.6604E-02	.6605E-02	.6605E-02
ELEMENTAL	I135	.1466E+00	.1708E+00	.2060E+00	.2490E+00	.2743E+00	.2743E+00
ORGANIC	I131	.3911E+00	.8426E+00	.1550E+01	.2768E+01	.6011E+01	.7229E+01
ORGANIC	I132	.3162E-02	.6269E-02	.1020E-01	.1290E-01	.1321E-01	.1321E-01
ORGANIC	I133	.1313E+00	.2805E+00	.5094E+00	.8645E+00	.1356E+01	.1359E+01
ORGANIC	I134	.7114E-03	.1248E-02	.1731E-02	.1843E-02	.1844E-02	.1844E-02
ORGANIC	I 35	.2148E-01	.4496E-01	.7917E-01	.1210E+00	.1449E+00	.1449E+00
PARTICULATE	I131	.1260E+00	.1413E+00	.1595E+00	.1744E+00	.2262E+00	.2516E+00
PARTICULATE	I132	.1055E-02	.1160E-02	.1262E-02	.1296E-02	.1299E-02	.1299E-02
PARTICULATE	I133	.4247E-01	.4751E-01	.5341E-01	.5777E-01	.6465E-01	.6471E-01
PARTICULATE	I134	.2508E-03	.2692E-03	.2819E-03	.2833E-03	.2833E-03	.2833E-03
PARTICULATE	I135	.7006E-02	.7801E-02	.8684E-02	.9198E-02	.9499E-02	.9499E-02

TOTAL DOSE FOR 30 DAYS .2292E+02

3/11/97  
mch

INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR

OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT,

CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4600E+04

FILTERED INLEAKAGE(CFM) .8000E+03

UNFILTERED INLEAKAGE(CFM) .4000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY  
DOSE(REM)

ELEMENTAL	I131	.2714E+01	.3196E+01	.3952E+01	.5382E+01	.1020E+02	.1251E+02
ELEMENTAL	I132	.2308E-01	.2639E-01	.3060E-01	.3376E-01	.3413E-01	.3413E-01
ELEMENTAL	I133	.9162E+00	.1075E+01	.1320E+01	.1737E+01	.2387E+01	.2393E+01
ELEMENTAL	I134	.5629E-02	.6201E-02	.6717E-02	.6849E-02	.6850E-02	.6850E-02
ELEMENTAL	I135	.1517E+00	.1768E+00	.2133E+00	.2624E+00	.2913E+00	.2913E+00
ORGANIC	I131	.4048E+00	.8722E+00	.1607E+01	.2995E+01	.6695E+01	.8085E+01
ORGANIC	I132	.3273E-02	.6489E-02	.1057E-01	.1365E-01	.1400E-01	.1400E-01
ORGANIC	I133	.1359E+00	.2904E+00	.5280E+00	.9330E+00	.1494E+01	.1497E+01
ORGANIC	I134	.7364E-03	.1292E-02	.1793E-02	.1921E-02	.1922E-02	.1922E-02
ORGANIC	I135	.2224E-01	.4654E-01	.8205E-01	.1297E+00	.1570E+00	.1570E+00
PARTICULATE	I131	.1311E+00	.1469E+00	.1660E+00	.1848E+00	.2501E+00	.2821E+00
PARTICULATE	I132	.1097E-02	.1207E-02	.1312E-02	.1355E-02	.1360E-02	.1360E-02
PARTICULATE	I133	.4417E-01	.4942E-01	.5558E-01	.6107E-01	.6974E-01	.6982E-01
PARTICULATE	I134	.2609E-03	.2800E-03	.2932E-03	.2950E-03	.2950E-03	.2950E-03
PARTICULATE	I135	.7288E-02	.8114E-02	.9036E-02	.9684E-02	.1006E-01	.1006E-01

TOTAL DOSE FOR 30 DAYS .2535E+02

6/2/95  
yjw

INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR  
OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT,

CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4600E+04

FILTERED INLEAKAGE(CFM) .8000E+03

UNFILTERED INLEAKAGE(CFM) .5000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY  
DOSE(REM)

ELEMENTAL	I131	.2806E+01	.3304E+01	.4088E+01	.5694E+01	.1111E+02	.1369E+02
ELEMENTAL	I132	.2386E-01	.2728E-01	.3164E-01	.3519E-01	.3560E-01	.3560E-01
ELEMENTAL	I133	.9472E+00	.1112E+01	.1365E+01	.1834E+01	.2564E+01	.2570E+01
ELEMENTAL	I134	.5820E-02	.6411E-02	.6945E-02	.7093E-02	.7094E-02	.7094E-02
ELEMENTAL	I135	.1569E+00	.1827E+00	.2206E+00	.2757E+00	.3082E+00	.3082E+00
ORGANIC	I131	.4185E+00	.9017E+00	.1663E+01	.3222E+01	.7376E+01	.8937E+01
ORGANIC	I132	.3383E-02	.6708E-02	.1094E-01	.1439E-01	.1479E-01	.1479E-01
ORGANIC	I133	.1405E+00	.3002E+00	.5465E+00	.1001E+01	.1631E+01	.1634E+01
ORGANIC	I134	.7613E-03	.1335E-02	.1854E-02	.1998E-02	.1999E-02	.1999E-02
ORGANIC	I135	.2299E-01	.4812E-01	.8492E-01	.1384E+00	.1690E+00	.1690E+00
PARTICULATE	I131	.1361E+00	.1526E+00	.1724E+00	.1951E+00	.2739E+00	.3125E+00
PARTICULATE	I132	.1139E-02	.1253E-02	.1364E-02	.1415E-02	.1420E-02	.1420E-02
PARTICULATE	I133	.4587E-01	.5132E-01	.5774E-01	.6436E-01	.7482E-01	.7491E-01
PARTICULATE	I134	.2710E-03	.2908E-03	.3045E-03	.3067E-03	.3067E-03	.3067E-03
PARTICULATE	I135	.7568E-02	.8426E-02	.9386E-02	.1017E-01	.1063E-01	.1063E-01

TOTAL DOSE FOR 30 DAYS .2777E+02

3/12/97  
JRW

INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR

OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT,

CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4500E+04

FILTERED INLEAKAGE(CFM) .9000E+03

UNFILTERED INLEAKAGE(CFM) .0000E+00

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY  
DOSE(REM)

ELEMENTAL	I131	.2391E+01	.2814E+01	.3473E+01	.4283E+01	.7014E+01	.8318E+01
ELEMENTAL	I132	.2033E-01	.2324E-01	.2691E-01	.2870E-01	.2891E-01	.2891E-01
ELEMENTAL	I133	.8069E+00	.9470E+00	.1160E+01	.1396E+01	.1765E+01	.1768E+01
ELEMENTAL	I134	.4958E-02	.5461E-02	.5912E-02	.5987E-02	.5987E-02	.5987E-02
ELEMENTAL	I135	.1336E+00	.1557E+00	.1875E+00	.2153E+00	.2317E+00	.2317E+00
ORGANIC	I131	.3565E+00	.7681E+00	.1408E+01	.2194E+01	.4289E+01	.5076E+01
ORGANIC	I132	.2882E-02	.5715E-02	.9277E-02	.1102E-01	.1122E-01	.1122E-01
ORGANIC	I133	.1197E+00	.2557E+00	.4626E+00	.6920E+00	.1009E+01	.1011E+01
ORGANIC	I134	.6485E-03	.1138E-02	.1575E-02	.1648E-02	.1649E-02	.1649E-02
ORGANIC	I135	.1959E-01	.4099E-01	.7192E-01	.9891E-01	.1144E+00	.1144E+00
PARTICULATE	I131	.1112E+00	.1247E+00	.1406E+00	.1442E+00	.1565E+00	.1625E+00
PARTICULATE	I132	.9310E-03	.1024E-02	.1113E-02	.1121E-02	.1122E-02	.1122E-02
PARTICULATE	I133	.3749E-01	.4194E-01	.4709E-01	.4813E-01	.4977E-01	.4978E-01
PARTICULATE	I134	.2214E-03	.2376E-03	.2488E-03	.2491E-03	.2491E-03	.2491E-03
PARTICULATE	I135	.6185E-02	.6886E-02	.7658E-02	.7780E-02	.7852E-02	.7852E-02

TOTAL DOSE FOR 30 DAYS .1679E+02

EB/12/93  
2pm

INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR

OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT, CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4500E+04

FILTERED INLEAKAGE(CFM) .9000E+03

UNFILTERED INLEAKAGE(CFM) .1000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY DOSE(REM)

ELEMENTAL	I131	.2484E+01	.2924E+01	.3611E+01	.4599E+01	.7930E+01	.9521E+01
ELEMENTAL	I132	.2112E-01	.2415E-01	.2797E-01	.3015E-01	.3041E-01	.3041E-01
ELEMENTAL	I133	.8383E+00	.9838E+00	.1206E+01	.1494E+01	.1943E+01	.1947E+01
ELEMENTAL	I134	.5150E-02	.5674E-02	.6143E-02	.6235E-02	.6235E-02	.6235E-02
ELEMENTAL	I135	.1388E+00	.1617E+00	.1949E+00	.2288E+00	.2488E+00	.2488E+00
ORGANIC	I131	.3704E+00	.7980E+00	.1465E+01	.2424E+01	.4980E+01	.5940E+01
ORGANIC	I132	.2994E-02	.5937E-02	.9649E-02	.1177E-01	.1202E-01	.1202E-01
ORGANIC	I133	.1244E+00	.2657E+00	.4814E+00	.7612E+00	.1148E+01	.1151E+01
ORGANIC	I134	.6737E-03	.1182E-02	.1638E-02	.1727E-02	.1727E-02	.1727E-02
ORGANIC	I135	.2035E-01	.4258E-01	.7483E-01	.1078E+00	.1266E+00	.1266E+00
PARTICULATE	I131	.1164E+00	.1304E+00	.1472E+00	.1547E+00	.1806E+00	.1934E+00
PARTICULATE	I132	.9738E-03	.1071E-02	.1165E-02	.1182E-02	.1184E-02	.1184E-02
PARTICULATE	I133	.3921E-01	.4387E-01	.4928E-01	.5147E-01	.5492E-01	.5495E-01
PARTICULATE	I134	.2316E-03	.2486E-03	.2602E-03	.2609E-03	.2609E-03	.2609E-03
PARTICULATE	I135	.6469E-02	.7202E-02	.8013E-02	.8271E-02	.8422E-02	.8422E-02

TOTAL DOSE FOR 30 DAYS .1924E+02

6/12/97  
mjt

INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR  
OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT, CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4500E+04

FILTERED INLEAKAGE(CFM) .9000E+03


UNFILTERED INLEAKAGE(CFM) .2000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY  
DOSE(REM)

ELEMENTAL	I131	.2576E+01	.3033E+01	.3748E+01	.4913E+01	.8842E+01	.1072E+02
ELEMENTAL	I132	.2190E-01	.2505E-01	.2902E-01	.3160E-01	.3190E-01	.3190E-01
ELEMENTAL	I133	.8695E+00	.1020E+01	.1252E+01	.1592E+01	.2121E+01	.2126E+01
ELEMENTAL	I134	.5342E-02	.5885E-02	.6373E-02	.6481E-02	.6482E-02	.6482E-02
ELEMENTAL	I135	1440E+00	.1678E+00	.2023E+00	.2423E+00	.2658E+00	.2658E+00
ORGANIC	I131	.3842E+00	.8277E+00	.1522E+01	.2653E+01	.5668E+01	.6800E+01
ORGANIC	I132	.3106E-02	.6158E-02	.1002E-01	.1252E-01	.1281E-01	.1281E-01
ORGANIC	I133	.1290E+00	.2756E+00	.5001E+00	.8301E+00	.1287E+01	.1290E+01
ORGANIC	I134	.6989E-03	.1226E-02	.1700E-02	.1805E-02	.1805E-02	.1805E-02
ORGANIC	I135	.2111E-01	.4417E-01	.7772E-01	.1166E+00	.1388E+00	.1388E+00
PARTICULATE	I131	.1215E+00	.1362E+00	.1537E+00	.1651E+00	.2047E+00	.2241E+00
PARTICULATE	I132	.1016E-02	.1118E-02	.1216E-02	.1242E-02	.1245E-02	.1245E-02
PARTICULATE	I133	.4093E-01	.4579E-01	.5146E-01	.5479E-01	.6005E-01	.6009E-01
PARTICULATE	I134	.2417E-03	.2594E-03	.2716E-03	.2727E-03	.2727E-03	.2727E-03
PARTICULATE	I135	.6752E-02	.7518E-02	.8367E-02	.8760E-02	.8990E-02	.8990E-02

TOTAL DOSE FOR 30 DAYS .2169E+02

tb/21.15  
vif



INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR  
OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT,

CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4500E+04

FILTERED INLEAKAGE(CFM) .9000E+03


UNFILTERED INLEAKAGE(CFM) .3000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY DOSE(REM)

ELEMENTAL	I131	.2668E+01	.3142E+01	.3884E+01	.5226E+01	.9751E+01	.1191E+02
ELEMENTAL	I132	.2269E-01	.2594E-01	.3007E-01	.3304E-01	.3338E-01	.3338E-01
ELEMENTAL	I133	.9007E+00	.1057E+01	.1297E+01	.1689E+01	.2299E+01	.2304E+01
ELEMENTAL	I134	.5534E-02	.6096E-02	.6603E-02	.6727E-02	.6727E-02	.6727E-02
ELEMENTAL	I135	.1492E+00	.1738E+00	.2097E+00	.2557E+00	.2828E+00	.2828E+00
ORGANIC	I131	.3979E+00	.8574E+00	.1578E+01	.2882E+01	.6353E+01	.7657E+01
ORGANIC	I132	.3217E-02	.6379E-02	.1039E-01	.1327E-01	.1360E-01	.1360E-01
ORGANIC	I133	.1336E+00	.2855E+00	.5187E+00	.8988E+00	.1425E+01	.1428E+01
ORGANIC	I134	.7239E-03	.1270E-02	.1762E-02	.1882E-02	.1883E-02	.1883E-02
ORGANIC	I135	.2186E-01	.4575E-01	.8061E-01	.1253E+00	.1509E+00	.1509E+00
PARTICULATE	I131	.1265E+00	.1418E+00	.1602E+00	.1755E+00	.2286E+00	.2547E+00
PARTICULATE	I132	.1059E-02	.1165E-02	.1267E-02	.1302E-02	.1305E-02	.1305E-02
PARTICULATE	I133	.4264E-01	.4770E-01	.5363E-01	.5810E-01	.6516E-01	.6522E-01
PARTICULATE	I134	.2519E-03	.2703E-03	.2830E-03	.2845E-03	.2845E-03	.2845E-03
PARTICULATE	I135	.7035E-02	.7832E-02	.8720E-02	.9247E-02	.9556E-02	.9556E-02

TOTAL DOSE FOR 30 DAYS .2412E+02

6/1/2014  
2014



INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR  
 OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT, CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4500E+04

FILTERED INLEAKAGE(CFM) .9000E+03


UNFILTERED INLEAKAGE(CFM) .4000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY DOSE(REM)

ELEMENTAL	I131	.2760E+01	.3250E+01	.4020E+01	.5538E+01	.1066E+02	.1310E+02
ELEMENTAL	I132	.2347E-01	.2684E-01	.3112E-01	.3448E-01	.3487E-01	.3487E-01
ELEMENTAL	I133	.9317E+00	.1093E+01	.1343E+01	.1785E+01	.2476E+01	.2481E+01
ELEMENTAL	I134	.5724E-02	.6306E-02	.6831E-02	.6971E-02	.6972E-02	.6972E-02
ELEMENTAL	I135	.1543E+00	.1797E+00	.2170E+00	.2691E+00	.2997E+00	.2997E+00
ORGANIC	I131	.4116E+00	.8869E+00	.1635E+01	.3109E+01	.7036E+01	.8511E+01
ORGANIC	I132	.3328E-02	.6599E-02	.1076E-01	.1402E-01	.1439E-01	.1439E-01
ORGANIC	I133	.1382E+00	.2953E+00	.5372E+00	.9672E+00	.1562E+01	.1566E+01
ORGANIC	I134	.7488E-03	.1314E-02	.1824E-02	.1960E-02	.1960E-02	.1960E-02
ORGANIC	I135	.2262E-01	.4733E-01	.8348E-01	.1341E+00	.1630E+00	.1630E+00
PARTICULATE	I131	.1316E+00	.1475E+00	.1666E+00	.1858E+00	.2525E+00	.2851E+00
PARTICULATE	I132	.1101E-02	.1211E-02	.1318E-02	.1361E-02	.1366E-02	.1366E-02
PARTICULATE	I133	.4434E-01	.4961E-01	.5579E-01	.6140E-01	.7025E-01	.7033E-01
PARTICULATE	I134	.2619E-03	.2811E-03	.2944E-03	.2962E-03	.2962E-03	.2962E-03
PARTICULATE	I135	.7316E-02	.8145E-02	.9071E-02	.9732E-02	.1012E-01	.1012E-01

TOTAL DOSE FOR 30 DAYS .2655E+02

3/12/97  
mta



INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR  
 OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT, CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4500E+04

FILTERED INLEAKAGE(CFM) .9000E+03


UNFILTERED INLEAKAGE(CFM) .5000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY DOSE(REM)

ELEMENTAL	I131	.2852E+01	.3358E+01	.4156E+01	.5849E+01	.1156E+02	.1429E+02
ELEMENTAL	I132	.2425E-01	.2773E-01	.3216E-01	.3591E-01	.3634E-01	.3634E-01
ELEMENTAL	I133	.9626E+00	.1130E+01	.1388E+01	.1882E+01	.2652E+01	.2658E+01
ELEMENTAL	I134	.5914E-02	.6515E-02	.7059E-02	.7215E-02	.7216E-02	.7216E-02
ELEMENTAL	I135	.1594E+00	.1857E+00	.2243E+00	.2824E+00	.3166E+00	.3166E+00
ORGANIC	I131	.4253E+00	.9164E+00	.1691E+01	.3336E+01	.7716E+01	.9362E+01
ORGANIC	I132	.3438E-02	.6818E-02	.1112E-01	.1476E-01	.1518E-01	.1518E-01
ORGANIC	I133	.1428E+00	.3051E+00	.5557E+00	.1035E+01	.1699E+01	.1703E+01
ORGANIC	I134	.7737E-03	.1357E-02	.1885E-02	.2037E-02	.2038E-02	.2038E-02
ORGANIC	I135	.2337E-01	.4890E-01	.8635E-01	.1428E+00	.1751E+00	.1751E+00
PARTICULATE	I131	.1366E+00	.1532E+00	.1731E+00	.1962E+00	.2762E+00	.3155E+00
PARTICULATE	I132	.1143E-02	.1258E-02	.1369E-02	.1421E-02	.1427E-02	.1427E-02
PARTICULATE	I133	.4604E-01	.5151E-01	.5795E-01	.6469E-01	.7533E-01	.7542E-01
PARTICULATE	I134	.2720E-03	.2919E-03	.3057E-03	.3079E-03	.3079E-03	.3079E-03
PARTICULATE	I135	.7596E-02	.8457E-02	.9421E-02	.1022E-01	.1068E-01	.1068E-01

TOTAL DOSE FOR 30 DAYS .2896E+02

3/12/97  
mew



INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR

OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT,

CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4400E+04

FILTERED INLEAKAGE(CFM) .1000E+04


UNFILTERED INLEAKAGE(CFM) .0000E+00

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY  
DOSE(REM)

ELEMENTAL	I131	.2437E+01	.2869E-01	.3542E+01	.4441E+01	.7472E+01	.8920E+01
ELEMENTAL	I132	.2072E-01	.2369E-01	.2744E-01	.2943E-01	.2966E-01	.2966E-01
ELEMENTAL	I133	.8226E+00	.9654E+00	.1183E+01	.1445E+01	.1854E+01	.1857E+01
ELEMENTAL	I134	.5054E-02	.5568E-02	.6028E-02	.6111E-02	.6111E-02	.6111E-02
ELEMENTAL	I135	.1362E+00	.1587E+00	.1912E+00	.2221E+00	.2402E+00	.2402E+00
ORGANIC	I131	.3634E+00	.7831E+00	.1436E+01	.2309E+01	.4635E+01	.5508E+01
ORGANIC	I132	.2938E-02	.5826E-02	.9463E-02	.1139E-01	.1162E-01	.1162E-01
ORGANIC	I133	.1220E+00	.2607E+00	.4720E+00	.7266E+00	.1079E+01	.1081E+01
ORGANIC	I134	.6611E-03	.11C0E-02	.1607E-02	.1687E-02	.1688E-02	.1688E-02
ORGANIC	I135	.1997E-01	.4179E-01	.7337E-01	.1033E+00	.1205E+00	.1205E+00
PARTICULATE	I131	.1118E+00	.1253E+00	.1413E+00	.1452E+00	.1589E+00	.1656E+00
PARTICULATE	I132	.9353E-03	.1029E-02	.1119E-02	.1127E-02	.1128E-02	.1128E-02
PARTICULATE	I133	.3766E-01	.4213E-01	.4731E-01	.4846E-01	.5028E-01	.5030E-01
PARTICULATE	I134	.2224E-03	.2387E-03	.2499E-03	.2503E-03	.2503E-03	.2503E-03
PARTICULATE	I135	.6213E-02	.6918E-02	.7693E-02	.7829E-02	.7909E-02	.7909E-02

TOTAL DOSE FOR 30 DAYS .1800E+02

6/12/95  
RJW



INPUT I:\NSLIMSA\CTRLROOM\THY9702.FOR

OUTPUT I:\NSLIMSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT,

CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4400E+04

FILTERED INLEAKAGE(CFM) .1000E+04


UNFILTERED INLEAKAGE(CFM) .1000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY  
DOSE(REM)

ELEMENTAL	I131	.2530E+01	.2978E+01	.3679E+01	.4756E+01	.8386E+01	.1012E+02
ELEMENTAL	I132	.2151E-01	.2460E-01	.2850E-01	.3088E-01	.3115E-01	.3115E-01
ELEMENTAL	I133	.8539E+00	.1002E+01	.1229E+01	.1543E+01	.2033E+01	.2037E+01
ELEMENTAL	I134	.5247E-02	.5780E-02	.6258E-02	.6358E-02	.6358E-02	.6358E-02
ELEMENTAL	I135	.1414E+00	.1647E+00	.1986E+00	.2356E+00	.2573E+00	.2573E+00
ORGANIC	I131	.3773E+00	.8129E+00	.1493E+01	.2539E+01	.5324E+01	.6370E+01
ORGANIC	I132	.3050E-02	.6048E-02	.9835E-02	.1215E-01	.1241E-01	.1241E-01
ORGANIC	I133	.1267E+00	.2706E+00	.4907E+00	.7957E+00	.1218E+01	.1220E+01
ORGANIC	I134	.6863E-03	.1204E-02	.1669E-02	.1766E-02	.1766E-02	.1766E-02
ORGANIC	I135	.2073E-01	.4338E-01	.7628E-01	.1122E+00	.1327E+00	.1327E+00
PARTICULATE	I131	.1169E+00	.1310E+00	.1478E+00	.1557E+00	.1830E+00	.1964E+00
PARTICULATE	I132	.9781E-03	.1076E-02	.1170E-02	.1188E-02	.1190E-02	.1190E-02
PARTICULATE	I133	.3938E-01	.4406E-01	.4950E-01	.5180E-01	.5543E-01	.5546E-01
PARTICULATE	I134	.2326E-03	.2496E-03	.2614E-03	.2621E-03	.2621E-03	.2621E-03
PARTICULATE	I135	.6497E-02	.7234E-02	.8048E-02	.8320E-02	.8479E-02	.8479E-02

TOTAL DOSE FOR 30 DAYS .2045E+02

1/21/93



INPUT I:\NSL\MSA\CTRLROOM\HY9702.FOR

OUTPUT I:\NSL\MSA\CTRLROOM\HY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT,

CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4400E+04

FILTERED INLEAKAGE(CFM) .1000E+04


UNFILTERED INLEAKAGE(CFM) .2000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY DOSE(REM)

ELEMENTAL	I131	.2622E+01	.3087E+01	.3816E+01	.5070E+01	.9297E+01	.1132E+02
ELEMENTAL	I132	.2230E-01	.2550E-01	.2955E-01	.3232E-01	.3264E-01	.3264E-01
ELEMENTAL	I133	.8851E+00	.1039E+01	.1274E+01	.1640E+01	.2210E+01	.2215E+01
ELEMENTAL	I134	.5438E-02	.5991E-02	.6488E-02	.6604E-02	.6605E-02	.6605E-02
ELEMENTAL	I135	.1466E+00	.1708E+00	.2060E+00	.2490E+00	.2743E+00	.2743E+00
ORGANIC	I131	.3911E+00	.8426E+00	.1550E+01	.2768E+01	.6011E+01	.7229E+01
ORGANIC	I132	.3162E-02	.6269E-02	.1020E-01	.1290E-01	.1321E-01	.1321E-01
ORGANIC	I133	.1313E+00	.2805E+00	.5094E+00	.8645E+00	.1356E+01	.1359E+01
ORGANIC	I134	.7114E-03	.1248E-02	.1731E-02	.1843E-02	.1844E-02	.1844E-02
ORGANIC	I135	.2148E-01	.4496E-01	.7917E-01	.1210E+00	.1449E+00	.1449E+00
PARTICULATE	I131	.1220E+00	.1367E+00	.1543E+00	.1661E+00	.2071E+00	.2271E+00
PARTICULATE	I132	.1021E-02	.1123E-02	.1221E-02	.1248E-02	.1251E-02	.1251E-02
PARTICULATE	I133	.4110E-01	.4598E-01	.5168E-01	.5512E-01	.6056E-01	.6061E-01
PARTICULATE	I134	.2428E-03	.2605E-03	.2728E-03	.2739E-03	.2739E-03	.2739E-03
PARTICULATE	I135	.6781E-02	.7549E-02	.8402E-02	.8808E-02	.9046E-02	.9046E-02

TOTAL DOSE FOR 30 DAYS .2289E+02

6/1/2015  
MPL



INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR  
OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT, CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4400E+04

FILTERED INLEAKAGE(CFM) .1000E+04

UNFILTERED INLEAKAGE(CFM) .3000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY  
DOSE(REM)

ELEMENTAL	I131	.2714E+01	.3196E+01	.3952E+01	.5382E+01	.1020E+02	.1251E+02
ELEMENTAL	I132	.2308E-01	.2639E-01	.3060E-01	.3376E-01	.3413E-01	.3413E-01
ELEMENTAL	I133	.9162E+00	.1075E+01	.1320E+01	.1737E+01	.2387E+01	.2393E+01
ELEMENTAL	I134	.5629E-02	.6201E-02	.6717E-02	.6849E-02	.6850E-02	.6850E-02
ELEMENTAL	I135	.1517E+00	.1768E+00	.2133E+00	.2624E+00	.2913E+00	.2913E+00
ORGANIC	I131	.4048E+00	.8722E+00	.1607E+01	.2995E+01	.6695E+01	.8085E+01
ORGANIC	I132	.3273E-02	.6489E-02	.1057E-01	.1365E-01	.1400E-01	.1400E-01
ORGANIC	I133	.1359E+00	.2904E+00	.5280E+00	.9330E+00	.1494E+01	.1497E+01
ORGANIC	I134	.7364E-03	.1292E-02	.1793E-02	.1921E-02	.1922E-02	.1922E-02
ORGANIC	I135	.2224E-01	.4654E-01	.8205E-01	.1297E+00	.1570E+00	.1570E+00
PARTICULATE	I131	.1270E+00	.1424E+00	.1608E+00	.1765E+00	.2310E+00	.2577E+00
PARTICULATE	I132	.1063E-02	.1169E-02	.1273E-02	.1308E-02	.1312E-02	.1312E-02
PARTICULATE	I133	.4281E-01	.4789E-01	.5385E-01	.5843E-01	.6567E-01	.6573E-01
PARTICULATE	I134	.2529E-03	.2714E-03	.2842E-03	.2856E-03	.2857E-03	.2857E-03
PARTICULATE	I135	.7063E-02	.7863E-02	.8755E-02	.9296E-02	.9612E-02	.9612E-02

TOTAL DOSE FOR 30 DAYS .2532E+02

3/12/97  
rfw

INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR  
OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT, CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4400E+04

FILTERED INLEAKAGE(CFM) .1000E+04


UNFILTERED INLEAKAGE(CFM) .4000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY  
DOSE(REM)

ELEMENTAL	I131	.2806E+01	.3304E+01	.4088E+01	.5694E+01	.1111E+02	.1369E+02
ELEMENTAL	I132	.2386E-01	.2728E-01	.3164E-01	.3519E-01	.3560E-01	.3560E-01
ELEMENTAL	I133	.9472E+00	.1112E+01	.1365E+01	.1834E+01	.2564E+01	.2570E+01
ELEMENTAL	I134	.5820E-02	.6411E-02	.6945E-02	.7093E-02	.7094E-02	.7094E-02
ELEMENTAL	I135	.1569E+00	.1827E+00	.2206E+00	.2757E+00	.3082E+00	.3082E+00
ORGANIC	I131	.4185E+00	.9017E+00	.1663E+01	.3222E+01	.7376E+01	.8937E+01
ORGANIC	I132	.3383E-02	.6708E-02	.1094E-01	.1439E-01	.1479E-01	.1479E-01
ORGANIC	I133	.1405E+00	.3002E+00	.5465E+00	.1001E+01	.1631E+01	.1634E+01
ORGANIC	I134	.7613E-03	.1335E-02	.1854E-02	.1998E-02	.1999E-02	.1999E-02
ORGANIC	I135	.2299E-01	.4812E-01	.8492E-01	.1384E+00	.1690E+00	.1690E+00
PARTICULATE	I131	.1321E+00	.1481E+00	.1673E+00	.1869E+00	.2548E+00	.2882E+00
PARTICULATE	I132	.1106E-02	.1216E-02	.1324E-02	.1367E-02	.1372E-02	.1372E-02
PARTICULATE	I133	.4451E-01	.4980E-01	.5601E-01	.6173E-01	.7076E-01	.7084E-01
PARTICULATE	I134	.2629E-03	.2822E-03	.2955E-03	.2974E-03	.2974E-03	.2974E-03
PARTICULATE	I135	.7344E-02	.8176E-02	.9106E-02	.9781E-02	.1018E-01	.1018E-01

TOTAL DOSE FOR 30 DAYS .2774E+02

3/12/97  
JAS



INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR  
OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4400E+04

FILTERED INLEAKAGE(CFM) .1000E+04

UNFILTERED INLEAKAGE(CFM) .5000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY  
DOSE(REM)

ELEMENTAL	I131	.2898E+01	.3411E+01	.4223E+01	.6004E+01	.1201E+02	.1488E+02
ELEMENTAL	I132	.2464E-01	.2817E-01	.3268E-01	.3662E-01	.3708E-01	.3708E-01
ELEMENTAL	I133	.9780E+00	.1148E+01	.1410E+01	.1930E+01	.2740E+01	.2746E+01
ELEMENTAL	I134	.6009E-02	.6620E-02	.7172E-02	.7337E-02	.7338E-02	.7338E-02
ELEMENTAL	I135	.1620E+00	.1887E+00	.2279E+00	.2890E+00	.3250E+00	.3250E+00
ORGANIC	I131	.4321E+00	.9310E+00	.1719E+01	.3449E+01	.8055E+01	.9786E+01
ORGANIC	I132	.3493E-02	.6927E-02	.1131E-01	.1513E-01	.1557E-01	.1557E-01
ORGANIC	I133	.1451E+00	.3100E+00	.5649E+00	.1069E+01	.1767E+01	.1771E+01
ORGANIC	I134	.7861E-03	.1379E-02	.1916E-02	.2075E-02	.2076E-02	.2076E-02
ORGANIC	I135	.2374E-01	.4968E-01	.8777E-01	.1471E+00	.1811E+00	.1811E+00
PARTICULATE	I131	.1371E+00	.1537E+00	.1737E+00	.1972E+00	.2786E+00	.3185E+00
PARTICULATE	I132	.1148E-02	.1262E-02	.1374E-02	.1427E-02	.1433E-02	.1433E-02
PARTICULATE	I133	.4621E-01	.5170E-01	.5817E-01	.6502E-01	.7583E-01	.7593E-01
PARTICULATE	I134	.2730E-03	.2929E-03	.3068E-03	.3090E-03	.3090E-03	.3090E-03
PARTICULATE	I135	.7624E-02	.8488E-02	.9456E-02	.1026E-01	.1074E-01	.1074E-01

TOTAL DOSE FOR 30 DAYS .3016E+02

t h, 12116  
RJR

INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR  
OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT, CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4300E+04

FILTERED INLEAKAGE(CFM) .1100E+04


UNFILTERED INLEAKAGE(CFM) .0000E+00

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY  
DOSE(REM)

ELEMENTAL	I131	.2484E+01	.2924E+01	.3611E+01	.4599E+01	.7930E+01	.9521E+01
ELEMENTAL	I132	.2112E-01	.2415E-01	.2797E-01	.3015E-01	.3041E-01	.3041E-01
ELEMENTAL	I133	.8383E+00	.9838E+00	.1206E+01	.1494E+01	.1943E+01	.1947E+01
ELEMENTAL	I134	.5150E-02	.5674E-02	.6143E-02	.6235E-02	.6235E-02	.6235E-02
ELEMENTAL	I135	.1388E+00	.1617E+00	.1949E+00	.2288E+00	.2488E+00	.2488E+00
ORGANIC	I131	.3704E+00	.7980E+00	.1465E+01	.2424E+01	.4980E+01	.5940E+01
ORGANIC	I132	.2994E-02	.5937E-02	.9649E-02	.1177E-01	.1202E-01	.1202E-01
ORGANIC	I133	.1244E+00	.2657E+00	.4814E+00	.7612E+00	.1148E+01	.1151E+01
ORGANIC	I134	.6737E-03	.1182E-02	.1638E-02	.1727E-02	.1727E-02	.1727E-02
ORGANIC	I135	.2035E-01	.4258E-01	.7483E-01	.1078E+00	.1266E+00	.1266E+00
PARTICULATE	I131	.1123E+00	.1259E+00	.1419E+00	.1463E+00	.1613E+00	.1687E+00
PARTICULATE	I132	.9396E-03	.1034E-02	.1124E-02	.1133E-02	.1135E-02	.1135E-02
PARTICULATE	I133	.3783E-01	.4233E-01	.4753E-01	.4880E-01	.5080E-01	.5081E-01
PARTICULATE	I134	.2235E-03	.2398E-03	.2510E-03	.2515E-03	.2515E-03	.2515E-03
PARTICULATE	I135	.6242E-02	.6949E-02	.7729E-02	.7878E-02	.7966E-02	.7966E-02

TOTAL DOSE FOR 30 DAYS .1921E+02

3/12/97  
MLC



INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR  
OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT, CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4300E+04

FILTERED INLEAKAGE(CFM) .1100E+04

UNFILTERED INLEAKAGE(CFM) .1000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY DOSE(REM)

ELEMENTAL	I131	.2576E+01	.3033E+01	.3748E+01	.4913E+01	.8842E+01	.1072E+02
ELEMENTAL	I132	.2190E-01	.2505E-01	.2902E-01	.3160E-01	.3190E-01	.3190E-01
ELEMENTAL	I133	.8695E+00	.1020E+01	.1252E+01	.1592E+01	.2121E+01	.2126E+01
ELEMENTAL	I134	.5342E-02	.5885E-02	.6373E-02	.6481E-02	.6482E-02	.6482E-02
ELEMENTAL	I135	.1440E+00	.1678E+00	.2023E+00	.2423E+00	.2658E+00	.2658E+00
ORGANIC	I131	.3842E+00	.8277E+00	.1522E+01	.2653E+01	.5668E+01	.6800E+01
ORGANIC	I132	.3106E-02	.6158E-02	.1002E-01	.1252E-01	.1281E-01	.1281E-01
ORGANIC	I133	.1290E+00	.2756E+00	.5001E+00	.8301E+00	.1287E+01	.1290E+01
ORGANIC	I134	.6989E-03	.1226E-02	.1700E-02	.1805E-02	.1805E-02	.1805E-02
ORGANIC	I135	.2111E-01	.4417E-01	.7772E-01	.1166E+00	.1388E+00	.1388E+00
PARTICULATE	I131	.1174E+00	.1316E+00	.1485E+00	.1567E+00	.1854E+00	.1995E+00
PARTICULATE	I132	.9824E-03	.1081E-02	.1175E-02	.1194E-02	.1196E-02	.1196E-02
PARTICULATE	I133	.3956E-01	.4425E-01	.4971E-01	.5213E-01	.5594E-01	.5598E-01
PARTICULATE	I134	.2336E-03	.2507E-03	.2625E-03	.2633E-03	.2633E-03	.2633E-03
PARTICULATE	I135	.6526E-02	.7266E-02	.8034E-02	.8369E-02	.8535E-02	.8535E-02

TOTAL DOSE FOR 30 DAYS .2166E+02

t.b/n/11C  
Duke

INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR  
OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT, CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4300E+04

FILTERED INLEAKAGE(CFM) .1100E+04

UNFILTERED INLEAKAGE(CFM) .2000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY  
DOSE(REM)

ELEMENTAL	I131	.2668E+01	.3142E+01	.3884E+01	.5226E+01	.9751E+01	.1191E+02
ELEMENTAL	I132	.2269E-01	.2594E-01	.3007E-01	.3304E-01	.3338E-01	.3338E-01
ELEMENTAL	I133	.9007E+00	.1057E+01	.1297E+01	.1689E+01	.2299E+01	.2304E+01
ELEMENTAL	I134	.5534E-02	.6096E-02	.6603E-02	.6727E-02	.6727E-02	.6727E-02
ELEMENTAL	I135	.1492E+00	.1738E+00	.2097E+00	.2557E+00	.2828E+00	.2828E+00
ORGANIC	I131	.3979E+00	.8574E+00	.1578E+01	.2882E+01	.6353E+01	.7657E+01
ORGANIC	I132	.3217E-02	.6379E-02	.1039E-01	.1327E-01	.1360E-01	.1360E-01
ORGANIC	I133	.1336E+00	.2855E+00	.5187E+00	.8988E+00	.1425E+01	.1428E+01
ORGANIC	I134	.7239E-03	.1270E-02	.1762E-02	.1882E-02	.1883E-02	.1883E-02
ORGANIC	I135	.2186E-01	.4575E-01	.8061E-01	.1253E+00	.1509E+00	.1509E+00
PARTICULATE	I131	.1225E+00	.1373E+00	.1550E+00	.1672E+00	.2095E+00	.2302E+00
PARTICULATE	I132	.1025E-02	.1127E-02	.1227E-02	.1254E-02	.1257E-02	.1257E-02
PARTICULATE	I133	.4127E-01	.4617E-01	.5189E-01	.5545E-01	.6107E-01	.6112E-01
PARTICULATE	I134	.2438E-03	.2616E-03	.2739E-03	.2751E-03	.2751E-03	.2751E-03
PARTICULATE	I135	.6809E-02	.7581E-02	.8438E-02	.8857E-02	.9103E-02	.9103E-02

TOTAL DOSE FOR 30 DAYS .2409E+02

3/12/97  
mfa

INPUT I:\NSL\MSAICTRLROOMIHY9702.FOR

OUTPUT I:\NSL\MSAICTRLROOMIHY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT,

CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4300E+04

FILTERED INLEAKAGE(CFM) .1100E+04


UNFILTERED INLEAKAGE(CFM) .3000E+02

	ISOTOPE	.5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
--	---------	-------------------	------------------	------------------	------------------	-----------------	------------------

ELEMENTAL	I131	.2760E+01	.3250E+01	.4020E+01	.5538E+01	.1066E+02	.1310E+02
ELEMENTAL	I132	.2347E-01	.2684E-01	.3112E-01	.3448E-01	.3487E-01	.3487E-01
ELEMENTAL	I133	.9317E+00	.1093E+01	.1343E+01	.1785E+01	.2476E+01	.2481E+01
ELEMENTAL	I134	.5724E-02	.6306E-02	.6831E-02	.6971E-02	.6972E-02	.6972E-02
ELEMENTAL	I135	.1543E+00	.1797E+00	.2170E+00	.2691E+00	.2997E+00	.2997E+00
ORGANIC	I131	.4116E+00	.8869E+00	.1635E+01	.3109E+01	.7036E+01	.8511E+01
ORGANIC	I132	.3328E-02	.6599E-02	.1076E-01	.1402E-01	.1439E-01	.1439E-01
ORGANIC	I133	.1382E+00	.2953E+00	.5372E+00	.9672E+00	.1562E+01	.1566E+01
ORGANIC	I134	.7488E-03	.1314E-02	.1824E-02	.1960E-02	.1960E-02	.1960E-02
ORGANIC	I135	.2262E-01	.4733E-01	.8348E-01	.1341E+00	.1630E+00	.1630E+00
PARTICULATE	I131	.1275E+00	.1430E+00	.1615E+00	.1776E+00	.2334E+00	.2608E+00
PARTICULATE	I132	.1067E-02	.1174E-02	.1278E-02	.1314E-02	.1318E-02	.1318E-02
PARTICULATE	I133	.4298E-01	.4808E-01	.5406E-01	.5876E-01	.6618E-01	.6624E-01
PARTICULATE	I134	.2539E-03	.2724E-03	.2853E-03	.2868E-03	.2868E-03	.2868E-03
PARTICULATE	I135	.7091E-02	.7895E-02	.8790E-02	.9344E-02	.9669E-02	.9669E-02

TOTAL DOSE FOR 30 DAYS .2652E+02

5/2/97  
 Dkay!



INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR  
OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4300E+04

FILTERED INLEAKAGE(CFM) .1100E+04

UNFILTERED INLEAKAGE(CFM) .4000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY  
DOSE(REM)

ELEMENTAL	I131	.2852E+01	.3358E+01	.4156E+01	.5849E+01	.1156E+02	.1429E+02
ELEMENTAL	I132	.2425E-01	.2773E-01	.3216E-01	.3591E-01	.3634E-01	.3634E-01
ELEMENTAL	I133	.9626E+00	.1130E+01	.1388E+01	.1882E+01	.2652E+01	.2658E+01
ELEMENTAL	I134	.5914E-02	.6515E-02	.7059E-02	.7215E-02	.7216E-02	.7216E-02
ELEMENTAL	I135	.1594E+00	.1857E+00	.2243E+00	.2824E+00	.3166E+00	.3166E+00
ORGANIC	I131	.4253E+00	.9164E+00	.1691E+01	.3336E+01	.7716E+01	.9362E+01
ORGANIC	I132	.3438E-02	.6818E-02	.1112E-01	.1476E-01	.1518E-01	.1518E-01
ORGANIC	I133	.1428E+00	.3051E+00	.5557E+00	.1035E+01	.1699E+01	.1703E+01
ORGANIC	I134	.7737E-03	.1357E-02	.1885E-02	.2037E-02	.2038E-02	.2038E-02
ORGANIC	I135	.2337E-01	.4890E-01	.8635E-01	.1428E+00	.1751E+00	.1751E+00
PARTICULATE	I131	.1326E+00	.1486E+00	.1679E+00	.1879E+00	.2572E+00	.2912E+00
PARTICULATE	I132	.1110E-02	.1221E-02	.1329E-02	.1373E-02	.1378E-02	.1378E-02
PARTICULATE	I133	.4468E-01	.4999E-01	.5623E-01	.6206E-01	.7127E-01	.7135E-01
PARTICULATE	I134	.2639E-03	.2832E-13	.2966E-03	.2985E-03	.2985E-03	.2985E-03
PARTICULATE	I135	.7372E-02	.8208E-02	.9141E-02	.9829E-02	.1023E-01	.1023E-01

TOTAL DOSE FOR 30 DAYS .2894E+02

4/21/93  
Dose

INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR

OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT,

CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4300E+04

FILTERED INLEAKAGE(CFM) .1100E+04


UNFILTERED INLEAKAGE(CFM) .5000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY  
DOSE(REM)

ELEMENTAL	I131	.2943E+01	.3465E+01	.4291E+01	.6159E+01	.1246E+02	.1547E+02
ELEMENTAL	I132	.2502E-01	.2862E-01	.3320E-01	.3733E-01	.3781E-01	.3781E-01
ELEMENTAL	I133	.9934E+00	.1166E+01	.1433E+01	.1978E+01	.2827E+01	.2834E+01
ELEMENTAL	I134	.6104E-02	.6724E-02	.7286E-02	.7458E-02	.7459E-02	.7459E-02
ELEMENTAL	I135	.1645E+00	.1917E+00	.2315E+00	.2957E+00	.3334E+00	.3334E+00
ORGANIC	I131	.4389E+00	.9457E+00	.1747E+01	.3561E+01	.8394E+01	.1021E+02
ORGANIC	I132	.3548E-02	.7036E-02	.1149E-01	.1550E-01	.1596E-01	.1596E-01
ORGANIC	I133	.1474E+00	.3149E+00	.5741E+00	.1103E+01	.1835E+01	.1840E+01
ORGANIC	I134	.7984E-03	.1401E-02	.1946E-02	.2114E-02	.2115E-02	.2115E-02
ORGANIC	I135	.2411E-01	.5047E-01	.8920E-01	.1515E+00	.1871E+00	.1871E+00
PARTICULATE	I131	.1376E+00	.1543E+00	.1744E+00	.1982E+00	.2810E+00	.3216E+00
PARTICULATE	I132	.1152E-02	.1267E-02	.1379E-02	.1433E-02	.1439E-02	.1439E-02
PARTICULATE	I133	.4638E-01	.5189E-01	.5838E-01	.6535E-01	.7634E-01	.7643E-01
PARTICULATE	I134	.2740E-03	.2940E-03	.3079E-03	.3102E-03	.3102E-03	.3102E-03
PARTICULATE	I135	.7652E-02	.8519E-02	.9491E-02	.1031E-01	.1079E-01	.1079E-01

TOTAL DOSE FOR 30 DAYS .3134E+02

3/12/97  
T. Hall



INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR

OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT,

CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4200E+04

FILTERED INLEAKAGE(CFM) .1200E+04


UNFILTERED INLEAKAGE(CFM) .0000E+00

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY  
DOSE(REM)

ELEMENTAL	I131	.2530E+01	.2978E 01	.3679E+01	.4756E+01	.8386E+01	.1012E+02
ELEMENTAL	I132	.2151E-01	.2460E-01	.2850E-01	.3088E-01	.3115E-01	.3115E-01
ELEMENTAL	I133	.8539E+00	.1002E+01	.1229E+01	.1543E+01	.2033E+01	.2037E+01
ELEMENTAL	I134	.5247E-02	.5780E-02	.6258E-02	.6358E-02	.6358E-02	.6358E-02
ELEMENTAL	I135	.1414E+00	.1647E+00	.1986E+00	.2356E+00	.2573E+00	.2573E+00
ORGANIC	I131	.3773E+00	.8129E+00	.1493E+01	.2539E+01	.5324E+01	.6370E+01
ORGANIC	I132	.3050E-02	.6048E-02	.9835E-02	.1215E-01	.1241E-01	.1241E-01
ORGANIC	I133	.1267E+00	.2706E+00	.4907E+00	.7957E+00	.1218E+01	.1220E+01
ORGANIC	I134	.6863E-03	.1204E-02	.1669E-02	.1766E-02	.1766E-02	.1766E-02
ORGANIC	I135	.2073E-01	.4338E-01	.7628E-01	.1122E+00	.1327E+00	.1327E+00
PARTICULATE	I131	.1128E+00	.1264E+00	.1426E+00	.1473E+00	.1637E+00	.1718E+00
PARTICULATE	I132	.9439E-03	.1038E-02	.1129E-02	.1139E-02	.1141E-02	.1141E-02
PARTICULATE	I133	.3801E-01	.4252E-01	.4775E-01	.4913E-01	.5131E-01	.5133E-01
PARTICULATE	I134	.2245E-03	.2409E-03	.2522E-03	.2526E-03	.2526E-03	.2526E-03
PARTICULATE	I135	.6270E-02	.6981E-02	.7764E-02	.7927E-02	.8023E-02	.8023E-02

TOTAL DOSE FOR 30 DAYS .2042E+02

3/21/97  
Dale



INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR

OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT,

CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4200E+04

FILTERED INLEAKAGE(CFM) .1200E+04

UNFILTERED INLEAKAGE(CFM) .1000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY  
DOSE(REM)

ELEMENTAL	I131	.2622E+01	.3087E+01	.3816E+01	.5070E+01	.9297E+01	.1132E+02
ELEMENTAL	I132	.2230E-01	.2550E-01	.2955E-01	.3232E-01	.3264E-01	.3264E-01
ELEMENTAL	I133	.8851E+00	.1039E+01	.1274E+01	.1640E+01	.2210E+01	.2215E+01
ELEMENTAL	I134	.5438E-02	.5991E-02	.6488E-02	.6604E-02	.6605E-02	.6605E-02
ELEMENTAL	I135	.1466E+00	.1708E+00	.2060E+00	.2490E+00	.2743E+00	.2743E+00
ORGANIC	I131	.3911E+00	.8426E+00	.1550E+01	.2768E+01	.6011E+01	.7229E+01
ORGANIC	I132	.3162E-02	.6269E-02	.1020E-01	.1290E-01	.1321E-01	.1321E-01
ORGANIC	I133	.1313E+00	.2805E+00	.5094E+00	.8645E+00	.1356E+01	.1359E+01
ORGANIC	I134	.7114E-03	.1248E-02	.1731E-02	.1843E-02	.1844E-02	.1844E-02
ORGANIC	I135	.2148E-01	.4496E-01	.7917E-01	.1210E+00	.1449E+00	.1449E+00
PARTICULATE	I131	.1179E+00	.1322E+00	.1491E+00	.1578E+00	.1878E+00	.2026E+00
PARTICULATE	I132	.9866E-03	.1085E-02	.1180E-02	.1200E-02	.1202E-02	.1202E-02
PARTICULATE	I133	.3973E-01	.4444E-01	.4993E-01	.5246E-01	.5646E-01	.5649E-01
PARTICULATE	I134	.2347E-03	.2518E-03	.2637E-03	.2645E-03	.2645E-03	.2645E-03
PARTICULATE	I135	.6554E-02	.7297E-02	.8119E-02	.8418E-02	.8592E-02	.8592E-02

TOTAL DOSE FOR 30 DAYS .2286E+02

tb/12/96  
DST

INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR

OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT, CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4200E+04

FILTERED INLEAKAGE(CFM) .1200E+04


UNFILTERED INLEAKAGE(CFM) .2000E+02

	ISOTOPE	.5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
--	---------	-------------------	------------------	------------------	------------------	-----------------	------------------

ELEMENTAL	I131	.2714E+01	.3196E+01	.3952E+01	.5382E+01	.1020E+02	.1251E+02
ELEMENTAL	I132	.2308E-01	.2639E-01	.3060E-01	.3376E-01	.3413E-01	.3413E-01
ELEMENTAL	I133	.9162E+00	.1075E+01	.1320E+01	.1737E+01	.2387E+01	.2393E+01
ELEMENTAL	I134	.5629E-02	.6201E-02	.6717E-02	.6849E-02	.6850E-02	.6850E-02
ELEMENTAL	I135	.1517E+00	.1768E+00	.2133E+00	.2624E+00	.2913E+00	.2913E+00
ORGANIC	I131	.4048E+00	.8722E+00	.1607E+01	.2995E+01	.6695E+01	.8085E+01
ORGANIC	I132	.3273E-02	.6489E-02	.1057E-01	.1365E-01	.1400E-01	.1400E-01
ORGANIC	I133	.1359E+00	.2904E+00	.5280E+00	.9330E+00	.1494E+01	.1497E+01
ORGANIC	I134	.7364E-03	.1292E-02	.1793E-02	.1921E-02	.1922E-02	.1922E-02
ORGANIC	I135	.2224E-01	.4654E-01	.8205E-01	.1297E+00	.1570E+00	.1570E+00
PARTICULATE	I131	.1230E+00	.1379E+00	.1556E+00	.1682E+00	.2119E+00	.2333E+00
PARTICULATE	I132	.1029E-02	.1132E-02	.1232E-02	.1260E-02	.1263E-02	.1263E-02
PARTICULATE	I133	.4144E-01	.4636E-01	.5211E-01	.5579E-01	.6158E-01	.6163E-01
PARTICULATE	I134	.2448E-03	.2627E-03	.2751E-03	.2763E-03	.2763E-03	.2763E-03
PARTICULATE	I135	.6837E-02	.7612E-02	.8473E-02	.8906E-02	.9160E-02	.9160E-02

TOTAL DOSE FOR 30 DAYS .2529E+02

t b/r/l/c  
Dose



INPUT I:\NSL\MSA\CTRLROOM\HY9702.FOR  
OUTPUT I:\NSL\MSA\CTRLROOM\HY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT.

CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4200E+04

FILTERED INLEAKAGE(CFM) .1200E+04


UNFILTERED INLEAKAGE(CFM) .3000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY DOSE(REM)

ELEMENTAL	I131	.2806E+01	.3304E+01	.4088E+01	.5694E+01	.1111E+02	.1369E+02
ELEMENTAL	I132	.2386E-01	.2728E-01	.3164E-01	.3519E-01	.3560E-01	.3560E-01
ELEMENTAL	I133	.9472E+00	.1112E+01	.1365E+01	.1834E+01	.2564E+01	.2570E+01
ELEMENTAL	I134	.5820E-02	.6411E-02	.6945E-02	.7093E-02	.7094E-02	.7094E-02
ELEMENTAL	I135	.1569E+00	.1827E+00	.2206E+00	.2757E+00	.3082E+00	.3082E+00
ORGANIC	I131	.4185E+00	.9017E+00	.1663E+01	.3222E+01	.7376E+01	.8937E+01
ORGANIC	I132	.3383E-02	.6708E-02	.1094E-01	.1439E-01	.1479E-01	.1479E-01
ORGANIC	I133	.1405E+00	.3002E+00	.5465E+00	.1001E+01	.1631E+01	.1634E+01
ORGANIC	I134	.7613E-03	.1335E-02	.1854E-02	.1998E-02	.1999E-02	.1999E-02
ORGANIC	I135	.2299E-01	.4812E-01	.8492E-01	.1384E+00	.1690E+00	.1690E+00
PARTICULATE	I131	.1281E+00	.1435E+00	.1621E+00	.1786E+00	.2358E+00	.2638E+00
PARTICULATE	I132	.1072E-02	.1179E-02	.1283E-02	.1320E-02	.1324E-02	.1324E-02
PARTICULATE	I133	.4315E-01	.4827E-01	.5428E-01	.5910E-01	.6669E-01	.6675E-01
PARTICULATE	I134	.2549E-03	.2735E-03	.2864E-03	.2880E-03	.2880E-03	.2880E-03
PARTICULATE	I135	.7119E-02	.7926E-02	.8825E-02	.9393E-02	.9725E-02	.9725E-02

TOTAL DOSE FOR 30 DAYS .2771E+02

7/21/97  
mpm



INPUT I:\NSL\MSA\CTRLROOM\HY9702.FOR

OUTPUT I:\NSL\MSA\CTRLROOM\HY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT.

CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4200E+04

FILTERED INLEAKAGE(CFM) .1200E+04


UNFILTERED INLEAKAGE(CFM) .4000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY DOSE(REM)

ELEMENTAL	I131	.2898E+01	.3411E-01	.4223E+01	.6004E+01	.1201E+02	.1488E+02
ELEMENTAL	I132	.2464E-01	.2817E-01	.3268E-01	.3662E-01	.3708E-01	.3708E-01
ELEMENTAL	I133	.9780E+00	.1148E+01	.1410E+01	.1930E+01	.2740E+01	.2746E+01
ELEMENTAL	I134	.6009E-02	.6620E-02	.7172E-02	.7337E-02	.7338E-02	.7338E-02
ELEMENTAL	I135	.1620E+00	.1887E+00	.2279E+00	.2890E+00	.3250E+00	.3250E+00
ORGANIC	I131	.4321E+00	.9310E+00	.1719E+01	.3449E+01	.8055E+01	.9786E+01
ORGANIC	I132	.3493E-02	.6927E-02	.1131E-01	.1513E-01	.1557E-01	.1557E-01
ORGANIC	I133	.1451E+00	.3100E+00	.5649E+00	.1069E+01	.1767E+01	.1771E+01
ORGANIC	I134	.7861E-03	.1379E-02	.1916E-02	.2075E-02	.2076E-02	.2076E-02
ORGANIC	I135	.2374E-01	.4968E-01	.8777E-01	.1471E+00	.1811E+00	.1811E+00
PARTICULATE	I131	.1331E+00	.1492E+00	.1686E+00	.1889E+00	.2596E+00	.2943E+00
PARTICULATE	I132	.1114E-02	.1225E-02	.1334E-02	.1379E-02	.1384E-02	.1384E-02
PARTICULATE	I133	.4485E-01	.5018E-01	.5644E-01	.6239E-01	.7178E-01	.7186E-01
PARTICULATE	I134	.2649E-03	.2843E-03	.2978E-03	.2997E-03	.2997E-03	.2997E-03
PARTICULATE	I135	.7400E-02	.8239E-02	.9176E-02	.9878E-02	.1029E-01	.1029E-01

TOTAL DOSE FOR 30 DAYS .3013E+02

tb/21/8  
MHD



INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR

OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT,

CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4200E+04

FILTERED INLEAKAGE(CFM) .1200E+04


UNFILTERED INLEAKAGE(CFM) .5000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY  
DOSE(REM)

ELEMENTAL	I131	.2989E+01	.3519E+01	.4358E+01	.6313E+01	.1291E+02	.1605E+02
ELEMENTAL	I132	.2541E-01	.2906E-01	.3372E-01	.3804E-01	.3854E-01	.3854E-01
ELEMENTAL	I133	.1009E+01	.1184E+01	.1455E+01	.2026E+01	.2915E+01	.2922E+01
ELEMENTAL	I134	.6198E-02	.6828E-02	.7399E-02	.7579E-02	.7580E-02	.7580E-02
ELEMENTAL	I135	.1671E+00	.1946E+00	.2352E+00	.3023E+00	.3417E+00	.3417E+00
ORGANIC	I131	.4457E+00	.9603E+00	.1775E+01	.3674E+01	.8732E+C1	.1063E+02
ORGANIC	I132	.3603E-02	.7145E-02	.1167E-01	.1587E-01	.1635E-01	.1635E-01
ORGANIC	I133	.1497E+00	.3197E+00	.5833E+00	.1137E+01	.1903E+C1	.1908E+01
ORGANIC	I134	.8108E-03	.1422E-02	.1977E-02	.2152E-02	.2153E-02	.2153E-02
ORGANIC	I135	.2449E-01	.5125E-01	.9062E-01	.1558E+00	.1931E+00	.1931E+00
PARTICULATE	I131	.1381E+00	.1549E+00	.1750E+00	.1993E-00	.2833E+00	.3246E+00
PARTICULATE	I132	.1156E-02	.1272E-02	.1384E-02	.1438E-02	.1445E-02	.1445E-02
PARTICULATE	I133	.4655E-01	.5208E-01	.5860E-01	.6568E-01	.7685E-01	.7694E-01
PARTICULATE	I134	.2750E-03	.2951E-03	.3091E-03	.3113E-03	.3114E-03	.3114E-03
PARTICULATE	I135	.7680E-02	.8551E-02	.9526E-02	.1036E-01	.1085E-01	.1085E-01

TOTAL DOSE FOR 30 DAYS .3253E+02

3/11/97  
R.P.W.



INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR  
 OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT.

CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4100E+04

FILTERED INLEAKAGE(CFM) .1300E+04


UNFILTERED INLEAKAGE(CFM) .0000E+00

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY DOSE(REM)

ELEMENTAL	I131	.2576E+01	.3033E+01	.3748E+01	.4913E+01	.8842E+01	.1072E+02
ELEMENTAL	I132	.2190E-01	.2505E-01	.2902E-01	.3160E-01	.3190E-01	.3190E-01
ELEMENTAL	I133	.8695E+00	.1020E+01	.1252E+01	.1592E+01	.2121E+01	.2126E+01
ELEMENTAL	I134	.5342E-02	.5885E-02	.6373E-02	.6481E-02	.6482E-02	.6482E-02
ELEMENTAL	I135	.1440E+00	.1678E+00	.2023E+00	.2423E+00	.2658E+00	.2658E+00
ORGANIC	I131	.3842E+00	.8277E+00	.1522E+01	.2653E+01	.5668E+01	.6800E+01
ORGANIC	I132	.3106E-02	.6158E-02	.1002E-01	.1252E-01	.1281E-01	.1281E-01
ORGANIC	I133	.1290E+00	.2756E+00	.5001E+00	.8301E+00	.1287E+01	.1290E+01
ORGANIC	I134	.6989E-03	.1226E-02	.1700E-02	.1805E-02	.1805E-02	.1805E-02
ORGANIC	I135	.2111E-01	.4417E-01	.7772E-01	.1166E+00	.1388E+00	.1388E+00
PARTICULATE	I131	.1133E+00	.1270E+00	.1432E+00	.1484E+00	.1662E+00	.1749E+00
PARTICULATE	I132	.9482E-03	.1043E-02	.1134E-02	.1146E-02	.1147E-02	.1147E-02
PARTICULATE	I133	.3818E-01	.4271E-01	.4797E-01	.4947E-01	.5183E-01	.5185E-01
PARTICULATE	I134	.2255E-03	.2420E-03	.2533E-03	.2538E-03	.2538E-03	.2538E-03
PARTICULATE	I135	.6299E-02	.7013E-02	.7800E-02	.7976E-02	.8080E-02	.8080E-02

TOTAL DOSE FOR 30 DAYS .2163E+02

4/12/98  
Dewey



INPUT I:\NSL\MSA\CTRL\ROOM\THY9702.FOR  
OUTPUT I:\NSL\MSA\CTRL ROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT, CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4100E+04

FILTERED INLEAKAGE(CFM) .1300E+04


UNFILTERED INLEAKAGE(CFM) .1000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY DOSE(REM)

ELEMENTAL	I131	.2668E+01	.3142E+01	.3884E+01	.5226E+01	.9751E+01	.1191E+02
ELEMENTAL	I132	.2269E-01	.2594E-01	.3007E-01	.3304E-01	.3338E-01	.3338E-01
ELEMENTAL	I133	.9007E+00	.1057E+01	.1297E+01	.1689E+01	.2299E+01	.2304E+01
ELEMENTAL	I134	.5534E-02	.6096E-02	.6603E-02	.6727E-02	.6727E-02	.6727E-02
ELEMENTAL	I135	.1492E+00	.1738E+00	.2097E+00	.2557E+00	.2828E+00	.2828E+00
ORGANIC	I131	.3979E+00	.8574E+00	.1578E+01	.2882E+01	.6353E+01	.7657E+01
ORGANIC	I132	.3217E-02	.6379E-02	.1039E-01	.1327E-01	.1360E-01	.1360E-01
ORGANIC	I133	.1336E+00	.2855E+00	.5187E+00	.8988E+00	.1425E+01	.1428E+01
ORGANIC	I134	.7239E-03	.1270E-02	.1762E-02	.1882E-02	.1883E-02	.1883E-02
ORGANIC	I135	.2186E-01	.4575E-01	.8061E-01	.1253E+00	.1509E+00	.1509E+00
PARTICULATE	I131	.1184E+00	.1327E+00	.1498E+00	.1588E+00	.1903E+00	.2057E+00
PARTICULATE	I132	.9909E-03	.1090E-02	.1186E-02	.1206E-02	.1208E-02	.1208E-02
PARTICULATE	I133	.3990E-01	.4464E-01	.5015E-01	.5280E-01	.5697E-01	.5701E-01
PARTICULATE	I134	.2357E-03	.2529E-03	.2648E-03	.2656E-03	.2657E-03	.2657E-03
PARTICULATE	I135	.6583E-02	.7329E-02	.8155E-02	.8467E-02	.8649E-02	.8649E-02

TOTAL DOSE FOR 30 DAYS .2406E+02

3/12/97  
DMM



INPUT I:\NSLIMSA\CTRLROOM\THY9702.FOR

OUTPUT I:\NSLIMSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT,

CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4100E+04

FILTERED INLEAKAGE(CFM) .1300E+04


UNFILTERED INLEAKAGE(CFM) .2000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY DOSE(REM)

ELEMENTAL	I131	.2760E+01	.3250E+01	.4020E+01	.5538E+01	.1066E+02	.1310E+02
ELEMENTAL	I132	.2347E-01	.2684E-01	.3112E-01	.3448E-01	.3487E-01	.3487E-01
ELEMENTAL	I133	.9317E+00	.1093E+01	.1343E+01	.1785E+01	.2476E+01	.2481E+01
ELEMENTAL	I134	.5724E-02	.6306E-02	.6831E-02	.6971E-02	.6972E-02	.6972E-02
ELEMENTAL	I135	.1543E+00	.1797E+00	.2170E+00	.2691E+00	.2997E+00	.2997E+00
ORGANIC	I131	.4116E+00	.8869E+00	.1635E+01	.3109E+01	.7036E+01	.8511E+01
ORGANIC	I132	.3328E-02	.6599E-02	.1076E-01	.1402E-01	.1439E-01	.1439E-01
ORGANIC	I133	.1382E+00	.2953E+00	.5372E+00	.9672E+00	.1562E+01	.1566E+01
ORGANIC	I134	.7488E-03	.1214E-02	.1824E-02	.1960E-02	.1960E-02	.1960E-02
ORGANIC	I135	.2262E-01	.4733E-01	.8348E-01	.1341E+00	.1630E+00	.1630E+00
PARTICULATE	I131	.1235E+00	.1384E+00	.1563E+00	.1693E+00	.2142E+00	.2363E+00
PARTICULATE	I132	.1033E-02	.1137E-02	.1237E-02	.1266E-02	.1269E-02	.1269E-02
PARTICULATE	I133	.4161E-01	.4655E-01	.5233E-01	.5612E-01	.6209E-01	.6215E-01
PARTICULATE	I134	.2458E-03	.2638E-03	.2762E-03	.2774E-03	.2774E-03	.2774E-03
PARTICULATE	I135	.6865E-02	.7644E-02	.8508E-02	.8955E-02	.9216E-02	.9216E-02

TOTAL DOSE FOR 30 DAYS .2649E+02

LB/21/93  
MSW



INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR

OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT,

CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4100E+04

FILTERED INLEAKAGE(CFM) .1300E+04


UNFILTERED INLEAKAGE(CFM) .3000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY  
DOSE(REM)

ELEMENTAL	I131	.2852E+01	.3358E+01	.4156E+01	.5849E+01	.1156E+02	.1429E+02
ELEMENTAL	I132	.2425E-01	.2773E-01	.3216E-01	.3591E-01	.3634E-01	.3634E-01
ELEMENTAL	I133	.9626E+00	.1130E+01	.1388E+01	.1882E+01	.2652E+01	.2658E+01
ELEMENTAL	I134	.5914E-02	.6515E-02	.7059E-02	.7215E-02	.7216E-02	.7216E-02
ELEMENTAL	I135	.1594E+00	.1857E+00	.2243E+00	.2824E+00	.3166E+00	.3166E+00
ORGANIC	I131	.4253E+00	.9164E+00	.1691E+01	.3336E+01	.7716E+01	.9362E+01
ORGANIC	I132	.3438E-02	.6818E-02	.1112E-01	.1476E-01	.1518E-01	.1518E-01
ORGANIC	I133	.1428E+00	.3051E+00	.5557E+00	.1035E+01	.1699E+01	.1703E+01
ORGANIC	I134	.7737E-03	.1357E-02	.1885E-02	.2037E-02	.2038E-02	.2038E-02
ORGANIC	I135	.2337E-01	.4890E-01	.8635E-01	.1428E+00	.1751E+00	.1751E+00
PARTICULATE	I131	.1286E+00	.1441E+00	.1627E+00	.1796E+00	.2382E+00	.2669E+00
PARTICULATE	I132	.1076E-02	.1183E-02	.1288E-02	.1325E-02	.1330E-02	.1330E-02
PARTICULATE	I133	.4332E-01	.4847E-01	.5450E-01	.5943E-01	.6720E-01	.6727E-01
PARTICULATE	I134	.2559E-03	.2746E-03	.2876E-03	.2892E-03	.2892E-03	.2892E-03
PARTICULATE	I135	.7147E-02	.7957E-02	.8860E-02	.9441E-02	.9781E-02	.9781E-02

TOTAL DOSE FOR 30 DAYS .2891E+02

3/12/97  
RDR



INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR  
OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT. CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4100E+04

FILTERED INLEAKAGE(CFM) .1300E+04


UNFILTERED INLEAKAGE(CFM) .4000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY  
DOSE(REM)

ELEMENTAL	I131	.2943E+01	.3465E+01	.4291E+01	.6159E+01	.1246E+02	.1547E+02
ELEMENTAL	I132	.2502E-01	.2862E-01	.3320E-01	.3733E-01	.3781E-01	.3781E-01
ELEMENTAL	I133	.9934E+00	.1166E+01	.1433E+01	.1978E+01	.2827E+01	.2834E+01
ELEMENTAL	I134	.6104E-02	.6724E-02	.7286E-02	.7458E-02	.7459E-02	.7459E-02
ELEMENTAL	I135	.1645E+00	.1917E+00	.2315E+00	.2957E+00	.3334E+00	.3334E+00
ORGANIC	I131	.4389E+00	.9457E+00	.1747E+01	.3561E+01	.8394E+01	.1021E+02
ORGANIC	I132	.3548E-02	.7036E-02	.1149E-01	.1550E-01	.1596E-01	.1596E-01
ORGANIC	I133	.1474E+00	.3149E+00	.5741E+00	.1103E+01	.1835E+01	.1840E+01
ORGANIC	I134	.7984E-03	.1401E-02	.1946E-02	.2114E-02	.2115E-02	.2115E-02
ORGANIC	I135	.2411E-01	.5047E-01	.8920E-01	.1515E+00	.1871E+00	.1871E+00
PARTICULATE	I131	.1336E+00	.1498E+00	.1692E+00	.1900E+00	.2620E+00	.2973E+00
PARTICULATE	I132	.1118E-02	.1230E-02	.1339E-02	.1385E-02	.1390E-02	.1390E-02
PARTICULATE	I133	.4502E-01	.5037E-01	.5666E-01	.6272E-01	.7228E-01	.7237E-01
PARTICULATE	I134	.2659E-03	.2854E 03	.2989E-03	.3009E-03	.3009E-03	.3009E-03
PARTICULATE	I135	.7428E-02	.8270E-02	.9211E-02	.9926E-02	.1034E-01	.1034E-01

TOTAL DOSE FOR 30 DAYS .3131E+02

LB/2/16  
mdu



INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR

OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT, CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4100E+04

FILTERED INLEAKAGE(CFM) .1300E+04


UNFILTERED INLEAKAGE(CFM) .5000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY DOSE(REM)

ELEMENTAL	I131	.3034E+01	.3572E+01	.4425E+01	.6467E+01	.1335E+02	.1664E+02
ELEMENTAL	I132	.2580E-01	.2950E-01	.3424E-01	.3875E-01	.3927E-01	.3927E-01
ELEMENTAL	I133	.1024E+01	.1202E+01	.1478E+01	.2073E+01	.3002E+01	.3010E+01
ELEMENTAL	I134	.6292E-02	.6931E-02	.7511E-02	.7700E-02	.7701E-02	.7701E-02
ELEMENTAL	I135	.1696E+00	.1976E+00	.2388E+00	.3089E+00	.3501E+00	.3501E+00
ORGANIC	I131	.4525E+00	.9749E+00	.1803E+01	.3786E+01	.9069E+01	.1105E+02
ORGANIC	I132	.3658E-02	.7253E-02	.1185E-01	.1624E-01	.1674E-01	.1674E-01
ORGANIC	I133	.1519E+00	.3246E+00	.5924E+00	.1171E+01	.1971E+01	.1976E+01
ORGANIC	I134	.8231E-03	.1444E-02	.2007E-02	.2190E-02	.2191E-02	.2191E-02
ORGANIC	I135	.2486E-01	.5202E-01	.9204E-01	.1601E+00	.1990E+00	.1990E+00
PARTICULATE	I131	.1386E+00	.1554E+00	.1756E+00	.2003E+00	.2857E+00	.3276E+00
PARTICULATE	I132	.1160E-02	.1276E-02	.1390E-02	.1444E-02	.1451E-02	.1451E-02
PARTICULATE	I133	.4672E-01	.5227E-01	.5881E-01	.6601E-01	.7735E-01	.7745E-01
PARTICULATE	I134	.2760E-03	.2961E-03	.3102E-03	.3125E-03	.3125E-03	.3125E-03
PARTICULATE	I135	.7708E-02	.8582E-02	.9561E-02	.1041E-01	.1091E-01	.1091E-01

TOTAL DOSE FOR 30 DAYS .3371E+02

X 3/21/97  
2004



INPUT I:\NSL\MSA\CTRLROOM\HY9702.FOR

OUTPUT I:\NSL\MSA\CTRLROOM\HY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT.

CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4000E+04

FILTERED INLEAKAGE(CFM) .1400E+04


UNFILTERED INLEAKAGE(CFM) .0000E+00

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY DOSE(REM)

ELEMENTAL	I131	.2622E+01	.3087E+01	.3816E+01	.5070E+01	.9297E+01	.1132E+02
ELEMENTAL	I132	.2230E-01	.2550E-01	.2955E-01	.3232E-01	.3264E-01	.3264E-01
ELEMENTAL	I133	.8851E+00	.1039E+01	.1274E+01	.1640E+01	.2210E+01	.2215E+01
ELEMENTAL	I134	.5438E-02	.5991E-02	.6488E-02	.6604E-02	.6605E-02	.6605E-02
ELEMENTAL	I135	.1466E+00	.1708E+00	.2060E+00	.2490E+00	.2743E+00	.2743E+00
ORGANIC	I131	.3911E+00	.8426E+00	.1550E+01	.2768E+01	.6011E+01	.7229E+01
ORGANIC	I132	.3162E-02	.6269E-02	.1020E-01	.1290E-01	.1321E-01	.1321E-01
ORGANIC	I133	.1313E+00	.2805E+00	.5094E+00	.8645E+00	.1356E+01	.1359E+01
ORGANIC	I134	.7114E-03	.1248E-02	.1731E-02	.1843E-02	.1844E-02	.1844E-02
ORGANIC	I135	.2148E-01	.4496E-01	.7917E-01	.1210E+00	.1449E+00	.1449E+00
PARTICULATE	I131	.1138E+00	.1276E+00	.1439E+00	.1494E+00	.1686E+00	.1780E+00
PARTICULATE	I132	.9525E-03	.1048E-02	.1139E-02	.1152E-02	.1153E-02	.1153E-02
PARTICULATE	I133	.3835E-01	.4290E-01	.4819E-01	.4980E-01	.5234E-01	.5237E-01
PARTICULATE	I134	.2265E-03	.2431E-03	.2545E-03	.2550E-03	.2550E-03	.2550E-03
PARTICULATE	I135	.6327E-02	.7044E-02	.7835E-02	.8026E-02	.8137E-02	.8137E-02

TOTAL DOSE FOR 30 DAYS .2283E+02

3/12/97  
HJM



INPUT I:\NSL\MSA\CTRLROOMIHY9702.FOR  
OUTPUT I:\NSL\MSA\CTRLROOMIHY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT, CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4000E+04

FILTERED INLEAKAGE(CFM) .1400E+04


UNFILTERED INLEAKAGE(CFM) .1000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY DOSE(REM)

ELEMENTAL	I131	.2714E+01	.3196E+01	.3952E+01	.5382E+01	.1020E+02	.1251E+02
ELEMENTAL	I132	.2308E-01	.2639E-01	.3060E-01	.3376E-01	.3413E-01	.3413E-01
ELEMENTAL	I133	.9162E+00	.1075E+01	.1320E+01	.1737E+01	.2387E+01	.2393E+01
ELEMENTAL	I134	.5629E-02	.6201E-02	.6717E-02	.6849E-02	.6850E-02	.6850E-02
ELEMENTAL	I135	.1517E+00	.1768E+00	.2133E+00	.2624E+00	.2913E+00	.2913E+00
ORGANIC	I131	.4048E+00	.8722E+00	.1607E+01	.2995E+01	.6695E+01	.8085E+01
ORGANIC	I132	.3273E-02	.6489E-02	.1057E-01	.1365E-01	.1400E-01	.1400E-01
ORGANIC	I133	.1359E+00	.2904E+00	.5280E+00	.9330E+00	.1494E+01	.1497E+01
ORGANIC	I134	.7364E-03	.1292E-02	.1793E-02	.1921E-02	.1922E-02	.1922E-02
ORGANIC	I135	.2224E-01	.4654E-01	.8205E-01	.1297E+00	.1570E+00	.1570E+00
PARTICULATE	I131	.1189E+00	.1333E+00	.1504E+00	.1599E+00	.1927E+00	.2087E+00
PARTICULATE	I132	.9952E-03	.1095E-02	.1191E-02	.1212E-02	.1214E-02	.1214E-02
PARTICULATE	I133	.4007E-01	.4483E-01	.5037E-01	.5313E-01	.5748E-01	.5752E-01
PARTICULATE	I134	.2367E-03	.2540E-03	.2659E-03	.2668E-03	.2668E-03	.2668E-03
PARTICULATE	I135	.6611E-02	.7360E-02	.8190E-02	.8515E-02	.8706E-02	.8706E-02

TOTAL DOSE FOR 30 DAYS .2526E+02

3/12/97  
JRW



INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR  
OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT, CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4000E+04

FILTERED INLEAKAGE(CFM) .1400E+04


UN:FILTERED INLEAKAGE(CFM) .2000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY  
DOSE(REM)

ELEMENTAL	I131	.2806E+01	.3304E+01	.4088E+01	.5694E+01	.1111E+02	.1369E+02
ELEMENTAL	I132	.2386E-01	.2728E-01	.3164E-01	.3519E-01	.3560E-01	.3560E-01
ELEMENTAL	I133	.9472E+00	.1112E+01	.1365E+01	.1834E+01	.2564E+01	.2570E+01
ELEMENTAL	I134	.5820E-02	.6411E-02	.6945E-02	.7093E-02	.7094E-02	.7094E-02
ELEMENTAL	I135	.1569E+00	.1827E+00	.2206E+00	.2757E+00	.3082E+00	.3082E+00
ORGANIC	I131	.4185E+00	.9017E+00	.1663E+01	.3222E+01	.7376E+01	.8937E+01
ORGANIC	I132	.3383E-02	.6708E-02	.1094E-01	.1439E-01	.1479E-01	.1479E-01
ORGANIC	I133	.1405E+00	.3002E+00	.5465E+00	.1001E+01	.1631E+01	.1634E+01
ORGANIC	I134	.7613E-03	.1335E-02	.1854E-02	.1998E-02	.1999E-02	.1999E-02
ORGANIC	I135	.2299E-01	.4812E-01	.8492E-01	.1384E+00	.1690E+00	.1690E+00
PARTICULATE	I131	.1240E+00	.1390E+00	.1569E+00	.1703E+00	.2136E+00	.2394E+00
PARTICULATE	I132	.1038E-02	.1141E-02	.1242E-02	.1272E-02	.1275E-02	.1275E-02
PARTICULATE	I133	.4179E-01	.4675E-01	.5254E-01	.5645E-01	.6261E-01	.6266E-01
PARTICULATE	I134	.2468E-03	.2649E-03	.2773E-03	.2786E-03	.2786E-03	.2786E-03
PARTICULATE	I135	.6894E-02	.7675E-02	.8543E-02	.9001E-02	.9273E-02	.9273E-02

TOTAL DOSE FOR 30 DAYS .2769E+02

3/12/97  
KPA



INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR

OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT, CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4000E+04

FILTERED INLEAKAGE(CFM) .1400E+04


UNFILTERED INLEAKAGE(CFM) .3000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY DOSE(REM)

ELEMENTAL	I131	.2898E+01	.3411E+01	.4223E+01	.6004E+01	.1201E+02	.1488E+02
ELEMENTAL	I132	.2464E-01	.2817E-01	.3268E-01	.3662E-01	.3708E-01	.3708E-01
ELEMENTAL	I133	.9780E+00	.1148E+01	.1410E+01	.1930E+01	.2740E+01	.2746E+01
ELEMENTAL	I134	.6009E-02	.6620E-02	.7172E-02	.7337E-02	.7338E-02	.7338E-02
ELEMENTAL	I135	.1620E+00	.1887E+00	.2279E+00	.2890E+00	.3250E+00	.3250E+00
ORGANIC	I131	.4321E+00	.9310E+00	.1719E+01	.3449E+01	.8055E+01	.9786E+01
ORGANIC	I132	.3493E-02	.6927E-02	.1131E-01	.1513E-01	.1557E-01	.1557E-01
ORGANIC	I133	.1451E+00	.3100E+00	.5649E+00	.1069E+01	.1767E+01	.1771E+01
ORGANIC	I134	.7861E-03	.1379E-02	.1916E-02	.2075E-02	.2076E-02	.2076E-02
ORGANIC	I135	.2374E-01	.4968E-01	.8777E-01	.1471E+00	.1811E+00	.1811E+00
PARTICULATE	I131	.1291E+00	.1447E+00	.1634E+00	.1807E+00	.2405E+00	.2699E+00
PARTICULATE	I132	.1080E-02	.1188E-02	.1293E-02	.1331E-02	.1336E-02	.1336E-02
PARTICULATE	I133	.4349E-01	.4866E-01	.5471E-01	.5976E-01	.6771E-01	.6778E-01
PARTICULATE	I134	.2569E-03	.2757E-03	.2887E-03	.2903E-03	.2903E-03	.2903E-03
PARTICULATE	I135	.7175E-02	.7989E-02	.8896E-02	.9490E-02	.9838E-02	.9838E-02

TOTAL DOSE FOR 30 DAYS .3010E+02

3/21/97  
KJW



INPUT I:\NSL\MSA\CTRLROOM\HY9702.FOR

OUTPUT I:\NSL\MSA\CTRLROOM\HY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT,

CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4000E+04

FILTERED INLEAKAGE(CFM) .1400E+04


UNFILTERED INLEAKAGE(CFM) .4000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY  
DOSE(REM)

ELEMENTAL	I131	.2989E+01	.3519E+01	.4358E+01	.6313E+01	.1291E+02	.1605E+02
ELEMENTAL	I132	.2541E-01	.2906E-01	.3372E-01	.3804E-01	.3854E-01	.3854E-01
ELEMENTAL	I133	.1009E+01	.1184E+01	.1455E+01	.2026E+01	.2915E+01	.2922E+01
ELEMENTAL	I134	.6198E-02	.6828E-02	.7399E-02	.7579E-02	.7580E-02	.7580E-02
ELEMENTAL	I135	.1671E+00	.1946E+00	.2352E+00	.3023E+00	.3417E+00	.3417E+00
ORGANIC	I131	.4457E+00	.9603E+00	.1775E+01	.3674E+01	.8732E+01	.1063E+02
ORGANIC	I132	.3603E-02	.7145E-02	.1167E-01	.1587E-01	.1635E-01	.1635E-01
ORGANIC	I133	.1497E+00	.3197E+00	.5833E+00	.1137E+01	.1903E+01	.1908E+01
ORGANIC	I134	.8108E-03	.1422E-02	.1977E-02	.2152E-02	.2153E-02	.2153E-02
ORGANIC	I135	.2449E-01	.5125E-01	.9062E-01	.1558E+00	.1931E+00	.1931E+00
PARTICULATE	I131	.1341E+00	.1503E+00	.1698E+00	.1910E+00	.2644E+00	.3003E+00
PARTICULATE	I132	.1122E-02	.1235E-02	.1344E-02	.1391E-02	.1396E-02	.1396E-02
PARTICULATE	I133	.4519E-01	.5056E-01	.5687E-01	.6305E-01	.7279E-01	.7288E-01
PARTICULATE	I134	.2669E-03	.2865E-03	.3000E-03	.3020E-03	.3020E-03	.3020E-03
PARTICULATE	I135	.7456E-02	.8301E-02	.9246E-02	.9974E-02	.1040E-01	.1040E-01

TOTAL DOSE FOR 30 DAYS .3250E+02

T-1/2/97  
2/24



INPUT I:\NSL\MSAICTRLROOM\THY9702.FOR

OUTPUT I:\NSL\MSAICTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT,

CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4000E+04

FILTERED INLEAKAGE(CFM) .1400E+04

UNFILTERED INLEAKAGE(CFM) .5000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY  
DOSE(REM)

ELEMENTAL	I131	.3079E+01	.3625E+01	.4492E+01	.6621E+01	.1380E+02	.1723E+02
ELEMENTAL	I132	.2618E-01	.2994E-01	.3475E-01	.3946E-01	.4000E-01	.4000E-01
ELEMENTAL	I133	.1039E+01	.1220E+01	.1500E+01	.2121E+01	.3089E+01	.3097E+01
ELEMENTAL	I134	.6386E-02	.7035E-02	.7624E-02	.7821E-02	.7822E-02	.7822E-02
ELEMENTAL	I135	.1721E+00	.2005E+00	.2424E+00	.3155E+00	.3584E+00	.3584E+00
ORGANIC	I131	.4592E+00	.9895E+00	.1831E+01	.3898E+01	.9405E+01	.1147E+02
ORGANIC	I132	.3713E-02	.7361E-02	.1204E-01	.1661E-01	.1713E-01	.1713E-01
ORGANIC	I133	.1542E+00	.3294E+00	.6016E+00	.1205E+01	.2039E+01	.2044E+01
ORGANIC	I134	.8354E-03	.1465E-02	.2038E-02	.2229E-02	.2230E-02	.2230E-02
ORGANIC	I135	.2523E-01	.5280E-01	.9346E-01	.1644E+00	.2050E+00	.2050E+00
PARTICULATE	I131	.1391E+00	.1560E+00	.1763E+00	.2013E+00	.2881E+00	.3306E+00
PARTICULATE	I132	.1165E-02	.1281E-02	.1395E-02	.1450E-02	.1457E-02	.1457E-02
PARTICULATE	I133	.4689E-01	.5246E-01	.5903E-01	.6633E-01	.7786E-01	.7796E-01
PARTICULATE	I134	.2770E-03	.2972E-03	.3113E-03	.3137E-03	.3137E-03	.3137E-03
PARTICULATE	I135	.7736E-02	.8613E-02	.9596E-02	.1046E-01	.1096E-01	.1096E-01

TOTAL DOSE FOR 30 DAYS .3489E+02

2/2/97  
3/12/97

INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR

OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT, CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .3900E+04

FILTERED INLEAKAGE(CFM) .1500E+04


UNFILTERED INLEAKAGE(CFM) .0000E+00

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY DOSE(REM)

ELEMENTAL	I131	.2668E+01	.3142E+01	.3884E+01	.5226E+01	.9751E+01	.1191E+02
ELEMENTAL	I132	.2269E-01	.2594E-01	.3007E-01	.3304E-01	.3338E-01	.3338E-01
ELEMENTAL	I133	.9007E+00	.1057E+01	.1297E+01	.1689E+01	.2299E+01	.2304E+01
ELEMENTAL	I134	.5534E-02	.6096E-02	.6603E-02	.6727E-02	.6727E-02	.6727E-02
ELEMENTAL	I135	.1492E+00	.1738E+00	.2097E+00	.2557E+00	.2828E+00	.2828E+00
ORGANIC	I131	.3979E+00	.8574E+00	.1578E+01	.2882E+01	.6353E+01	.7657E+01
ORGANIC	I132	.3217E-02	.6379E-02	.1039E-01	.1327E-01	.1360E-01	.1360E-01
ORGANIC	I133	.1336E+00	.2855E+00	.5187E+00	.8988E+00	.1425E+01	.1428E+01
ORGANIC	I134	.7239E-03	.1270E-02	.1762E-02	.1882E-02	.1883E-02	.1883E-02
ORGANIC	I135	.2186E-01	.4575E-01	.8061E-01	.1253E+00	.1509E+00	.1509E+00
PARTICULATE	I131	.1143E+00	.1282E+00	.1445E+00	.1505E+00	.1710E+00	.1811E+00
PARTICULATE	I132	.9567E-03	.1052E-02	.1144E-02	.1158E-02	.1159E-02	.1159E-02
PARTICULATE	I133	.3852E-01	.4310E-01	.4840E-01	.5013E-01	.5286E-01	.5288E-01
PARTICULATE	I134	.2275E-03	.2442E-03	.2556E-03	.2562E-03	.2562E-03	.2562E-03
PARTICULATE	I135	.6356E-02	.7076E-02	.7871E-02	.8075E-02	.8194E-02	.8194E-02

TOTAL DOSE FOR 30 DAYS .2403E+02

7/12/93  
JRW



INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR

OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT,

CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .3900E+04

FILTERED INLEAKAGE(CFM) .1500E+04


UNFILTERED INLEAKAGE(CFM) .1000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY  
DOSE(REM)

ELEMENTAL	I131	.2760E+01	.3250E+01	.4020E+01	.5538E+01	.1066E+02	.1310E+02
ELEMENTAL	I132	.2347E-01	.2684E-01	.3112E-01	.3448E-01	.3487E-01	.3487E-01
ELEMENTAL	I133	.9317E+00	.1093E+01	.1343E+01	.1785E+01	.2476E+01	.2481E+01
ELEMENTAL	I134	.5724E-02	.6306E-02	.6831E-02	.6971E-02	.6972E-02	.6972E-02
ELEMENTAL	I135	.1543E+00	.1797E+00	.2170E+00	.2691E+00	.2997E+00	.2997E+00
ORGANIC	I131	.4116E+00	.8869E+00	.1635E+01	.3109E+01	.7036E+01	.8511E+01
ORGANIC	I132	.3328E-02	.6599E-02	.1076E-01	.1402E-01	.1439E-01	.1439E-01
ORGANIC	I133	.1382E+00	.2953E+00	.5372E+00	.9672E+00	.1562E+01	.1566E+01
ORGANIC	I134	.7488E-03	.1314E-02	.1824E-02	.1960E-02	.1960E-02	.1960E-02
ORGANIC	I135	.2262E-01	.4733E-01	.8348E-01	.1341E+00	.1630E+00	.1630E+00
PARTICULATE	I131	.1194E+00	.1339E+00	.1511E+00	.1609E+00	.1951E+00	.2118E+00
PARTICULATE	I132	.9994E-03	.1099E-02	.1196E-02	.1218E-02	.1220E-02	.1220E-02
PARTICULATE	I133	.4024E-01	.4502E-01	.5059E-01	.5346E-01	.5800E-01	.5804E-01
PARTICULATE	I134	.2377E-03	.2551E-03	.2671E-03	.2680E-03	.2680E-03	.2680E-03
PARTICULATE	I135	.6639E-02	.7392E-02	.8225E-02	.8564E-02	.8763E-02	.8763E-02

TOTAL DOSE FOR 30 DAYS .2646E+02

3/12/97  
JRC



INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR  
OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT,

CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .3900E+04

FILTERED INLEAKAGE(CFM) .1500E+04


UNFILTERED INLEAKAGE(CFM) .2000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY  
DOSE(REM)

ELEMENTAL	I131	.2852E+01	.3358E+01	.4156E+01	.5849E+01	.1156E+02	.1429E+02
ELEMENTAL	I132	.2425E-01	.2773E-01	.3216E-01	.3591E-01	.3634E-01	.3634E-01
ELEMENTAL	I133	.9626E+00	.1130E+01	.1388E+01	.1882E+01	.2652E+01	.2658E+01
ELEMENTAL	I134	.5914E-02	.6515E-02	.7059E-02	.7215E-02	.7216E-02	.7216E-02
ELEMENTAL	I135	.1594E+00	.1857E+00	.2243E+00	.2824E+00	.3166E+00	.3166E+00
ORGANIC	I131	.4253E+00	.9164E+00	.1691E+01	.3336E+01	.7716E+01	.9362E+01
ORGANIC	I132	.3438E-02	.6818E-02	.1112E-01	.1476E-01	.1518E-01	.1518E-01
ORGANIC	I133	.1428E+00	.3051E+00	.5557E+00	.1035E+01	.1699E+01	.1703E+01
ORGANIC	I134	.7737E-03	.1357E-02	.1885E-02	.2037E-02	.2038E-02	.2038E-02
ORGANIC	I135	.2337E-01	.4890E-01	.8635E-01	.1428E+00	.1751E+00	.1751E+00
PARTICULATE	I131	.1245E+00	.1396E+00	.1576E+00	.1713E+00	.2190E+00	.2424E+00
PARTICULATE	I132	.1042E-02	.1146E-02	.1247E-02	.1278E-02	.1281E-02	.1281E-02
PARTICULATE	I133	.4196E-01	.4694E-01	.5276E-01	.5678E-01	.6312E-01	.6317E-01
PARTICULATE	I134	.2478E-03	.2659E-03	.2785E-03	.2798E-03	.2798E-03	.2798E-03
PARTICULATE	I135	.6922E-02	.7707E-02	.8579E-02	.9052E-02	.9330E-02	.9330E-02

TOTAL DOSE FOR 30 DAYS .2888E+02

3/12/97  
T.L.P.



INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR

OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT, CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .3900E+04

FILTERED INLEAKAGE(CFM) .1500E+04


UNFILTERED INLEAKAGE(CFM) .3000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY DOSE(REM)

ELEMENTAL	I131	.2943E+01	.3465E+01	.4291E+01	.6159E+01	.1246E+02	.1547E+02
ELEMENTAL	I132	.2502E-01	.2862E-01	.3320E-01	.3733E-01	.3781E-01	.3781E-01
ELEMENTAL	I133	.9934E+00	.1166E+01	.1433E+01	.1978E+01	.2827E+01	.2834E+01
ELEMENTAL	I134	.6104E-02	.6724E-02	.7286E-02	.7458E-02	.7459E-02	.7459E-02
ELEMENTAL	I135	.1645E+00	.1917E+00	.2315E+00	.2957E+00	.3334E+00	.3334E+00
ORGANIC	I131	.4389E+00	.9457E+00	.1747E+01	.3561E+01	.8394E+01	.1021E+02
ORGANIC	I132	.3548E-02	.7036E-02	.1149E-01	.1550E-01	.1596E-01	.1596E-01
ORGANIC	I133	.1474E+00	.3149E+00	.5741E+00	.1103E+01	.1835E+01	.1840E+01
ORGANIC	I134	.7984E-03	.1401E-02	.1946E-02	.2114E-02	.2115E-02	.2115E-02
ORGANIC	I135	.2411E-01	.5047E-01	.8920E-01	.1515E+00	.1871E+00	.1871E+00
PARTICULATE	I131	.1296E+00	.1452E+00	.1640E+00	.1817E+00	.2429E+00	.2730E+00
PARTICULATE	I132	.1084E-02	.1193E-02	.1298E-02	.1337E-02	.1342E-02	.1342E-02
PARTICULATE	I133	.4366E-01	.4885E-01	.5493E-01	.6009E-01	.6822E-01	.6829E-01
PARTICULATE	I134	.2579E-03	.2768E-03	.2898E-03	.2915E-03	.2915E-03	.2915E-03
PARTICULATE	I135	.7203E-02	.8020E-02	.8931E-02	.9538E-02	.9894E-02	.9894E-02

TOTAL DOSE FOR 30 DAYS .3129E+02

tb/2/1/E  
2/2/97



INPUT I:\NSL\MSA\CTRLROOM\HY9702.FOR  
OUTPUT I:\NSL\MSA\CTRLROOM\HY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT.

CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .3900E+04

FILTERED INLEAKAGE(CFM) .1500E+04


UNFILTERED INLEAKAGE(CFM) .4000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY  
DOSE(REM)

ELEMENTAL	I131	.3034E+01	.3572E+01	.4425E+01	.6467E+01	.1335E+02	.1664E+02
ELEMENTAL	I132	.2580E-01	.2950E-01	.3424E-01	.3875E-01	.3927E-01	.3927E-01
ELEMENTAL	I133	.1024E+01	.1202E+01	.1478E+01	.2073E+01	.3002E+01	.3010E+01
ELEMENTAL	I134	.6292E-02	.6931E-02	.7511E-02	.7700E-02	.7701E-02	.7701E-02
ELEMENTAL	I135	.1696E+00	.1976E+00	.2388E+00	.3089E+00	.3501E+00	.3501E+00
ORGANIC	I131	.4525E+00	.9749E+00	.1803E+01	.3786E+01	.9069E+01	.1105E+02
ORGANIC	I132	.3658E-02	.7253E-02	.1185E-01	.1624E-01	.1674E-01	.1674E-01
ORGANIC	I133	.1519E+00	.3246E+00	.5924E+00	.1171E+01	.1971E+01	.1976E+01
ORGANIC	I134	.8231E-03	.1444E-02	.2007E-02	.2190E-02	.2191E-02	.2191E-02
ORGANIC	I135	.2486E-01	.5202E-01	.9204E-01	.1601E+00	.1990E+00	.1990E+00
PARTICULATE	I131	.1346E+00	.1509E+00	.1705E+00	.1920E+00	.2607E+00	.3034E+00
PARTICULATE	I132	.1127E-02	.1239E-02	.1349E-02	.1397E-02	.1402E-02	.1402E-02
PARTICULATE	I133	.4536E-01	.5075E-01	.5709E-01	.6338E-01	.7330E-01	.7338E-01
PARTICULATE	I134	.2679E-03	.2876E-03	.3012E-03	.3032E-03	.3032E-03	.3032E-03
PARTICULATE	I135	.7484E-02	.8333E-02	.9282E-02	.1002E-01	.1046E-01	.1046E-01

TOTAL DOSE FOR 30 DAYS .3368E+02

2/21/97  
mjl



INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR  
OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT.

CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .3900E+04

FILTERED INLEAKAGE(CFM) .1500E+04


UNFILTERED INLEAKAGE(CFM) .5000E+02

ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY  
DOSE(REM)

ELEMENTAL	I131	.3125E+01	.3679E+01	.4559E+01	.6775E+01	.1424E+02	.1781E+02
ELEMENTAL	I132	.2657E-01	.3038E-01	.3527E-01	.4017E-01	.4073E-01	.4073E-01
ELEMENTAL	I133	.1055E+01	.1238E+01	.1522E+01	.2169E+01	.3176E+01	.3184E+01
ELEMENTAL	I134	.6480E-02	.7138E-02	.7737E-02	.7941E-02	.7942E-02	.7942E-02
ELEMENTAL	I135	.1747E+00	.2035E+00	.2460E+00	.3220E+00	.3667E+00	.3667E+00
ORGANIC	I131	.4660E+00	.1004E+01	.1859E+01	.4010E+01	.9741E+01	.1189E+02
ORGANIC	I132	.3767E-02	.7470E-02	.1222E-01	.1697E-01	.1752E-01	.1752E-01
ORGANIC	I133	.1565E+00	.3343E+00	.6107E+00	.1238E+01	.2107E+01	.2112E+01
ORGANIC	I134	.8477E-03	.1487E-02	.2068E-02	.2267E-02	.2268E-02	.2268E-02
ORGANIC	I135	.2560E-01	.5358E-01	.9488E-01	.1687E+00	.2109E+00	.2109E+00
PARTICULATE	I131	.1396E+00	.1565E+00	.1769E+00	.2023E+00	.2905E+00	.3337E+00
PARTICULATE	I132	.1169E-02	.1286E-02	.1400E-02	.1456E-02	.1463E-02	.1463E-02
PARTICULATE	I133	.4706E-01	.5265E-01	.5924E-01	.6666E-01	.7836E-01	.7846E-01
PARTICULATE	I134	.2780E-03	.2983E-03	.3124E-03	.3148E-03	.3148E-03	.3148E-03
PARTICULATE	I135	.7764E-02	.8644E-02	.9631E-02	.1051E-01	.1102E-01	.1102E-01

TOTAL DOSE FOR 30 DAYS .3607E+02

EB/2/15  
2/27



Calculation RD-97-02  
 Attachment 3  
 Page 1 of 1  
 March 11, 1997

INPUT I:\NSL\MSA\CTRLROOM\MSAFINAL.FOR  
 OUTPUT I:\NSL\MSA\CTRLROOM\MSAFINAL.OUT


FINAL CASE: NEW XQ, 3588.70 GPM, CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4400E+04  
 FILTERED INLEAKAGE(CFM) .1000E+04  
 UNFILTERED INLEAKAGE(CFM) .3000E+02

ISOTOPE		.5 HOUR DOSE(CFM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
ELEMENTAL	I131	.2714E+01	.3196E+01	.3952E+01	.4853E+01	.6730E+01	.7501E+01
ELEMENTAL	I132	.2308E-0	.2639E-01	.3060E-01	.3294E-01	.3310E-01	.3310E-01
ELEMENTAL	I133	.9162E+00	.1075E+01	.1320E+01	.1587E+01	.1860E+01	.1862E+01
ELEMENTAL	I134	.5629E-02	.6201E-02	.6717E-02	.6834E-02	.6834E-02	.6834E-02
ELEMENTAL	I135	.1517E+00	.1768E+00	.2133E+00	.2461E+00	.2590E+00	.2590E+00
ORGANIC	I131	.4048E+00	.8722E+00	.1607E+01	.2984E+01	.6622E+01	.7980E+01
ORGANIC	I132	.3273E-02	.6489E-02	.1057E-01	.1363E-01	.1398E-01	.1398E-01
ORGANIC	I133	.1359E+00	.2904E+00	.5280E+00	.9299E+00	.1483E+01	.1486E+01
ORGANIC	I134	.7364E-03	.1292E-02	.1793E-02	.1921E-02	.1921E-02	.1921E-02
ORGANIC	I135	.2224E-01	.4654E-01	.8205E-01	.1294E+00	.1563E+00	.1563E+00
PARTICULATE	I131	.1270E+00	.1424E+00	.1608E+00	.1698E+00	.1870E+00	.1943E+00
PARTICULATE	I132	.1063E-02	.1169E-02	.1273E-02	.1297E-02	.1299E-02	.1299E-02
PARTICULATE	I133	.4281E-01	.4789E-01	.5385E-01	.5654E-01	.5900E-01	.5901E-01
PARTICULATE	I134	.2529E-03	.2714E-03	.2842E-03	.2854E-03	.2855E-03	.2855E-03
PARTICULATE	I135	.7063E-02	.7863E-02	.8755E-02	.9088E-02	.9203E-02	.9203E-02

TOTAL DOSE FOR 30 DAYS .1956E+02

3/12/97  
 mjt



INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR

OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT,

CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4400E+04


FILTERED INLEAKAGE(CFM) .1000E+04

UNFILTERED INLEAKAGE(CFM) .3000E+02

ISOTOPE	.5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
ELEMENTAL I131	.2714E+01	.3196E+01	.3952E+01	.5382E+01	.1020E+02	.1251E+02
ELEMENTAL I132	.2308E-01	.2639E-01	.3060E-01	.3376E-01	.3413E-01	.3413E-01
ELEMENTAL I133	.9162E+00	.1075E+01	.1320E+01	.1737E+01	.2387E+01	.2393E+01
ELEMENTAL I134	.5629E-02	.6201E-02	.6717E-02	.6849E-02	.6850E-02	.6850E-02
ELEMENTAL I135	.1517E+00	.1768E+00	.2133E+00	.2624E+00	.2913E+00	.2913E+00
ORGANIC I131	.4048E+00	.8722E+00	.1607E+01	.2995E+01	.6695E+01	.8085E+01
ORGANIC I132	.3273E-02	.6489E-02	.1057E-01	.1365E-01	.1400E-01	.1400E-01
ORGANIC I133	.1359E+00	.2904E+00	.5280E+00	.9330E+00	.1494E+01	.1497E+01
ORGANIC I134	.7364E-03	.1292E-02	.1793E-02	.1921E-02	.1922E-02	.1922E-02
ORGANIC I135	.2224E-01	.4654E-01	.8205E-01	.1297E+00	.1570E+00	.1570E+00
PARTICULATE I131	.1270E+00	.1424E+00	.1608E+00	.1765E+00	.2310E+00	.2577E+00
PARTICULATE I132	.1063E-02	.1169E-02	.1273E-02	.1308E-02	.1312E-02	.1312E-02
PARTICULATE I133	.4281E-01	.4789E-01	.5385E-01	.5843E-01	.6567E-01	.6573E-01
PARTICULATE I134	.2529E-03	.2714E-03	.2842E-03	.2856E-03	.2857E-03	.2857E-03
PARTICULATE I135	.7063E-02	.7863E-02	.8755E-02	.9296E-02	.9612E-02	.9612E-02

TOTAL DOSE FOR 30 DAYS .2532E+02

t b / 21/8



INPUT I:\NSL\MSA\CTRLROOM\THY9702.FOR  
OUTPUT I:\NSL\MSA\CTRLROOM\THY9702.OUT

NRC CASE: NEW XQ, 3588, 70 GPM CONSTANT,

CORRECTED I-135

1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4400E+04


FILTERED INLEAKAGE(CFM) .1000E+04

UNFILTERED INLEAKAGE(CFM) .3000E+02

ISOTOPE	.5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
ELEMENTAL I131	.2714E+01	.3196E+01	.3952E+01	.5382E+01	.1020E+02	.1251E+02
ELEMENTAL I132	.2308E-01	.2639E-01	.3060E-01	.3376E-01	.3413E-01	.3413E-01
ELEMENTAL I133	.9162E+00	.1075E+01	.1320E+01	.1737E+01	.2387E+01	.2393E+01
ELEMENTAL I134	.5629E-02	.6201E-02	.6717E-02	.6849E-02	.6850E-02	.6850E-02
ELEMENTAL I135	.1517E+00	.1768E+00	.2133E+00	.2624E+00	.2913E+00	.2913E+00
ORGANIC I131	.4048E+00	.8722E+00	.1607E+01	.2995E+01	.6695E+01	.8085E+01
ORGANIC I132	.3273E-02	.6489E-02	.1057E-01	.1365E-01	.1400E-01	.1400E-01
ORGANIC I133	.1359E+00	.2904E+00	.5280E+00	.9330E+00	.1494E+01	.1497E+01
ORGANIC I134	.7364E-03	.1292E-02	.1793E-02	.1921E-02	.1922E-02	.1922E-02
ORGANIC I135	.2224E-01	.4654E-01	.8205E-01	.1297E+00	.1570E+00	.1570E+00
PARTICULATE I131	.1270E+00	.1424E+00	.1608E+00	.1765E+00	.2310E+00	.2577E+00
PARTICULATE I132	.1063E-02	.1169E-02	.1273E-02	.1308E-02	.1312E-02	.1312E-02
PARTICULATE I133	.4281E-01	.4789E-01	.5385E-01	.5843E-01	.6567E-01	.6573E-01
PARTICULATE I134	.2529E-03	.2714E-03	.2842E-03	.2856E-03	.2857E-03	.2857E-03
PARTICULATE I135	.7063E-02	.7863E-02	.8755E-02	.9296E-02	.9612E-02	.9612E-02


TOTAL DOSE FOR 30 DAYS .2532E+02

t b / 21/93  
22/93



ATTACHMENT 4 TO AEP:NRC:1238F1

TEST RESULTS FROM \*\*12EHP4030STP229  
"CONTROL ROOM EMERGENCY VENTILATION SYSTEM"




Test Results.  
SOP.I RESPONSE Attachment B, Issue 2

PROCEDURE NUMBER: 4412 ETH 4030 STD. 229  
DATE STARTED: 4-2-96  
DATE COMPLETED: 4-9-96  
CONDUCTED BY: Terry M. Dohle

UNIT NUMBER: V2

0001-06 (D)



5.5.24 Before adjusting any dampers, inspect door seals, drains, hatches, and fire seals for leak paths.

*N/A*  
\*NO ADJUSTMENTS REQUIRED.

NOTE

The 800 cfm filtered makeup airflow limit is a desired value. The actual limit is to be determined based on unfiltered leakage and dose value.

5.5.25 If desired (to meet desirable criteria), mark position of dampers HV-ACRDA-2 and HV-ACRDV-7, then adjust them to obtain the following. If no adjustments are necessary, mark substeps N/A.

1. Adjust HV-ACRDA-2 and HV-ACRDV-7, then retest as appropriate starting at Step 5.5.6, until all the following criteria are met:

- HV-ACRF-2 airflow is 6160 - 6440 cfm
- Combined filter  $\Delta P$  is  $\leq 3.5$  iwg
- Control Room  $\Delta P$  relative to Turbine Building is  $\geq 0.064$  iwg
- Filtered makeup airflow is  $\leq 800$  cfm (desirable)
- Equipment Room  $\Delta P$  relative to Turbine Building is  $\geq 0.041$  iwg (desirable)
- Unfiltered makeup airflow is 5 - 10 cfm.


*N/A*

2. Record final values below, including sign (+ or -) and magnitude as applicable:

UNIT  
*2*

- HV-ACRF-2 airflow: 6400 cfm
- Combined filter  $\Delta P$ : 2.30 iwg
- Control Room  $\Delta P$  relative to Turbine Building:  
+0.26 iwg
- Filtered makeup airflow: 820 cfm
- Equip Room  $\Delta P$  relative to Turbine Building:  
+0.26 iwg
- Unfiltered makeup airflow: 12.6 cfm

*820* 14-2-86



## NOTE

The 800 cfm filtered makeup airflow limit is a desired value. The actual limit is to be determined based on unfiltered leakage and dose value.

- 5.4.25 If desired (to meet desirable criteria), mark position of dampers HV-ACRDA-2 and HV-ACRDV-7, then adjust them to obtain the following. If no adjustments are necessary, mark substeps N/A.

1. Adjust HV-ACRDA-2 and HV-ACRDV-7, then retest as appropriate starting at Step 5.4.6, until all the following criteria are met:


- HV-ACRF-1 airflow is 6160 - 6440 cfm
- Combined filter  $\Delta P$  is  $\leq$  3.5 iwg
- Control Room  $\Delta P$  relative to Turbine Building is  $\geq$  0.064 iwg
- Filtered makeup airflow is  $\leq$  800 cfm (desirable)
- Equipment Room  $\Delta P$  relative to Turbine Building is  $\geq$  0.041 iwg (desirable)
- Unfiltered makeup airflow is 5 - 10 CFM.

N/AUNIT  
1

2. Record final values below, including sign (+ or -) and magnitude as applicable:


- HV-ACRF-1 airflow: 6350 cfm
- Combined filter  $\Delta P$ : 2.25 iwg
- Control Room  $\Delta P$  relative to Turbine Building:  
+.30 iwg
- Filtered makeup airflow: 820 cfm
- Equip Room  $\Delta P$  relative to Turbine Building:  
+.23 iwg
- Unfiltered makeup airflow: 12.6 cfm

Al Hughes 4/2/96



ATTACHMENT 5 TO AEP:NRC:1238F1

CALCULATION NO. RD-94-01  
"OFFSITE DOSES DUE TO ECCS LEAKAGE"



00100150001

661100-STG-2300-01

REV. 0

PAGE 9 OF 12

American Electric Power Service Corporation

**Nuclear Safety, Licensing & Assessment**  
**Calculation Cover Sheet**

Calculation No. <u>RD-94-01</u> Rev. <u>  </u>	Plant <u>Donald C. Cook</u> Unit <u>1 &amp; 2</u>
Subject <u>Offsite Doses Due to ECCR Leakage</u>	Company <u>EM</u>
Safety Related System Yes <u>✓</u> No <u>  </u>	Calculated By <u>D.J.G.</u>
Supercedes Calc. No. <u>RD 85-03</u>	Verified/Checked By <u>Howard Colvin</u>
Method of Verification <u>Review/Independent Calculation</u>	
Approved By <u>D.X. Miller 2/24/94</u>	

Problem Description: Site boundary, a LPZ doses post-LLOCA due to ECCR leakage in aux. block and leakage to RUST, following shutdown to containment pump for ECCR suction.

## Design Basis Or References:

UFSAR, 14.3.5  
IE Info Notice 91-56 (AEP: NRC: 9945)

## Executive Summary:


Doses due to ~~offsite basis~~ ECCR leakage of 457.6 ccf/h. of RUST leakage of air to 10 rpm were determined. Doses were very small (compared to 10 CFR 100 limits). Sources of leakage are transparent to calc., see statement of source for details.

Superseded By Calculation No. \_\_\_\_\_ Dated \_\_\_\_\_

Reason: \_\_\_\_\_

Page 1 Of 2

Attachment 2




0 0 1 3 3 1 3 0 0 0 2

06/12/194  
2/23

## 1. TABLE OF CONTENTS

1. Table of Contents	p. 2
2. Statement of Purpose	p. 3
3. Assumptions	p. 4
4. Analysis	p. 9
5. Verification	p. 11
6. Results	p. 16
7. Discussion of Results	p. 18
8. References	p. 19



9 0 1 3 0 1 ; 0 0 0 0

1/28/84  
3/23


## 2. STATEMENT OF PURPOSE

The purpose of this calculation is to determine offsite thyroid doses due to leakage of ECCS water during the recirculation phase of a LOCA. The leakage, which occurs outside containment, is comprised of two parts:

- (i) Leakage from ECCS components (pumps, valves, etc.) in the auxiliary building, and
- (ii) Leakage through valves (e.g. SI miniflow valves) back to the refueling water storage tank (RWST).

The calculation will determine the 2 hour dose at the site boundary and the 30 day dose at the low population zone. This is consistent with the requirements of 10 CFR 100 (Ref. 1).

\* note that the leakages . . . . . w/lef t & RWST,  
on a per cc basis, have the same  
contribution to the offsite dose. This is  
because 1) no credit is taken for  
L = ventilation factor, 2) no dilution  
as the RWST is credited, and 3) the same w/c  
is used for both w/left & RWST leakages.



0 0 1 0 0 1 1 0 0 0 4

1/6/94

4/23

### 3. ASSUMPTIONS

This section will be divided into two parts, one for the leakage from ECCS components in the auxiliary building, and the second for leakage through valves back to the RWST.

#### 3.1 Assumptions for Dose Due to Leakage in the Auxiliary Building.

##### 3.1.1 Source Term

Fifty percent of the core iodine is released and is contained in the containment sump. (Ref. 2). The iodine inventory derived by Westinghouse for the power uprate program (Ref. 3) will be used. This source term was derived for a thermal power level of 3588 MW, which bounds the licensed power level of Unit 1 (3250 MW) and Unit 2 (3411 MW).

<u>ISOTOPE</u>	<u>ACTIVITY (CURIES)</u>
I-131	5.0E+7
I-132	7.3E+7
I-133	1.0E+8
I-134	1.1E+8
I-135	1.9E+8

##### 3.1.2 Dilution Volume

The iodine concentration is diluted by only by the water in the sump. (Dilution by RWST water is conservatively ignored.) The volume of water in the sump is 2.2E+9 cc, which includes the RCS and ECCS water, plus water from the melting of 50% of the total ice (Ref. 4).

##### 3.1.3 Sump Water Temperature

No flashing to steam occurs in the sump (Ref. 4).

##### 3.1.4 Iodine Entrainment

Iodine entrainment in vapor (from evaporation) is factor of 10E-4 (Ref. 4). This factor was based on experiments described in Ref. 4.

##### 3.1.5 Iodine Filtration

No credit was taken for filtration of the ECCS leakage in the auxiliary building by the ESF ventilation system.

3 0 1 0 0 ! , 0 0 0 4

Argon  
1/2/76  
5723

### 3.1.6 Leakage Rate

The design basis leakage rate of 4576 cc/hr was used for ECCS leakage in the auxiliary building (Ref. 4). This leakage was considered to be constant throughout the entire course of the LOCA (30 days). The leakage of concern is from the water that is recirculated from the containment sump following switchover of ECCS suction from the RWST to the containment sump. No credit was taken for the fact that there is approximately a 20 minute delay before recirculation flow is established.

### 3.1.7 Breathing Rate

Breathing Rate of  $3.47 \times 10^{-4} \text{ sec/m}^3$  (Ref. 2).

### 3.1.8 Atmospheric Dispersion Factor

ECCS leakage in the auxiliary building would be picked up by the ESF ventilation system and ultimately released to the containment unit vent. (The auxiliary building is maintained at a negative pressure relative to the outside air post-accident.) The X/Q's developed for a containment release will be used, as provided in Ref. 4. Note that the containment X/Q's in Ref. 4 were developed for a ground level release. This is conservative, since the unit vent is located on top of the containment and therefore which results in an elevating of the release.


Values of X/Q (site boundary and low population zone) used in the calculation are:

<u>TIME (HR)</u>	<u>X/Q (SB), SEC/M<sup>3</sup></u>	<u>X/Q (LPZ), SEC/M<sup>3</sup></u>
0-24	3.15E-4 ✓	7.5E-5 ✓
24-120	2.5E-5 ✓	2.6E-6 ✓
120-720	8.4E-6 ✓	7.9E-7 ✓

### 3.1.9 Dose Conversion Factors

Dose conversion factors are from ICRP-30, as listed in Ref. 5.

<u>ISOTOPE</u>	<u>DCF (REM/GI)</u>
I-131	1.07E+6 ✓
I-132	6.29E+3 ✓
I-133	1.81E+5 ✓
I-134	1.07E+3 ✓



0 0 1 0 3 1 6 0 0 5

Ar-40  
1/20/67  
6(23)


I-135

3.14E+4 ✓

## 3.1.10 Radioactive Decay Data

Data taken from Ref. 6.

<u>ISOTOPE</u>	<u>HALF-LIFE (hrs)</u>	<u>LAMBDA (ln 2/half-life)</u>
I-131	193	3.59E-3 ✓
I-132	2.30	3.01E-1 ✓
I-133	20.8	3.33E-2 ✓
I-134	0.877	7.91E-1 ✓
I-135	6.61	1.05E-1 ✓



0 0 1 0 3 1 , 0 0 5 ,

1/26/44  
7(23)

### 3.2 Assumptions for Dose Due to Leakage to RWST

#### 3.2.1 Source Term

Same as Section 3.1.1

#### 3.2.2 Dilution Volume

Same as Section 3.1.2. Dilution of the water by the RWST will conservatively be ignored.

#### 3.2.3 Sump Water Temperature

Same as Section 3.1.3.

#### 3.2.4 Iodine Entrainment

Same as Section 3.1.4.

#### 3.2.5 Iodine Filtration

There are no filters that would affect the leak path from the refueling water storage tank to the atmosphere.

#### 3.2.6 Leakage Rate


Values of leakage back to the RWST of 1.0 and 10.0 gpm will be analyzed. As discussed in Section 3.1.6, no credit is taken for the delay that exists before the recirculation flow path is established.

#### 3.2.7 Breathing Rate

Same as Section 3.1.7.

#### 3.2.8 Atmospheric Dispersion Factor

The same factors presented in section 3.1.8 will be used. It is noted that the X/Q values presented in that section were derived using the cross-sectional area of the containment building. (X/Q is inversely related to the cross-sectional area of the building.) Although the RWST has a smaller cross-sectional area, the UFSAR values are considered to be acceptable since, 1) the plant structures influence the wake around the



0 0 1 3 3 1 3 0 0 3 ;

AT&T  
1/26/44  
8/23

D  
RWST for all wind directions, and 2) as discussed in Section 2.2.3 of the UFSAR, the worst case X/Q ever recorded was approximately an order of magnitude lower than the UFSAR value.

### 3.2.9 Dose Conversion Factors

Same as Section 3.1.9.

### 3.2.10 Radioactive Decay Data

Same as Section 3.1.10.

0 0 1 0 3 1 , 0 0 0 5

07/26  
1128/44  
9/23

#### 4. ANALYSIS

The offsite dose rate from an iodine isotope due to leakage from a liquid source is expressed as:

$$DR = (L)(C)(X/Q)(B)(DCF)(F) \quad (1)$$

where:

DR = dose rate, rem/hr

L = leakage rate, cc/hr

C = concentration of activity, Ci/cc

B = breathing rate, cc/sec

DCF = dose conversion factor, rem/Ci

F = entrainment factor

X/Q = atmospheric dispersion factor, sec/m<sup>3</sup>

The concentration, C, is obtained by dividing the activity (Ci) by the volume in the sump (cc). The concentration, C, is a time dependent function, due to radioactive decay. Thus,  $C(t) = C_0 \exp(-\lambda t)$ .

The atmospheric dispersion term, X/Q, also varies with time. The UFSAR defines discrete intervals (0-1 day, 1-5 days, and 5-30 days) in which X/Q is held constant.

Eqn. (1) can be written in time dependent terms as:

$$DR = (L)[C_0 \exp(-\lambda t)][X/Q(t)](B)(DCF)(F) \quad (2)$$

The total dose received is the integral of eqn.(2), or:

$$D = DR = \int_0^t (L)[C_0 \exp(-\lambda t)][X/Q(t)](B)(DCF)(F) dt \quad (3)$$

Over the time interval in which X/Q is held constant, the eqn.(3) becomes:

$$D = (L)(C_0)(X/Q)(B)(DCF)(F) \left\{ \int_0^t \exp(-\lambda t) dt \right\} \quad (4)$$

Solving the integral for the time period t=0 to t, the equation becomes:


$$D = (L)(C_0)(X/Q)(B)(DCF)(F)(1/\lambda)[1 - \exp(-\lambda t)] \quad (5)$$

In order to obtain the total dose, the above equations would be repeated for each of the five iodine isotopes of interest, and the results summed.

0 0 1 0 0 1 > 0 0 1 0

11-7A  
1/26/94  
10123

The calculation was performed using a program written in MSFORTRAN 5.0, which runs on a PC. Attachment 1 contains the computer code (the version with leakage to the RWST of 10.0 gpm was provided.) Section 6 contains the output results for the 2 cases analyzed, i.e., leakage to the RWST of 1.0 and 10 gpm.




0 0 | 0 0 | : 0 0 | :

Nov 84  
1/28/4W  
11/23

## 5. VERIFICATION

The calculational results are provided in the next section. The code was verified by performing hand calculations to ensure the code output matched the exact solution, which is expressed in eqn. (5). Verification was performed for I-131 for site boundary and low population zone doses, for both ESF and RWST leakage. In addition, a check of the site boundary dose for RWST leakage was made for I-133. These hand calculations are provided below. Lastly, the code output was reviewed to ensure that the doses due to the various isotopes were added correctly, and that the ESF and RWST leakage contributions were added correctly. In all cases, the code results matched the hand calculations.



ENGINEERING DEPT.

AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO0 0 1 0 0 1 5 0 0 1 ?  
SHEET 112 OF 23  
DATE 1/28/94 BY 17-L-1 CK  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_SUBJECT Verification

Case 1: E&amp;F Leakage, Site Boundary (0-2 hrs, T=13)

$$\frac{\gamma}{Q} = 3.15 \times 10^{-4}$$

$$D = L C_0 \frac{\gamma}{Q} \beta (OCF) (F) \left(\frac{1}{\lambda}\right) (1 - e^{-\lambda t})$$

$$= .4576 \left( \frac{5.0 \times 10^7}{2.2 \times 10^4} \right) (3.15 \times 10^{-4}) (3.47 \times 10^{-4}) (1.07 \times 10^6) \left( \frac{1}{10000} \right) \\ * \left( \frac{1}{3.59 \times 10^{-3}} \right) (1 - e^{-(3.59 \times 10^{-3} \times 2)})$$

$$= 2.4 \times 10^{-3} \quad (some \quad as \quad code)$$

E.N. 2/24/94

Case 2: RWST Leakage Site Boundary  
(0-2 hrs, T=13)


$$\frac{\gamma}{Q} = 3.15 \times 10^{-4}$$

$$D = L C_0 \frac{\gamma}{Q} \beta (OCF) (F) \left(\frac{1}{\lambda}\right) (1 - e^{-\lambda t})$$

$$L = \frac{1 \text{ gal}}{\text{min}} \times \frac{60 \text{ min}}{\text{hr}} \times \frac{37854 \text{ cm}^3}{\text{gal}} = 227,125.8 \text{ cm}^3$$

$$D = (227,125.8) \left( \frac{5 \times 10^{-2}}{2.2 \times 10^{-4}} \right) (3.15 \times 10^{-4}) (3.47 \times 10^{-4}) \\ * (1.07 \times 10^6) \left( \frac{1}{10000} \right) \left( \frac{1}{3.59 \times 10^{-3}} \right) (1 - e^{-(3.59 \times 10^{-3} \times 2)})$$

$$= 0.12 \quad (some \quad as \quad (code))$$



ENGINEERING DEPT.

AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO0 0 1 0 0 1 3 0 0 1 3  
SHEET 116 OF 27DATE 1/18/94 BY MHC CK  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

Case 3 : ESF Leakage, LPZ

$$\text{Dose at LPZ} = \text{Dose}_{0-1 \text{ day}} + \text{Dose}_{1-5 \text{ days}} + \text{Dose}_{5-30 \text{ days}}$$

$$\text{Dose } \sim 1 \text{ day } (\frac{\lambda}{Q} = 7.5 \times 10^{-5})$$

$$\begin{aligned} D_{0-1} &= L C_0 \frac{\lambda}{Q} B (OCF) (F) \left(\frac{1}{\lambda}\right) (1 - e^{-\lambda t}) \\ &= (4576) \left(\frac{5 \times 10^{-7}}{2.2 \times 10^{-6}}\right) (7.5 \times 10^{-5}) (3.47 \times 10^{-4}) (1.07 \times 10^6) \\ &\quad + (10,000) \left(\frac{1}{3.59 \times 10^{-3}}\right) (1 - e^{-(3.59 \times 10^{-3})(24)}) \\ &= 0.666 \times 10^{-2} \checkmark \quad (\text{Same as code}) \end{aligned}$$

$$\text{Dose } 1-5 \text{ day } (\frac{\lambda}{Q} = 2.6 \times 10^{-6})$$

To obtain dose @ 1-5 days, first determine C @ 1 day by  $C = C_0 e^{-\lambda t}$ .  
 In subsequent calc,  $t = 5 \text{ days} - 1 \text{ day} = 4 \text{ days}$   
 $= 96 \text{ hrs.}$

$$C = C_0 e^{-\lambda t} = \left(\frac{5 \times 10^{-7}}{2.2 \times 10^{-6}}\right) \left(e^{-(3.59 \times 10^{-3})(24)}\right) = 0.0208$$

$$D = L C \frac{\lambda}{Q} B (OCF) (F) \left(\frac{1}{\lambda}\right) (1 - e^{-\lambda t})$$

$$= (4576) (0.02085) (2.6 \times 10^{-6}) (3.47 \times 10^{-4}) (1.07 \times 10^6) (10,000) \\ * \left(\frac{1}{3.59 \times 10^{-3}}\right) (1 - e^{-(3.59 \times 10^{-3})(96)})$$

$$= 7.48 \times 10^{-4}$$

ENGINEERING DEPT.

AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO00100115001412 SHEET 12 OF 23  
DATE 1/28/44 BY Mr. G. CK.  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

Case 3 : ESF Leaking, LPZ (cont'd)

$$Dose_{5-30 \text{ days}} \cdot (\frac{X}{Q} = 7.9 \times 10^{-7})$$

To obtain dose @ 5-30 days, first determine  
 $C @ 5 \text{ days}$ , by  $C = C_0 e^{-\lambda t}$ . In  
 -background value,  $t = 30 \text{ days} - 5 \text{ days} =$   
 $25 \text{ days} = 600 \text{ hrs}$

$$C = C_0 e^{-\lambda t} = \left(\frac{5 \times 10^{-7}}{2.2 \times 10^{-6}}\right) e^{-(7.59 \times 10^{-4})(120)} = 0.01477$$

$$D_{5-30} = LC \approx B(DCF)(F) \left(\frac{1}{\lambda}\right) \left(1 - e^{-\lambda t}\right)$$

$$= (4576)(0.01477) (7.9 \times 10^{-7}) (3.47 \times 10^{-4}) (1.07 \times 10^6) (1/4000) \\ \left(\frac{1}{3.59 \times 10^{-2}}\right) \left(1 - e^{-\frac{7.59 \times 10^{-4}}{(3.59 \times 10^{-2})}(600)}\right)$$

$$= 0.4882 E-3$$

$$\text{Total Dose @ } 50 \text{ days} = D_{0-5} + D_{5-30} + D_{30-50}$$

$$= 0.666 E-2 + 0.748 E-3 + 0.488 E-3$$

$$= \boxed{0.710 E-2} \quad \text{same} = \\ \text{case}$$

**SUBJECT** \_\_\_\_\_

Case 4: Rust Leaks, LPZ, I-13

$$\text{Dose at LPZ} = \frac{\text{Dose}}{\text{0-1 day}} + \frac{\text{Dose}}{\text{1-5 day}} + \frac{\text{Dose}}{\text{5-10 day}}$$

pose 0-1 day ( $\frac{N}{Q} = 7.5 \times 10^{-5}$ )

$$D_{j-1} = \left\lfloor C_0 \sum_{k=1}^j B(D(F))(F)(\frac{1}{k}) \left(1 - e^{-\lambda \frac{1}{k}}\right) \right\rfloor$$

L = same as case 2; 227, 125.8

$$D_{0-1} = (227, 125.8) \left( \frac{e^{1.67}}{2.2 \times 10^6} \right) \left( \frac{1}{7.7 \times 10^{-5}} \right) \left( 3.47 \times 10^{-4} \right) \\ \left( 1.07 \times 10^{-6} \right) \left( \frac{1}{10,000} \right) \left( \frac{1}{3.5 \times 10^{-3}} \right) \left( 1 - e^{-\frac{1}{3.5 \times 10^{-3}}} \right) (24)$$

= 0.331, same as code

$$Dose_{\text{per day}} \quad (\frac{\text{kg}}{\text{day}} = 2.6 \times 10^{-3})$$

To obtain dust @ 1-5 days, first determine

at ④, by  $C = C_0 e^{-\lambda t}$ . In such a case

$$\text{Calc., } t = 5 \text{ days} - 1 \text{ day} = 4 \text{ days} = 96 \text{ hours}$$


$$C = C_0 e^{-\lambda t} = \left( \frac{5 - x_1 / 0.7}{2 + 2x_1 / 0.7} \right) \left( e^{-(3.54 \times 10^{-3})(24)} \right) = 0.0208$$

$$D = L \cdot C \approx B(\rho, F)(F) \left( \frac{1}{\lambda} \right) \left( 1 - e^{-\lambda \tau} \right)$$

$$= (227,125.8)(0.02035) \left( 2.6 \times 10^{-5} \right) \left( 2.47 \times 10^{-4} \right) / (1.07 \times 10^6)$$

$$\left( \frac{1}{1,000} \right) \left( \frac{1}{3.59 \times 10^{-3}} \right) \left( 1 - e^{-\frac{1.5}{0.0247}} \right)$$

$$= 0.3712 \pi - 1$$



ENGINEERING DEPT.

AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO

0 0 1 0 0 ! 6 0 0 ! SHEET 14 OF 23

DATE 1/26/94 BY M.L.C. CK.

COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_

PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

Case 4 : Rust Leaking, LPZ, I-131 (cont'd)

$$Dose_{s-30} \left( \frac{\text{R}^2}{\text{Q}} = 7.9 \times 10^{-3} \right)$$

To obtain dose @ 30 days, first determine  
 $C @ 5 \text{ days} = b$ ,  $C = C_0 e^{-\lambda t}$ . In subsequent  
 calc,  $t = 30 \text{ days} - 5 \text{ days} = 25 \text{ days} =$   
 $600 \text{ hrs.}$


$$C = C_0 e^{-\lambda t} = \left( \frac{-\lambda r^2}{2.2 \times 10^{-3}} \right) e^{-13.59 \times 10^{-3} \cdot 600} = 0.01472$$

$$\begin{aligned} D_{s-30} &= L \left( \frac{r^2}{Q} \right) \cdot (D_C F) \left( \frac{1}{\lambda} \right) \left( 1 - e^{-\lambda t} \right) \\ &= (227,125.8) (0.01472) (7.9 \times 10^{-3}) (347 \times 10^{-4}) \\ &\quad (1.07 \times 10^6) \left( \frac{1}{10,000} \right) \left( 1 - e^{-13.59 \times 10^{-3} \cdot 600} \right) \\ &= 0.2423 E-1 \end{aligned}$$

$$\text{Total Dose @ 30 days} = D_{s-1} + D_{s-2} + D_{s-30}$$

$$\Rightarrow 0.331 E+0 + 0.371 E-1 + 0.242 E-1$$

$$= \boxed{0.392 E+0} \text{ so ~ as code}$$




ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO0 0 1 0 0 ! 3 0 0 SHEET 15 OF 23  
DATE 1/28/64 BY 17-24 CK  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

S U B J E C T \_\_\_\_\_

Case 5: Rust Leckage, S/k Boundary (cont'd) I-133

$$\frac{d}{dt} = 3.15 \times 10^{-4}$$

$$\begin{aligned} D &= L C_0 \frac{d}{dt} B (D/F) (F) \left( \frac{1}{\lambda} \right) \left( 1 - e^{-\lambda t} \right) \\ &= (227125.8) \left( \frac{1 \times 10^8}{2.2 \times 10^7} \right) (3.15 \times 10^{-4}) (3.47 \times 10^{-4}) (1.81 \times 10^5) \\ &\quad (10,000) \left( \frac{1}{3.33 \times 10^{-2}} \right) \left( 1 - e^{-\frac{10}{3.33 \times 10^{-2}}} \right) \\ &= [0.40 \text{ E } -1], \text{ same as code} \end{aligned}$$



9 0 1 9 3 1 6 0 0 1 :

11-60

1/26/94

16/23

## 6. RESULTS

### 6.1 RWST LEAKAGE = 1.0 GPM

ESF LEAKAGE = 4576. CC/HR  
 RWST LEAKAGE = 1.00 GPM

#### SITE BOUNDARY DOSE (ESF LEAKAGE)

##### ISOTOPE 2-HR DOSE (REM)

I131	.242D-02
I132	.159D-04
I133	.798D-03
I134	.280D-05
I135	.246D-03
TOTAL =	.349D-02

#### SITE BOUNDARY DOSE (RWST LEAKAGE)

##### ISOTOPE 2-HR DOSE (REM)

I131	.120D+00
I132	.790D-03
I133	.396D-01
I134	.139D-03
I135	.122D-01
TOTAL =	.173D+00

TOTAL ESF + RWST = .177D+00

#### LPZ DOSE (ESF LEAKAGE) (REM)

##### ISOTOPE 2-HR 1-DAY 5-DAY 30-DAY


I131	.577D-03	.666D-02	.741D-02	.790D-02
I132	.379D-05	.838D-05	.838D-05	.838D-05
I133	.190D-03	.162D-02	.167D-02	.167D-02
I134	.666D-06	.838D-06	.838D-06	.838D-06
I135	.586D-04	.284D-03	.285D-03	.285D-03
TOTAL =	.830D-03	.858D-02	.937D-02	.986D-02

#### LPZ DOSE (RWST LEAKAGE) (REM)

##### ISOTOPE 2-HR 1-DAY 5-DAY 30-DAY

I131	.287D-01	.331D+00	.368D+00	.392D+00
I132	.188D-03	.416D-03	.416D-03	.416D-03
I133	.943D-02	.805D-01	.827D-01	.827D-01
I134	.330D-04	.416D-04	.416D-04	.416D-04
I135	.291D-02	.141D-01	.142D-01	.142D-01
TOTAL =	.412D-01	.426D+00	.465D+00	.489D+00

TOTAL 30-DAY DOSE (ESF + RWST) = .499D+00 REM



0 0 1 3 0 1 ; 0 0 1 9

17/23  
17/23

## 6.2 RWST LEAKAGE - 10 GPM

ESF LEAKAGE = 4576. CC/HR  
RWST LEAKAGE = 10.00 GPM

### SITE BOUNDARY-DOSE (ESF LEAKAGE)

#### ISOTOPE 2-HR DOSE (REM)

I131	.242D-02
I132	.159D-04
I133	.798D-03
I134	.280D-05
I135	.246D-03
TOTAL =	.349D-02

### SITE BOUNDARY DOSE (RWST LEAKAGE)

#### ISOTOPE 2-HR DOSE (REM)

I131	.120D+01
I132	.790D-02
I133	.396D+00
I134	.139D-02
I135	.122D+00
TOTAL =	.173D+01

TOTAL ESF + RWST = .173D+01

### LPZ DOSE (ESF LEAKAGE) (REM)

#### ISOTOPE 2-HR 1-DAY 5-DAY 30-DAY


I131	.11 D-0	.666D-02	.741D-02	.790D-02
I132	.379D-05	.838D-05	.838D-05	.838D-05
I133	.190D-03	.162D-02	.167D-02	.167D-02
I134	.666D-06	.838D-06	.838D-06	.838D-06
I135	.586D-04	.284D-03	.285D-03	.285D-03
TOTAL =	.830D-03	.858D-02	.937D-02	.986D-02

### LPZ DOSE (RWST LEAKAGE) (REM)

#### ISOTOPE 2-HR 1-DAY 5-DAY 30-DAY

I131	.287D+00	.331D+01	.368D+01	.392D+01
I132	.188D-02	.416D-02	.416D-02	.416D-02
I133	.943D-01	.805D+00	.827D+00	.827D+00
I134	.330D-03	.416D-03	.416D-03	.416D-03
I135	.291D-01	.141D+00	.142D+00	.142D+00
TOTAL =	.412D+00	.426D+01	.465D+01	.489D+01

TOTAL 30-DAY DOSE (ESF + RWST) = .490D+01 REM



9 0 1 3 0 1 , 0 0 . 0

J. J. G.  
1/26/94


10/23.

## 7. DISCUSSION OF RESULTS

The results of the calculation demonstrate that the contribution to the LOCA offsite doses (site boundary and LPZ) from ECCS leakage and leakage back to the RWST is only a small fraction of the total dose. The 10 CFR 100 offsite dose criteria is 300 rem to the thyroid for the 0-2 hour dose at the site boundary and the dose at the LPZ over the course of the accident, which is typically taken to be 30 days.

In Ref. 3, the 2 hour site boundary dose was calculated to be 134 rem. The additional site boundary dose due to design basis ECCS leakage plus a 10.0 gpm leak to the RWST was determined to be 1.7 rem. The total site boundary dose is therefore 135.7 rem, well within the 300 rem limit.

In Ref. 3, the 30 day LPZ dose was calculated to be 126 rem. The additional LPZ dose due to design basis ECCS leakage plus a 10.0 gpm leak to the RWST was determined to be 4.9 rem. The total LPZ dose is therefore 130.9 rem, well within the 300 rem limit.




0 0 1 0 3 1 3 0 0 ? 1

Mr. La  
1/28/94  
1912;

8. REFERENCES

1. 10 CFR 100
2. NUREG 0800 (Standard Review Plan), Chapter 15.6.5 Appx B, Rev. 1.
3. WCAP 12135
4. UFSAR, Chapter 14.3.5
5. WCAP 11020
6. ICRP 30
7. Reg Guide 1.4 <sup>1/28/94</sup>



0 0 1 0 3 1 6 0 0 2 2

Mr. La  
1/28/94  
20/23

ATTACHMENT

CODE LISTING (RWST LEAKAGE = 10 GPM)

```
REAL*8 EDOSESBT(5),EDOSELPT(5),XQSB,XQESFSB(3)
REAL*8 XQLP,XQESFLP(3),DELTAT,EDOSESBT(5),ESFLEAK
REAL*8 ICI(5),VOL,BREATHE,IDCF(5),PTFACT,ILAMB(5),T
REAL*8 EDOSELPT(5),ESB2(5)
REAL*8 ELP2(5),ELP24(5),ELP120(5),ELP720(5)
REAL*8 RDOSESBT(5),RDOSELPT(5),XQRWSTSB(3),XQRWSTLP(3)
REAL*8 RDOSESBT(5),RWSTGFM,RWSTLEAK,RDOSELPT(5),RSB2(5),RLP2(5)
REAL*8 RLP24(5),RLP120(5),RLP720(5),TOTALESB,TOTALRSB,TOTALSB
REAL*8 TOTLE2,TOTLE24,TOTLE120,TOTLE720
REAL*8 TOTLR2,TOTLR24,TOTLR120,TOTLR720,TOTAL
CHARACTER*4 NAME(5)
DATA NAME/'I131','I132','I133','I134','I135'
DATA IDCF/1.07D+06,6.29D+03,1.81D+05,1.07D+03,3.14D+04/
DATA BREATHE/3.47D-04/
DATA XQESFSB/3.15D-04,2.5D-05,8.4D-06/
DATA XQRWSTSB/3.15D-04,2.5D-05,8.4D-06/
DATA XQESFLP/7.5D-05,2.6D-06,7.9D-07/
DATA XQRWSTLP/7.5D-05,2.6D-06,7.9D-07/
DATA ICI/5.0D+07,7.3D+07,1.0D+08,1.1D+08,1.9D+08/
DATA ILAMB/3.59D-03,3.01D-01,3.33D-02,7.91D-01,1.05D-01/
DATA ESFLEAK/4576.0D0/
DATA RWSTGPM/10.0/
DATA PTFACT/10000.0D0/
DATA VOL/2.2D+09/

C **PART OF THE CODE THAT CALCULATES THE DOSE DUE TO ESF LEAKAGE**
C

C *****OUTER LOOP FOR ALL ISOTOPES*****
C
      DO.130 I=1,5
      T = 0.0
      EDOSESBT(I) = 0.0D0
      EDOSELPT(I) = 0.0D0
C
C *****INNER LOOP FOR TIME 0 TO 30 DAYS*****
C
10      XQSB = XQESFSB(1)
      IF (T.GT.24.0) XQSB = XQESFSB(2)
      IF (T.GT.120.0) XQSB = XQESFSB(3)
C
      XQLP = XQESFLP(1)
      IF (T.GT.24.0) XQLP = XQESFLP(2)
      IF (T.GT.120.0) XQLP = XQESFLP(3)
C
      DELTAT = 0.1D+0
      IF (T.GT. 48.0) DELTAT = 1.0D0
      EDOSESBT(I)=ESFLEAK*ICI(I)/VOL*XQSB*BREATHE*IDCF(I)/PTFACT
      1 *DEXP(-ILAMB(I)*T)*DELTAT
      EDOSELPT(I)=ESFLEAK*ICI(I)/VOL*XQLP*BREATHE*IDCF(I)/PTFACT
      1 *DEXP(-ILAMB(I)*T)*DELTAT
C
      EDOSESBT(I) = EDOSESBT(I)+EDOSESBT(I)
      EDOSELPT(I) = EDOSELPT(I)+EDOSELPT(I)
C
      IF ((T+DELTAT) .GT. 1.59 .AND. (T+DELTAT).LT. 2.01) THEN
```

0 0 1 0 0 1 5 0 0 2 3

Mr. La  
1/28/94  
24/2/2


ATTACHMENT

CODE LISTING (RWST LEAKAGE = 10 GPM)

```
REAL*8 EDOSESBT(5),EDOSELPT(5),XQSB,XQESFSB(3)
REAL*8 XQLP,XQESFLP(3),DELTAT,EDOSES(5),ESFLEAK
REAL*8 ICI(5),VOL,BREATHE,IDCF(5),PTFACT,ILAMB(5),T
REAL*8 EDOSEL(5),ESB2(5)
REAL*8 ELP2(5),ELP24(5),ELP120(5),ELP720(5)
REAL*8 RDOSES(5),RDOSELPT(5),XQRWSTSB(3),XQRWSTLP(3)
REAL*8 RDOSES(5),RWSTGPM,RWSTLEAK,RDOSEL(5),RSB2(5),RLP2(5)
REAL*8 RLP24(5),RLP120(5),RLP720(5),TOTALS(5),TOTALRSB,TOTALS(5)
REAL*8 TOTLE2,TOTLE24,TOTLE120,TOTLE720
REAL*8 TOTLR2,TOTLR24,TOTLR120,TOTLR720,TOTAL
CHARACTER*4 NAME(5)
DATA NAME/'I131','I132','I133','I134','I135'
DATA IDCF/1.07D+06,6.29D+03,1.81D+05,1.07D+03,3.14D+04/
DATA BREATHE/3.47D-04/
DATA XQESFSB/3.15D-04,2.5D-05,8.4D-06/
DATA XQRWSTSB/3.15D-04,2.5D-05,8.4D-06/
DATA XQESFLP/7.5D-05,2.6D-06,7.9D-07/
DATA XQRWSTLP/7.5D-05,2.6D-06,7.9D-07/
DATA ICI/5.0D+07,7.3D+07,1.0D+08,1.1D+08,1.9D+08/
DATA ILAMB/3.59D-03,3.01D-01,3.33D-02,7.91D-01,1.05D-01/
DATA ESFLEAK/4576.00D/
DATA RWSTGPM/10.0/
DATA PTFACT/10000.00D/
DATA VOL/2.2D+09/

C **PART OF THE CODE THAT CALCULATES THE DOSE DUE TO ESF LEAKAGE**
C

C *****OUTER LOOP FOR ALL ISOTOPES*****
C
      DO 130 I=1,5
         T = 0.0
         EDOSES(5) = 0.0D0
         EDOSELPT(5) = 0.0D0
C
C *****INNER LOOP FOR TIME 0 TO 30 DAYS*****
C
10      XQSB = XQESFSB(1)
        IF (T.GT.24.0) XQSB = XQESFSB(2)
        IF (T.GT.120.0) XQSB = XQESFSB(3)
C
        XQLP = XQESFLP(1)
        IF (T.GT.24.0) XQLP = XQESFLP(2)
        IF (T.GT.120.0) XQLP = XQESFLP(3)
C
        DELTAT = 0.1D+0
        IF (T.GT. 48.0) DELTAT = 1.0D0
        EDOSES(5)=ESFLEAK*ICI(5)/VOL*XQSB*BREATHE*IDCF(5)/PTFACT
        *DEXP(-ILAMB(5)*T)*DELTAT
        EDOSEL(5)=ESFLEAK*ICI(5)/VOL*XQLP*BREATHE*IDCF(5)/PTFACT
        *DEXP(-ILAMB(5)*T)*DELTAT
C
        EDOSES(5) = EDOSES(5)+EDOSES(5)
        EDOSELPT(5) = EDOSELPT(5)+EDOSEL(5)
C
        IF ((T+DELTAT) .GT. 1.95 .AND. (T+DELTAT).LT. 2.05) THEN
           ESB2(5) = EDOSES(5)
           ELP2(5) = EDOSELPT(5)
```



0 0 1 0 0 1 6 0 0 2 4


1/23/84  
2145

```
ENDIF
IF ((T+DELTAT) .GT. 23.95.AND.(T+DELTAT).LT. 24.05) THEN
    ELP24(I) = EDOSELPT(I)
ENDIF
IF ((T+DELTAT) .GT. 119.5.AND.(T+DELTAT).LT. 120.5) THEN
    ELP120(I) = EDOSELPT(I)
ENDIF
IF ((T+DELTAT) .GT. 719.5 .AND.(T+DELTAT).LT.720.5) THEN
    ELP720(I) = EDOSELPT(I)
ENDIF
C
T = T+DELTAT
IF (T.LE.720.0) GO TO 10
130
CONTINUE
C
C**PART OF THE CODE THAT CALCULATES THE DOSE DUE TO LEAKAGE TO RWST**
C
RWSTLEAK = RWSTGPM*2.271258D+5
C *****OUTER LOOP FOR ALL ISOTOPES*****
C
DO 140 I=1,5
    T = 0.0
    RDOSESBT(I) = 0.0D0
    RDOSELPT(I) = 0.0D0
C
*****INNER LOOP FOR TIME 0 TO 30 DAYS*****
C
20
    XQSB = XQRWSTSB(1)
    IF (T.GT.24.0) XQSB = XQRWSTSB(2)
    IF (T.GT.120.0) XQSB = XQRWSTSB(3)
C
    XQLP = XQRWSTLP(1)
    IF (T.GT.24.0) XQLP = XQRWSTLP(2)
    IF (T.GT.120.0) XQLP = XQRWSTLP(3)
C
    DELTAT = 0.1D+0
    IF (T.GT. 48.0) DELTAT = 1.0D0
    RDOSESBT(I)=RWSTLEAK*ICI(I)/VOL*XQSB*BREATHE*IDCF(I)/PTFACT
    1 *DEXP(-ILAMB(I)*T)*DELTAT
    RDOSELPT(I)=RWSTLEAK*ICI(I)/VOL*XQLP*BREATHE*IDCF(I)/PTFACT
    1 *DEXP(-ILAMB(I)*T)*DELTAT
C
    RDOSESBT(I) = RDOSESBT(I)+RDOSESBT(I)
    RDOSELPT(I) = RDOSELPT(I)+RDOSELPT(I)
C
    IF ((T+DELTAT) .GT. 1.95 .AND. (T+DELTAT).LT. 2.05) THEN
        RSB2(I) = RDOSESBT(I)
        RLP2(I) = RDOSELPT(I)
    ENDIF
    IF ((T+DELTAT) .GT.23.95 .AND.(T+DELTAT).LT. 24.05) THEN
        RLP24(I) = RDOSELPT(I)
    ENDIF
    IF ((T+DELTAT) .GT. 119.5 .AND.(T+DELTAT).LT. 120.5) THEN
        RLP120(I) = RDOSELPT(I)
    ENDIF
    IF ((T+DELTAT) .GT. 719.5 .AND.(T+DELTAT).LT. 720.5) THEN
        RLP720(I) = RDOSELPT(I)
    ENDIF
C
    T = T+DELTAT
    IF (T.LE.720.0) GO TO 20
140
CONTINUE
C
C **PART OF THE CODE THAT OUTPUTS THE RESULTS**
```

0 0 1 0 0 ! , 0 0 : 5

17-20  
1 / 25/12  
22/23.


```
OPEN (UNIT =6, FILE = 'I:\NSL\MSA\ESFOUT10.MSA')
WRITE (6,800) ESFLEAK
  FORMAT('ESF LEAKAGE = ',F5.0, ' CC/HR')
WRITE (6,810) RWSTGFM
  FORMAT('RWST LEAKAGE = ',F5.2, ' GFM',//)
WRITE (6,820)
  FORMAT('SITE BOUNDARY DOSE (ESF LEAKAGE)',/)
WRITE (6,830)
  FORMAT('ISOTOPE',3X,'2-HR DOSE (REM)',/)
C
DO 150 I = 1,5
  WRITE (6,840) NAME(I), ESB2(I)
  FORMAT(A4,6X,D8.3)
150 CONTINUE
C
TOTALF*3 = 0.0D0
DO 160 I = 1,5
  TOTALESB = TOTALESB + ESB2(I)
160 CONTINUE
  WRITE (6,860) TOTALESB
  FORMAT('TOTAL = ',2X,D8.3,/)
WRITE (6,870)
  FORMAT('SITE BOUNDARY DOSE (RWST LEAKAGE)',/)
WRITE (6,880)
  FORMAT('ISOTOPE',3X,'2-HR DOSE (REM)',/)
C
DO 170 I = 1,5
  WRITE (6,890) NAME(I), RSB2(I)
  FORMAT(A4,6X,D8.3)
170 CONTINUE
TOTALRSB = 0.0D0
DO 180 I = 1,5
  TOTALRSB = TOTALRSB + RSB2(I)
180 CONTINUE
  WRITE (6,900) TOTALRSB
  FORMAT('TOTAL = ',2X,D8.3,/)
TOTALSB = TOTALESB + TOTALRSB
  WRITE (6,910) TOTALSB
  FORMAT('TOTAL ESF + RWST= ',D8.3,///)
C
C
  WRITE (6,915)
  FORMAT('LPZ DOSE (ESF LEAKAGE) (REM)',/)
  WRITE (6,920)
  FORMAT('ISOTOPE',1X,'2-HR',5X,'1-DAY',4X,'5-DAY',4X,
1 '30-DAY',/)
  DO 190 I = 1,5
    WRITE (6,930) NAME(I), ELP2(I), ELP24(I), ELP120(I), ELP720(I)
    FORMAT(A4,4X,D8.3,1X,D8.3,1X,D8.3,1X,D8.3)
190 CONTINUE
C
TOTLE2 = 0.0D0
TOTLE24 = 0.0D0
TOTLE120 = 0.0D0
TOTLE720 = 0.0D0
DO 200 I = 1,5
  TOTLE2 = TOTLE2 + ELP2(I)
  TOTLE24 = TOTLE24 + ELP24(I)
  TOTLE120 = TOTLE120 + ELP120(I)
  TOTLE720 = TOTLE720 + ELP720(I)
200 CONTINUE
  WRITE (6,940) TOTLE2, TOTLE24, TOTLE120, TOTLE720
  FORMAT('TOTAL = ',D8.3,1X,D8.3,1X,D8.3,1X,D8.3,/)
C
  WRITE (6,950)
  FORMAT('LPZ DOSE (RWST LEAKAGE) (REM)',/)
```



3 0 1 0 0 1 ; 0 0 : 3

11274  
23123

```
      WRITE (6,920)
      DO 210 I = 1,5
         WRITE (6,930) NAME(I),RLP2(I),RLP24(I),RLP120(I),RLP720(I)
210   CONTINUE
C
      TOTLR2 = 0.0D0
      TOTLR24 = 0.0D0
      TOTLR120 = 0.0D0
      TOTLR720 = 0.0D0
      DO 220 I = 1,5
         TOTLR2 = TOTLR2 + RLP2(I)
         TOTLR24 = TOTLR24 + RLP24(I)
         TOTLR120 = TOTLR120 + RLP120(I)
         TOTLR720 = TOTLR720 + RLP720(I)
220   CONTINUE
      WRITE (6,940) TOTLR2,TOTLR24,TOTLR120,TOTLR720
      TOTAL = TOTLR720 + TOTLR24
      WRITE (6,960) TOTAL
960   FORMAT('TOTAL 30-DAY DOSE (ESF + RWST) = ',D8.3,1X,'REM')
      STOP
      END
```



## 2 hour Site Boundary Dose

ESF Leakage (I-132)


$$\text{Dose}_{0.2 \text{ hrs}} = (4576) * (7.3E+07 / 2.2E+09) * (3.15E-04) * (3.47E-04) * \\ (6.29E+03) * (1E-04) * (1/.301) * (1-e^{-301*2})$$

$\text{Dose}_{0.2 \text{ hrs}} = .157\text{E}-04$  which agrees with the calculated value of  
.159E-04 within roundoff

RWST Leakage = 10 qpm (I-132)

$$\text{Dose}_{0.2 \text{ hrs}} = (2271258) * (7.3E+07 / 2.2E+09) * (3.15E-04) * (3.47E-04) * \\ (6.29E+03) * (1E-04) * (1/.301) * (1-e^{-301*2})$$

$\text{Dose}_{0.2 \text{ hrs}} = .779\text{E}-02$  which agrees with the calculated value of  
.790E-02 within roundoff



0 . 0 | 0 . 0 | ; 0 0 , 0

## Low Population Zone 30 day dose

RWST Leakage = 1.0 GPM (I-134)

$$30 \text{ day dose} = \text{Dose}_{0-24 \text{ hrs}} + \text{Dose}_{24 \text{ hrs}-5 \text{ days}} + \text{Dose}_{5-30 \text{ days}}$$

$$\text{Dose}_{0-24 \text{ hrs}} = (227125.8) * (1.1E+08 / 2.2E+09) * (7.5E-5) * (3.47E-04) * \\ (1.07E+03) * (1E-04) * (1/.791) * (1-e^{-.791*24})$$

$$\text{Dose}_{0-24 \text{ hrs}} = 3.998E-05$$

$$\text{Activity at 24 hours} = 1.1E+08 e^{-(.791*24)} = 6.26E-01$$

$$\text{Dose}_{1-5 \text{ days}} = (227125.8) * (6.26E-01 / 2.2E+09) * (2.6E-06) * (3.47E-04) * \\ (1.07E+03) * (1E-04) * (1/.791) * (1-e^{-.791*96})$$

$$\text{Dose}_{1-5 \text{ days}} = 7.890E-15$$


$$\text{Activity at 5 days} = 1.1E+08 e^{-(.791*96)} = 5.58E-34$$

$$\text{Dose}_{5-30 \text{ days}} = (227125.8) * (6.58E-34 / 2.2E+09) * (7.9E-07) * (3.47E-04) * \\ (1.07E+03) * (1E-04) * (1/.791) * (1-e^{-.791*96})$$

$$\text{Dose}_{5-30 \text{ days}} = 2.519E-48$$

$$\text{Total 30 day dose} = 3.998E-05 + 7.890E-15 + 2.519E-48$$

Total 30 day I-134 dose = 3.998E-05 = .3998E-04, which agrees within roundoff error with the calculated value of .416E-04.



0 0 | 0 0 | ; 0 0 ; |

## Low Population Zone 30 Day Dose

ESF Leakage (I-132)

$$30 \text{ day dose} = \text{Dose}_{0-24 \text{ hrs}} + \text{Dose}_{24 \text{ hrs}-5 \text{ days}} + \text{Dose}_{5-30 \text{ days}}$$

$$\begin{aligned} \text{Dose}_{0-24 \text{ hrs}} = & (4576) * (7.3E+07 / 2.2E+09) * (7.5E-5) * (3.47E-04) * \\ & (6.29E+03) * (1E-04) * (1/.301) * (1-e^{-.301*24}) \end{aligned}$$

$$\text{Dose}_{0-24 \text{ hrs}} = 8.252E-06$$

$$\text{Activity at 24 hours} = 7.3E+07 e^{-(.301*24)} = 5.32E+04$$

$$\begin{aligned} \text{Dose}_{1-5 \text{ days}} = & (4576) * (5.32E+04 / 2.2E+09) * (2.6E-06) * (3.47E-04) * \\ & (6.29E+03) * (1E-04) * (1/.301) * (1-e^{-.301*96}) \end{aligned}$$

$$\text{Dose}_{1-5 \text{ days}} = 2.087E-10$$


$$\text{Activity at 5 days} = 7.3E+07 e^{-(.301*96)} = 1.50E-08$$

$$\begin{aligned} \text{Dose}_{5-30 \text{ days}} = & (4576) * (1.50E-08 / 2.2E+09) * (7.9E-07) * (3.47E-04) * \\ & (6.29E+03) * (1E-04) * (1/.301) * (1-e^{-.301*96}) \end{aligned}$$

$$\text{Dose}_{5-30 \text{ days}} = 1.781E-23$$


$$\text{Total 30 day dose} = 8.252E-06 + 2.087E-10 + 1.789E-23$$

Total 30 day I-132 dose = .8252E-06 = .8252E-05, which agrees within roundoff error with the calculated value of .838E-05



ATTACHMENT 6 TO AEP:NRC:1238F1

CALCULATION NO. RD-88-01, REV. 2  
"CONTROL ROOM DOSE TO OPERATORS FOLLOWING A LOCA"



American Electric Power Service Corporation

**N**uclear Safety, Licensing & Assessment  
Calculation Cover Sheet

Calculation No. <u>RD 88-01</u> Rev. <u>2</u>	Plant <u>Cook</u> Unit <u>1 &amp; 2</u>
Subject <u>Control Room Dose to</u> <u>operators following a</u> <u>LOCA</u>	Company <u>AEP</u>
Safety Related System Yes <u>X</u> No <u>      </u>	Calculated By <u>Mark Ackerman</u>
Supercedes Calc. No. <u>RD 88-01 &amp; 88-01 Rev.1</u>	Verified/Checked By <u>W. Hall</u>
Method of Verification <u>Review of Calculations</u> Approved By <u>D. M. Hall 8/18/94</u>	

## Problem Description:

Determine the 30-day dose to control room operators following a LOCA, with TID 14840 source term. The calculation differs from Rev. 0 & Rev. 1 of this calc because it incorporates increased source terms based on an uprated power level (3588 Mwth), a revised atmospheric dispersion factor, and daughter products of metastable forms of Krypton-89.

## Design Basis Or References:

General Design Criterion 19. of  
10 CFR 50 Appx A.

## Executive Summary:

The dose to control room operators will be within 30 rem thyroid provided limits on intake are established as follows.

$$y = -0.048x + 150, \text{ where:}$$


$x$  = unfiltered intakeage (cFm)

$x$  = filtered intakeage (cFm)

Superseded By Calculation No. \_\_\_\_\_ Dated \_\_\_\_\_

Reason: \_\_\_\_\_

Page \_\_\_\_ Of \_\_\_\_



0 0 2 0 0 1 3 0 0 0 2

7223(9-83)  
FORM GE-8 (C)

8(c) ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO

SHEET 2 OF 41  
DATE 8-5-61 BY M.L.G. CK. as per  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

**SUBJECT** \_\_\_\_\_

## Table of Contents

A. Table of Contents	p. 2
B. Statement of Purpose	p. 3
C. Assumptions	p. 5
D. Analysis	p. 8
E. Verification	p. 31
F. Results	p. 32
G. Discussion of Results	p. 40
H. References	p. 41

0 0 1 0 0 1 3 0 0 0 2

00200150003

7223(9-83)  
FORM GE-8(C)ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIOSHEET 3 OF 41  
DATE 8-5-94 BY M.La CK estm  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_


SUBJECT \_\_\_\_\_

B. Statement of Purpose

Calc. RD 88-01 determined skin, whole body, and thyroid doses for control room operators in the event of a loss of cool. Calc. RD 88-01 Rev. 1 was written to correct an error in the thyroid dose analysis of RD 88-01. This revision (Rev. 2) of RD 88-01 is performed to accomplish the following:

- 1) Use radioactive source-term based on 3588 Mwt, versus the present 3411 Mwt, to bound a potential future power uprate for Cook Unit 2 (Applicable to thyroid skin and whole body doses.)
- 2) Enhance the calculational methodology by accounting for additional doses due to decay of metastable forms of Xenon and Krypton into normal forms. (Applicable to skin and whole body doses.)

00100150003




ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO

SHEET 4 OF 41  
DATE 5-5-94 BY MKA CK. WMH  
COMPANY  G.O.   
PLANT

SUBJECT \_\_\_\_\_

- 3) Allow for an additional 10 gpm of leakage of radioactive fluid from ECCS systems outside containment specifically, the calculation will account for 10 gpm of back-leakage into the RUST (Applicable to thyroid dose).
- 4) Correct a minor coding error for the whole body annual working dose code. Specifically, a spelling error was made in the original code ("Dedat" was misspelled as "Decdat"). The error affected the position of the code that calculated dose due to Kryptosite loop that did not contain Xenon dose did not contain the error. The error was in the conservative direction.
- 5) Incorporate revised atmospheric dispersion factors (~) into the code. These revised factors were developed by PLG, Inc. and have been factored into the plant operational limits via calculation RD-93-01. However, the actual codes were not previously modified.




SUBJECT \_\_\_\_\_

C Assumptions1 Source Term

1. 3.588 Mwt source terms: from Ref. 1.  
 As in the RD 88-01 Rev. 0 and Rev. 1,  
 100% of the core noble gas inventory  
 is released to the containment building  
 and is available for leakage. 50%  
 of the core iodine inventory is  
 released to the containment building,  
 and of this amount 50%  
 plates out on the containment  
 surface, leaving 25% of the core  
 iodine inventory available for  
 leakage.

Iodine Isotope	50% core (c.)	25% core (c.)
I-131	$5.0 \times 10^7$	$2.5 \times 10^7$
I-132	$7.3 \times 10^7$	$3.7 \times 10^7$
I-133	$1.0 \times 10^8$	$5.0 \times 10^7$
I-134	$1.1 \times 10^8$	$5.5 \times 10^7$
I-135	$1.9 \times 10^8$	ut core see sheet

Noble Gas Isotope	100% core (c.)	Actual Volume for
Kr 85 m	$2.16 \times 10^7$	$8.12 \times 10^7$
Kr 85	$8.3 \times 10^5$	Actual volume for
Kr 87	$4.8 \times 10^7$	I-135 are
Kr 88	$6.8 \times 10^7$	$50.2 \rightarrow 9.5 \times 10^7$ c.
Xe 131 m	$7.1 \times 10^5$	$25.7 \rightarrow 4.4 \times 10^7$ c.
Xe 133 m	$2.9 \times 10^7$	Amplified $8.7 \times 10^7$
Xe 133	$2.0 \times 10^8$	
Xe 135 m	$4.1 \times 10^7$	
Xe 135	$4.2 \times 10^7$	
Xe 138	$1.6 \times 10^8$	



00200150 SHEET 59 OF 41  
DATE BY CK. wby  
COMPANY G.O.  
PLANT

SUBJECT \_\_\_\_\_

Note:

In the process of the calculation being independently verified, an error was discovered in Ref. 1. Specifically, Table S-3.8-1 of the document listed the 100% core E-135 source term as  $1.9 \times 10^8$  Ci, while Table S-3.8-6 of the same document listed the 50% core value as  $1.9 \times 10^8$  Ci. The calculation was originally performed using the 50% value as  $1.9 \times 10^8$ . The discrepancy was discussed with Mr. Robin Lepidier of Westinghouse, who confirmed that  $1.9 \times 10^8$  Ci was the value for 100% of the core. E-135 thus, the calculation was in error since the E-135 source term was a factor of 2 too high.

The final version of the code and the final output were modified to reflect the correct E-135 source term. The corrected version was used in developing the final report provided in the Executive Summary (p. 1 of this addendum). However, the thyroid code was developed in discrete steps and each of these steps was verified as they were developed. The individual benchmark runs were not re-done, but the test has been post-noted where applicable to indicate that the problem existed.

00207130007

7223(9-83)  
FORM GE-8(C)ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIOSHEET 6 OF 41  
DATE 8-5-94 BY M.La CK. CKM  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

2. Atmospheric Dispersion Factors

The atmospheric dispersion factor ( $\gamma$ ) was taken from a special study conducted by PLG (Ref. 2). The baseline  $\gamma$  is  $7.85 \text{ E-4 sec}^{1/2}$ . As is RD-88-01 Rev. D, this value is adjusted downward for various time periods using the Murphy-Campbell factors (Ref. 3).


Time(h) Adjustment Factor ( $\gamma^{(Q)}$ )  $\gamma^{(50 \text{ sec})} (m^3)$

0-8	1.00	$6.17 \times 10^{-9}$	$7.85 \text{ E-4}$
8-24	0.59	$3.64 \times 10^{-9}$	$4.63 \text{ E-4}$
24-96	0.23	$1.42 \times 10^{-9}$	$1.81 \text{ E-4}$
96-720	0.066	$4.07 \times 10^{-10}$	$5.18 \text{ E-5}$

3. ESF Leaking

Sec. RD-88-01 indicates a  $4,576 \text{ sec/h}$  of leakage from ESF fluid systems outside containment. An additional 10 gpm of leakage to the KWT, fire facilities or intake of various valves in the facility (e.g., sump minim flow valves) will be included in the calculation revision. The leakage procedure accounted for ( $4,576 \text{ sec/h}$ ) was from components in the auxiliary buildings, which would be vented directly through the leak vent located on top of the containment building. This is an elevated release compound.

00100130007



ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO

SHEET 7 OF 41  
DATE 5-5-74 BY LMG CK WDM  
COMPANY AMERICAN ELECTRIC POWER G.O. 1  
PLANT COLUMBUS

SUBJECT \_\_\_\_\_

to the containment leakage release which assumed a release over the entire containment surface. The calc RD 88-01 conservatively used the  $\frac{1}{4}$  for the containment leakage for the E&F leakages portion.


For the release from the RUST (10 gpm) modeled in this calc revision, the distances from the RUST to the control room is greater than that from the containment building to the control room. From a discussion held with PLG (Ref E&F) on the containment leakage  $\times 10$  would be expected to bound the RUST release  $\times 10$  and therefore it will be used. The leakage is conservatively assumed to start from time zero rather than RUST startup due to recirculation which occurs at approximately 20 minutes.

The E&F leakage assumptions affect only the thyroid dose since the body goes remain in the containment atmosphere.

Additionally, the calc will neglect dilution of the E&F recirculation fluid by the RUST.

(See calc RD 94-01 for incorporation of additional 10 gpm into offsite air calculations)

\* Note that the leakages discussed above, contain, Piping fittings have been omitted.



ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO


DATE 6-5-77 BY LM CG CK WPM  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

D. Analysis

The analyses for calculation RD 88-01 and RD 88-01 Rev.1 were performed using 2 computer programs that run on VMS Fortran on the Eaton mainframe computer. For this revision of the calculation, the programs were re-typed and converted onto Microsoft Fortran for the IBM PC. The analysis was done as follows:

Step 1: Convert codes to Microsoft Fortran, including correction of known rounding precision errors. Ensure code gives same results as VMS Fortran 4.1 version, with the exception of the known lemma in the Krypton's close contribution to the whole body load due to verify results of Krypton's close contribution using hand calculations.



00200130010

7223(9-83)  
FORM GE-8(C)

ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO

SHEET B6 OF 41  
DATE 8-5-74 BY M-24 CK. WTM  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_


SUBJECT \_\_\_\_\_

Step 2: Incorporate revised assumptions  
into codes

Step 3: Verify codes

Step 4: Using results of revised codes,  
determine revised plant operating  
limits

00100130010




00200130011

7223(9-83)  
FORM GE-8(C)ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIOSHEET 9 OF 41  
DATE 3-5-74 BY M-LG CK. WRM  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT Sk. 1 : Coal Cons.

Sk. 1.1. survivor of whole Body Skin Dose ScaleAttachment 1 contains Figs. P.C.-baseFactor program which is essentially thesame as that used in the maincomputer for code RD. 83-01. Itincludes the original programsbased on error minimization of anumerical method that affected thecalculation of whole body and skindosage due to Kryptite radiationDirect comparison to the originalcode can be performed for theisobars; but, not for Kryptite source.(The purpose of the step issimply to verify the adequacy ofthe baseline code prior to makingany modifications associated with thisrevision.)

00100130011



00200130012

7223(9-83)  
FORM GE-8(C)ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIOSHEET 10 OF 41  
DATE 3-5-74 BY IN-01 CK 6024  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

Comparison of  $X_0 = 13.3$  from the attachment

1 cycle vs. the RD 88-01 Rev. 0

cycle is presented in the tables  
below.Flow Rate W.B. Dose (RD 88-01), W.B. Dose (PC) % diff  
(ccfm) (rem) (rem)

920 0.387 0.386 -0.26

1020 0.389 0.388 -0.26

1120 0.390 0.389 -0.26

Flow Rate Skin Dose (RD 88-01) Skin Dose (PC) % diff  
(ccfm) (rem) (rem)


920 11.2 11.2 0

1020 11.3 11.3 -0.89

1120 11.3 11.3 0

Excellent agreement is demonstrated between the  
PC and Mainframe versions of the code.

00100130012



00200130013

7223(9-83)  
FORM GE-8(C)ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIOSHEET 11 OF 41  
DATE: 5/14 BY J. M. H. CK. 6821  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_


As a second check, the sum of the Xenon isotope contributions to the whole body and skin dose will be compared at one foot rock (920 cfm).

	$\sum Xe_{35}$ w.p. (rem)	$\sum Xe_{35}$ s.t. (rem)
RD 88-01	0.647	21.1
PC	0.647	21.1
% DIFF.	0	0

The agreement is exact to 3 significant figures.

Next, a check will be made for 2 isotopes (Xe-133 and Kr-87) to check the PC program output versus an exact solution of the dose terms. The calc RD 88-01 is the exact sum of the dose eqn. for

00130130013



7223(9-83)  
FORM GE-8(C)ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIOSHEET 17 OF 41  
DATE 8-5-74 BY 7/2/74 CK. CDTL  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

A particular isotope was shown to be

$$\text{Dose } \int_0^T = (IA)(DCF)$$

where:  $\text{Dose } \int_0^T = \text{Dose whole body or skin accumlated}$   
 $\text{between time zero and } T$

$IA = \text{Integrated activity}$

$$= A_0 \left[ \frac{1}{\lambda_2} (1 - e^{-\lambda_2 T}) - \frac{1}{\lambda_1 + \lambda_2} (1 - e^{-(\lambda_1 + \lambda_2)T}) \right]$$

$$A_0 = S L \frac{x}{Q}$$

where:  $S = \text{Source at time zero}$

$L = \text{Containment tube length}$


$\frac{x}{Q} = \text{Dimensionless distance}$

$\lambda_2 = \text{radiative decay constant}$

$\lambda_1 = \text{Fluoride}$

control room volume

$DCF = \text{decay correction factor}$   
(cu. ft. or sec.)



2 0 2 2 2 1 3 0 0 1 5

7223(9-83) -  
FORM GE-8 (C)

**AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO**


SHEET 13 OF 41

DATE 3-5-76 BY P.M.H. CK.CURRY  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

**SUBJECT**

The exact eqn must be solved over discrete time steps, since factors such as  $\frac{x}{Q}$  and latent change over time. The following 2 tables provide the exact solution does tabulations for  $x_0 = 133$  and  $k_v = 85$ . Input parameters were derived from calc:  $R_D = 88.01$ . The calc. is done for a flow rate of 1020 cfm control room volume = 62356 ft<sup>3</sup>,  $p_{ex} = 0.88-01$ .

0 0 | 0 0 | 3 0 0 | 5



00200130016

7223(9-83)  
FORM GE-8(C)ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIOSHEET 14 OF 41  
DATE 5-14 BY 129 CK. WTRW  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

Isotope: Xe-133  
 Initial Activity:  $1.85 \times 10^8 \text{ Ci}$   
 $DCF(\text{W.B.}) = 1230 \text{ (rem-ff)} / (\text{Ci-h})$   
 $DCF(\text{skin}) = 1190 \text{ (rem-ff)} / (\text{Ci-h})$   
 $\lambda_2 = 5.5 \times 10^{-3} \text{ h}^{-1}$

Time Interval (hrs)	$\frac{\gamma}{Q}$ ( $\text{Ci}/\text{ft}^3$ )	Leak Rate ( $\text{hr}^{-1}$ )	W.B. Dose (rem)	skin dose (rem)
0-8	$1.90 \times 10^{-8}$	$1.04 \times 10^{-4}$	0.106	3.06
8-24	$1.12 \times 10^{-8}$	$1.04 \times 10^{-4}$	0.125	3.63
24-96	$-.37 \times 10^{-9}$	$5.20 \times 10^{-5}$	0.0914	2.64
96-720	$1.25 \times 10^{-9}$	$5.20 \times 10^{-5}$	0.0526	1.52

Total (from 0.375 10.9  
step-soln)


Exact soln :  $\frac{W.B.}{0.375} = 10.9$

PC output : 0.388 11.2

% Diff : 3.5 2.8

Very good agreement is demonstrated for Xe-133. The output agrees within 4% to the exact solution. Note that the PC output provides conservative results compared to the exact soln. The difference can be attributed to round off error, and the methodology used in the PC code which assumes radioactive decay occurs at the beginning of a time step, which is conservative.

00100130016



00200130017

7223(9-83)  
FORM GE-8(C)ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIOSHEET 15 OF 41  
DATE 6-5-74 BY MKA CKW  
COMPANY G.O.  
PLANT 

SUBJECT \_\_\_\_\_

Isotope:  $K_{\text{40}}$ -85Initial Activity:  $6.3 \times 10^5 \text{ Ci}$ DCF (w.p.) :  $6.5 \times 10^{-13} / \text{Ci-h}$ DCF (std) :  $5400 \times 10^{-13} / \text{Ci-h}$  $\lambda_2 = 1.738 \times 10^{-6} \text{ hr}^{-1}$ 


Time Interval (hr-1)	Leak Rate (hr-1)	W.B. Dose (rem)	SK - Dose (rem)
0-8	$1.90 \times 10^{-8}$	$1.04 \times 10^{-4}$	$1.99 \times 10^{-5}$
8-24	$1.12 \times 10^{-8}$	$1.04 \times 10^{-4}$	$2.53 \times 10^{-5}$
24-96	$4.37 \times 10^{-9}$	$5.20 \times 10^{-5}$	$2.35 \times 10^{-5}$
96-720	$1.25 \times 10^{-9}$	$5.20 \times 10^{-5}$	$5.90 \times 10^{-5}$
Total (from spreadsheet)		$1.28 \times 10^{-4}$	0.297

W.B.	SK
$1.28 \times 10^{-4}$	0.297

PC Output	6.305
70 Diff	23 27

Agreement (in) agreement is demonstrated
This time, the results change within 3% with the PC version again being conservative

00100130017




7223(9-83)  
FORM GE-8(C)ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIOSHEET 16 OF 41  
DATE 8-5-94 BY 17-16 CK. WWM  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

Step 1.2... conversion of Thru C6

Attachments 2 and 3 contain the PC-based Fortran programs which are essentially the same as those for the mainframe computer (in code R088-01 Rev 1). (Attachments 2 and 3 are identical except that one line is commented out. In Attachment 2 the line is not in Attachment 3. This line is: after the integer failure to filter normal intake damper in Attachment 3.) The programs in Attachment 2 and 3 consider values of filtered intake ranging from 900 to 1200 cfm, and unfiltered intake ranging from 10 to 40 cfm.



ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO


SHEET 17 OF 41  
DATE 8-5-94 BY CK.CWTH  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

A comparison of its program output for various combinations of filtered and unfiltered intakes vs. the RD 88-01. Below results are presented below.

	Base Case		Single failure	
Flow filt. (cfm)	Dose RD/Dose PC (rem)	% diff.	Dose RD/Dose PC (rem)	% diff.
900/10	24.1 / 24.1	0	37.4 / 37.4	0
1000/30	35.0 / 35.0	0	48.1 / 48.1	0
1100/20	32.8 / 32.8	0	45.9 / 45.9	0
1200/40	43.5 / 43.6	0.2	56.6 / 56.6	0

It is demonstrated above that the program results are essentially identical.



00200130010

7223(9-83)  
FORM GE-8(C)ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO

SHEET 18 OF 41

DATE 7-5-94 BY Linda CK WTR  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

Step 2.1. Revised Whole Body/Skin Code

There are 3 parts to this step:

i) incorporation of 3588 M.W. source term

ii) incorporation of revised 74/95

iii) incorporation of change in protection factor  
of nobly est. 5%


i) Incorporate 3588 M.W. source term

From Ref. 1, the 3588 M.W. source term  
for this noble gas fusion case:

Isotope	R.D. 88:91 Term (C:)	3588 M.W. Term (C:)	% diff.
Kr 85m	$2.6 \times 10^7$	$2.6 \times 10^7$	0
Kr 87	$6.3 \times 10^5$	$8.3 \times 10^5$	32
Kr 88	$4.7 \times 10^7$	$4.8 \times 10^7$	2.1
Xe 131m	$6.6 \times 10^5$	$7.1 \times 10^5$	7.6
Xe 133m	$2.8 \times 10^7$	$2.9 \times 10^7$	3.6
Xe 132	$1.9 \times 10^8$	$2.0 \times 10^8$	5.3
Xe 135m	$5.8 \times 10^7$	$4.1 \times 10^7$	7.9
Xe 135	$4.2 \times 10^7$	$4.2 \times 10^7$	0
Xe 138	$1.5 \times 10^8$	$1.6 \times 10^8$	6.7

The PC code was modified to incorporate the 3588 M.W.  
source term. The % diff. between the source case  
and 3588 M.W. source terms are shown in  
the table below, at 10<sup>20</sup> cfm. Although not  
demonstrated, the values are reasonable in light of the 10-20

00100130020



0 0 2 3 0 1 3 0 0 2 1

7223(9-83)  
FORM GE-8(C)


ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO

SHEET 19 OF 41  
DATE 6-5-94 BY 17-261 CK COTM  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

a significant digit with the 358.8 Mw  
source terms.

0 0 1 0 0 1 3 0 0 2 1



0 0 2 0 0 1 3 0 0 2 2

7223(9-63)  
FORM GE-6(C)ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIOSHEET 2A OF 41  
DATE 5-94 BY 1/21/61 CK.CKTR  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_


Feature	3598 MW	Base Case	% Diff.	% Diff.
	WB (cm)	WB (cm)	Some terms	Coder

Kr 85m	.42 E-1	.41 E-1	0	2.4
Kr 85	.17 E-3	.13 E-3	.32	3.1
Kr 87	.10 E-0	.99 E-1	.21	1.0
Kr 98	.59 E-0	.88 E-0	0	1.1
Xe 131m	.59 E-3	.54 E-2	.7.6	9.2
Xe 133m	.31 E-1	.37 E-1	.3.6	5.4
Xe 133	.42 E-0	.39 E-0	.5.3	7.7
Xe 135m	.46 E-2	.42 E-2	.7.9	7.0
Xe 135	.18 E-0	.13 E-0	0	0
Xe 138	.46 E-1	.43 E-1	.6.7	7.0

Feature	3598 MW	Base Case	% Diff.	% Diff.
	Stir (cm)	Stir (cm)	some terms	(n/a)

Kr 85m	.15 E-1	.14 E-1	0	7.1
Kr 85	.40 E-0	.30 E-0	.32	3.3
Kr 87	.46 E-1	.45 E-1	.2.1	2.2
Kr 98	.40 E-1	.40 E-1	0	0
Xe 131m	.95 E-1	.77 E-1	.7.6	9.6
Xe 133m	.44 E-1	.41 E-1	.3.6	7.3
Xe 133	.12 E-2	.11 E-2	.5.3	9.1
Xe 135m	.30 E-1	.27 E-1	.7.9	11
Xe 135	.52 E-1	.52 E-1	0	0
Xe 138	.60 E-0	.55 E-0	.6.7	7.1

0 0 1 0 0 1 3 0 0 2 2



0 0 2 0 0 1 3 0 0 ? 3

7223(9-63)  
FORM GE-8(C)ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO

SHEET 2 OF 41

DATE 7/5/67 BY Mr. JC CK CDR  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

Next, the revised  $\frac{V}{Q}$  is now incorporated into the calculations. The new  $\frac{V}{Q}$  is lower than the PD 88-01  $\frac{V}{Q}$  by a factor of  $\frac{6.17 \times 10^{-9}}{1.90 \times 10^{-8}} = 0.32$


The total whole body dose calculated at 1020 cfm will be compressed to 1112 ccf and result in the following table:

Whole Body Dose, units, Bq, Date (3588 mut, old $\frac{V}{Q}$ )	Whole Body Dose, units, Bq, Date (3588 mut, new $\frac{V}{Q}$ )	Ratio
1.72	0.5587	0.32

Skin Dose (3588 mut, old $\frac{V}{Q}$ )	Skin Dose (3588 mut, new $\frac{V}{Q}$ )	Ratio
32.85	10.67	0.32

Thus, it is demonstrated that the new  $\frac{V}{Q}$  is properly input into the code.

0 0 1 0 0 1 3 0 0 2 3



ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO

SHEET 2 OF 41  
DATE 7-5-74 BY 12-2A CK COTM  
COMPANY G.O.  
PLANT

SUBJECT \_\_\_\_\_

Next, the daughter products of the radioactive forms of the Americium and Krypton isotopes will be incorporated into the whole body/skin dose code.

The noble gas source term include: metastable forms of Xe-133m and Kr-85m. These metastable forms decay into the normal form of the isotope. Metastable forms b6, Kr-85t, Xe-131, Xe-133 and Xe-135 are included in the source term (of course, the normal form of Xe-131 is stable.)

Calc RP 88-01 account for the decay of the original inventory of the metastable form of the isotopes, but did not account for the subsequent buildup of the normal form. Since this is conservative to account for the buildup in this revision of the calculation.

From Ref. 3, the amount of the non-metastable form of the isotope at any time,  $t$ , is expressed by:


$$(1) \quad N_2(t) = \left[ N_2(0) e^{-\lambda_2 t} + \left( \frac{\lambda_1}{\lambda_2 - \lambda_1} \right) N_1(0) (e^{-\lambda_1 t} - e^{-\lambda_2 t}) \right]$$

where:  $N_2$  = activity of non-metastable form of isotope (c/s)

$\lambda_2$  = radioactive decay constant of non-metastable form ('time')

$\lambda_1$  = radioactive decay constant of metastable form of isotope ('time')

$N_1$  = activity of metastable form (c/s)



SUBJECT \_\_\_\_\_

The part bracketed,  $\lambda_2 - \lambda$ , in this equation represents the additional activity of the non-metastable form introduced by decay of the metastable form. As discussed previously, this is applicable to  $Kr = 85$ ,  $Xe = 133$ , and  $Xe = 135$ .

Eqn. 1 is written in terms of atoms ( $N$ ). Our input is in terms of activity, and activity is used in the Fortran program to determine dose. Activity =  $N\lambda$ , where  $\lambda$  = radioactive decay constant.

Rewriting part b. of eqn. 1 in terms of activity:


$$(2) N_2(t) = \lambda_1 A_1(0) (e^{-\lambda_1 t} - e^{-\lambda_2 t}) / (\lambda_2 - \lambda_1)$$

$$\text{Now, } A_2'(t) = N_2'(t) \lambda_2$$

$$(3) A_2'(t) = \lambda_2 N_2(0) (e^{-\lambda_1 t} - e^{-\lambda_2 t}) / (\lambda_2 - \lambda_1)$$

The PC code was modified to include the additional activity term represented by part b. above, for the applicable isotopes. Note that

Note that for  $Kr 85m$ , only 21.9% of the decay is lost in  $Kr 85$  (Ref. 7). This factor was 0.013047360255 in PC program.



ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO

0 0 2 0 0 1 3 SHEET 2 OF 41  
DATE 8/11/64 BY M.L.A. CK. 6001  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

## Verification of Daughter Product Changes

In order to verify appropriate inclusion of the daughter product decay in exact solution of the dose rate will be sought, similar to the method used earlier to verify the ICRU baseline code.

The additional activity due to metastable decay is:

$$(a) A_2 = \lambda_2 \left[ N_1 (e^{-\lambda_1 t} - e^{-\lambda_2 t}) \right] \quad (\lambda_2 = \lambda_1)$$

The integrated activity over the time period  $0 \rightarrow T$  is


$$(b) IA = \int_0^T \lambda_2 \left[ N_1 (e^{-\lambda_1 t} - e^{-\lambda_2 t}) \right] dt$$

Rewriting (b),

$$IA = \frac{\lambda_2 N_1}{\lambda_2 - \lambda_1} \int_0^T (e^{-\lambda_1 t} - e^{-\lambda_2 t}) dt$$

$$IA = \frac{N_1 \lambda_2}{\lambda_2 - \lambda_1} \left[ -\frac{1}{\lambda_1} e^{-\lambda_1 t} + \frac{1}{\lambda_2} e^{-\lambda_2 t} \right]_0^T$$

$$IA = \frac{N_1 \lambda_2}{\lambda_2 - \lambda_1} \left[ \left( -\frac{1}{\lambda_1} e^{-\lambda_1 T} + \frac{1}{\lambda_2} e^{-\lambda_2 T} \right) - \left( -\frac{1}{\lambda_1} + \frac{1}{\lambda_2} \right) \right]$$



ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO

00200 | 3-00 SHEET 725 OF 41  
DATE 8-11-94 BY M. L. G. CK. AMY  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

$$(3) \text{ If } A = \frac{N_1 \lambda_2}{\lambda_2 - \lambda_1} [1 - (1 - e^{-\lambda_1 T})] - \frac{1}{\lambda_2} (1 - e^{-\lambda_2 T})]$$

The dose due to this activity in the time period  $0 \rightarrow T$  is:


$$(4) \text{ Dose} = (\text{Eq. } A) \left(\frac{x}{Q}\right) (L) (DCF)$$

where  $\frac{x}{Q}$  = atom. disp. factor

$L$  = cont. leak. rate

DCF = Dose calc. factor

Note that eqn. 4 is actually a slight simplification since the development neglected build-up. As discussed previously, the "build-up factor" expresses the relationship between the concentration in the control room and the concentration outside the control room. The concentration inside the control room "builds up" to that of the outside atmosphere by an exponential function dependent on the control room volume and the intake air rate. Thus, the actual dose addition is reduced by the effect of the build-up factor.




ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO00200 DATE 8-18-70 SHEET 25a OF 41  
BY U/M/EE CK. 00M  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

In order to verify that the code was properly accounting for the metastable daughter products, the code was temporarily modified. One version looked at the time period 0-8 hours, and accounted for daughter products. The other version commented out the daughter product decay lines, and also looked at the 0-8 hour time period. Both of these cases set the buildup factor equal to 1.0, with no effect due to buildup, the difference between the two cases far the first iteration of the test should be equal to the solution at each end from the previous page.

The results of these runs for skin dose are provided in the following tables for the 0.20 cfm case.




ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO0 0 2 SHEET 25b OF 41  
DATE 81-10445 BY D.J. LARSON CK. 204COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

Isotope	skin dose w/daughters	skin dose, w/o daughters	$\lambda$	Exch rate
Kr-85	.02330	.02329	$1 \times 10^{-5}$	$3.1 \times 10^{-6}$
Xe-133	.255	1.251	0.10440	0.0038
Xe-135	1.258	1.226	0.032	0.032

For Kr-85, the difference between the calculated values and the  $\Delta$  can be attributed to round off. (We are looking at the 5th decimal place.) The additional value due to this is 0.00001. (Call it zero. For the other two isotopes good agreement is demonstrated.

The final version of the code is contained in Attachment 4.



00200130030

7223(9-83)  
FORM GE-8(C)ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIOSHEET 25 OF 41  
DATE 8/11/84 BY Mr. Miller - Director  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

Step 2? Revise thyroid code.

There are 3 parts to this step:

- i) Incorporation of 3588 mut source term
- ii) Incorporation of revised X/9
- iii) Incorporation of 10 gpm additional ECCS leakage outside containment

i) Incorporate 3588 mut source term

From ref. 1 thru 3588 mut source term for the iodine isotopes code

Isotope RD 88-01. Term 3588 mut term off  
(c) C.G.D.I-121 12.33 E7 2.5 x 10<sup>-7</sup> 3.3I-132 3.40 E7 3.7 x 10<sup>-7</sup> 8.8I-123 4.60 E7 5.0 x 10<sup>-7</sup> 4.12I-124 5.50 E7 5.5 x 10<sup>-7</sup> 0I-135 4.45 E7 1.5 x 10<sup>-7</sup> (13)

See classification

on page


Sig

MOLG 8-12-94

\* 25% of core inventory

\*\* Difference point due to new calculation method see discussion in Ref. 1

00100130030



7223(9-83)  
FORM GE-8(C)ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIOSHEET 77 OF 41  
DATE 6-5-94 BY 122111 CK ATM  
COMPANY AMERICAN ELECTRIC POWER G.O.  
PLANT COLUMBUS

SUBJECT \_\_\_\_\_

The new source terms were incorporated into the third stage positive base placement and the results compared to the previous version for the case of 900 cfm filtered / 10 cfm unfiltered single element fading.

Filter Type	30-00, Dose	30-00, Dose	70 Dose	2 Dose
I-(3)	124 E2	133 E2	7.3	7.3
I-132	6.38 E-1	6.95 E-1	8.8	8.9
I-133	3.38 E-1	3.52 E-1	4.2	4.1
I-134	1.57 E-1	1.57 E-1	0	0
I-135	4.73 E-0	10.1 E-1	(11.2)	(11.4)

3rd distribution


as per Sec 6.1.2.2.4

Excellent agreement is demonstrated.

Next, the revised X/Q will be incorporated. The revised X/Qs are listed below:

Time (hr.)	New X/Q (hr./ft <sup>3</sup> )
0-8	6.17 x 10 <sup>-9</sup>
8-24	3.64 x 10 <sup>-9</sup>
24-96	1.42 x 10 <sup>-9</sup>
96-720	4.07 x 10 <sup>-10</sup>

The new X/Q is lower than the 120.82 of Rev 1. X/Q by a factor of 0.32, or shown previously. The total thyroid dose for 900 cfm filtered / 10 cfm unfiltered intake, single failure case is shown in the table below.



ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO

SHEET 28 OF 41  
DATE 3-5-74 BY 172 fil CK ESTD  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

Thyroid Dose	Thyroid Dose	see d i s c u s s
Old X/Q	New X/Q	<u>P = 5 g</u>
(rem)	(rem)	<u>mg/g = 2.27</u>
<u>40.8</u>	<u>13.3</u>	<u>Ratio</u>
		<u>0.38</u>

This demonstrates that the new X/Q's were correctly input.


Next, the FSF leakage term will be increased.

In Calc. RD 88-D1, 4576 cc/hr. of FSF leakage was accounted for. (see page 12 of calc.) The dilution volume was  $2.2 \times 10^9$  cc and the fraction of the iodine extracted was  $1.8 \times 10^{-4}$ . The leakage fraction was taken as  $Source (c_i) \times \frac{4576 \text{ cc/hr.}}{2.2 \times 10^9 \text{ cc}} \times 10^{-4} = \text{Source} (2.08 \times 10^{-10} \text{ h.}$

We now wish to allow for an additional 10 gpm. The term can include tube flow besides.

$$\text{Source } (c_i) \times \left[ \frac{4576 \text{ cc/hr.} + 10 \text{ gal/min} \times 3785.43 \text{ cc}}{2.2 \times 10^9 \text{ cc}} \right]$$

$$= \text{Source } (c_i) \left( \frac{1.03 \times 10^{-7}}{\text{hr.}} \right)$$



00200130033

7223(9-83)  
FORM GE-8(C)ENGINEERING DEPT..  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIOSHEET 19 OF 41  
DATE 8-5-96 BY msl CK. wra  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

The revised leakage term was incorporated into the code. A quick check of the input can be made by noting the following:


The dose is proportional to the source term, leaking both inside and outside containment. The source term is comprised of the following two leakage factors:

a) Cont. Leak rate and b) ECCS leakage  
Leakage Factor

Item (b) has just been demonstrated to be  $2.08 \times 10^{-6}/\text{hr}$ . (Item (b) is essentially zero prior to incorporation of 10% of leakage for item (a), we will look at the dose from Item (b) over 18 days in (F) life between 2 and 8 hours. At this time period, the spray factor is constant at 12.5, thus the ratio of (b) to (a) is

$$\frac{1.03 \times 10^{-7}/\text{hr}}{\left[ \frac{1.08 \times 10^{-4}/\text{hr}}{12.5} \right]} = 0.124$$

00130130033



00200130034

7223(9-83)  
FORM GE-8(C)      ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO

SHEET 30 OF 41  
DATE 5-5-84 BY lh-lci CK WOM  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

For the 900/10 cfm case, the T-131 dose contributions for the old and new (Log rpm) runs are:

Old

$$\begin{aligned} 2 \text{ hrs} &= 2.654 \text{ rem} \\ 8 \text{ hrs} &= 3.016 \text{ rem} \\ \Delta &= 0.362 \text{ rem} \end{aligned}$$

New


$$\begin{aligned} 2 \text{ hrs} &= 2.722 \text{ rem} \\ 8 \text{ hrs} &= 3.129 \text{ rem} \\ \Delta &= 0.407 \text{ rem} \end{aligned}$$

These values differ by  $(0.407 - 0.362) = 0.045$ .

$$\frac{0.045 \text{ rem}}{0.362 \text{ rem}} = 0.124, \text{ which checks.}$$

The final version of the thyroid code is provided in Attachment 5. This listing is for the case of single fault O.A. for normal intake damper since that is the case in that it is applicable to current plant operations.

00100130034



0 0 2 0 0 - 3 0 0 0 5

7223(9-83)  
FORM GE-8 (C)

E-8(C) ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO

SHEET 31 OF L:

DATE - 7-3-94 BY - J.J. - 11 CK CORR

**COMPANY** \_\_\_\_\_ **G.O.** \_\_\_\_\_


**PLANT** \_\_\_\_\_

**SUBJECT** \_\_\_\_\_

## E.1 verification

Verification of the code was performed at 20% of the magnification and is described throughout the previous section.

0 0 1 0 0 1 3 0 0 3 5




SUBJECT \_\_\_\_\_

F. Results

The output from the final version of the whole body skin dose code provided in Attachment 6. The output of the final version of the thyroid code is provided in Attachment 7.

The code does provide the whole body doses for various fun rates. For the thyroid dose, it is necessary to distinguish between filtered and unfiltered leakage since the ionization room charcoal & HEPA filters are ineffective in removing radioactive iodine. For the whole body and skin dose, no distinction need be made since the dose is due to noble gases which are not removed by the filters. For the whole body and skin dose, both total leakage (filtered plus unfiltered) is important.

The thyroid dose results account for failure of the normal intake clamp to isolate consistently with the methodology of calc R.D. 88-0 and R.D. 88-01 Rel. 1, this amount to an additional 200 CFM of unfiltered leakage for the time period 0-2 hours after which the danger is assumed to be manually isolated.



SUBJECT \_\_\_\_\_


For the whole building and kitchen doors, single failure was not considered. However, the flow rate only impacts the building factors, which express the ratio of the concentration of noble gases inside the control room to that outside the control room. The building factor is:

$$BUF = 1 - e^{-\frac{E_{vol}}{vol} t}$$

At a typical flow rate of 1200 cfm, the BUF at 2 hrs (120 minutes) is:

$$BUF(2 \text{ hrs}) = 1 - e^{-\frac{1200 \text{ cfm}}{62.5 \text{ min}} (120 \text{ min})}$$

So, at 2 hours the noble gas concentration inside the control room is reduced 90% of that outside the control room. Thus, the effect of a 2 hour failure of the normal intake damper to isolate is essentially the same as adding an additional 200 cfm. As the intake base, in other words, 200 cfm of normal intake is equivalent to 1000 cfm of normal intake plus failure of the normal intake damper (200 cfm).




ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO

SHEET 34 OF 41  
DATE 7-5-64 BY MR. H. C. DOW  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

Per Ref. 4, themissible dose limits for control room operators are 30 rem thyroid, 5 rem whole body, and 30 rem skin. The objective of this calculation is to establish limits on filtered and unfiltered intakeage for the plant such that adherence to the dose limits is assured. This will be done by establishing the equation of a line that expresses the relationship between filtered and unfiltered intakeage rates. That result is a 30 rem thyroid dose. The first will be demonstrated that the intakeage limits established for thyroid dose will bound the skin and whole body dose.

A plot of the thyroid dose vs. unfiltered intakeage is provided in the following figure. The figure has lines for 800, 1000, and 1200 cfm. As seen in the figure, the dose works linearly with both filtered and unfiltered intakeage. This is as expected, given the linear nature of the dose equation. The data for the figure is provided on the next page.




0 0 2 0 0 1 3 0 0 3 9

8/18/42 - 35/41  
work

35/41

### THYROID DOSE

DOSE (REM)




800 CFM

1000 CFM

1200 CFM

0 0 1 0 0 1 3 0 0 3 9



ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO

SHEET 56 OF 41  
DATE 6-7-13 BY J. M. G. G. C. W. C. W. C. W.

COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_

PLANT \_\_\_\_\_

OBJECT \_\_\_\_\_

Unfilled

Unreduced

800

1000

1200

0

11.1

12.6

14.2

10

12.6

14.2

15.7

20

14.2

15.7

17.7

30

15.8

17.3

19.8

40

17.3

19.9


21.4

50

18.9

20.4

21.4



8/5/44

00230130041

7223(9-63)  
FORM GE-8(C)ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIOSHEET 32 OF 41  
DATE 8/5/44 BY M.A. CK W.M.  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

The next step is to determine two points which represent 2 combinations of filtered and unfiltered leakage which yield a 30 rem thyroid dose. Since the dose varies linearly with filtered and unfiltered leakage, 2 points are adequate. These 2 points will be used to determine the eqn. of a line in the form  $y = mx + b$ , where  $x$  = filtered leakage,  $y$  = unfiltered leakage.

800 cfm : 18.9 rem : 8:13-44

Dose @ 50 cfm unfiltered = 19.2 rem

Dose @ 0 cfm unfiltered = 11.3 rem

Slope =  $(19.2 - 11.3) / 50 \text{ cfm}$  =  $0.156 \text{ rem/unfiltered cfm}$

50 cfm : 0.156 rem : 8:13-44

Extrapolate to 30 rem

$30 \text{ rem} = \frac{(50 \text{ cfm})}{0.156} x + 11.3 \Rightarrow x = 148 \text{ cfm unfiltered}$

Point 1 = (800 cfm filtered, 118 cfm unfiltered)


1200 cfm : 14.2 rem : 8:13-44

Dose @ 50 cfm unfiltered = 22.3 rem

Dose @ 0 cfm unfiltered = 14.5 rem

Slope =  $(22.3 - 14.5) / 50 = 0.156 \text{ rem/unfiltered cfm}$   
(very close to previous slope, well within round-off error)

00100130041



00200150042

7223(9-83)  
FORM GE-8(C)ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIOSHEET 38 OF 41  
DATE 8/5/44 BY J.H. AB. CK. WDM  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

Extrapolate to 3.0 rem.

$$3.0 \text{ rem} = (0.156) x + 14.5$$

$$x = 9.94 \text{ cfm unfiltered}$$

$$\text{Point } 2 = (1200 \text{ cfm}, 9.94 \text{ cfm unfiltered})$$

Now, use points 1 and 2 to determine the slope of the line.

$$m = \text{slope} = \frac{y_2 - y_1}{x_2 - x_1} = \frac{9.94 - 48}{1200 - 800} = -0.047$$

Next, determine y-intercept ( $b$ )

$$y = mx + b$$


$$9.94 = (-0.047)(1200) + b \Rightarrow b = 156 \text{ cfm unfiltered}$$

So, the equation of the line expressing combinations of filtered & unfiltered intake is:

$$y = (-0.047)x + 156, \quad y = 0.048x + 159$$

where  $x = \text{filtered intake (cfm)}$   
 $y = \text{unfiltered intake (cfm)}$

00100130042



00200130043

7223(9-63)  
FORM GE-6(C)ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIOSHEET 39 OF 41DATE 5/14/64 BY M.L.A. CK COTM  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

The final step is to insure that the equation developed based on the thyroid dose limit of 30 rem will bound the whole body and skin dose limit of 5 and 30 rem, respectively.


For the whole body and skin doses only the total intake must be noted. The breakdown between filtered and unfiltered intake we will first determine. The maximum amount of total intake allowed by the thyroid dose limit is found by setting the y intercept equal to zero and determining the corresponding value of x.

$$\text{Thus, } y = mx + b \\ 0 = (0.048) x + 156$$

$$x = 3312 \text{ cfm}$$

An additional 200 cfm must be added to this for a total. The code contained in Attachment 4 was revised with a flowrate of 3573 cfm. The output is contained in Attachment 8. The whole body dose was 0.655 rem, and the skin dose was 12.2 rem. Both of these are well below the regulatory limits.

00103130043



00200130054

7223(9-63)  
FORM GE-8(C)ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO

SHEET 40 OF 41


DATE 7/7/44 BY M.L.C. CK copy  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

G. Discussion of Results


The results demonstrate the acceptability of the real nuclear plant control room ventilation system for assuring control room doses during emergency shutdowns. Dose rates at the control room operator's position - head, neck, and hands - are within regulatory limits. Typical values for neck are 10.00 cfr, filtered and 2.0 cfr unfiltered. These result in a thyroid dose of approximately 16 rem, skin dose of approximately 17 rem, and whole body dose of approximately 0.7 rem. All of these are well within the limits of 30 rem thyroid, 5 rem whole body, and 3.0 rem skin.

00100130044



SUBJECT \_\_\_\_\_

- H. References:
1. IWCAP 11902 Supplement, "Revised Power and Period Temperature and Pressure Operations for Donald C. Cook Nuclear Plant Units 1 and 2," Licensing Report, Westinghouse Electric Corp., September 1989.
  2. "Calc RD 93-01," including PLG Inc. report "Calculation of X/Q values for the Control Room Intakes," February 1993.
  3. "Mathematical Theory of Radiation Dosimetry," Fitzgerald Browne & McNamee, authors Gordon & Breach Science Publishers, 1967.
  4. NUREG 0800 (Standard Revision Plan) section 64.
  5. F.G. Murphy & K.M. Complex, "Nuclear Power Plant Control Room Monitoring System Design for Meeting Functional Criteria," 1971, 13th AECIAT (Cleaning), Kestrel, Inc.
  6. Personal discussion, Dr. S. Ackermann with Paul Abrams (PLG), 1-28-84.
  7. Kotter, D.C.: "Radiation Protection Data Tables," DOE/TIC 11026, 1981.



0 0 2 0 3 1 3 0 0 4 6

7223(9-83)  
FORM GE-8(C)


ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO

SHEET \_\_\_\_\_ OF \_\_\_\_\_  
DATE 2/1/84 BY DR. LIA CK. WONG  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

Attachment 1: Baseline code for  
whole body / skin Dose (Prismatic  
chamber Model for this calc)

0 0 1 0 0 1 3 0 0 4 6




0 0 2 6 3 ! 3 0 0 4 91:194 .  
DATE

Attachment 1

P 1/2

```
REAL*8 LEAKRT, KRCI(4), XECI(6), T, DELTAT, XQ,S,  
1 BUF,SKINT,WBDST,WBDS1,WBDS2,LAMBKR(4),LAMBXE(6),  
2 VOL,FLRT,KDCFS(4),KDCFB(4),SKIN1,SKIN2,  
3 XDCFS(6),XDCFB(6),XQF(4)  
INTEGER I,J,L  
CHARACTER*6 NAMEKR(4),NAMEXE(6)  
DATA NAMEKR /'KR85M','KR85','KR87','KR88',//  
1 NAMEXE /'XE131M','XE133M','XE133','XE135M','XE135','XE138',//  
2 KRCI /2.57D7,6.3D5,4.74D7,6.75D7//  
3 XECI /6.58D5,2.75D7,1.85D8,3.80D7,4.23D7,1.50D8//  
4 LAMBKR /0.155D0,7.40D-06,0.545D0,0.244D0//  
5 LAMBXE /2.43D-3,0.0132D0,5.51D-03,2.72D0,0.0763D0,2.93D0//  
DATA VOL /62356.0D0/,FLRT /920.0D0/,GF /28.0D0/  
DATA KDCFS /5.89D3,5.40D3,3.92D4,9.55D3//  
1 KDCFB /4.72D3,65.0D0,2.39D4,5.93D4//  
2 XDCFS /1.92D3,4.01D3,1.23D3,2.87D3,7.50D3,1.66D4//  
3 XDCFB /370.0D0,1.01D3,1.19D3,1.26D4,7.3D3,3.56D4//  
DATA XQF /1.90D-8,1.12D-8,4.37D-9,1.25D-9/  
OPEN (UNIT = 6, FILE = 'I:\NSL\MSA\CTRLROOM\NOBLEGAS.OUT')  
DO 900 L = 1,3  
    FLRT = DBLE(8.2D2+(DBLE(L)*100.0D0))  
    WRITE(6,500) FLRT  
500 FORMAT(' THE AIR FLOW TO THE CONTROL ROOM IS',F6.0,' CFM',//)  
    WRITE(6,600)  
600 FORMAT(' ISOTOPE WHOLE BODY BETA SKIN')  
    SKINT=0.0D0  
    WBDST=0.0D0  
    DO 100 I=1,4  
        SKIN1=0.0D0  
        WBDS1=0.0D0  
        T=0.0D0  
        DELTAT=0.1D0  
10     IF(T.GE.100.0) DELTAT=1.0D0  
        XQ=XQF(1)  
        IF (T.GT.8.0) XQ=XQF(2)  
        IF (T.GT.24.0) XQ=XQF(3)  
        IF (T.GT.96.0) XQ=XQF(4)  
        LEAKRT=1.04D-4  
        IF (T.GT.24.0) LEAKRT=5.21D-5  
        IF (LAMBKR(I)*T.LT.100.0) GO TO 15  
        S=0.0D0  
        GO TO 17  
15     S=KRCI(I)*DEXP(-LAMBKR(I)*T)*XQ*LEAKRT  
17     BUF=1.0D0  
        IF (T.LE.100.0) BUF=1.0D0-DEXP(-FLRT*60.0D0/VOL*(T+DELTAT))  
        SKIN1=SKIN1+(S*BUF*KDCFS(I)*DELTAT)  
        WBDS1=WBDS1+(S*BUF*KDCFB(I)*DELTAT)/GF  
        T=T+DELTAT  
        IF (T.LE.720.0) GO TO 10  
        SKINT=SKINT+SKIN1  
        WBDST=WBDST+WBDS1  
        WRITE (6,800) NAMEKR(I),WBDS1,SKIN1  
800     FORMAT (' ',A6,2X,D10.4,2X,D10.4)  
100    CONTINUE
```


0 0 | 0 0 | 3 0 0 4 7



3151  
A4 Document 1 P. 2/2

C  
C LOOPS FOR XENON ISOTOPES  
C  
DO 200 J=1,6  
SKIN2=0.0D0  
WBDS2=0.0D0  
T=0.0D0  
20 DELTAT=0.1D0  
IF (T.GE.100.0) DELTAT=1.0D0  
LEAKRT=1.04D-4  
IF (T.GT.24.0) LEAKRT=5.21D-5  
XQ=XQF(1)  
IF (T.GT.8.0) XQ=XQF(2)  
IF (T.GT.24.0) XQ=XQF(3)  
IF (T.GT.96.0) XQ=XQF(4)  
IF (LAMBXE(J)\*T.LE.100.0) GO TO 25  
S=0.0D0  
GO TO 27  
25 S=XECI(J)\*DEXP(-LAMBXE(J)\*T)\*XQ\*LEAKRT  
27 BUF=1.0D0  
IF (T.LE.100.0) BUF=1.0-DEXP(-FLRT\*50.0D0/VOL\*(T+DELTAT))  
SKIN2=SKIN2+(S\*BUF\*XDCFS(J)\*DELTAT)  
WBDS2=WBDS2+(S\*BUF\*XDCFB(J)\*DELTAT)/GF  
T=T+DELTAT  
IF (T.LE.720.0) GO TO 20  
SKINT=SKINT+SKIN2  
WBDST=WBDST+WBDS2  
WRITE (6,800) NAMEXE(J),WBDS2,SKIN2  
200 CONTINUE  
C  
C PRINT TOTAL DOSES  
C  
WRITE (6,810) WBDST  
810 FORMAT(/' TOTAL WHOLEBODY DOSE FOR 30 DAYS IS ',D10.4,'  
REM')  
820 WRITE(6,820) SKINT  
FORMAT(/' TOTAL SKINDOSE FOR 30 DAYS IS ',D10.4,' REM')  
WRITE (6,830)  
8 FORMAT('\*\*\*\*\*')  
900 CONTINUE  
STOP  
END

0 0 | 0 0 | 3 0 0 4 8



00200130049

7223(9-83)  
FORM GE-8(C)D  
ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIOSHEET 0 OF 0DATE 6/5/64 BY M. A. G. CK WPM  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_


SUBJECT \_\_\_\_\_

Attachment 2

Base Case Thyrid Col.

No. Failures

00100130049




21-72  
JFC  
eta

Attachment 2

P. 1/4

```
REAL*8 ILAMB(5),IDCF(5),PFACT(3),LEAKRT,LPART,  
1 SF,ICI(5),BREATH,F1,F2,F3,F30,ETA(3),IPF(3),  
2 DOSE,DOSET(7),T,DELTAT,XQF(4),S,DOSE05,  
3 DOSE10,DOSE20,DOSE80,DOSE96,TFLOW,XQ,F10  
CHARACTER*4 NAME(5)  
DATA DELTAT/1.0/  
DATA NAME/'I131','I132','I133','I134','I135'/  
DATA ILAMB/0.00359, 0.301, 0.0333, 0.791, 0.105/  
DATA ICI/ 2.33E+07,3.40E+07,4.80E+07,5.50E+07,4.45D+07/  
DATA IDCF/1.07E+06,6.29E+03,1.81E+05,1.07E+03,3.14E+04/  
DATA XQF/1.90D-08,1.12D-08,4.37D-09,1.25D-09/  
DATA BREATH/44.1/  
DATA LPART/6.7/  
DATA ETA/0.95,0.95,0.99/  
DATA PFACT/0.955,0.02,0.025/  
OPEN (UNIT = 6, FILE = 'I:\NSL\MSA\CTRLROOM\THYBASE.OUT')  
C VENTILATION SYSTEM FLOWRATE .  
TFLOW=5400.0D0  
C LOOP TO USE VARIOUS FILTERED INTAKE RATES  
DO 130 I2=1,4  
F1=900.0D0  
IF(I2.EQ.2) F1=1000.0D0  
IF(I2.EQ.3) F1=1100.0D0  
IF(I2.EQ.4) F1=1200.0D0  
F10=4200.0  
F2=TFLOW-F1  
C LOOP TO USE VARIOUS UNFILTERED INLEAKAGE RATES  
DO 120 I3=1,4  
F3=10.0D0  
IF(I3.EQ.2) F3=20.0D0  
IF(I3.EQ.3) F3=30.0D0  
IF(I3.EQ.4) F3=40.0D0  
F30 = F3 + 200  
DOSET(I3) = 0.0D0  
WRITE (6,290)  
290 FORMAT('INPUT I:\NSL\MSA\CTRLROOM\THYBASE.FOR')  
WRITE (6,295)  
295 FORMAT('OUTPUT I:\NSL\MSA\CTRLROOM\THYBASE.OUT')  
WRITE (6,297)
```




81 > 174  
L61  
A3

Attachment 2

P. 2/4

```
297  FORMAT('BASE CASE, NO FA LURE')
      WRITE(6,12) F2,F1,F3
12   FORMAT ('1',4X,'RECIRCULATION FLOW FROM CONTROL ROOM(CFM)',/
1     E10.4,/5X,'FILTERED INLEAKAGE(CFM)' E10.4,/5X,
2     'UNFILTERED INLEAKAGE(CFM)',E10.4,/13X,
3     'ISOTOPE',1X,'.5 HOUR DOSE(REM)',1X,' 1 HOUR DOSE(REM)',
4     ' 1X,' 2 HOUR DOSE(REM)',1X,' 8 HOUR DOSE(REM)',
5     ' 1X,' 4 DAY DOSE(REM)',1X,' 30 DAY DOSE(REM)',/)
C   LOOP TO SUM DOSES AND DISTINGUISH ELEMENTAL=1 ORGANIC=2 PART=3
      DO 110 I = 1,3
C   LOOP FOR DIFFERENT ISOTOPES OF IODINE
      DO 100 K=1,5
      DOSE = 0.0D0
      T=0.0D0
90   DELTAT = 0.01D0
      IF(T.GE.1.0) DELTAT = 0.1D0
      IF(T.GE.24.0) DELTAT = 1.0D0
C   LOOP FOR TIME INCREMENTS TO SUM CONCENTRATIONS AND DOSES
      IF(I.EQ.1) THEN
      SF=125.0
      IF (T.LT.0.100) SF=1.0/DEXP(-17.0*T)
      IF (T.GT.0.100.AND.T.LT.0.167) SF=5.47/DEXP(-14.3*(T-0.100))
      IF (T.GT.0.167.AND.T.LT.0.333) SF=14.26/DEXP(-22.5*(T-0.167))
      GO TO 11
      ENDIF
      IF(I.EQ.2) THEN
      SF=1.0
      GO TO 11
      ENDIF
      IF(I.EQ.3) THEN
      SF=200.0
      IF (T.LT.0.584) SF=1.0/DEXP(-LPART*T)
      IF (T.GT.0.584.AND.T.LT.2.65) THEN
          SF = 50.0/DEXP((-LPART/10.0)*(T-0.584))
      ENDIF
      GO TO 11
      ENDIF
C   DISPERSION FACTORS
11   XQ=XQF(1)
```




177  
11/25/84

Attachment 2

P. 3/4

```
IF(T.GT.8.0) XQ=XQF(2)
IF(T.GT.24.0) XQ=XQF(3)
IF(T.GT.96.0) XQ=XQF(4)
LEAKRT = 1.04D-04
IF(T.GT.24.0) LEAKRT = 5.21D-05
IF((ILAMB(K)*T).LT.100.0) GO TO 31
S = 0.0D0
GO TO 32
31   S = ICI(K)*(DEXP(-ILAMB(K)*T))*XQ*PFACT(I)*(LEAKRT/SF+
      2.08D-10)
      1 IPF(I)=(F1+ETA(I)*F2+F3)/((1.0-ETA(I))*F1+F3)
C     IF (T.LT.2.00) IPF(I)=(F1+ETA(I)*F2+F30)/((1.0-ETA(I))*F1+F30)
C     IF (T.LT.2.00) IPF(I)=(F10+F3)/((1.0-ETA(I))*F10+F3)
      DOSE = DOSE + (IDCF(K)*BREATH*S*DELTAT)/IPF(I)
32   IF(T.LT.0.51.AND.T.GT.0.49) DOSE05=DOSE
      IF(T.LT.1.01.AND.T.GT.0.99) DOSE10=DOSE
      IF(T.LT.2.05.AND.T.GT.1.95) DOSE20=DOSE
      IF(T.LT.8.05.AND.T.GT.7.95) DOSE80=DOSE
      IF(T.LT.96.1.AND.T.GT.95.9) DOSE96=DOSE
      T = T+DELTAT
34   IF(T.LE.720.0) GO TO 90
      IF(I.NE.1) GO TO 71
      WRITE(6,70) NAME(K),DOSE05,DOSE10,DOSE20,DOSE80,DOSE96,DOSE
70   FORMAT(' ELEMENTAL ',A4,6(8X,E10.4))
71   IF(I.NE.2) GO TO 72
      WRITE(6,75) NAME(K),DOSE05,DOSE10,DOSE20,DOSE80,DOSE96,DOSE
75   FORMAT(' ORGANIC ',A4,6(8X,E10.4))
72   IF(I.NE.3) GO TO 73
      WRITE(6,74) NAME(K),DOSE05,DOSE10,DOSE20,DOSE80,DOSE96,DOSE
74   FORMAT(' PARTICULATE ',A4,6(8X,E10.4))
73   DOSET(I3) = DOSET(I3) + DOSE
100  CONTINUE
110  CONTINUE
      WRITE(6,200) DOSET(I3)
200  FORMAT(' //, 'TOTAL DOSE FOR 30 DAYS ',E10.4//')
120  CONTINUE
130  CONTINUE
      WRITE(6,140)
140  FORMAT(';')
```



8 3174  
GL  
Cutter


Attachment 2

P. 414

STOP  
END

0 0 1 0 0 1 3 0 0 3 3

0 0 2 0 0 1 3 0 0 3 3



0 0 2 0 0 1 3 0 0 3 A

7223(9-83)  
FORM GE-8(C)

ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO

SHEET \_\_\_\_\_ OF \_\_\_\_\_  
DATE 1/16/64 BY CK 2021  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_


Attachment 3

Base Core Thyroid Cycle Size

Failure of normal size

Damper


0 0 1 0 0 1 3 0 0 4



Attachment 3

P- 114

```
REAL*8 ILAMB(5),IDCF(5),PFACT(3),LEAKRT,LPART,  
1 SF,ICI(5),BREATH,F1,F2,F3,F30,ETA(3),IPF(3),  
2 DOSE,DOSET(7),T,DELTAT,XQF(4),S,DOSE05,  
3 DOSE10,DOSE20,DOSE80,DOSE96,TFLOW,XQ,F10  
CHARACTER*4 NAME(5)  
DATA DELTAT/1.0/  
DATA NAME/'I131','I132','I133','I134','I135'/  
DATA ILAMB/0.00359, 0.301, 0.0333, 0.791, 0.105/  
DATA ICI/ 2.33E+07,3.40E+07,4.80E+07,5.50E+07,4.45D+07/  
DATA IDCF/1.07E+06,6.29E+03,1.81E+05,1.07E+03,3.14E+04/  
DATA XQF/1.90D-08,1.12D-08,4.37D-09,1.25D-09/  
DATA BREATH/44.1/  
DATA LPART/6.7/  
DATA ETA/0.95,0.95,0.99/  
DATA PFACT/0.955,0.02,0.025/  
OPEN (UNIT = 6, FILE = 'I:\NSL\MSA\CTRLROOM\THYBASEF.OUT')  
C VENTILATION SYSTEM FLOWRATE  
    TFLOW=5400.0D0  
C LOOP TO USE VARIOUS FILTERED INTAKE RATES  
    DO 130 I2=1,4  
        F1=900.0D0  
        IF(I2.EQ.2) F1=1000.0D0  
        IF(I2.EQ.3) F1=1100.0D0  
        IF(I2.EQ.4) F1=1200.0D0  
        F10=4200.0  
        F2=TFLOW-F1  
C LOOP TO USE VARIOUS UNFILTERED INLEAKAGE RATES  
    DO 120 I3=1,4  
        F3=10.0D0  
        IF(I3.EQ.2) F3=20.0D0  
        IF(I3.EQ.3) F3=30.0D0  
        IF(I3.EQ.4) F3=40.0D0  
        F30 = F3 + 200  
        DOSET(I3) = 0.0D0  
        WRITE (6,290)  
290     FORMAT('INPUT I:\NSL\MSA\CTRLROOM\THYBASEF.FOR')  
        WRITE (6,295)  
295     FORMAT('OUTPUT I:\NSL\MSA\CTRLROOM\THYBASEF.OUT')  
        WRITE (6,297)
```




815144  
7/1/84

Attachment 3

P. 2/4

```
297      FORMAT('BASE CASE, NORMAL INTAKE DAMPER FAILURE')
        WRITE(6,12) F2,F1,F3
12       FORMAT ('1',4X,'RECIRCULATION FLOW FROM CONTROL ROOM(CFM)',,
1       E10.4,/,5X,'FILTERED INLEAKAGE(CFM)' E10.4,/5X,
2       'UNFILTERED INLEAKAGE(CFM)',E10.4,/13X,
3       'ISOTOPE',1X,'.5 HOUR DOSE(REM)',1X,' 1 HOUR DOSE(REM)',
4       1X,' 2 HOUR DOSE(REM)',1X,' 8 HOUR DOSE(REM)',
5       1X,' 4 DAY DOSE(REM)',1X,' 30 DAY DOSE(REM)',/)
C LOOP TO SUM DOSES AND DISTINGUISH ELEMENTAL=1 ORGANIC=2 PART=3
DO 110 I = 1,3
C LOOP FOR DIFFERENT ISOTOPES OF IODINE
DO 100 K=1,5
DOSE = 0.0D0
T=0.0D0
90      DELTAT = 0.01D0
IF(T.GE.1.0) DELTAT = 0.1D0
IF(T.GE.24.0) DELTAT = 1.0D0
C LOOP FOR TIME INCREMENTS TO SUM CONCENTRATIONS AND DOSES
IF(I.EQ.1) THEN
SF=125.0
IF (T.LT.0.100) SF=1.0/DEXP(-17.0*T)
IF (T.GT.0.100.AND.T.LT.0.167) SF=5.47/DEXP(-14.3*(T-0.100))
IF (T.GT.0.167.AND.T.LT.0.333) SF=14.26/DEXP(-22.5*(T-0.167))
GO TO 11
ENDIF
IF(I.EQ.2) THEN
SF=1.0
GO TO 11
ENDIF
IF(I.EQ.3) THEN
SF=200.0
IF (T.LT.0.584) SF = 0/DEXP(-LPART*T)
IF (T.GT.0.584.AND.T.LT.2.65) THEN
SF = 50.0/DEXP((-LPART/10.0)*(T-0.584))
ENDIF
GO TO 11
ENDIF
C DISPERSION FACTORS
11      XQ=XQF(1)
```




8/5/91  
Jrd

Attachment 3

p. 3/4

```
IF(T.GT.8.0) XQ=XQF(2)
IF(T.GT.24.0) XQ=XQF(3)
IF(T.GT.96.0) XQ=XQF(4)
LEAKRT = 1.04D-04
IF(T.GT.24.0) LEAKRT = 5.21D-05
IF((ILAMB(K)*T).LT.100.0) GO TO 31
S = 0.0D0
GO TO 32
31   S = ICI(K)*(DEXP(-ILAMB(K)*T))*XQ*PFACT(I)*(LEAKRT/SF+
           2.08D-10)
      1 IPF(I)=(F1+ETA(I)*F2+F3)/((1.0-ETA(I))*F1+F3)
         IF (T.LT.2.00) IPF(I)=(F1+ETA(I)*F2+F30)/((1.0-ETA(I))*F1+F30)
C       IF (T.LT.2.00) IPF(I)=(F10+F3)/((1.0-ETA(I))*F10+F3)
DOSE = DOSE + (IDCF(K)*BREATH*S*DELTAT)/IPF(I)
32   IF(T.LT.0.51.AND.T.GT.0.49) DOSE05=DOSE
      IF(T.LT.1.01.AND.T.GT.0.99) DOSE10=DOSE
      IF(T.LT.2.05.AND.T.GT.1.95) DOSE20=DOSE
      IF(T.LT.8.05.AND.T.GT.7.95) DOSE80=DOSE
      IF(T.LT.96.1.AND.T.GT.95.9) DOSE96=DOSE
      T = T+DELTAT
34   IF(T.LE.720.0) GO TO 90
      IF(I.NE.1) GO TO 71
      WRITE(6,70) NAME(K),DOSE05,DOSE10,DOSE20,DOSE80,DOSE96,DOSE
      70  FORMAT(' ELEMENTAL ',A4,6(8X,E10.4))
      71  IF(I.NE.2) GO TO 72
      WRITE(6,75) NAME(K),DOSE05,DOSE10,DOSE20,DOSE80,DOSE96,DOSE
      75  FORMAT(' ORGANIC ',A4,6(8X,E10.4))
      72  IF(I.NE.3) GO TO 73
      WRITE(6,74) NAME(K),DOSE05,DOSE10,DOSE20,DOSE80,DOSE96,DOSE
      74  FORMAT(' PARTICULATE ',A4,6(8X,E10.4))
      73  DOSET(I3) = DOSET(I3) + DOSE
100   CONTINUE
110   CONTINUE
      WRITE(6,200).DOSET(I3)
200   FORMAT(' ',/,'TOTAL DOSE FOR 30 DAYS ',E10.4//)
120   CONTINUE
130   CONTINUE
      WRITE(6,140)
140   FORMAT(' ;')
```



8/15/94  
10 AM  
WAMM


Attachment 3

P. 414

STOP  
END

0 0 1 0 0 1 3 0 0 5 8

0 0 2 0 0 1 5 0 0 1 0



00200130059

7223(9-83)  
FORM GE-8(C)

ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO


SHEET \_\_\_\_\_ OF \_\_\_\_\_  
DATE 6/15/94 BY Miller CK. WSM  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

Attachment 4

Final Code Listing Re-  
whole Body / SLM Dose

00100130059




Attachment 4

P. 113

8/11/44

m2a  
wta


REAL\*8 LEAKRT, KRCI(4), XECI(6), T, DELTAT, XQ,S,  
1 BUF, SKINT, WBDST, WBDS1, WBDS2, LAMBKR(4), LAMBXE(6),  
2 VOL, FLRT, KDCFS(4), KDCFB(4), SKIN1, SKIN2,  
3 XDCFS(6), XDCFB(6), XQF(4), XEMETA(6), KRMETA(5)  
  
INTEGER I,J,L  
CHARACTER\*6 NAMEKR(4),NAMEXE(6)  
DATA NAMEKR /'KR85M','KR85','KR87','KR88'/,  
1 NAMEXE /'XE131M','XE133M','XE133','XE135M','XE135','XE138'/,  
2 KRCI /2.6D7,8.3D5,4.8D7,6.8D7/,  
3 XECI /7.1D5,2.9D7,2.0D8,4.1D7,4.2D7,1.6D8/,  
4 LAMBKR /0.155D0,7.40D-06,0.545D0,0.244D0/,  
5 LAMBXE /2.43D-3,0.0132D0,5.51D-03,2.72D0,0.0763D0,2.93D0/  
DATA VOL /62356.0D0/,FLRT /920.0D0/,GF /28.0D0/  
DATA KDCFS /5.89D3,5.40D3,3.92D4,9.55D3/,  
1 KDCFB /4.72D3,65.0D0,2.39D4,5.93D4/,  
2 XDCFS /1.92D3,4.01D3,1.23D3,2.87D3,7.50D3,1.66D4/,  
3 XDCFB /370.0D0,1.01D3,1.19D3,1.26D4,7.3D3,3.56D4/  
DATA XQF /6.17E-9,3.64E-9,1.42E-9,4.07E-10/  
OPEN (UNIT = 6, FILE = 'I:\NSL\MSA\CTRLROOM\NOBFINAL.OUT')  
DO 900 L = 1,3  
    FLRT = DBLE(8.2D2+(DBLE(L)\*100.0D0))  
    WRITE(6,300)  
300 FORMAT('INPUT:NOBFINAL.FOR; OUTPUT:NOBFINAL.OUT')  
    WRITE(6,350)  
350 FORMAT('3588 MWT, NEW X/Q, CORRECTED METASTABLE DECAY')  
    WRITE(6,500) FLRT  
500 FORMAT(' THE AIR FLOW TO THE CONTROL ROOM IS',F6.0,' CFM',/),  
    WRITE(6,600)  
60 FORMAT(' ISOTOPE WHOLE BODY BETA SKIN')  
    SKINT=0.0D0  
    WBDST=0.0D0  
  
C  
C LOOPS FOR KRYPTON ISOTOPES  
C  
DO 100 I=1,4  
 SKIN1=0.0D0  
 WBDS1=0.0D0  
 T=0.0D0  
 DELTAT=0.1D0  
10 IF(T.GE.100.0) DELTAT=1.0D0  
 XQ=XQF(1)  
 IF (T.GT.8.0) XQ=XQF(2)  
 IF (T.GT.24.0) XQ=XQF(3)  
 IF (T.GT.96.0) XQ=XQF(4)  
 LEAKRT=1.04D-4  
 IF (T.GT.24.0) LEAKRT=5.21D-5  
 IF (LAMBKR(I)\*T.LT.100.0) GO TO 15  
 S=0.0D0  
 GO TO 17  
 IF (I.EQ.2) THEN  
 KRMETA(I) = ((LAMBKR(I)/(LAMBKR(I)-LAMBKR(I-1)))\*KRCI(I-1)\*  
 (DEXP(-LAMBKR(I-1)\*T)-DEXP(-LAMBKR(I)\*T)))\*0.211D0  
 ELSE  
 KRMETA(I) = 0.0D0  
 ENDIF  
 S=(KRCI(I)\*DEXP(-LAMBKR(I)\*T)+KRMETA(I))\*XQ\*LEAKRT  
 BUF=1.0D0  
 IF (T.LE.100.0) BUF=1.0D0-DEXP(-FLRT\*60.0D0/VOL\*(T+DELTAT))  
 SKIN1=SKIN1+(S\*BUF\*KDCFS(I)\*DELTAT)  
 WBDS1=WBDS1+(S\*BUF\*KDCFB(I)\*DELTAT)/GF  
900 0 0 | 0 0 | 3 0 0 5 0



*A+Tachment* 0 0 2 0 0 1 3 0 0 5 1 P. 213  
0 0 2 0 0 1 3 0 0 5 1 M-FG 8/1/66

T=T+DELTAT  
IF (T.LE.720.0) GO TO 10

0 0 1 0 0 1 3 0 0 6 1



0 0 2 0 0 1 3 0 0 &gt; 2

T-100

11/24

WTM

```

SKINT=SKINT+SKIN1
WBDST=WBDST+WBDS1
WRITE (6,800) NAMEKR(I),WBDS1,SKIN1
FORMAT (' ',A6,2X,D10.4,2X,D10.4)
CONTINUE

```

## C LOOPS FOR XENON ISOTOPES

```

DO 200 J=1,6
SKIN2=0.0D0
WBDS2=0.0D0
T=0.0D0
20 DELTAT=0.1D0
IF (T.GE.100.0) DELTAT=1.0D0
LEAKRT=1.04D-4
IF (T.GT.24.0) LEAKRT=5.21D-5
XQ=XQF(1)
IF (T.GT.8.0) XQ=XQF(2)
IF (T.GT.24.0) XQ=XQF(3)
IF (T.GT.96.0) XQ=XQF(4)
IF (LAMBXE(J)*T.LE.100.0) GO TO 25
S=0.0D0
GO TO 27
IF (J.EQ.3.OR.J.EQ.5) THEN
XEMETA(J) = (LAMBXE(J) / (LAMBXE(J)-LAMBXE(J-1))) * XECI(J-1) *
1 (DEXP(-LAMBXE(J-1)*T) - DEXP(-LAMBXE(J)*T))
ELSE
XEMETA(J) = 0.0D0
ENDIF

```

```

S=(XECI(J)*DEXP(-LAMBXE(J)*T)+XEMETA(J))*XQ*LEAKRT
BUF=1.0D0
IF (T.LE.100.0) BUF=1.0-DEXP(-FLRT*60.0D0/VOL*(T+DELTAT))
SKIN2=SKIN2+(S*BUF*XDCFS(J)*DELTAT)
WBDS2=WBDS2+(S*BUF*XDCFB(J)*DELTAT)/GF
T=T+DELTAT
IF (T.LE.720.0) GO TO 20
SKINT=SKINT+SKIN?
WBDST=WBDST+WBDS2
WRITE (6,800) NAMEXE(J),WBDS2,SKIN2
200 CONTINUE

```


## C PRINT TOTAL DOSES

```

810 WRITE (6,810) WBDST
FORMAT(' TOTAL WHOLEBODY DOSE FOR 30 DAYS IS ',D10.4,' REM')
WRITE(6,820) SKINT
820 FORMAT(' TOTAL SKINDOSE FOR 30.DAYS IS ',D10.4,' REM')
WRITE (6,830)
830 FORMAT('*****')
900 CONTINUE
STOP
END

```

0 0 1 0 0 1 3 0 0 6 2



0 0 2 0 0 1 3 0 0 , 3

7223(9-83)  
FORM GE-8(C)

ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO


SHEET 1 OF 1  
DATE 1/5/44 BY 12-ACKW  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

Attachment 5

Final Code Listings for  
Thyroid Dose

0 0 1 0 0 1 3 0 0 6 3



A + 10-6 2 0 3 1 3 0 0 ; *mtg*  
P. 115  
7-13-91  
*WAM*

REAL\*8 ILAMB(5), IDC(5), PFACT(3), LEAKRT, LPART,  
1 SF, ICI(5), BREATH, F1, F2, F3, F30, ETA(3), IPF(3),  
2 DOSE, DOSET(7), T, DELTAT, XQF(4), S, DOSE05,  
3 DOSE10, DOSE20, DOSE80, DOSE96, TFLOW, XQ, F10  
CHARACTER\*4 NAME(5)  
DATA DELTAT/1.0/  
DATA NAME/'I131','I132','I133','I134','I135'/  
DATA ILAMB/0.00359, 0.301, 0.0333, 0.791, 0.105/  
DATA ICI/ 2.5E+07, 3.7E+07, 5.0E+07, 5.5E+07, 4.8D+07/  
DATA IDC/1.07E+06, 6.29E+03, 1.81E+05, 1.07E+03, 3.14E+04/  
DATA XQF/6.17D-9, 3.64D-9, 1.42D-9, 4.07D-10/  
DATA BREATH/44.1/  
DATA LPART/6.7/  
DATA ETA/0.95, 0.95, 0.99/  
DATA PFACT/0.955, 0.02, 0.025/  
OPEN (UNIT = 6, FILE = 'I:\NSL\MSA\CTRLROOM\THYFINAL.OUT')  
C VENTILATION SYSTEM FLOWRATE  
TFLOW=5400.0DO  
C LOOP TO USE VARIOUS FILTERED INTAKE RATES  
DO 130 I2=1,8  
F1=800.0DO  
IF(I2.EQ.2) F1=900.0DO  
IF(I2.EQ.3) F1=1000.0DO  
IF(I2.EQ.4) F1=1100.0DO  
IF(I2.EQ.5) F1=1200.0DO  
IF(I2.EQ.6) F1=1300.0DO  
IF(I2.EQ.7) F1=1400.0DO  
IF(I2.EQ.8) F1=1500.0DO  
F10=4200.0  
F2=TFLOW-F1  
LOOP TO USE VARIOUS UNFILTERED INLEAKAGE RATES  
DO 120 I3=1,6  
F3=0.0DO  
IF(I3.EQ.2) F3=10.0DO  
IF(I3.EQ.3) F3=20.0DO  
IF(I3.EQ.4) F3=30.0DO  
IF(I3.EQ.5) F3=40.0DO  
IF(I3.EQ.6) F3=50.0DO  
F30 = F3 + 200  
DOSET(I3) = 0.0DO  
WRITE (6,290)  
290 FORMAT('INPUT I:\NSL\MSA\CTRLROOM\THYFINAL.FOR')  
WRITE (6,295)  
295 FORMAT('OUTPUT I:\NSL\MSA\CTRLROOM\THYFINAL.OUT')  
WRITE (6,297)  
297 FORMAT('FINAL CASE: NEW XQ, 3588,10 GPM, CORRECTED I-135 ')  
WRITE(6,12) F2,F1,F3  
12 FORMAT ('1',4X,'RECIRCULATION FLOW FROM CONTROL ROOM(CFM)',  
1 E10.4,/,5X,'FILTERED INLEAKAGE(CFM)' E10.4,/,5X,  
2 'UNFILTERED INLEAKAGE(CFM)', E10.4,/,13X,  
3 'ISOTOPE',1X,'.5 HOUR DOSE(REM)',1X,' 1 HOUR DOSE(REM)',  
4 1X,' 2 HOUR DOSE(REM)',1X,' 8 HOUR DOSE(REM)',  
5 1X,' 4 DAY DOSE(REM)',1X,' 30 DAY DOSE(REM)',/)  
C LOOP TO SUM DOSES AND DISTINGUISH ELEMENTAL=1 ORGANIC=2 PART=3  
DO 110 I = 1,3  
LOOP FOR DIFFERENT ISOTOPES OF IODINE  
DO 100 K=1,5  
DOSE = 0.0DO  
T=0.0DO  
90 DELTAT = 0.01DO  
0 0 1 0 0 1 3 0 0 3 4

*A + f* 0 0 8 0 2 0 0 1 3 0 0 0 5 5 2 1 5


IF(T.GE.1.0) DELTAT = 0.1D0  
IF(T.GE.24.0) DELTAT = 1.0D0

*mfc*

8-13-94

WTH

0 0 1 0 0 1 3 0 0 6 5



A 44.5 D-315  
0 0 2 0 3 1 3 0 0 , 5 4 - 13 - 4 -  
m-R2  
WRI

C LOOP FOR TIME INCREMENTS TO SUM CONCENTRATIONS AND DOSES  
IF(I.EQ.1) THEN  
SF=125.0  
IF (T.LT.0.100) SF=1.0/DEXP(-17.0\*T)  
IF (T.GT.0.100.AND.T.LT.0.167) SF=5.47/DEXP(-14.3\*(T-0.100))  
IF (T.GT.0.167.AND.T.LT.0.333) SF=14.26/DEXP(-22.5\*(T-0.167))  
GO TO 11  
ENDIF  
IF(I.EQ.2) THEN  
SF=1.0  
GO TO 11  
ENDIF  
IF(I.EQ.3) THEN  
SF=200.0  
IF (T.LT.0.584) SF=1.0/DEXP(-LPART\*T)  
IF (T.GT.0.584.AND.T.LT.2.65) THEN  
SF = 50.0/DEXP((-LPART/10.0)\*(T-0  
ENDIF  
GO TO 11  
ENDIF

C DISPERSION FACTORS

11 XQ=XQF(1)

IF(T.GT.8.0) XQ=XQF(2)  
IF(T.GT.24.0) XQ=XQF(3)  
IF(T.GT.96.0) XQ=XQF(4)

LEAKRT = 1.04D-04

IF(T.GT.24.0) LEAKRT = 5.21D-05  
IF((ILAMB(K)\*T).LT.100.0) GO TO 31

S = 0.0D0

GO TO 32

S = ICI(K)\*(DEXP(-ILAMB(K)\*T))\*XQ\*PFACT(I)\*(LEAKRT/SF+  
1.03D-7)

1 IPF(I)=(F1+ETA(I)\*F2+F3)/((1.0-ETA(I))\*F1+F3)  
IF (T.LT.2.00) IPF(I)=(F1+ETA(I)\*F2+F30)/((1.0-ETA(I))\*F1+F30)

C IF (T.LT.2.00) IPF(I)=(F10+F3)/((1.0-ETA(I))\*F10+F3)

DOSE = DOSE + (IDCF(K)\*BREATH\*S\*DELTAT)/IPF(I)

32 IF(T.LT.0.51.AND.T.GT.0.49) DOSE05=DOSE

IF(T.LT.1.01.AND.T.GT.0.99) DOSE10=DOSE

IF(T.LT.2.05.AND.T.GT.1.95) DOSE20=DOSE

IF(T.LT.8.05.AND.T.GT.7.95) DOSE80=DOSE

IF(T.LT.96.1.AND.T.GT.95.9) DOSE96=DOSE

T = T+DELTAT

34 IF(T.LE.720.0) GO TO 90

IF(I.NE.1) GO TO 71

WRITE(6,70) NAME(K),DOSE05,DOSE10,DOSE20,DOSE80,DOSE96,DOSE

70 FORMAT(' ELEMENTAL ',A4,6(8X,E10.4))

71 IF(I.NE.2) GO TO 72

WRITE(6,75) NAME(K),DOSE05,DOSE10,DOSE20,DOSE80,DOSE96,DOSE

75 FORMAT(' ORGANIC ',A4,6(8X,E10.4))

72 IF(I.NE.3) GO TO 73

WRITE(6,74) NAME(K),DOSE05,DOSE10,DOSE20,DOSE80,DOSE96,DOSE

74 FORMAT(' PARTICULATE ',A4,6(8X,E10.4))

73 DOSET(I3) = DOSET(I3) + DOSE

100 CONTINUE

CONTINUE

200 WRITE(6,200) DOSET(I3)


FORMAT(' //,'TOTAL DOSE FOR 30 DAYS ',E10.4//)

120 CONTINUE

130 CONTINUE

WRITE(6,140)

0 0 | 0 0 | 3 0 0 3 6




140

FORMAT(';',  
STOP

A+1052001300;7  
P. 4/5  
9-13-44  
mfh  
wsm

00100130067




END

A+1 0 5 0 2 0 0 1 3 0 0 6 3875

8-13-94

mfa  
wtrn

0 0 1 0 0 1 3 0 0 6 8



0 0 2 0 9 1 3 0 0 5 9

7223(9-83)  
FORM GE-8(C)

ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO


SHEET 1 OF 1  
DATE 8/15/94 BY JL STICK WM  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

Attachment 6

Output of Final Version of  
whole Body/Skin Dose Code

0 0 1 0 0 1 3 0 0 5 9



Attachment 6  
00200130070  
6/11/84  
P. 1/1 way

INPUT: NOBFINAL.FOR; OUTPUT: NOBFINAL.OUT  
3588 MWT, NEW X/Q, CORRECTED METASTABLE DECAY  
THE AIR FLOW TO THE CONTROL ROOM IS 920. CFM

ISOTOPE	WHOLE BODY	BETA SKIN
KR85M	.1333D-01	.4659D+00
KR85	.5598D-04	.1302D+00
KR87	.3126D-01	.1436D+01
KR88	.2819D+00	.1271D+01
XE131M	.1901D-03	.2762D-01
XE133M	.1265D-01	.1406D+01
XE133	.1391D+00	.4027D+01
XE135M	.1391D-02	.8874D-02
XE135	.5957D-01	.1714D+01
XE138	.1373D-01	.1792D+00

TOTAL WHOLEBODY DOSE FOR 30 DAYS IS .5532D+00 REM

TOTAL SKINDOSE FOR 30 DAYS IS .1067D+02 REM

\*\*\*\*\*  
INPUT: NOBFINAL.FOR; OUTPUT: NOBFINAL.OUT  
3588 MWT, NEW X/Q, CORRECTED METASTABLE DECAY  
THE AIR FLOW TO THE CONTROL ROOM IS 1020. CFM

ISOTOPE	WHOLE BODY	BETA SKIN
KR85M	.1357D-01	.4740D+00
KR85	.5612D-04	.1305D+00
KR87	.3248D-01	.1492D+01
KR88	.2884D+00	.1301D+01
XE131M	.1908D-03	.2772D-01
XE133M	.1272D-01	.1414D+01
XE133	.1397D+00	.4044D+01
XE135M	.1502D-02	.9581D-02
XE135	.6026D-01	.1733D+01
XE138	.1484D-01	.1938D+00

TOTAL WHOLEBODY DOSE FOR 30 DAYS IS .5638D+00 REM

TOTAL SKINDOSE FOR 30 DAYS IS .1082D+02 REM


\*\*\*\*\*  
INPUT: NOBFINAL.FOR; OUTPUT: NOBFINAL.OUT  
3588 MWT, NEW X/Q, CORRECTED METASTABLE DECAY  
THE AIR FLOW TO THE CONTROL ROOM IS 1120. CFM

ISOTOPE	WHOLE BODY	BETA SKIN
KR85M	.1376D-01	.4808D+00
KR85	.5623D-04	.1308D+00
KR87	.3356D-01	.1541D+01
KR88	.2941D+00	.1326D+01
XE131M	.1913D-03	.2780D-01
XE133M	.1278D-01	.1421D+01
XE133	.1402D+00	.4058D+01
XE135M	.1607D-02	.1025D-01
XE135	.6083D-01	.1750D+01
XE138	.1590D-01	.2076D+00

TOTAL WHOLEBODY DOSE FOR 30 DAYS IS .5730D+00 REM

TOTAL SKINDOSE FOR 30 DAYS IS .1095D+02 REM

\*\*\*\*\*  
00100130070



00200130071

7223(9-63)  
FORM GE-8(C)

ENGINEERING DEPT.  
AMERICAN ELECTRIC POWER SERVICE CORP.  
1 RIVERSIDE PLAZA  
COLUMBUS, OHIO


SHEET \_\_\_\_\_ OF \_\_\_\_\_  
DATE 7/15/74 BY IML CK. WJM  
COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_  
PLANT \_\_\_\_\_

SUBJECT \_\_\_\_\_

Attachment 7

Output of Final version of  
Thyroid Code

00100130071



**INPUT 1:\NSL\MSA\CTRL ROOM\THY FINAL.FOR**  
**OUTPUT 1:\NSL\MSA\CTRL ROOM\THY FINAL.OUT**  
FINAL CASE: NEW X0 = 3588 10 GPM, CORRECTED I-135  
1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4600E+04  
1 PTI FILTER IN PACKAGE (CFM) .8000E+03  
1 UNFILTERED INLEAKAGE (CFM) .0000E+00      1 YARD DOSE(REM)

UNFILTERED IN LEAKAGE (CFM)	0000E+00	ISOTOPE .5 HOUR DOSE (REM)	1 HOUR DOSE (REM)	2 HOUR DOSE (REM)	8 HOUR DOSE (REM)	4 DAY DOSE (REM)	30 DAY DOSE (REM)
ELEMENTAL	131	2132E+01	2303E+01	2568E+01	2864E+01	3686E+01	4011E+01
ELEMENTAL	132	1920E+01	1939E+01	2087E+01	2152E+01	2160E+01	2160E+01
ELEMENTAL	133	7200E+00	7762E+00	8622E+00	9486E+00	1071E+01	1071E+01
ELEMENTAL	134	4475E+00	4628E+00	4742E+00	4887E+00	4889E+00	4888E+00
ELEMENTAL	135	1194E+00	1283E+00	1311E+00	1323E+00	1341E+00	1377E+00
ORGANIC	131	3451E+00	1243E+00	1892E+01	2052E+01	1885E+01	1426E+01
ORGANIC	132	2790E+02	5532E+02	8975E+02	1050E+03	1068E+01	1176E+01
ORGANIC	133	1156E+00	2476E+00	4475E+00	6490E+00	9271E+00	1387E+00
ORGANIC	134	6278E+03	1101E+02	1522E+02	1588E+02	1589E+02	1589E+02
ORGANIC	135	1892E+00	1966E+01	6957E+01	9328E+01	1068E+00	1068E+00
PARTICULATE	131	1082E+00	1141E+00	1211E+00	1228E+00	1256E+00	1267E+00
PARTICULATE	132	8892E+03	9445E+03	9888E+03	9903E+03	9905E+03	9905E+03
PARTICULATE	133	2575E+01	3841E+01	4088E+01	4118E+01	4159E+01	4160E+01
PARTICULATE	134	2120E+03	2211E+03	2271E+03	2292E+03	2292E+03	2292E+03
PARTICULATE	135	5901E+02	6320E+02	6690E+02	6725E+02	6745E+02	6745E+02

TOTAL DOSE FOR 30 DAYS .1106E+02


INPUT I:\NSI\MSA\CTRL ROOM\THYFINAL.FOR  
OUTPUT I:\NSI\MSA\CTRL ROOM\THYFINAL.OUT  
FINAL CASE - REV X0 3588 TO GPM. CORRECTED I-135  
RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4600E+04  
FILTED INLEAKAGE (CFM) .8000E+03  
UNFILTERED INLEAKAGE (CFM) .1000E+02. VOLD. DOSE(CFM)

	UNFILTERED INHALATION (CFM)	1000E+02	ISOTOPE .5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
ELEMENTAL	131	.2217E+01	.2394E+01	.2671E+01	.3041E+01	.4066E+01	.4471E+01	.4471E+01
ELEMENTAL	1894	.1894E+01	.2016E+01	.2170E+01	.2205E+01	.2291E+01	.2291E+01	.2291E+01
ELEMENTAL	7486	.7486E+00	.8073E+00	.8968E+00	.1008E+01	.1132E+01	.1132E+01	.1132E+01
ELEMENTAL	4653	.4653E-02	.4864E-02	.5054E-02	.5088E-02	.5088E-02	.5088E-02	.5088E-02
ELEMENTAL	1241	.1241E+00	.1334E+00	.1461E+00	.1594E+00	.1661E+00	.1661E+00	.1661E+00
ORGANIC	92	.9885E+00	.1273E+00	.1418E+01	.2280E+01	.4564E+01	.5415E+01	.5415E+01
ORGANIC	93	.9801E-02	.5723E-02	.9343E-02	.1125E+01	.1147E+01	.1147E+01	.1147E+01
ORGANIC	94	.1209E-03	.1572E+00	.4660E+00	.2174E+01	.1064E+00	.1064E+00	.1064E+00
ORGANIC	95	.6292E-03	.1143E-02	.1580E-02	.1666E+02	.6666E+02	.6666E+02	.6666E+02
ORGANIC	96	.1971E-01	.4126E-01	.7244E-01	.9200E+00	.1882E+00	.1882E+00	.1882E+00
PARTICULATE	32	.1100E+00	.1192E+00	.1274E+00	.1366E+00	.1366E+00	.1366E+00	.1366E+00
PARTICULATE	32	.9302E-03	.9888E-03	.1034E-03	.1039E-03	.1039E-03	.1039E-03	.1039E-03
PARTICULATE	33	.3741E-01	.4019E-01	.4278E-01	.4345E-01	.4438E-01	.4438E-01	.4438E-01
PARTICULATE	34	.2212E-03	.2319E-03	.2376E-03	.2378E-03	.2378E-03	.2378E-03	.2378E-03
PARTICULATE	35	.6123E-02	.6612E-02	.7001E-02	.7080E-02	.7124E-02	.7124E-02	.7124E-02

TOTAL DOSE FOR 30 DAYS 1263E+02

INPUT I:\NSI\MSA\CTRL ROOM\THYFINAL.FOR  
OUTPUT I:\NSI\MSA\CTRL ROOM\THYFINAL.OUT  
FINAL CASE - REF. NO. 3588 10 GPM CORRECTED I-135  
1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4600E+04  
FILTED INLEAKAGE (CFM) .8000E+03  
UNFILTERED INLEAKAGE (CFM) .2000E+02

	UNFILTERED INHALATION (CFM)	2000E+02	ISOTOPE .5 HOUR DOSE (REM)	1 HOUR DOSE (REM)	2 HOUR DOSE (REM)	8 HOUR DOSE (REM)	4 DAY DOSE (REM)	30 DAY DOSE (REM)
ELEMENTAL	131	.2301E+01	.2486E+01	.2774E+01	.3216E+01	.4444E+01	.4929E+01	.5236E+01
ELEMENTAL	132	.1966E+01	.2082E+01	.2225E+01	.2526E+01	.2832E+01	.2936E+01	.2936E+01
ELEMENTAL	133	.7771E+00	.8380E+00	.9337E+00	.1080E+01	.1239E+01	.1344E+01	.1344E+01
ELEMENTAL	134	.4830E+00	.5050E+00	.5710E+00	.5929E+00	.5928E+00	.5928E+00	.5928E+00
ELEMENTAL	135	.1288E+00	.1384E+00	.1524E+00	.1676E+00	.1763E+00	.1763E+00	.1763E+00
ORGANIC	131	.3725E+00	.4026E+00	.4374E+01	.5050E+01	.5242E+01	.6262E+01	.6262E+01
ORGANIC	132	.3011E-02	.5971E-02	.9710E-02	.1199E-01	.1226E-01	.1226E-01	.1226E-01
ORGANIC	133	.1251E+00	.1267E+00	.4842E+00	.7856E+00	.1207E+01	.1204E+01	.1204E+01
ORGANIC	134	.5776E-03	.1188E-02	.1624E-02	.1743E-02	.1744E-02	.1744E-02	.1744E-02
ORGANIC	135	.2048E+00	.3329E+00	.4231E+00	.5107E+00	.5310E+00	.5310E+00	.5310E+00
PARTICULATE	131	.1155E+00	.1249E+00	.1392E+00	.1688E+00	.1688E+00	.1688E+00	.1688E+00
PARTICULATE	132	.9712E-03	.1039E-02	.1073E-02	.1098E-02	.1098E-02	.1098E-02	.1098E-02
PARTICULATE	133	.3905E-01	.4195E-01	.4467E-01	.4571E-01	.4716E-01	.4716E-01	.4716E-01
PARTICULATE	134	.2315E-03	.2421E-03	.2481E-03	.2484E-03	.2484E-03	.2484E-03	.2484E-03
PARTICULATE	135	.6445E-02	.6902E-02	.7310E-02	.7433E-02	.7501E-02	.7501E-02	.7501E-02



TOTAL DOSE FOR 30 DAYS .1420E+02

**INPUT : \NSL\MSA\CTRL ROOM\THYFINAL.FOR**  
**OUTPUT : \NSL\MSA\CTRL ROOM\THYFINAL.OUT**  
**FINAL CASE : REV X0-3588 TO GPM, CORRECTED I-135**  
RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4600E+04  
FILTERED INLEAKAGE(CFM) .8000E+03  
UNFILTERED INLEAKAGE(CFM) .3000E+02  
VOLUME DOSE(CFM)

	UNFILTERED INHALATION (CFM)	.5 HOUR DOSE (REM)	1 HOUR DOSE (REM)	2 HOUR DOSE (REM)	8 HOUR DOSE (REM)	4 DAY DOSE (REM)	30 DAY DOSE (REM)
ISOTOPE	.500E+02						
ELEMENTAL	31	.2385E+01	.2576E+01	.2876E+01	.3391E+01	.4821E+01	.5386E+01
ELEMENTAL	32	.2038E+01	.2169E+01	.2336E+01	.2450E+01	.2463E+01	.2492E+01
ELEMENTAL	33	.8038E+00	.8687E+00	.9656E+00	.1116E+01	.1328E+01	.1329E+01
ELEMENTAL	34	.2002E+00	.2234E+02	.2430E+02	.5486E+02	.5486E+02	.5486E+02
ELEMENTAL	35	.2002E+00	.1432E+00	.1584E+00	.1727E+00	.1858E+00	.1858E+00
ORGANIC	31	.3861E+00	.8319E+00	.1530E+01	.2232E+01	.5917E+01	.7105E+01
ORGANIC	32	.3121E+02	.6189E+02	.1008E+03	.1233E+01	.3044E+01	.3044E+01
ORGANIC	33	.1292E+00	.2770E+00	.5029E+00	.8535E+00	.3337E+01	.3401E+01
ORGANIC	34	.7024E+03	.1232E+02	.1709E+02	.1820E+02	.8212E+02	.8212E+02
ORGANIC	35	.2121E+01	.4239E+01	.7816E+01	.1394E+00	.4300E+00	.4300E+00
PARTICULATE	31	.1030E+00	.1288E+00	.1388E+00	.1434E+00	.5658E+00	.6222E+00
PARTICULATE	32	.1016E+01	.1652E+01	.1832E+01	.1936E+01	.1932E+02	.1932E+02
PARTICULATE	33	.4069E+01	.4971E+01	.4958E+01	.4926E+01	.4932E+01	.4932E+01
PARTICULATE	34	.2412E+03	.2523E+03	.2583E+03	.2570E+03	.2570E+03	.2570E+03
PARTICULATE	35	.6716E+02	.7192E+02	.7618E+02	.7784E+02	.7877E+02	.7877E+02

TOTAL DOSE FOR 30 DAYS . . 1576E+02


INPUT I:\WSL\MSA\CTRL ROOM\THY FINAL.FOR  
OUTPUT I:\WSL\MSA\CTRL ROOM\THY FINAL.OUT  
FINAL CASE - NEW X0 = 3588.10 GPM, CORRECTED I-135  
RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4600E+04  
FILTED INLEAKAGE (CFM) .8000E+03  
UNFILTERED INLEAKAGE (CFM) .4000E+02, VENT RATE(PSM)

	UNFILTERED INHALATION (CFM)	4000E+02	ISOTOPE .5 HOUR DOSE (REM)	1 HOUR DOSE (REM)	2 HOUR DOSE (REM)	8 HOUR DOSE (REM)	4 DAY DOSE (REM)	30 DAY DOSE (REM)
ELEMENTAL	31	2469E+01		2667E+01	2978E+01	3566E+01	5197E+01	5841E+01
ELEMENTAL	32	2102E+01		2226E+01	2418E+01	2924E+01	3564E+01	3564E+01
ELEMENTAL	33	8338E+00		8992E+00	9923E+00	1171E+01	1413E+01	1413E+01
ELEMENTAL	34	5183E+00		5418E+00	5630E+00	5984E+02	5984E+02	5984E+02
ELEMENTAL	35	3822E+00		4185E+00	4636E+00	4898E+00	4898E+00	4898E+00
ORGANIC	31	3997E+00		4611E+00	5386E+01	2957E+01	6320E+01	7945E+01
ORGANIC	32	3231E+02		6406E-02	1044E+01	1347E+01	382E+01	1382E+01
ORGANIC	33	1942E+00		2867E+02	5213E+00	9212E+00	473E+01	1476E+01
ORGANIC	34	1270E+03		1270E+02	1710E+02	1897E+02	897E+02	1897E+02
ORGANIC	35	2129E+00		4565E+01	8100E+01	281E+00	5550E+00	1550E+00
PARTICULATE	31	2292E+00		1134E+00	4424E+00	1503E+00	739E+00	1740E+00
PARTICULATE	32	1033E+01		1119E+01	1170E+01	1184E+01	1184E+01	1184E+01
PARTICULATE	33	4233E+01		4547E+01	4843E+01	5020E+01	2208E+01	2208E+01
PARTICULATE	34	2509E+03		2624E+03	2689E+03	2695E+03	2695E+03	2695E+03
PARTICULATE	35	6985E+02		7481E+02	7925E+02	8135E+02	3252E+02	8252E+02

TOTAL DOSE FOR 30 DAYS - 1731E+02

**INPUT 1:** \NSI\MSA\CTRL ROOM\THY FINAL.FOR  
**OUTPUT 1:** \NSI\MSA\CTRL ROOM\THY FINAL OUT  
FINAL CASE - NEW X0: 3588 10 GPM, CORRECTED 1-135  
1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) ,1600E+04  
1 FILTERED INLEAKAGE (CFM) .8000E+03  
1 FILTERED TURFAGE (CFM) .5000E-02

	UNFILTERED INHALATION (CFM)	ISOTOPE .5 HOUR DOSE (REM)	1 HOUR DOSE (REM)	2 HOUR DOSE (REM)	8 HOUR DOSE (REM)	4 DAY DOSE (REM)	30 DAY DOSE (REM)
ELEMENTAL	131	.2552E+01	.2757E+01	.3079E+01	.3740E+01	.5571E+01	.6296E+01
ELEMENTAL	132	.2181E+01	.2262E+01	.2531E+01	.2624E+01	.3664E+01	.3663E+01
ELEMENTAL	133	.8620E+00	.9296E+00	.1034E+01	.1226E+01	.1498E+01	.1500E+01
ELEMENTAL	134	.5358E-02	.5601E-02	.5821E-02	.5892E-02	.5882E-02	.5882E-02
ELEMENTAL	135	.1429E+00	.1536E+00	.1691E+00	.1918E+00	.2048E+00	.2048E+00
ORGANIC	131	.4132E+00	.4890E+00	.6424E+01	.3182E+01	.7260E+01	.8782E+01
ORGANIC	132	.3340E-02	.6623E-02	.1080E-01	.1421E-01	.4606E-01	.4606E-01
ORGANIC	133	.1387E+00	.2964E+00	.5363E+00	.9886E+00	.6080E+00	.6121E+00
ORGANIC	134	.2216E-03	.1348E-02	.1831E-02	.1873E-02	.9724E-02	.9724E-02
ORGANIC	135	.2270E-03	.4795E-01	.9284E-01	.1267E+00	.6696E+00	.8669E+00
PARTICULATE	131	.1304E+00	.1493E+00	.1493E+00	.1924E+00	.2255E+00	.1892E+00
PARTICULATE	132	.1093E-02	.1192E-01	.1218E-01	.1232E-01	.1238E-01	.1234E-01
PARTICULATE	133	.4395E-01	.4722E-01	.5030E-01	.5244E-01	.5544E-01	.5544E-01



A-07-02-00-00-00-00

Rev 3/17/2017  
2017-03-17

PARTICULATE	134	.2606E-03	.2725E-03	.2793E-03	.2800E-03	.2800E-03	.2800E-03
PARTICULATE	135	.7254E-02	.7769E-02	.8231E-02	.8484E-02	.8625E-02	.8625E-02

TOTAL DOSE FOR 30 DAYS .1886E+02

INPUT : \NSL\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT : \NSL\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0 .3588 10 GPM, CORRECTED I-135  
 1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4500E+04  
 FILTERED INLEAKAGE(CFM) .9000E+03  
 UNFILTERED INLEAKAGE(CFM) .0000E+00

	ISOTOPE	.5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
ELEMENTAL	131	.2174E+01	.2349E+01	.2620E+01	.2953E+01	.3876E+01	.4241E+01
ELEMENTAL	132	.1858E+01	.1979E+01	.2126E+01	.2214E+01	.2212E+01	.2215E+01
ELEMENTAL	133	.7343E+00	.7918E+00	.8795E+00	.9766E+00	.1114E+01	.1115E+01
ELEMENTAL	134	.4564E-02	.4711E-02	.4952E-02	.4998E-02	.4998E-02	.4998E-02
ELEMENTAL	135	.1218E+00	.1308E+00	.1439E+00	.1553E+00	.1619E+00	.1619E+00
ORGANIC	131	.1520E+00	.1584E+00	.1642E+00	.1708E+01	.1766E+01	.1767E+01
ORGANIC	132	.3845E-02	.4242E-02	.4159E-02	.4088E-01	.4102E-01	.4102E-01
ORGANIC	133	.1182E+00	.1252E+00	.1325E+00	.1395E+00	.1455E+00	.1456E+00
ORGANIC	134	.6403E-03	.6724E-03	.7124E-03	.7627E-02	.8128E-02	.8128E-02
ORGANIC	135	.1934E-01	.2042E-01	.2101E-01	.2166E-01	.2226E-01	.2227E-01
PARTICULATE	131	.1066E+00	.1148E+00	.1262E+00	.1329E+00	.1393E+00	.1453E+00
PARTICULATE	132	.8933E-03	.9492E-03	.9939E-03	.9959E-03	.9982E-03	.9982E-03
PARTICULATE	133	.8692E-01	.8859E-01	.8410E-01	.8414E-01	.8418E-01	.8418E-01
PARTICULATE	134	.2129E-03	.2227E-03	.2282E-03	.2283E-03	.2283E-03	.2283E-03
PARTICULATE	135	.5928E-02	.6349E-02	.6721E-02	.6761E-02	.6783E-02	.6783E-02

TOTAL DOSE FOR 30 DAYS .1184E+02

INPUT : \NSL\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT : \NSL\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0 .3588 10 GPM, CORRECTED I-135  
 1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4500E+04  
 FILTERED INLEAKAGE(CFM) .9000E+03  
 UNFILTERED INLEAKAGE(CFM) .1000E+02


	ISOTOPE	.5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
ELEMENTAL	131	.2259E+01	.2440E+01	.2722E+01	.3129E+01	.4255E+01	.4700E+01
ELEMENTAL	132	.1630E+01	.2055E+01	.2212E+01	.2302E+01	.2312E+01	.2312E+01
ELEMENTAL	133	.7628E+00	.8227E+00	.9140E+00	.1032E+01	.1200E+01	.1201E+01
ELEMENTAL	134	.4742E+02	.4955E+02	.5150E+02	.5188E+02	.5188E+02	.5188E+02
ELEMENTAL	135	.1265E+00	.1353E+00	.1495E+00	.1638E+00	.1711E+00	.1711E+00
ORGANIC	131	.3657E+00	.3879E+00	.4449E+00	.5337E+00	.6921E+00	.6942E+00
ORGANIC	132	.3956E-02	.4862E-02	.9527E-02	.1162E-01	.1388E-01	.1388E-01
ORGANIC	133	.1228E+00	.1262E+00	.4753E+00	.7515E+00	.1133E+01	.1133E+01
ORGANIC	134	.6552E-03	.1067E-02	.1617E-02	.1705E-02	.1705E-02	.1705E-02
ORGANIC	135	.2009E-01	.2094E-01	.2388E-01	.2506E+00	.2506E+00	.2506E+00
PARTICULATE	131	.1113E+00	.1199E+00	.1289E+00	.1304E+00	.1371E+00	.1398E+00
PARTICULATE	132	.9343E-03	.9429E-03	.1029E-02	.1044E-02	.1044E-02	.1044E-02
PARTICULATE	133	.3757E-01	.4036E-01	.4289E-01	.4382E-01	.4468E-01	.4468E-01
PARTICULATE	134	.2227E-03	.2330E-03	.2387E-03	.2389E-03	.2389E-03	.2389E-03
PARTICULATE	135	.6201E-02	.6641E-02	.7032E-02	.7115E-02	.7162E-02	.7162E-02

TOTAL DOSE FOR 30 DAYS .1341E+02

INPUT : \NSL\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT : \NSL\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0 .3588 10 GPM, CORRECTED I-135  
 1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4500E+04  
 FILTERED INLEAKAGE(CFM) .9000E+03  
 UNFILTERED INLEAKAGE(CFM) .2000E+02

	ISOTOPE	.5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
ELEMENTAL	131	.2343E+01	.2531E+01	.2825E+01	.3304E+01	.4633E+01	.5158E+01
ELEMENTAL	132	.2002E+01	.2181E+01	.2295E+01	.2401E+01	.2413E+01	.2413E+01
ELEMENTAL	133	.7913E+00	.8534E+00	.9484E+00	.1088E+01	.1285E+01	.1287E+01
ELEMENTAL	134	.4919E+02	.5142E+02	.5243E+02	.5387E+02	.5387E+02	.5387E+02
ELEMENTAL	135	.1312E+00	.1410E+00	.1522E+00	.1716E+00	.1811E+00	.1811E+00
ORGANIC	131	.3793E+00	.4172E+00	.4502E+01	.4942E+01	.5398E+01	.5694E+01
ORGANIC	132	.3066E-02	.6080E-02	.9893E-02	.1236E-01	.1265E-01	.1265E-01
ORGANIC	133	.1274E+00	.1272E+00	.4937E+00	.8196E+00	.1269E+01	.1272E+01
ORGANIC	134	.6500E-03	.1170E-02	.1678E-02	.1782E-02	.1782E-02	.1782E-02
ORGANIC	135	.2084E-01	.4361E-01	.7674E-01	.1151E+00	.1370E+00	.1370E+00

0 0 1 0 0 1 3 0 0 7 4



PARTICULATE	131	.1164E+00	.1252E+00	.1336E+00	.1379E+00	.1475E+00	.1516E+00
PARTICULATE	132	.1036E-02	.1084E-02	.1092E-02	.1093E-02	.1093E-02	
PARTICULATE	133	.4213E-01	.4486E-01	.4593E-01	.4743E-01	.4744E-01	
PARTICULATE	134	.2432E-03	.2481E-03	.2495E-03	.2498E-03	.2495E-03	
PARTICULATE	135	.8932E-02	.7341E-02	.7468E-02	.7538E-02	.7539E-02	

TOTAL DOSE FOR 30 DAYS .1497E+02

INPUT : \NSL\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT : \NSL\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0, 3588 10 GPM, CORRECTED I-135  
 1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4500E+04  
 FILTERED INLEAKAGE(CFM) .9000E+03  
 UNFILTERED INLEAKAGE(CFM) .9000E+02  
 ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY DOSE(REM)

ELEMENTAL	131	.2427E+01	.2622E+01	.2927E+01	.3479E+01	.5009E+01	.5614E+01
ELEMENTAL	132	.3893E-01	.3922E+00	.1144E+01	.1371E+01	.1322E+01	
ELEMENTAL	133	.8932E-02	.5923E+00	.5583E-02	.5888E-02	.4266E-02	
ELEMENTAL	134	.1460E+00	.1608E+00	.1797E+00	.1906E+00	.1906E+00	
ORGANIC	131	.8465E+00	.1558E+00	.2845E+01	.6254E+01	.7525E+01	
ORGANIC	132	.6298E-02	.1026E+01	.1310E+01	.1343E+01	.1343E+01	
ORGANIC	133	.2818E+00	.5121E+00	.8824E+00	.1405E+01	.1408E+01	
ORGANIC	134	.1252E-02	.1739E-02	.1858E-02	.1859E-02	.1859E-02	
ORGANIC	135	.4517E-01	.7958E+00	.2371E+00	.4901E+00	.4901E+00	
PARTICULATE	131	.1030E+00	.932E+00	.1441E+00	.1572E+00	.1634E+00	
PARTICULATE	132	.1080E-02	.1232E-02	.1140E-02	.1242E-02	.1242E-02	
PARTICULATE	133	.4388E-01	.4674E-01	.4818E-01	.5020E-01	.5021E-01	
PARTICULATE	134	.2533E-03	.2596E-03	.2600E-03	.2600E-03	.2600E-03	
PARTICULATE	135	.7221E-02	.7649E-02	.7819E-02	.7915E-02	.7915E-02	

TOTAL DOSE FOR 30 DAYS .1653E+02

INPUT : \NSL\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT : \NSL\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0, 3588 10 GPM, CORRECTED I-135  
 1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4500E+04  
 FILTERED INLEAKAGE(CFM) .9000E+03  
 UNFILTERED INLEAKAGE(CFM) .9000E+02  
 ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY DOSE(REM)

ELEMENTAL	131	.2511E+01	.2712E+01	.3029E+01	.3653E+01	.5384E+01	.6068E+01
ELEMENTAL	132	.2282E-01	.2460E-01	.2508E-01	.2614E-01	.2614E-01	
ELEMENTAL	133	.9144E+00	.1011E+01	.1168E+01	.1456E+01	.1457E+01	
ELEMENTAL	134	.7510E-02	.5726E-02	.5785E-02	.5785E-02	.5785E-02	
ELEMENTAL	135	.1910E+00	.1664E+00	.1878E+00	.2001E+00	.2001E+00	
ORGANIC	131	.8757E+00	.1614E+01	.3070E+01	.6926E+01	.8364E+01	
ORGANIC	132	.6515E-02	.1062E-01	.1384E-01	.1421E-01	.1421E-01	
ORGANIC	133	.2915E+00	.5304E+00	.9549E+00	.1541E+01	.1544E+01	
ORGANIC	134	.1292E-02	.1800E-02	.1935E-02	.1936E-02	.1936E-02	
ORGANIC	135	.4672E-01	.8242E-01	.1324E+00	.1608E+00	.1609E+00	
PARTICULATE	131	.1362E+00	.1439E+00	.1510E+00	.1583E+00	.1583E+00	
PARTICULATE	132	.1093E-02	.1132E-02	.1169E-02	.1182E-02	.1182E-02	
PARTICULATE	133	.4563E-01	.4882E-01	.5043E-01	.5229E-01	.5229E-01	
PARTICULATE	134	.2635E-03	.2699E-03	.2706E-03	.2706E-03	.2706E-03	
PARTICULATE	135	.7510E-02	.7956E-02	.8169E-02	.8289E-02	.8289E-02	


TOTAL DOSE FOR 30 DAYS .1808E+02

INPUT : \NSL\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT : \NSL\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0, 3588 10 GPM, CORRECTED I-135  
 1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4500E+04  
 FILTERED INLEAKAGE(CFM) .9000E+03  
 UNFILTERED INLEAKAGE(CFM) .9000E+02  
 ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY DOSE(REM)

ELEMENTAL	131	.2594E+01	.2802E+01	.3130E+01	.3826E+01	.5758E+01	.6521E+01
ELEMENTAL	132	.2359E-01	.2542E-01	.2696E-01	.2713E-01	.2713E-01	
ELEMENTAL	133	.9447E+00	.1061E+01	.1254E+01	.1541E+01	.1632E+01	
ELEMENTAL	134	.5699E-02	.5916E-02	.6830E-02	.6980E-02	.6980E-02	
ELEMENTAL	135	.1261E+00	.1718E+00	.1938E+00	.2038E+00	.2038E+00	
ORGANIC	131	.9042E+00	.1670E+01	.2323E+01	.5938E+01	.9199E+01	
ORGANIC	132	.6731E-02	.1098E-01	.1457E-01	.1499E-01	.1499E-01	

11/14/2011 - A  
11/14/2011 - D

11/14/2011 - C  
11/14/2011 - C



ORGANIC	133	.1410E+00	.3012E+00	.5486E+00	.1022E+01	.1675E+01	.1680E+01
ORGANIC	134	.7639E-03	.1340E-02	.1861E-02	.2011E-02	.2012E-02	.2012E-02
ORGANIC	135	.2307E-01	.4828E-01	.8525E-01	.1410E+00	.1728E+00	.1728E+00
PARTICULATE	131	.1309E+00	.1308E+00	.1504E+00	.1578E+00	.1785E+00	.1868E+00
PARTICULATE	132	.1092E-02	.1186E-02	.1220E-02	.1232E-02	.1238E-02	.1238E-02
PARTICULATE	133	.2411E-01	.3437E-01	.4048E-01	.5209E-01	.5710E-01	.5710E-01
PARTICULATE	134	.2912E-01	.5779E-02	.8262E-02	.8518E-02	.8663E-02	.8663E-02
PARTICULATE	135	.7281E-02					

TOTAL DOSE FOR 30 DAYS .1963E+02

INPUT : \NSI\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT : \NSI\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0: 3588 10 GPM, CORRECTED I-135  
 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4400E+04  
 FILTERED INLEAKAGE(CFM) .1000E+04  
 UNFILTERED INLEAKAGE(CFM) .0000E+00

		ISOTOPE .5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
ELEMENTAL	131	.2217E+01	.2394E+01	.2671E+01	.3041E+01	.4066E+01	.4471E+01
ELEMENTAL	132	.1894E-01	.2016E-01	.2170E-01	.2252E-01	.2261E-01	.2261E-01
ELEMENTAL	133	.7486E+00	.8073E+00	.8968E+00	.1005E+01	.1152E+01	.1158E+01
ELEMENTAL	134	.4653E-02	.4864E-02	.5054E-02	.5088E-02	.5088E-02	.5088E-02
ORGANIC	131	.1241E+00	.1334E+00	.1467E+00	.1595E+00	.1661E+00	.1661E+00
ORGANIC	132	.1588E+00	.1731E+00	.1918E+01	.2280E+01	.4564E+01	.5415E+01
ORGANIC	133	.2801E-02	.3272E-02	.3942E-02	.4660E-02	.5152E-01	.5147E-01
ORGANIC	134	.1202E+00	.1472E+00	.1786E+00	.2088E+00	.2088E+00	.1066E+00
ORGANIC	135	.6528E-03	.1071E-01	.1266E+01	.1244E+01	.1020E+00	.1088E+00
PARTICULATE	131	.1071E+00	.1152E+00	.1229E+00	.1241E+00	.1271E+00	.1291E+00
PARTICULATE	132	.8974E-03	.9536E-03	.9971E-03	.1000E-02	.1000E-02	.1000E-02
PARTICULATE	133	.3609E-01	.3877E-01	.4126E-01	.4163E-01	.4216E-01	.4216E-01
PARTICULATE	134	.2186E-03	.2337E-03	.2282E-03	.2282E-03	.2293E-03	.2293E-03
PARTICULATE	135	.5955E-02	.6378E-02	.6752E-02	.6796E-02	.6821E-02	.6821E-02

TOTAL DOSE FOR 30 DAYS .1262E+02

INPUT : \NSI\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT : \NSI\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0: 3588 10 GPM, CORRECTED I-135  
 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4400E+04  
 FILTERED INLEAKAGE(CFM) .1000E+04  
 UNFILTERED INLEAKAGE(CFM) .1000E+02

		ISOTOPE .5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
ELEMENTAL	131	.2301E+01	.2486E+01	.2741E+01	.3216E+01	.4444E+01	.4929E+01
ELEMENTAL	132	.1966E-01	.2083E-01	.2262E-01	.2362E-01	.2363E-01	.2363E-01
ELEMENTAL	133	.7771E+00	.8380E+00	.9312E+00	.1080E+01	.1243E+01	.1244E+01
ELEMENTAL	134	.4830E-02	.5050E-02	.5246E-02	.5288E-02	.5288E-02	.5288E-02
ORGANIC	131	.1288E+00	.1384E+00	.1524E+00	.1676E+00	.1763E+00	.1763E+00
ORGANIC	132	.3725E+00	.4026E+00	.4747E+01	.5050E+01	.5242E+01	.6262E+01
ORGANIC	133	.3011E-02	.5871E-02	.9710E-02	.1166E-01	.1226E-01	.1226E-01
ORGANIC	134	.1251E+00	.1567E+00	.1842E+00	.1956E+00	.2017E+01	.2102E+01
ORGANIC	135	.5778E-03	.1188E-03	.1648E-03	.1923E-03	.1944E-03	.1944E-03
PARTICULATE	131	.2046E-01	.2288E-01	.2383E-01	.2383E-01	.1311E+00	.1310E+00
PARTICULATE	132	.1120E+00	.1292E+00	.1285E+00	.1049E-02	.1049E-02	.1049E-02
PARTICULATE	133	.9384E-03	.9972E-03	.1043E-02	.1049E-02	.1410E+00	.1410E+00
PARTICULATE	134	.3237E-03	.3540E-03	.2397E-03	.2400E-03	.2400E-03	.2400E-03
PARTICULATE	135	.6228E-02	.6670E-02	.7063E-02	.7150E-02	.7200E-02	.7200E-02

TOTAL DOSE FOR 30 DAYS .1418E+02


INPUT : \NSI\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT : \NSI\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0: 3588 10 GPM, CORRECTED I-135  
 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4400E+04  
 FILTERED INLEAKAGE(CFM) .1000E+04  
 UNFILTERED INLEAKAGE(CFM) .2000E+02

		ISOTOPE .5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
ELEMENTAL	131	.2385E+01	.2576E+01	.2876E+01	.3391E+01	.4821E+01	.5386E+01
ELEMENTAL	132	.9028E-01	.9188E-01	.9332E-01	.9459E-01	.2452E-01	.2452E-01
ELEMENTAL	133	.8055E+00	.8981E+00	.9638E+00	.1116E+01	.1328E+01	.1329E+01
ELEMENTAL	134	.5007E-02	.5234E-02	.5439E-02	.5486E-02	.5486E-02	.5486E-02

1/13/96 1-2  
1/13/96 1-2

1/13/96 1-2  
1/13/96 1-2

A  
1/13/96 1-2  
1/13/96 1-2



ELEMENTAL	135	.1336E+00	.1435E+00	.1580E+00	.1757E+00	.1858E+00	.1858E+00
ORGANIC	32	.3861E+00	.8319E+00	.1530E+01	.2732E+01	.5917E+01	.105E+01
ORGANIC	32	.3121E+02	.6169E+02	.1008E+01	.1273E+01	.1304E+01	.1304E+01
ORGANIC	32	.1262E+00	.2270E+00	.5029E+00	.8535E+00	.1337E+01	.1340E+01
ORGANIC	32	.1024E+03	.1232E+02	.1709E+02	.1820E+02	.1821E+02	.1821E+02
PARTICULATE	31	.2121E+01	.4439E+01	.7811E+01	.1194E+00	.1430E+00	.1430E+00
PARTICULATE	32	.1168E+00	.1251E+00	.1243E+00	.1380E+00	.1388E+00	.1388E+00
PARTICULATE	32	.9793E+03	.1041E+02	.1088E+01	.1097E+02	.1098E+02	.1098E+02
PARTICULATE	33	.3938E+01	.4231E+01	.4505E+01	.4616E+01	.3771E+01	.3772E+01
PARTICULATE	33	.2334E+03	.2442E+03	.2502E+03	.2506E+03	.2506E+03	.2506E+03
PARTICULATE	35	.6499E+02	.6961E+02	.7372E+02	.7503E+02	.7577E+02	.7577E+02

TOTAL DOSE FOR 30 DAYS .1574E+02

INPUT I:\NSL\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT I:\NSL\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0, 3588 10 GPM, CORRECTED I-135  
 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4400E+04  
 FILTERED INLEAKAGE(CFM) .1000E+04  
 UNFILTERED INLEAKAGE(CFM) .5000E+02

	ISOTOPE	.5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
ELEMENTAL	131	.2469E+01	.2667E+01	.2978E+01	.3566E+01	.5197E+01	.5841E+01
ELEMENTAL	131	.2109E+01	.2246E+01	.2419E+01	.2549E+01	.2564E+01	.2564E+01
ELEMENTAL	132	.8438E+00	.8932E+00	.9998E+00	.1171E+01	.1413E+01	.1415E+01
ELEMENTAL	132	.7109E+02	.7418E+02	.5630E+02	.5684E+02	.5685E+02	.5685E+02
ELEMENTAL	132	.1089E+00	.1402E+00	.1296E+00	.1838E+00	.1853E+00	.1853E+00
ORGANIC	32	.3927E+00	.6611E+00	.1086E+01	.1232E+01	.6580E+01	.7642E+01
ORGANIC	32	.3231E+02	.6406E+02	.1044E+01	.1241E+01	.6303E+01	.6892E+01
ORGANIC	32	.1342E+00	.2862E+00	.5213E+00	.9212E+00	.4746E+01	.4916E+01
ORGANIC	32	.7270E+03	.1225E+02	.1770E+02	.1897E+02	.1897E+02	.1897E+02
ORGANIC	35	.2196E+01	.4505E+01	.8100E+01	.1281E+00	.1650E+00	.1550E+00
PARTICULATE	31	.1219E+00	.1309E+00	.1398E+00	.1448E+00	.1589E+00	.1646E+00
PARTICULATE	32	.1602E+02	.1084E+02	.1134E+02	.1145E+02	.1147E+02	.1147E+02
PARTICULATE	32	.4102E+01	.4307E+01	.4693E+01	.4841E+01	.5041E+01	.5049E+01
PARTICULATE	33	.2432E+03	.2523E+03	.2606E+03	.2811E+03	.2811E+03	.2811E+03
PARTICULATE	35	.6770E+02	.7250E+02	.7680E+02	.7854E+02	.7952E+02	.7952E+02

TOTAL DOSE FOR 30 DAY: .1730E+02

6.57

9.17

15.28

17.30


INPUT I:\NSL\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT I:\NSL\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0, 3588 10 GPM, CORRECTED I-135  
 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4400E+04  
 FILTERED INLEAKAGE(CFM) .1000E+04  
 UNFILTERED INLEAKAGE(CFM) .4000E+02

	ISOTOPE	.5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
ELEMENTAL	131	.2552E+01	.2757E+01	.3079E+01	.3740E+01	.5571E+01	.6295E+01
ELEMENTAL	131	.2181E+01	.2322E+01	.2501E+01	.2647E+01	.2664E+01	.2664E+01
ELEMENTAL	132	.8620E+00	.9296E+00	.1034E+01	.1226E+01	.1498E+01	.1500E+01
ELEMENTAL	132	.5358E+02	.5601E+02	.5821E+02	.5882E+02	.5882E+02	.5882E+02
ELEMENTAL	132	.1428E+00	.1536E+00	.1691E+00	.1918E+00	.2048E+00	.2048E+00
ORGANIC	32	.4132E+00	.8923E+00	.1642E+01	.1831E+01	.2260E+01	.2878E+01
ORGANIC	32	.1240E+02	.9823E+02	.1080E+03	.1331E+03	.1460E+03	.1460E+03
ORGANIC	32	.1382E+00	.2964E+00	.5932E+00	.9886E+00	.1898E+01	.1892E+01
ORGANIC	32	.7516E+03	.1318E+02	.1893E+02	.1973E+02	.1974E+02	.1974E+02
PARTICULATE	31	.2220E+00	.4751E+01	.8384E+01	.1367E+00	.1669E+00	.1669E+00
PARTICULATE	32	.1265E+00	.1361E+00	.1453E+00	.1517E+00	.1692E+00	.1763E+00
PARTICULATE	32	.1061E+02	.1127E+02	.1179E+02	.1193E+02	.1195E+02	.1195E+02
PARTICULATE	32	.4226E+01	.4582E+01	.4881E+01	.5066E+01	.5232E+01	.5324E+01
PARTICULATE	32	.2538E+03	.2959E+03	.2970E+03	.3116E+03	.3116E+03	.3116E+03
PARTICULATE	35	.7039E+02	.7539E+02	.7987E+02	.8204E+02	.8327E+02	.8327E+02

TOTAL DOSE FOR 30 DAYS .1885E+02

	ISOTOPE	.5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
ELEMENTAL	1131	.2636E+01	.2847E+01	.3181E+01	.3913E+01	.5944E+01	.6746E+01

11/21/01  
hinsel  
hinsel



3700310107

APR 2001  
Principia  
4-1244  
mem

ELEMENTAL	32	2252E-01	2397E-01	2583E-01	2745E-01	2763E-01	2763E-01
ELEMENTAL	33	8900E+00	8168E+00	1068E+00	1281E+00	1583E+00	1583E+00
ELEMENTAL	34	5200E+00	5768E+00	6014E+00	6078E+00	6078E+00	6143E+00
ORGANIC	31	4266E+00	4188E+00	4744E+00	4938E+00	4938E+00	5015E+00
ORGANIC	32	3449E-02	6839E-02	1161E+00	1405E+01	1537E+01	1537E+01
ORGANIC	33	1433E+00	2060E+00	5577E+00	1056E+01	1743E+01	1743E+01
ORGANIC	34	1761E-03	1361E-02	1891E-02	2049E-02	2050E-02	2050E-02
PARTICULATE	31	2344E+00	2305E+01	8666E+00	1453E+00	1788E+00	1788E+00
PARTICULATE	32	1101E+00	1141E+00	1923E+00	1531E+02	1223E+02	1880E+00
PARTICULATE	33	4428E-01	4757E-01	5068E-01	5584E-01	5584E-01	5584E-01
PARTICULATE	34	2629E-03	2746E-03	2813E-03	2821E-03	2821E-03	2821E-03
PARTICULATE	35	7308E-02	7826E-02	8292E-02	8553E-02	8700E-02	8700E-02

TOTAL DOSE FOR 30 DAYS .2039E+02

INPUT : \NSL\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT : \NSL\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0: 3588 10 GPM, CORRECTED I-135  
 1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4300E+04  
 FILTERED IN LEAKAGE(CFM) .1100E+04  
 UNFILTERED IN LEAKAGE(CFM) .0000E+00

	ISOTOPE .5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)	
ELEMENTAL	31	.2259E+01	.2440E+01	.2722E+01	.3129E+01	.4255E+01	.4700E+01
ELEMENTAL	32	.1930E+01	.2055E+01	.2212E+01	.2302E+01	.2312E+01	.2312E+01
ELEMENTAL	33	.7628E+00	.8222E+00	.9130E+00	.1032E+01	.1200E+01	.1201E+01
ELEMENTAL	34	.4742E-02	.4957E-02	.5150E-02	.5188E-02	.5188E-02	.5188E-02
ORGANIC	31	.1265E+00	.1350E+00	.1496E+00	.1635E+00	.1715E+00	.1715E+00
ORGANIC	32	.3855E+00	.3878E+00	.4446E+00	.4932E+00	.5182E+00	.5839E+01
ORGANIC	33	.2228E+00	.2292E+00	.2522E+00	.2797E+00	.3182E+00	.3182E+00
ORGANIC	34	.1228E+00	.1263E+00	.1473E+00	.1705E+00	.1705E+00	.1705E+00
ORGANIC	35	.6652E-03	.1161E-02	.1617E-02	.1664E+00	.2501E+00	.2501E+00
PARTICULATE	31	.2009E-01	.4204E-01	.7388E-01	.1064E+00	.1281E+00	.1303E+00
PARTICULATE	32	.1076E+00	.1157E+00	.1234E+00	.1248E+00	.1005E-02	.1005E-02
PARTICULATE	33	.9015E-03	.9580E-03	.1002E-02	.1005E-02	.1005E-02	.1005E-02
PARTICULATE	34	.3622E-04	.3948E-04	.4145E-04	.4186E-01	.4243E-01	.4243E-01
PARTICULATE	35	.1435E-04	.1448E-04	.2403E-04	.2408E-03	.2304E-03	.2304E-03
PARTICULATE	36	.5983E-02	.6401E-02	.6784E-02	.6832E-02	.6859E-02	.6859E-02


TOTAL DOSE FOR 30 DAYS .1339E+02

INPUT : \NSL\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT : \NSL\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0: 3588 10 GPM, CORRECTED I-135  
 1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4300E+04  
 FILTERED IN LEAKAGE(CFM) .1100E+04  
 UNFILTERED IN LEAKAGE(CFM) .1000E+02

	ISOTOPE .5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)	
ELEMENTAL	31	.2243E+01	.2531E+01	.2825E+01	.3304E+01	.4633E+01	.5158E+01
ELEMENTAL	32	.2002E+01	.2188E+01	.2259E+01	.2404E+01	.2448E+01	.2448E+01
ELEMENTAL	33	.7913E+00	.8534E+00	.9484E+00	.1088E+01	.1288E+01	.1288E+01
ELEMENTAL	34	.4919E-02	.5142E-02	.5343E-02	.5387E-02	.5387E-02	.5387E-02
ORGANIC	31	.1312E+00	.1410E+00	.1552E+00	.1716E+00	.1811E+00	.1811E+00
ORGANIC	32	.3793E+00	.8172E+00	.1502E+01	.2620E+01	.5580E+01	.6684E+01
ORGANIC	33	.2066E+00	.2492E+00	.2892E+00	.3126E+00	.3263E+01	.3263E+01
ORGANIC	34	.1279E+00	.1310E+00	.1482E+00	.1792E+00	.1792E+00	.1792E+00
ORGANIC	35	.6900E-03	.1210E-02	.1676E-02	.1719E+00	.1730E+00	.1730E+00
PARTICULATE	31	.2084E-01	.4361E+01	.7674E+01	.1318E+00	.1392E+00	.1422E+00
PARTICULATE	32	.1125E+00	.1210E+00	.1291E+00	.1318E+00	.1054E-02	.1054E-02
PARTICULATE	33	.9425E-03	.1002E-02	.1041E-02	.1053E-02	.4513E-01	.4522E-01
PARTICULATE	34	.3790E-01	.4072E-01	.4335E-01	.4410E-01	.2410E-03	.2410E-03
PARTICULATE	35	.1244E+00	.1355E+00	.1408E+00	.1718E-02	.7237E-02	.7237E-02
PARTICULATE	36	.6255E-02	.6699E-02	.7094E-02	.7186E-02	.7237E-02	.7237E-02

TOTAL DOSE FOR 30 DAYS .1496E+02

INPUT : \NSL\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT : \NSL\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0: 3588 10 GPM, CORRECTED I-135  
 1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4300E+04  
 FILTERED IN LEAKAGE(CFM) .1100E+04  
 UNFILTERED IN LEAKAGE(CFM) .2000E+02



6/11/2007 11:00:00 AM

MSA

115-12-01

ISOTOPE	.5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
ELEMENTAL	31 .2427E+01	.2622E+01	.2927E+01	.3479E+01	.5009E+01	.5614E+01
ELEMENTAL	32 .2714E+01	.2898E+01	.3027E+01	.3495E+01	.4213E+01	.4342E+01
ELEMENTAL	33 .8196E+00	.8838E+00	.9827E+00	.1144E+01	.1371E+01	.1228E+01
ELEMENTAL	34 .5095E+02	.5326E+02	.5534E+02	.5585E+02	.5586E+02	.5588E+02
ORGANIC	31 .1359E+00	.1460E+00	.1608E+00	.1797E+00	.1906E+00	.1906E+00
ORGANIC	32 .3376E+02	.4046E+02	.4558E+02	.4845E+02	.6251E+02	.7525E+02
ORGANIC	33 .1318E+00	.1618E+00	.1626E+01	.1310E+01	.1343E+01	.1343E+01
ORGANIC	34 .1319E+02	.1619E+02	.1630E+02	.1887E+02	.1895E+02	.1895E+02
ORGANIC	35 .7197E+02	.8917E+02	.7958E+02	.1037E+02	.1486E+02	.1296E+02
PARTICULATE	31 .1173E+00	.1262E+00	.1347E+00	.1386E+00	.1496E+00	.1349E+00
PARTICULATE	32 .9834E-03	.1045E-02	.1093E-02	.102E-02	.103E-02	.103E-02
PARTICULATE	33 .3954E-01	.4248E-01	.4524E-01	.4638E-01	.4799E-01	.4800E-01
PARTICULATE	34 .2324E-03	.2452E-03	.2516E-03	.2516E-03	.2516E-03	.2516E-03
PARTICULATE	35 .6526E-02	.6990E-02	.7403E-02	.7538E-02	.7614E-02	.7614E-02

TOTAL DOSE FOR 30 DAYS .1652E+02

INPUT : \NSI\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT : \NSI\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0: 3588.10 GPM, CORRECTED I-135  
 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4300E+04  
 FILTEDER IN LEAKAGE(CFM) .1100E+04  
 UNFILTERED IN LEAKAGE(CFM) .3000E+02

ISOTOPE	.5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
ELEMENTAL	31 .2511E+01	.2712E+01	.3029E+01	.3653E+01	.5384E+01	.6068E+01
ELEMENTAL	32 .2145E+01	.2384E+01	.2460E+01	.2598E+01	.2614E+01	.2614E+01
ELEMENTAL	33 .8478E+00	.8144E+00	.7917E+00	.1198E+01	.1456E+01	.1457E+01
ELEMENTAL	34 .2270E-02	.2410E-02	.2456E-02	.2483E-02	.2483E-02	.2483E-02
ELEMENTAL	35 .1406E+00	.1910E+00	.1861E+00	.1878E+00	.2001E+00	.2001E+00
ORGANIC	31 .4064E+00	.8557E+00	.1614E+01	.3070E+01	.6929E+01	.8364E+01
ORGANIC	32 .3288E-02	.9515E-02	.1062E-01	.1384E-01	.1421E-01	.1421E-01
ORGANIC	33 .1365E+00	.2915E+00	.5304E+00	.9549E+00	.1541E+01	.1544E+01
ORGANIC	34 .2393E-03	.1297E-02	.1800E-02	.1935E-02	.1936E-02	.1936E-02
ORGANIC	35 .2332E-01	.4673E-01	.8242E-01	.1322E+00	.1609E+00	.1609E+00
PARTICULATE	31 .1533E+00	.3814E+00	.1303E+00	.4556E+00	.1299E+00	.1658E+00
PARTICULATE	32 .1632E+00	.4088E+00	.1193E+00	.1450E+00	.1531E+00	.1531E+00
PARTICULATE	33 .1624E+00	.4088E+00	.1193E+00	.1450E+00	.1531E+00	.1531E+00
PARTICULATE	34 .4118E-01	.4524E-01	.4712E-01	.5863E-01	.2078E-01	.2078E-01
PARTICULATE	35 .2441E-03	.7554E-03	.2616E-03	.2621E-03	.2622E-03	.2622E-03
PARTICULATE	36 .6797E-02	.7279E-02	.77.0E-02	.7889E-02	.7990E-02	.7990E-02


TOTAL DOSE FOR 30 DAYS .1807E+02

INPUT : \NSI\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT : \NSI\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0: 3588.10 GPM, CORRECTED I-135  
 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4300E+04  
 FILTEDER IN LEAKAGE(CFM) .1100E+04  
 UNFILTERED IN LEAKAGE(CFM) .4000E+02

ISOTOPE	.5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
ELEMENTAL	31 .2594E+01	.2802E+01	.3130E+01	.3826E+01	.5758E+01	.6521E+01
ELEMENTAL	32 .2216E+01	.2359E+01	.2542E+01	.2696E+01	.2713E+01	.2713E+01
ELEMENTAL	33 .8760E+00	.9447E+00	.1051E+01	.1254E+01	.1540E+01	.1542E+01
ELEMENTAL	34 .5445E-02	.5692E-02	.5916E-02	.5980E-02	.6080E-02	.6080E-02
ELEMENTAL	35 .1423E+00	.1861E+00	.1740E+00	.1958E+00	.2095E+00	.2095E+00
ORGANIC	31 .4199E+00	.9047E+00	.1740E+01	.3438E+01	.7562E+01	.9166E+01
ORGANIC	32 .3395E-02	.6331E-02	.7182E-01	.7457E-01	.1497E-01	.1499E-01
ORGANIC	33 .1410E+00	.3012E+00	.5466E+00	.1022E+01	.2676E+01	.3680E+01
ORGANIC	34 .7639E-03	.1340E-02	.1861E-02	.2011E-02	.2012E-02	.2012E-02
ORGANIC	35 .2307E-01	.4328E-01	.8225E-01	.1410E+00	.1728E+00	.1728E+00
PARTICULATE	31 .1220E+00	.3867E+00	.1189E+00	.1745E+00	.1745E+00	.1745E+00
PARTICULATE	32 .1632E+00	.4189E+00	.1189E+00	.1745E+00	.1745E+00	.1745E+00
PARTICULATE	33 .1624E+00	.4189E+00	.1189E+00	.1745E+00	.1745E+00	.1745E+00
PARTICULATE	34 .2482E+00	.4600E+00	.3892E+00	.5081E+00	.9320E+00	.3352E+01
PARTICULATE	35 .2538E-03	.2953E-03	.2720E-03	.2727E-03	.2727E-03	.2727E-03
PARTICULATE	36 .7066E-02	.7568E-02	.8017E-02	.8239E-02	.8364E-02	.8364E-02

TOTAL DOSE FOR 30 DAYS .1961E+02

INPUT : \NSI\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT : \NSI\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0: 3588.10 GPM, CORRECTED I-135



1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4300E+04  
FILTRATED IN LEAKAGE(CFM) .1100E+04  
UNFILTERED IN LEAKAGE(CFM) .5000E+02  
TSOLOPE 5 HOUR DOSE(REM) 1 HOUR DOSE(REM)

ELEMENTAL	131	2677E+01	2892E+01	3231E+01	3999E+01	6130E+01	6971E+01
ELEMENTAL	132	2982E+01	2435E+01	2623E+01	2793E+01	2813E+01	2813E+01
ELEMENTAL	133	2040E+00	1085E+00	1085E+01	1309E+01	1622E+01	1622E+01
ELEMENTAL	134	1915E+02	1674E+02	1674E+02	2176E+02	1677E+02	1677E+02
ELEMENTAL	135	1495E+00	1611E+00	1611E+00	2038E+00	1190E+00	1190E+00
ORGANIC	131	4333E+00	3333E+00	7231E+01	3516E+01	8261E+01	10031E+01
ORGANIC	132	3503E-02	6946E-02	1134E-01	1530E-01	1576E-01	1576E-01
ORGANIC	133	1455E+00	3109E+00	1581E+00	1089E+01	1810E+01	2814E+01
ORGANIC	134	2883E-03	11883E-02	11883E-02	2087E-02	2088E-02	2088E-02
ORGANIC	135	4989E+00	3882E+01	8402E+01	1495E+00	1847E+00	1847E+00
PARTICULATE	131	1105E+00	1418E+00	2321E+00	1292E+00	1805E+00	1892E+00
PARTICULATE	132	1105E+01	1174E+02	1232E+02	1249E+02	1248E+02	1248E+02
PARTICULATE	133	4444E-01	4774E-01	5080E-01	2311E-01	5629E-01	5962E-01
PARTICULATE	134	2634E-03	2756E-03	2824E-03	2831E-03	2831E-03	2831E-03
PARTICULATE	135	2634E-02	2855E-02	8123E-02	8585E-02	8737E-02	8737E-02

TOTAL DOSE FOR 30 DAYS 2116E+02

INPUT : \NSL\MSA\CTRL ROOM\THYFINAL.FOR  
OUTPUT : \NSL\MSA\CTRL ROOM\THYFINAL.OUT  
FINAL CASE - NEW X0 = 3588 10 GPM CORRECTED I-135  
RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4200E+04  
PIPE FILTERED IN PACKAGE (CFM) .1200E+04  
URE FILTERED IN LEAKAGE (CFM) .0000E+00 , YOUR DOSE(REM)

ISOTOPE	.5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
ELEMENTAL	31	2301E+01	2486E+01	2774E+01	3216E+01	4444E+01
ELEMENTAL	32	2093E+01	2209E+01	2426E+01	2836E+01	3263E+01
ELEMENTAL	33	7771E+00	8380E+00	9312E+00	10601E+01	12441E+01
ELEMENTAL	34	4830E-02	5050E-02	5246E-02	5288E-02	5288E-02
ELEMENTAL	35	1288E+00	1384E+00	1524E+00	1676E+00	1763E+00
ORGANIC	32	1295E+00	1362E+00	1474E+01	1500E+01	1626E+01
ORGANIC	33	3011E-02	3097E-02	9710E-02	11600E-01	12260E-01
ORGANIC	34	1295E+00	1362E+00	1474E+01	1500E+01	1626E+01
ORGANIC	35	3011E-02	3097E-02	9710E-02	11600E-01	12260E-01
ORGANIC	36	9770E+00	1086E+00	1238E+00	1352E+00	1442E+00
ORGANIC	37	2048E+00	2198E+00	2331E+00	2472E+00	2610E+00
PARTICULATE	32	1080E+00	1182E+00	1240E+00	1293E+00	1318E+00
PARTICULATE	33	9050E-03	9623E-03	1006E-03	1010E-02	1010E-02
PARTICULATE	34	3642E-01	3912E-01	4164E-01	4209E-01	4271E-01
PARTICULATE	35	2159E-03	2258E-03	2333E-03	2381E-03	2315E-03
PARTICULATE	36	6010E-02	6437E-02	6882E-02	6862E-02	6897E-02


TOTAL DOSE FOR 30 DAYS -1417E+02

INPUT I:\NSI\MSA\CTRL ROOM\THYFINAL.FOR  
OUTPUT I:\NSI\MSA\CTRL ROOM\THYFINAL.OUT  
FINAL CASE - NEW XO .3588 10 GPM. CORRECTED I-135  
1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4200E+04  
1 FILTERED IN LEAKAGE (CFM) .1200E-04  
UNFILTERED IN LEAKAGE (CFM) .1000E+02  
LEAKAGE DUE TO DRAFT (CFM) .1000E+02 3 HOUR DOSE(REM)

	ISOTURE 15 HOUR DOSE (REM)	1 HOUR DOSE (REM)	2 HOUR DOSE (REM)	3 HOUR DOSE (REM)	4 DAY DOSE (REM)	30 DAY DOSE (REM)	
ELEMENTAL	131	2385E+01	2576E+01	2876E+01	2391E+01	4821E+01	5386E+01
ELEMENTAL	132	2055E+00	2162E+00	2350E+00	2456E+00	4256E+00	4265E+00
ELEMENTAL	133	5055E+00	8682E+00	9658E+00	11161E+00	13288E+00	13292E+00
ELEMENTAL	134	5007E+00	5234E+00	5439E+00	5486E+00	5486E+00	5486E+00
ELEMENTAL	135	1336E+00	1435E+00	1580E+00	1752E+00	1858E+00	1858E+00
ORGANIC	131	3861E+00	8319E+00	1530E+01	2732E+01	3917E+01	7105E+01
ORGANIC	132	3121E+02	6169E+02	1008E+03	1273E+03	1304E+03	1304E+03
ORGANIC	133	1297E+00	2770E+00	5079E+00	8535E+00	1337E+01	1440E+01
ORGANIC	134	2024E+03	1232E+02	1410E+02	1820E+02	823E+02	823E+02
ORGANIC	135	5121E+01	4428E+01	5311E+01	1192E+01	430E+00	430E+00
PARTICULATE	131	2126E+00	2116E+00	2047E+00	1922E+00	1450E+00	1450E+00
PARTICULATE	132	2126E+00	2116E+00	2047E+00	1922E+00	1450E+00	1450E+00
PARTICULATE	133	2389E+03	1089E+03	4325E+03	1058E+03	1058E+03	1058E+03
PARTICULATE	134	2389E+03	1089E+03	4325E+03	1058E+03	1058E+03	1058E+03
PARTICULATE	135	2239E+03	2360E+03	2418E+03	2421E+03	2421E+03	2421E+03
PARTICULATE	136	6282E+02	6728E+02	7125E+02	7221E+02	7275E+02	7275E+02

TOTAL DOSE FOR 30 DAYS .1573E+02

stelle: man



**INPUT** I:\NSL\MSA\CTRL ROOM\THYFINAL.FOR  
**OUTPUT** I:\NSL\MSA\CTRL ROOM\THYFINAL.OUT  
FINAL CASE: NEW X0 .3588 10 GPM. CORRECTED I:135  
I RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4200E+04  
FILTERED IN LEAKAGE(CFM) ..1200E+04

UNFILTERED IN LEAKAGE (CFM)	2000E+02	ISOTOPE .5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
ELEMENTAL	31	2469E+01	2667E+01	2978E+01	3566E+01	5197E+01	5841E+01
ELEMENTAL	32	2102E+01	2226E+01	2419E+01	2529E+01	3554E+01	3562E+01
ELEMENTAL	33	8338E+00	8952E+00	9926E+00	1173E+01	1413E+01	1412E+01
ELEMENTAL	34	5183E-02	5418E-02	5630E-02	5984E-02	5969E-02	5969E-02
ELEMENTAL	35	1382E+00	1485E+00	1636E+00	1838E+00	1953E+00	1953E+00
ORGANIC	31	3997E+00	8611E+00	1586E+01	2957E+01	6590E+01	7945E+01
ORGANIC	32	3231E+02	6406E+02	1044E+01	1347E+01	382E+01	1382E+01
ORGANIC	33	3231E+00	3827E+00	5213E+00	9212E+00	473E+01	1476E+01
ORGANIC	34	2326E+00	1976E+02	1710E+02	8847E+02	887E+02	887E+02
ORGANIC	35	2196E+01	4552E+01	8100E+01	2381E+00	250E+00	250E+00
PARTICULATE	31	1718E+00	1262E+00	1333E+00	1393E+00	506E+00	552E+00
PARTICULATE	32	9875E-03	1049E-02	1098E-02	1107E-02	108E-02	1108E-02
PARTICULATE	33	9971E-03	4266E-01	4542E-01	4661E-01	4826E-01	4827E-01
PARTICULATE	34	2354E+00	2426E+03	2523E+03	2527E+03	2527E+03	2527E+03
PARTICULATE	35	2254E+00	2018E+02	2431E+02	2573E+02	2552E+02	2552E+02

TOTAL DOSE FOR 30 DAYS - 1729E+02

INPUT I:\NSL\MSA\CTRL ROOM\THYFINAL.FOR  
OUTPUT I:\NSL\MSA\CTRL ROOM\THYFINAL.OUT  
FINAL CASE - NEW X0 .3588 10 GPM CORRECTED I-135  
RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4200E+04  
FILTERED RELEASE (CFM) .1200E+04  
UNFILTERED THY LEAKAGE (CFM) .3000E+02


	UNFILTERED IN/FARAGE(LFM)	ISOTOPE .5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
ELEMENTAL	31	2552E+01	.2757E+01	.3079E+01	.3740E+01	.5571E+01	.6295E+01
ELEMENTAL	32	2181E-01	.2322E-01	.2501E-01	.2647E-01	.2664E-01	.2654E-01
ELEMENTAL	33	.8620E+00	.5295E+00	.1034E+01	.1226E+01	.1498E+01	.1500E+01
ELEMENTAL	34	.2320E+02	.5601E+02	.5931E+02	.5882E+02	.5898E+02	.5895E+02
ELEMENTAL	35	.1439E+00	.1828E+00	.1921E+00	.1918E+00	.2048E+00	.2048E+00
ORGANIC	31	4132E+00	.8902E+00	.6424E+01	.3182E+01	.7260E+01	.8782E+01
ORGANIC	32	.3340E+02	.6623E+02	.1080E+03	.1421E+03	.1460E+03	.1460E+03
ORGANIC	33	.1387E+00	.2964E+00	.5395E+00	.9886E+00	.1608E+01	.6122E+01
ORGANIC	34	.2516E+03	.1318E+02	.1831E+02	.1973E+02	.974E+02	.974E+02
ORGANIC	35	.5230E+03	.4741E+01	.8084E+01	.1367E+00	.659E+00	.659E+00
PARTICULATE	31	.3349E+01	.1320E+00	.4093E+00	.4622E+00	.910E+00	.669E+00
PARTICULATE	32	.1038E+02	.1093E+02	.143E+02	.1555E+02	.1595E+02	.1156E+02
PARTICULATE	33	.4135E+01	.4442E+01	.4731E+01	.4988E+01	.5102E+01	.5104E+01
PARTICULATE	34	.2451E+03	.2564E+03	.2627E+03	.2632E+03	.2632E+03	.2632E+03
PARTICULATE	35	.6824E+02	.7308E+02	.7741E+02	.7924E+02	.8027E+02	.8027E+02

TOTAL DOSE FOR 30 DAYS . 1884E+02

INPUT I:\NSL\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT I:\NSL\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE, NET X0: 3588 10 GPM, CORRECTED I-135  
 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4200E+04  
 FILTERED INLEAKAGE (CFM) .1200E+04  
 UNFILTERED INLEAKAGE (CFM) .4000E+02

	ISOTOPE	.5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
ELEMENTAL	31	.2636E+01	.2847E+01	.3181E+01	.3913E+01	.5944E+01	.6746E+01
ELEMENTAL	32	.2252E+01	.2397E+01	.2583E+01	.2745E+01	.2763E+01	.2763E+01
ELEMENTAL	33	.8900E+00	.9568E+00	.1068E+01	.1281E+01	.1583E+01	.1583E+01
ELEMENTAL	34	.6322E+02	.5783E+02	.6011E+02	.6078E+02	.6078E+02	.6078E+02
ELEMENTAL	35	.1322E+00	.1382E+00	.1498E+00	.1598E+00	.2143E+00	.2143E+00
ORGANIC	31	.4268E+00	.4792E+00	.6971E+00	.3405E+01	.7928E+01	.9615E+01
ORGANIC	32	.3449E+02	.6839E+02	.1116E+03	.4944E+01	.5371E+01	.1537E+01
ORGANIC	33	.1433E+00	.3060E+00	.5571E+00	.1056E+01	.1743E+01	.1743E+01
ORGANIC	34	.7761E+03	.1361E+02	.1891E+02	.2049E+02	.2050E+02	.2050E+02
ORGANIC	35	.2344E+01	.4905E+01	.8666E+01	.1453E+00	.1788E+00	.1788E+00
PARTICULATE	31	.1275E+00	.1372E+00	.1465E+00	.1530E+00	.1718E+00	.1784E+00
PARTICULATE	32	.1099E+02	.1175E+02	.1308E+02	.1429E+02	.1529E+02	.1529E+02
PARTICULATE	33	.4298E+01	.4917E+01	.4918E+01	.5110E+01	.5379E+01	.5379E+01
PARTICULATE	34	.2548E+03	.2665E+03	.2731E+03	.2737E+03	.2737E+03	.2737E+03
PARTICULATE	35	.7093E+02	.7596E+02	.8048E+02	.8274E+02	.8401E+02	.8401E+02

1943-1-2  
D. C. M.



TOTAL DOSE FOR 30 DAYS .2038E+02

INPUT I:\NSL\MSA\CTRL ROOM\THYFINAL.FOR  
OUTPUT I:\NSL\MSA\CTRL ROOM\THYFINAL.OUT  
FINAL CASE: NEW X0 .3588 10 GPM, CORRECTED I-135  
RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4200E+04  
FILTERED INLEAKAGE(CFM) .1200E+04  
UNFILTERED INLEAKAGE(CFM) .5000E+02

ISOTOPE	.5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
ELEMENTAL	131	.2718E+01	.2936E+01	.3281E+01	.4085E+01	.6315E+01
ELEMENTAL	133	.2323E+01	.2473E+01	.2664E+01	.2842E+01	.2863E+01
ELEMENTAL	135	.9180E+00	.9900E+00	.1102E+01	.1336E+01	.1669E+01
ELEMENTAL	137	.1570E+02	.5965E+02	.6200E+02	.6274E+02	.6275E+02
ORGANIC	131	.1522E+00	.1635E+00	.1802E+00	.2078E+00	.2237E+00
ORGANIC	133	.4400E+00	.4831E+00	.5123E+00	.5627E+01	.8534E+01
ORGANIC	135	.3555E+00	.3704E+00	.3929E+00	.4194E+01	.6832E+01
ORGANIC	137	.1478E+00	.1515E+00	.1592E+00	.1742E+01	.1882E+01
ORGANIC	139	.8005E+00	.1404E+01	.1952E+01	.2126E+02	.2126E+02
PARTICULATE	131	.2418E+01	.5060E+01	.8947E+01	.1538E+00	.1906E+00
PARTICULATE	132	.1103E+02	.1323E+00	.1424E+00	.1520E+00	.1521E+00
PARTICULATE	133	.4460E+01	.4792E+01	.5105E+01	.5333E+01	.5654E+01
PARTICULATE	135	.3644E+02	.3762E+02	.3834E+02	.3834E+02	.3834E+02
PARTICULATE	137	.7361E-02	.7884E-02	.8353E-02	.8623E-02	.8774E-02

TOTAL DOSE FOR 30 DAYS .2192E+02

7 24

INPUT I:\NSL\MSA\CTRL ROOM\THYFINAL.FOR  
OUTPUT I:\NSL\MSA\CTRL ROOM\THYFINAL.OUT  
FINAL CASE: NEW X0 .3588 10 GPM, CORRECTED I-135  
RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4100E+04  
FILTERED INLEAKAGE(CFM) .1300E+04  
UNFILTERED INLEAKAGE(CFM) .0000E+00


ISOTOPE	.5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
ELEMENTAL	131	.2343E+01	.2531E+01	.2825E+01	.3304E+01	.4523E+01
ELEMENTAL	133	.7804E+00	.8534E+00	.9364E+00	.1089E+01	.1282E+01
ELEMENTAL	135	.4919E+02	.5142E+02	.5343E+02	.5387E+02	.5387E+02
ELEMENTAL	137	.1312E+00	.1410E+00	.1552E+00	.1716E+00	.1811E+00
ORGANIC	131	.3793E+00	.8172E+00	.1502E+01	.2620E+01	.5580E+01
ORGANIC	133	.3066E+02	.6080E+02	.9893E+02	.1236E+01	.1265E+01
ORGANIC	135	.1224E+00	.2221E+00	.4937E+00	.8186E+00	.1229E+01
ORGANIC	137	.6900E+03	.1210E+02	.1628E+02	.1785E+02	.1785E+02
ORGANIC	139	.4088E+01	.4110E+01	.7624E+01	.1193E+00	.1320E+00
PARTICULATE	131	.1085E+00	.1168E+00	.1246E+00	.1624E+00	.3081E+00
PARTICULATE	132	.9097E+03	.9669E+03	.1011E+02	.1015E+02	.1015E+02
PARTICULATE	133	.3658E+01	.3930E+01	.4183E+01	.4231E+01	.4299E+01
PARTICULATE	135	.2169E+03	.2268E+03	.2324E+03	.2325E+03	.2325E+03
PARTICULATE	137	.6037E+02	.6166E+02	.6346E+02	.6393E+02	.6393E+02

TOTAL DOSE FOR 30 DAYS .1495E+02

INPUT I:\NSL\MSA\CTRL ROOM\THYFINAL.FOR  
OUTPUT I:\NSL\MSA\CTRL ROOM\THYFINAL.OUT  
FINAL CASE: NEW X0 .3588 10 GPM, CORRECTED I-135  
RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4100E+04  
FILTERED INLEAKAGE(CFM) .1300E+04  
UNFILTERED INLEAKAGE(CFM) .1000E+02

ISOTOPE	.5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
ELEMENTAL	131	.2427E+01	.2622E+01	.2927E+01	.3479E+01	.5009E+01
ELEMENTAL	133	.2024E+01	.2368E+01	.2577E+01	.3166E+01	.4514E+01
ELEMENTAL	135	.8109E+00	.8839E+00	.9327E+00	.1143E+01	.1341E+01
ELEMENTAL	137	.7928E+02	.8520E+02	.9324E+02	.9785E+02	.9886E+02
ORGANIC	131	.3929E+00	.8465E+00	.1558E+01	.2845E+01	.6254E+01
ORGANIC	133	.3176E+02	.6298E+02	.1026E+01	.1310E+01	.1343E+01
ORGANIC	135	.1319E+00	.2818E+00	.5126E+00	.8874E+00	.1405E+01
ORGANIC	137	.2156E+01	.4514E+01	.7626E+01	.1859E+02	.1859E+02
PARTICULATE	131	.9504E+00	.1020E+00	.1302E+00	.1837E+00	.4121E+00
PARTICULATE	132	.9507E+03	.1010E+02	.1057E+02	.1063E+02	.1445E+00
PARTICULATE	133	.3823E-01	.4107E-01	.4373E-01	.4458E-01	.4577E-01

Copy  
8-13-94  
mrd  
p. 11/17



PARTICULATE	134	.2266E-03	.2370E-03	.2429E-03	.2431E-03	.2431E-03
PARTICULATE	135	.6309E-02	.6757E-02	.7155E-02	.7256E-02	.7313E-02

TOTAL DOSE FOR 30 DAYS .1650E+02

INPUT I:\NSI\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT I:\NSI\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0=.3588 10 GPM, CORRECTED I-135  
 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4100E+04  
 FILTERED INLEAKAGE(CFM) .1300E+04  
 UNFILTERED INLEAKAGE(CFM) .2000E+02  
 ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY DOSE(REM)

ELEMENTAL	131	.2511E+01	.2712E+01	.3029E+01	.3653E+01	.5284E+01	.6068E+01
ELEMENTAL	132	.2145E+01	.2184E+01	.2460E+01	.2888E+01	.3613E+01	.4014E+01
ELEMENTAL	133	.8479E+00	.9144E+00	.1017E+01	.1199E+01	.1458E+01	.1457E+01
ELEMENTAL	134	.5270E-02	.5610E-02	.5725E-02	.5783E-02	.5783E-02	.5783E-02
ELEMENTAL	135	.1406E+00	.1610E+00	.1664E+00	.1878E+00	.2001E+00	.2001E+00
ORGANIC	131	.4064E+00	.4757E+00	.6144E+00	.3070E+01	.6926E+01	.8365E+01
ORGANIC	132	.3886E+00	.4815E+00	.6062E+00	.3246E+00	.5541E+01	.6541E+01
ORGANIC	133	.3365E+00	.4297E+00	.5304E+00	.1935E+02	.1938E+02	.1938E+02
ORGANIC	134	.7393E+03	.1297E+02	.1800E+02	.1924E+02	.1609E+02	.1609E+02
ORGANIC	135	.2233E+01	.4673E+01	.8242E+01	.3243E+00	.1516E+00	.1564E+00
PARTICULATE	131	.1183E+00	.1273E+00	.1358E+00	.4000E+00	.1113E+02	.1113E+02
PARTICULATE	132	.4916E+03	.1054E+02	.1102E+02	.1112E+02	.1113E+01	.1113E+01
PARTICULATE	133	.3987E+01	.4289E+01	.4561E+01	.4683E+01	.2634E+01	.2634E+01
PARTICULATE	134	.2884E+03	.3299E+03	.3430E+03	.2537E+03	.2537E+03	.2537E+03
PARTICULATE	135	.6581E-02	.7048E-02	.7461E-02	.7608E-02	.7689E-02	.7689E-02

TOTAL DOSE FOR 30 DAYS .1806E+02

INPUT I:\NSI\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT I:\NSI\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0=.3588 10 GPM, CORRECTED I-135  
 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4100E+04  
 FILTERED INLEAKAGE(CFM) .1300E+04  
 UNFILTERED INLEAKAGE(CFM) .3000E+02  
 ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2-HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY DOSE(REM)


ELEMENTAL	131	.2594E+01	.2802E+01	.3130E+01	.3826E+01	.5758E+01	.6521E+01
ELEMENTAL	132	.3760E+00	.5247E+00	.1031E+01	.1952E+01	.1540E+01	.1642E+01
ELEMENTAL	133	.5445E-02	.5892E-02	.9218E-02	.1950E-02	.3980E-02	.3980E-02
ELEMENTAL	134	.1452E+00	.1661E+00	.1719E+00	.1958E+00	.2092E+00	.2092E+00
ORGANIC	131	.4199E+00	.9047E+00	.1670E+01	.3293E+01	.7595E+01	.9199E+01
ORGANIC	132	.3395E-02	.6131E-02	.1098E-01	.1457E-01	.1499E-01	.1499E-01
ORGANIC	133	.1210E+00	.3012E+00	.5486E+00	.1022E+01	.1676E+01	.1680E+01
ORGANIC	134	.2659E+03	.3340E+02	.1861E+02	.2011E+02	.2012E+02	.2012E+02
ORGANIC	135	.2307E+01	.4828E+01	.8525E+01	.1410E+00	.1638E+00	.1748E+00
PARTICULATE	131	.1232E+00	.1897E+02	.1414E+00	.4169E+00	.1620E+00	.1681E+00
PARTICULATE	132	.1032E-02	.1097E-02	.1147E-02	.1606E-02	.1161E-02	.1161E-02
PARTICULATE	133	.4151E-01	.4459E-01	.4749E-01	.4908E-01	.5130E-01	.5131E-01
PARTICULATE	134	.2461E-03	.2574E-03	.2637E-03	.2643E-03	.2643E-03	.2643E-03
PARTICULATE	135	.6851E-02	.7337E-02	.7772E-02	.7959E-02	.8063E-02	.8063E-02

TOTAL DOSE FOR 30 DAYS .1960E+02

INPUT I:\NSI\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT I:\NSI\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0=.3588 10 GPM, CORRECTED I-135  
 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4100E+04  
 FILTERED INLEAKAGE(CFM) .1300E+04  
 UNFILTERED INLEAKAGE(CFM) .4000E+02  
 ISOTOPE .5 HOUR DOSE(REM) 1 HOUR DOSE(REM) 2 HOUR DOSE(REM) 8 HOUR DOSE(REM) 4 DAY DOSE(REM) 30 DAY DOSE(REM)

ELEMENTAL	131	.2677E+01	.2892E+01	.3231E+01	.3999E+01	.6130E+01	.6971E+01
ELEMENTAL	132	.3267E+01	.3233E+01	.3622E+01	.3765E+01	.3813E+01	.3814E+01
ELEMENTAL	133	.9040E+00	.9249E+00	.1085E+01	.1308E+01	.1624E+01	.1624E+01
ELEMENTAL	134	.5619E-02	.5874E-02	.6105E-02	.6178E-02	.5777E-02	.5777E-02
ELEMENTAL	135	.1499E+00	.1611E+00	.1775E+00	.2038E+00	.2190E+00	.2190E+00
ORGANIC	131	.4333E+00	.9337E+00	.1725E+01	.3516E+01	.8261E+01	.1003E+02
ORGANIC	132	.3503E-02	.6046E-02	.1134E-01	.1530E-01	.1576E-01	.1576E-01
ORGANIC	133	.1252E+00	.3109E+00	.5668E+00	.1089E+01	.1810E+01	.1811E+01
ORGANIC	134	.2888E+03	.3483E+02	.5821E+02	.1087E+02	.2088E+02	.2688E+02
ORGANIC	135	.2381E-01	.4982E-01	.8807E-01	.1495E+00	.1847E+00	.1847E+00

11/12/17  
11:30 AM  
MSA  
11/12/17  
11:30 AM  
MSA



PART	CULATE	131	$1.280E+00$	$1.377E+00$	$1.470E+00$	$1.537E+00$	$1.722E+00$	$1.798E+00$
PART	CULATE	132	$.1073E-02$	$.140E-02$	$.193E-02$	$.208E-02$	$.209E-02$	$.209E-02$
PART	CULATE	133	$.4314E-01$	$.4635E-01$	$.4934E-01$	$.5132E-01$	$.5405E-01$	$.5490E-01$
PART	CULATE	134	$.2557E-03$	$.2675E-03$	$.2741E-03$	$.2747E-03$	$.2748E-03$	$.2748E-03$
PART	CULATE	135	$.7120E-02$	$.7625E-02$	$.8078E-02$	$.8309E-02$	$.8439E-02$	$.8439E-02$

TOTAL DOSE FOR 30 DAYS .2114E+02

INPUT 1: \NSI\MSA\CTRL ROOM\THYFINAL.FOR  
OUTPUT 1: \NSI\MSA\CTRL ROOM\THYFINAL.OUT  
FINAL CASE: NEW X0 = 3588, 10 GPM, CORRECTED I-135  
1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4100E+04  
1 FILTERED INLEAKAGE (CFM) .1300E+04  
1 INFECTED TEFERD THY LEAKAGE (CFM) .5000E+02

	UNFILTERED INLEAKAGE (CFM)	SOURCE=02	1 HOUR DOSE (REM)	2 HOUR DOSE (REM)	8 HOUR DOSE (REM)	4 DAY DOSE (REM)	30 DAY Dose (REM)
ISOTOPE	.5 HOUR DOSE (REM)						
ELEMENTAL	31	2760E+01	2981E+01	3332E+01	4171E+01	6500E+01	7420E+01
ELEMENTAL	32	3528E+01	3510E+01	3708E+01	2891E+01	2912E+01	2912E+01
ELEMENTAL	33	3538E+00	1002E+01	1118E+01	1362E+01	1709E+01	1712E+01
ELEMENTAL	34	3538E+00	6058E+02	9204E+02	9372E+02	9372E+02	9372E+02
ELEMENTAL	35	5545E+00	1650E+00	1810E+00	2117E+00	2628E+00	2628E+00
ORGANIC	31	4267E+00	9625E+00	1781E+01	3738E+01	8923E+01	1088E+02
ORGANIC	32	3612E+02	7161E+02	1170E+01	1603E+01	1653E+01	1653E+01
ORGANIC	33	1500E+00	3205E+00	5849E+00	1568E+01	1944E+01	1949E+01
ORGANIC	34	8125E+03	1426E+02	1982E+02	2163E+02	2164E+02	2164E+02
ORGANIC	35	8125E+03	1136E+01	9082E+01	1581E+00	1965E+00	1965E+00
PARTICULATE	31	3388E+00	1128E+00	1538E+00	6026E+00	8272E+00	1978E+00
PARTICULATE	32	1119E+01	4808E+02	1129E+02	4523E+01	5678E+01	5678E+01
PARTICULATE	33	947E+01	4808E+01	5125E+01	2852E+01	2852E+01	2852E+01
PARTICULATE	34	2654E+03	2776E+03	2844E+03	2852E+03	2852E+03	2852E+03
PARTICULATE	35	7988E+02	7912E+02	8384E+02	8658E+02	8811E+02	8811E+02

TOTAL DOSE FOR 30 DAYS .2268E+02

**INPUT 1:\NSI\MSA\CTRL ROOM\THYFINAL.FOR**  
**OUTPUT 1:\NSI\MSA\CTRL ROOM\THYFINAL.OUT**  
**FINAL CASE - NEW X0: 3588 10 GPM CORRECTED I-135**  
1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4000E+04  
1 FILTRATED INLEAKAGE (CFM) .1400E+04  
1 UNFILTERED INLEAKAGE (CFM) .0000E+00


	UNFILTERED IN LEAKAGE (CFM)	.000DE+00	ISOTOPE .5 HOUR DOSE (REM)	1 HOUR DOSE (REM)	2 HOUR DOSE (REM)	8 HOUR DOSE (REM)	4 DAY DOSE (REM)	30 DAY DOSE (REM)
ELEMENTAL	31	2385E+01		2576E+01	2876E+01	3391E+01	4821E+01	5386E+01
ELEMENTAL	32	2038E+01		2168E+01	2336E+01	2450E+01	2463E+01	2463E+01
ELEMENTAL	33	8022E+00		8988E+00	9634E+00	1116E+01	1328E+01	1328E+01
ELEMENTAL	34	5901E-02		9434E-02	1232E-02	5498E-02	5498E-02	5498E-02
ELEMENTAL	35	1830E+00		1435E+00	1780E+00	1732E+00	1858E+00	1888E+00
ORGANIC	31	3861E+00		8319E+00	1530E+01	2732E+01	5973E+01	7105E+01
ORGANIC	32	1212E-02		6188E-02	1008E-01	1273E-01	304E-01	304E-01
ORGANIC	33	1297E+00		2770E+00	5029E+00	8535E+00	1337E+00	1404E+00
ORGANIC	34	2024E-03		1232E-02	1700E-02	1820E-02	821E-02	821E-02
ORGANIC	35	1913E+00		1438E-01	1816E-01	194E+00	430E+00	430E+00
PARTICULATE	31	1050E+00		1117E+00	1251E+00	1260E+00	2192E+00	2329E+00
PARTICULATE	32	2613E-03		3711E-03	1013E-03	1013E-02	1020E-02	1020E-02
PARTICULATE	33	3675E+01		3948E+01	4202E+01	4254E+01	4327E+01	4327E+01
PARTICULATE	34	2178E-03		2278E-03	2334E-03	2336E-03	2336E-03	2336E-03
PARTICULATE	35	6468E+02		6498E+02	6871E+02	6938E+02	6973E+02	6973E+02

TOTAL DOSE FOR 30 DAYS .1572E+02

**INPUT** I:\NSI\MSA\CTRL ROOM\THYFINAL.FOR  
**OUTPUT** I:\NSI\MSA\CTRL ROOM\THYFINAL.OUT  
**FINAL CASE NEW XQ:** 3588 10 GPM, **CORRECTED I-135**  
1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4000E+04  
1 FILTRATED INLEAKAGE (CFM) .1400E+04  
1 UNFILTERED INLEAKAGE (CFM) .1000E+02

	UNFILTERED INLEAKAGE (CFM)	1000E+02	ISOTOPE .5 HOUR DOSE (REM)	1 HOUR DOSE (REM)	2 HOUR DOSE (REM)	8 HOUR DOSE (REM)	4 DAY DOSE (REM)	30 DAY DOSE (REM)
ELEMENTAL	131	.2469E+01	.2667E+01	.2978E+01	.3566E+01	.5197E+01	.5841E+01	
ELEMENTAL	132	.2109E+01	.2246E+01	.2419E+01	.2549E+01	.2564E+01	.2564E+01	
ELEMENTAL	33	.8338E+00	.8992E+00	.9988E+00	.1171E+01	.1413E+01	.1415E+01	
ELEMENTAL	32	.1583E-02	.5418E-02	.5630E-02	.5684E-02	.5688E-02	.5688E-02	
ELEMENTAL	34	.1986E+00	.1488E+00	.1335E+00	.1838E+00	.1893E+00	.1893E+00	
ORGANIC	33	.9921E+00	.8611E+00	.5868E+00	.2952E+01	.6590E+01	.7945E+01	
ORGANIC	32	.2234E-02	.6406E-02	.0444E-01	.1347E-01	.3382E-01	.3382E-01	

1. Miss  
2. Mr.



ORGANIC	33	.1342E+00	.2867E+00	.5213E+00	.9212E+00	.1473E+01	.1476E+01
ORGANIC	34	.2196E-01	.4522E-01	.9100E-01	.1897E-02	.1897E-02	.1897E-02
PARTICULATE	31	.1139E+00	.1225E+00	.1008E+00	.1422E+00	.1422E+00	.1422E+00
PARTICULATE	32	.9548E-03	.1015E-02	.1061E-02	.1068E-02	.1069E-02	.1069E-02
PARTICULATE	33	.3839E-01	.4125E-01	.4391E-01	.4480E-01	.4605E-01	.4605E-01
PARTICULATE	34	.2276E-03	.2381E-03	.2439E-03	.2442E-03	.2442E-03	.2442E-03
PARTICULATE	35	.6337E-02	.6786E-02	.7186E-02	.7292E-02	.7351E-02	.7351E-02

TOTAL DOSE FOR 30 DAYS .1728E+02

INPUT I:\NSL\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT I:\NSL\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0: 3588 10 GPM, CORRECTED I-135  
 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4000E+04  
 FILTEDERD INLEAKAGE(CFM) .1400E+04  
 UNFILTERED INLEAKAGE(CFM) .2000E+02

	ISOTOPE	.5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
ELEMENTAL	31	.2552E+01	.2757E+01	.3079E+01	.3740E+01	.5571E+01	.6295E+01
ELEMENTAL	32	.2181E-01	.2322E-01	.2501E-01	.2647E-01	.2664E-01	.2664E-01
ELEMENTAL	33	.8266E+00	.9266E+00	.1034E+01	.1226E+01	.1498E+01	.1500E+01
ELEMENTAL	34	.2328E-02	.2501E-02	.2621E-02	.2682E-02	.2682E-02	.2682E-02
ELEMENTAL	35	.1439E+01	.1626E+00	.1691E+00	.1718E+00	.2044E+00	.2044E+00
ORGANIC	31	.4132E+00	.8902E+00	.1642E+01	.3181E+01	.7260E+01	.8782E+01
ORGANIC	32	.3340E-02	.6623E-02	.1080E-01	.1421E-01	.1460E-01	.1460E-01
ORGANIC	33	.1382E+00	.2664E+00	.5393E+00	.9886E+00	.1608E+01	.1612E+01
ORGANIC	34	.7516E-03	.1318E-02	.1831E-02	.1973E-02	.1974E-02	.1974E-02
ORGANIC	35	.2270E-01	.4751E-01	.8384E-01	.1367E+00	.1669E+00	.1669E+00
PARTICULATE	31	.1188E+00	.1278E+00	.1364E+00	.1407E+00	.1527E+00	.1527E+00
PARTICULATE	32	.9956E-01	.1059E-01	.1080E-01	.1107E-01	.1117E-02	.1117E-02
PARTICULATE	33	.4004E-01	.4301E-01	.4580E-01	.4808E-01	.4882E-01	.4882E-01
PARTICULATE	34	.2313E-03	.2482E-03	.2544E-03	.2548E-03	.2548E-03	.2548E-03
PARTICULATE	35	.6608E-02	.7076E-02	.7495E-02	.7644E-02	.7727E-02	.7727E-02

TOTAL DOSE FOR 30 DAYS .1882E+02

INPUT I:\NSL\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT I:\NSL\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0: 3588 10 GPM, CORRECTED I-135  
 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4000E+04  
 FILTEDERD INLEAKAGE(CFM) .1400E+04  
 UNFILTERED INLEAKAGE(CFM) .30 E+02


	ISOTOPE	.5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
ELEMENTAL	31	.2636E+01	.2847E+01	.3181E+01	.3913E+01	.5944E+01	.6746E+01
ELEMENTAL	32	.2252E+01	.2397E+01	.2583E+01	.2745E+01	.2763E+01	.2763E+01
ELEMENTAL	33	.8900E+00	.9598E+00	.1068E+01	.1281E+01	.1583E+01	.1585E+01
ELEMENTAL	34	.5532E-02	.5783E-02	.6011E-02	.6078E-02	.6079E-02	.6079E-02
ELEMENTAL	35	.1227E+00	.1687E+00	.1742E+00	.1998E+00	.2143E+00	.2143E+00
ORGANIC	31	.4269E+00	.9326E+00	.1697E+01	.3405E+01	.7028E+01	.3917E+01
ORGANIC	32	.3449E-02	.6839E-02	.1116E-01	.1494E-01	.1537E-01	.1537E-01
ORGANIC	33	.1433E+00	.3060E+00	.5577E+00	.1056E+01	.1743E+01	.1747E+01
ORGANIC	34	.7761E-03	.1361E-02	.1891E-02	.2049E-02	.2050E-02	.2050E-02
ORGANIC	35	.2342E-01	.2905E-01	.8666E-01	.1453E+00	.1788E+00	.1788E+00
PARTICULATE	31	.1236E+00	.1330E+00	.1420E+00	.1476E+00	.1630E+00	.1630E+00
PARTICULATE	32	.1028E+02	.1101E+02	.1152E+02	.1168E+02	.1172E+02	.1172E+02
PARTICULATE	33	.4197E-01	.4471E-01	.4768E-01	.5221E-01	.5129E-01	.5129E-01
PARTICULATE	34	.2470E-03	.2584E-03	.2648E-03	.2692E-03	.2693E-03	.2693E-03
PARTICULATE	35	.6878E-02	.7366E-02	.7803E-02	.7995E-02	.8102E-02	.8102E-02

TOTAL DOSE FOR 30 DAYS .2037E+02

INPUT I:\NSL\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT I:\NSL\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0: 3588 10 GPM, CORRECTED I-135  
 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4000E+04  
 FILTEDERD INLEAKAGE(CFM) .1400E+04  
 UNFILTERED INLEAKAGE(CFM) .4000E+02

	ISOTOPE	.5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
ELEMENTAL	31	.2718E+01	.2936E+01	.3281E+01	.4085E+01	.6315E+01	.7196E+01
ELEMENTAL	32	.2323E+01	.2473E+01	.2664E+01	.2842E+01	.2863E+01	.2863E+01
ELEMENTAL	33	.9180E+00	.9900E+00	.1102E+01	.1336E+01	.1667E+01	.1669E+01
ELEMENTAL	34	.5708E-02	.5965E-02	.6200E-02	.6274E-02	.6275E-02	.6275E-02

VADIM  
11/21/04



ELEMENTAL	135	.1522E+00	.1635E+00	.1802E+00	.2078E+00	.2237E+00	.2237E+00
ORGANIC	132	.4400E+00	.481E+00	.702E+00	.1123E+01	.1627E+01	.1045E+02
ORGANIC	133	.3298E+02	.702E+02	.1123E+01	.1627E+01	.1615E+01	.1615E+01
ORGANIC	134	.1978E+00	.1423E+00	.1722E+00	.2132E+00	.1882E+01	.2126E+02
ORGANIC	135	.8005E-03	.1404E-03	.1792E-03	.1538E-03	.2126E-04	.2126E-04
PARTICULATE	131	.2418E-01	.5060E-01	.8947E-01	.1476E+00	.1905E+00	.1905E+00
PARTICULATE	132	.1285E+00	.3882E+00	.1144E-02	.1197E-02	.1213E-02	.1214E-02
PARTICULATE	133	.1077E-02	.1144E-02	.1197E-02	.1213E-02	.1213E-02	.1214E-02
PARTICULATE	134	.4330E-01	.4652E-01	.4956E-01	.5165E-01	.5433E-01	.5434E-01
PARTICULATE	135	.2567E-03	.2685E-03	.2771E-03	.2758E-03	.2758E-03	.2758E-03
PARTICULATE	135	.7147E-02	.7634E-02	.8109E-02	.8344E-02	.8476E-02	.8476E-02

TOTAL DOSE FOR 30 DAYS .2191E+02

INPUT : \NSL\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT : \NSL\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0: 3588 10 GPM, CORRECTED I-135  
 1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .4000E+04  
 FILTERED INLEAKAGE(CFM) .1400E+04  
 UNFILTERED INLEAKAGE(CFM) .5000E+02

ISOTOPE	.5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)	
ELEMENTAL	131	.2801E+01	.3025E+01	.3382E+01	.4257E+01	.6685E+01	.7644E+01
ELEMENTAL	132	.5980E+00	.1028E+01	.1138E+01	.1391E+01	.1791E+01	.1792E+01
ELEMENTAL	133	.2423E+00	.1028E+01	.1138E+01	.1391E+01	.1791E+01	.1792E+01
ELEMENTAL	134	.5880E-02	.6149E-03	.6389E-03	.6470E-02	.6470E-02	.6470E-02
ELEMENTAL	135	.1568E+00	.1685E+00	.1857E+00	.2158E+00	.2330E+00	.2330E+00
ORGANIC	131	.4534E+00	.9769E+00	.1808E+01	.3849E+01	.9256E+01	.1127E+02
ORGANIC	132	.3666E-02	.7268E-02	.1188E-01	.1640E-01	.1692E-01	.1692E-01
ORGANIC	133	.1522E+00	.3252E+00	.5940E+00	.1189E+01	.2011E+01	.2016E+01
ORGANIC	134	.8243E-03	.1447E-02	.3013E-03	.1200E-02	.2201E-02	.2201E-02
ORGANIC	135	.2491E-01	.5213E-01	.9221E-01	.1923E-00	.2624E+00	.2624E+00
PARTICULATE	131	.3333E+00	.1434E+00	.1531E+00	.1612E+00	.1836E+00	.1927E+00
PARTICULATE	132	.1111E-02	.1182E-02	.1242E-02	.1260E-02	.1262E-02	.1262E-02
PARTICULATE	133	.4493E-01	.4882E-01	.5142E-01	.5378E-01	.5706E-01	.5709E-01
PARTICULATE	134	.2663E-03	.2786E-03	.2855E-03	.2863E-03	.2863E-03	.2863E-03
PARTICULATE	135	.7415E-02	.7941E-02	.8414E-02	.8692E-02	.8849E-02	.8849E-02

TOTAL DOSE FOR 30 DAYS .2344E+02

INPUT : \NSL\MSA\CTRL ROOM\TUYFINAL.FOR  
 OUTPUT : \NSL\MSA\CTRL ROOM\TUYFINAL.OUT  
 FINAL CASE: NEW X0: 3588 10 GPM, CORRECTED I-135  
 1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .3900E+04  
 FILTERED INLEAKAGE(CFM) .1500E-04  
 UNFILTERED INLEAKAGE(CFM) .0000E+00


ISOTOPE	.5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)	
ELEMENTAL	131	.2427E+01	.2622E+01	.2927E+01	.3479E+01	.5009E+01	.5614E+01
ELEMENTAL	132	.2074E-01	.2208E-01	.2377E-01	.2499E-01	.2513E-01	.2513E-01
ELEMENTAL	133	.8196E+00	.8832E+00	.8832E+00	.1144E+01	.1331E+01	.1331E+01
ELEMENTAL	134	.3498E+00	.3932E+00	.3932E+00	.5589E+00	.5589E+00	.5589E+00
ELEMENTAL	135	.1352E+00	.1460E+00	.1608E+00	.1797E+00	.1906E+00	.1906E+00
ORGANIC	131	.3929E+00	.8465E+00	.1558E+01	.2845E+01	.6254E+01	.7525E+01
ORGANIC	132	.3176E-02	.6298E-02	.1026E-01	.1310E-01	.1343E-01	.1343E-01
ORGANIC	133	.1319E+00	.2818E+00	.5121E+00	.8874E+00	.1405E+01	.1408E+01
ORGANIC	134	.5147E-03	.1245E-02	.1739E-02	.1858E-02	.8630E-02	.8630E-02
ORGANIC	135	.2158E-01	.4573E-01	.7958E-01	.1527E+00	.1538E+00	.1539E+00
PARTICULATE	131	.1038E+00	.1176E+00	.1327E+00	.1526E+00	.1539E+00	.1539E+00
PARTICULATE	132	.9179E-03	.9754E-03	.1020E-02	.1024E-02	.1025E-02	.1025E-02
PARTICULATE	133	.3691E-01	.3965E-01	.4221E-01	.4277E-01	.4355E-01	.4355E-01
PARTICULATE	134	.2188E-03	.2289E-03	.2345E-03	.2347E-03	.2347E-03	.2347E-03
PARTICULATE	135	.6092E-02	.6524E-02	.6908E-02	.6974E-02	.7010E-02	.7010E-02

TOTAL DOSE FOR 30 DAYS .1649E+02

INPUT : \NSL\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT : \NSL\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0: 3588 10 GPM, CORRECTED I-135  
 1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .3900E+04  
 FILTERED INLEAKAGE(CFM) .1500E-04  
 UNFILTERED INLEAKAGE(CFM) .1000E+02

ISOTOPE	.5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)	
ELEMENTAL	131	.2511E+01	.2712E+01	.3029E+01	.3653E+01	.5384E+01	.6068E+01

1/5/04  
1/5/04  
1/5/04



ELEMENTAL	32	.2145E-01	.2284E-01	.2460E-01	.2508E-01	.2614E-01	.2614E-01
ELEMENTAL	33	.8479E+00	.9144E+00	.1017E+01	.1199E+01	.1456E+01	.1457E+01
ELEMENTAL	34	.5270E-02	.5510E-02	.5725E-02	.5783E-02	.5783E-02	.5783E-02
ELEMENTAL	35	.1404E+00	.1510E+00	.1664E+00	.1828E+00	.2001E+00	.2001E+00
ORGANIC	32	.4062E+00	.4717E+00	.1614E+01	.3070E+01	.6326E+01	.8364E+01
ORGANIC	33	.1288E-02	.2832E-02	.1082E+00	.1984E+01	.1211E+01	.1211E+01
ORGANIC	34	.1365E+00	.2349E+00	.5304E+00	.9349E+00	.9349E+00	.9349E+00
ORGANIC	35	.7393E-03	.1247E-02	.1800E-02	.1935E+00	.9348E+00	.1609E+00
ORGANIC	36	.2233E-01	.4673E-01	.8242E+01	.1324E+00	.1609E+00	.1609E+00
PARTICULATE	31	.1144E+00	.1231E+00	.1313E+00	.1345E+00	.4333E+00	.4669E+00
PARTICULATE	32	.9589E-03	.1019E-02	.1066E-02	.1073E-02	.1074E-02	.1074E-02
PARTICULATE	33	.3856E-01	.4142E-01	.4410E-01	.4503E-01	.4632E-01	.4633E-01
PARTICULATE	34	.3982E-03	.2481E-03	.2450E-03	.2452E-03	.2452E-03	.2452E-03
PARTICULATE	35	.6364E-02	.6815E-02	.7217E-02	.7327E-02	.7388E-02	.7388E-02

TOTAL DOSE FOR 30 DAYS .1804E+02

INPUT : \NSI\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT : \NSI\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0: 3588 10 GPM, CORRECTED I-135  
 1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .3900E+04  
 FILTRATED INLEAKAGE(CFM) .1500E+04  
 UNFILTERED INLEAKAGE(CFM) .2000E+02

	ISOTOPE .5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)	
ELEMENTAL	31	.2592E+01	.2802E+01	.3130E+01	.3826E+01	.5758E+01	.6521E+01
ELEMENTAL	32	.5978E+01	.6236E+01	.6542E+01	.7296E+01	.9713E+01	.1044E+01
ELEMENTAL	33	.8760E+00	.9487E-01	.1051E+00	.1254E+01	.1648E+01	.1648E+01
ELEMENTAL	34	.5449E-02	.5692E-02	.5918E+00	.5980E+00	.5980E+00	.5980E+00
ELEMENTAL	35	.1452E+00	.1561E+00	.1719E+00	.1958E+00	.2095E+00	.2095E+00
ORGANIC	31	.4199E+00	.9047E+00	.1670E+01	.3293E+01	.7595E+01	.9199E+01
ORGANIC	32	.3395E-02	.6731E-02	.1098E+01	.1457E+01	.1499E+01	.1499E+01
ORGANIC	33	.1410E+00	.3012E+00	.5486E+00	.1022E+01	.1676E+01	.1680E+01
ORGANIC	34	.7693E+00	.1340E+02	.1894E+02	.2011E+02	.2011E+02	.2011E+02
ORGANIC	35	.2307E-01	.4828E+01	.9547E+01	.1410E+00	.1547E+00	.1547E+00
PARTICULATE	31	.1193E+00	.1283E+00	.1370E+00	.1414E+00	.1547E+00	.1587E+00
PARTICULATE	32	.9997E-03	.1062E-02	.1111E-02	.1121E-02	.1122E-02	.1122E-02
PARTICULATE	33	.4020E-01	.4319E-01	.4599E-01	.4728E-01	.4909E-01	.4910E-01
PARTICULATE	34	.2383E-03	.2493E-03	.2554E-03	.2558E-03	.2558E-03	.2558E-03
PARTICULATE	35	.6635E-02	.7105E-02	.7526E-02	.7879E-02	.7765E-02	.7765E-02

TOTAL DOSE FOR 30 DAYS .1959E+02


INPUT : \NSI\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT : \NSI\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0: 3588 10 GPM, CORRECTED I-135  
 1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .3900E+04  
 FILTRATED INLEAKAGE(CFM) .1500E+04  
 UNFILTERED INLEAKAGE(CFM) .3000E+02

	ISOTOPE .5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)	
ELEMENTAL	31	.2677E+01	.2892E+01	.3231E+01	.3999E+01	.6130E+01	.6971E+01
ELEMENTAL	32	.2287E+01	.2435E+01	.2623E+01	.3793E+01	.5813E+01	.6814E+01
ELEMENTAL	33	.8040E+00	.9748E+00	.1082E+01	.1509E+01	.1812E+01	.1822E+01
ELEMENTAL	34	.5618E-02	.5874E-02	.6102E+00	.9478E+00	.9197E+00	.9177E+00
ELEMENTAL	35	.1499E+00	.1611E+00	.1737E+00	.2038E+00	.2190E+00	.2190E+00
ORGANIC	31	.4333E+00	.9337E+00	.1225E+01	.3516E+01	.8261E+01	.1003E+02
ORGANIC	32	.3503E-02	.6946E-02	.1134E+01	.1530E+01	.1576E+01	.1576E+01
ORGANIC	33	.1455E+00	.3109E+00	.5768E+00	.1089E+01	.1810E+01	.1814E+01
ORGANIC	34	.7883E-03	.1383E+02	.1371E+02	.2087E+02	.2088E+02	.2088E+02
ORGANIC	35	.2381E+01	.3882E+01	.1337E+00	.1488E+00	.1847E+00	.1847E+00
PARTICULATE	31	.1040E+00	.1106E+02	.1127E+02	.1166E+02	.1171E+02	.1171E+02
PARTICULATE	32	.4184E+01	.4394E+01	.4787E+01	.4953E+01	.5185E+01	.5187E+01
PARTICULATE	33	.2480E+03	.2594E+03	.2658E+03	.2664E+03	.2664E+03	.2664E+03
PARTICULATE	34	.6905E-02	.7395E-02	.7833E-02	.8030E-02	.8140E-02	.8140E-02

TOTAL DOSE FOR 30 DAYS .2113E+02

INPUT : \NSI\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT : \NSI\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0: 3588 10 GPM, CORRECTED I-135  
 1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .3900E+04  
 FILTRATED INLEAKAGE(CFM) .1500E+04  
 UNFILTERED INLEAKAGE(CFM) .4000E+02

11/17/2014  
DRAFT  
Initial



	ISOTOPE	.5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
ELEMENTAL	31	.2760E+01	.2981E+01	.3332E+01	.4171E+01	.6500E+01	.7420E+01
ELEMENTAL	32	.6320E+00	.1005E+01	.1118E+01	.1363E+01	.1709E+01	.1711E+01
ELEMENTAL	33	.5793E+02	.6056E+02	.6294E+02	.6718E+02	.6932E+02	.6972E+02
ELEMENTAL	34	.1545E+00	.1660E+00	.1830E+00	.2118E+00	.2388E+00	.2362E+00
ORGANIC	31	.4467E+00	.9625E+00	.1780E+01	.3738E+01	.8938E+01	.1088E+01
ORGANIC	32	.3612E+02	.7161E+02	.1170E+03	.1603E+03	.1653E+03	.1653E+03
ORGANIC	33	.1500E+00	.3205E+00	.5849E+00	.1156E+01	.1944E+01	.1949E+01
ORGANIC	34	.9792E+02	.1236E+02	.1682E+02	.2163E+02	.2164E+02	.2164E+02
ORGANIC	35	.2164E+01	.5139E+01	.9087E+01	.1681E+00	.1965E+00	.1965E+00
PARTICULATE	31	.1290E+00	.1387E+00	.1411E+00	.1521E+00	.1742E+00	.1822E+00
PARTICULATE	32	.1081E+02	.1149E+02	.1172E+02	.1211E+02	.1216E+02	.1216E+02
PARTICULATE	33	.4347E+01	.4670E+01	.4974E+01	.5177E+01	.5460E+01	.5462E+01
PARTICULATE	34	.2577E+03	.2695E+03	.2762E+03	.2768E+03	.2769E+03	.2768E+03
PARTICULATE	35	.7174E+02	.7683E+02	.8140E+02	.8379E+02	.8513E+02	.8513E+02

TOTAL DOSE FOR 30 DAYS .2267E+02

INPUT I:\NSI\MSA\CTRL ROOM\THYFINAL.FOR  
 OUTPUT I:\NSI\MSA\CTRL ROOM\THYFINAL.OUT  
 FINAL CASE: NEW X0: 3588 10 GPM, CORRECTED I-135  
 1 RECIRCULATION FLOW FROM CONTROL ROOM(CFM) .3900E+04  
 FILTERED INLEAKAGE(CFM) .1500E+04  
 UNFILTERED INLEAKAGE(CFM) .5000E+02


	ISOTOPE	.5 HOUR DOSE(REM)	1 HOUR DOSE(REM)	2 HOUR DOSE(REM)	8 HOUR DOSE(REM)	4 DAY DOSE(REM)	30 DAY DOSE(REM)
ELEMENTAL	31	.2842E+01	.3070E+01	.3432E+01	.4343E+01	.6870E+01	.7866E+01
ELEMENTAL	32	.2428E+01	.2585E+01	.2786E+01	.2981E+01	.3011E+01	.3011E+01
ELEMENTAL	33	.8568E+00	.1035E+01	.1152E+01	.1418E+01	.1793E+01	.1795E+01
ELEMENTAL	34	.5892E+02	.6337E+02	.6483E+02	.6567E+02	.6567E+02	.6567E+02
ELEMENTAL	35	.1591E+00	.1910E+00	.1932E+00	.2187E+00	.2377E+00	.2377E+00
ORGANIC	31	.4601E+00	.4342E+00	.4337E+00	.4959E+01	.5587E+01	.1169E+02
ORGANIC	32	.3719E+02	.3935E+02	.4006E+02	.4676E+02	.5130E+02	.5130E+02
ORGANIC	33	.1545E+00	.3300E+00	.6030E+00	.1222E+01	.2078E+01	.2083E+01
ORGANIC	34	.8369E+03	.1468E+02	.2042E+02	.2238E+02	.2239E+02	.2239E+02
ORGANIC	35	.2538E+01	.5290E+01	.9367E+01	.1666E+00	.2082E+00	.2082E+00
PARTICULATE	31	.1339E+00	.1339E+00	.1537E+00	.1619E+00	.1846E+00	.1939E+00
PARTICULATE	32	.1139E+02	.1392E+02	.1527E+02	.1566E+02	.1567E+02	.1567E+02
PARTICULATE	33	.4569E+01	.4844E+01	.5191E+01	.5300E+01	.5394E+01	.5395E+01
PARTICULATE	34	.2673E+03	.2796E+03	.2862E+03	.2918E+03	.2981E+03	.2981E+03
PARTICULATE	35	.7442E+02	.7970E+02	.8445E+02	.8727E+02	.8886E+02	.8886E+02

TOTAL DOSE FOR 30 DAYS .2419E+02

0 0 1 0 0 1 3 0 0 3 3

RECALC  
8-17-91  
mws

P-1711



ENGINEERING DEPT.

AMERICAN ELECTRIC POWER SERVICE CORP.

1 RIVERSIDE PLAZA  
COLUMBUS, OHIO

0 0 2 0 0 1 5 0 SHEET 9 OF

DATE 8/5/94 BY M-LA CK 68M

COMPANY \_\_\_\_\_ G.O. \_\_\_\_\_


PLANT \_\_\_\_\_

OBJECT \_\_\_\_\_

Attachment 8

whole Body / Skin Dose Results

@ 3519 cfm Intake



0 0 2 , 0 0 1 3 0 0 0 . 0

INPUT: NOBFlim.FOR; OUTPUT: NOBFlim.OUT

final code, run at 3313+200 cfm

THE AIR FLOW TO THE CONTROL ROOM IS 3513. CFM

8-13-94

WPA

OPE	WHOLE BODY	BETA SKIN
KR85M	.1527D-01	.5334D+00
KR85	.5701D-04	.1326D+00
KR87	.4354D-01	.2000D+01
KR88	.3394D+00	.1530D+01
XE131M	.1951D-03	.2834D-01
XE133M	.1320D-01	.1467D+01
XE133	.1436D+00	.4157D+01
XE135M	.3122D-02	.1991D-01
XE135	.6499D-01	.1870D+01
XE138	.3150D-01	.4113D+00

TOTAL WHOLEBODY DOSE FOR 30 DAYS IS .6549D+00 REM

TOTAL SKINDOSE FOR 30 DAYS IS .1215D+02 REM

\*\*\*\*\*

0 0 1 0 0 1 3 0 0 9 0

