

**TELEDYNE
ENGINEERING SERVICES**

Docket # 50-315
Control # 8312210221
Date 12/18/83 of Document
REGULATORY DOCKET FILE

**TELEDYNE ENGINEERING SERVICES
CONTROLLED
DOCUMENT**

TES PROJ. NO. 5364
DATE 12/17/83

**TELEDYNE
ENGINEERING SERVICES**

**TELEDYNE
ENGINEERING SERVICES**

TECHNICAL REPORT

**TECHNICAL REPORT TR-5364-3
REVISION 0**


BOOK 1 OF 3

DONALD C. COOK NUCLEAR GENERATING PLANT

**ANALYSIS OF PRESSURIZER SAFETY VALVE DISCHARGE
PIPING SYSTEM, WITH DRAINED LOOP SEALS
PER NUREG 0737, II.D.1,
UNIT 1**

JULY 18, 1983

8312210225 831215
PDR ADDOCK 05000315
PDR



AMERICAN ELECTRIC POWER SERVICE CORPORATION
2 BROADWAY
NEW YORK, NEW YORK 10004

TECHNICAL REPORT TR-5364-3
REVISION 0

BOOK 1 OF 3

DONALD C. COOK NUCLEAR GENERATING STATION

ANALYSIS OF PRESSURIZER SAFETY VALVE DISCHARGE
PIPING SYSTEM, WITH DRAINED LOOP SEALS
PER NUREG 0737, II. D.1,
UNIT 1

JULY 18, 1983

TELEDYNE ENGINEERING SERVICES
130 SECOND AVENUE
WALTHAM, MASSACHUSETTS 02254
617-890-3350




TABLE OF CONTENTS

	<u>PAGE</u>
1.0 INTRODUCTION	Book 1 of 3 1-1
2.0 CONCLUSIONS	2-1
3.0 SYSTEM DESCRIPTION/DISCUSSION	3-1
4.0 THERMAL FLUIDS ANALYSIS	4-1
4.1 Introduction	4-1
4.2 RELAP Model	4-3
4.2.1 Pressurizer Conditions	4-3
4.2.2 Valve Modeling	4-4
4.2.3 Discharge Piping	4-4
4.2.4 Quench Tank	4-4
4.3 RELAP Model Control Volumes	4-11
4.4 Valve Flow Rate Calculation	4-19
4.5 RELAP Plots	4-25
4.6 Force Time History Plots	4-63
4.7 RELAP Input	4-134
4.8 REPIPE Input	4-154
4.8.1 REPIPE Input - Section A	4-155
4.8.2 REPIPE Input - Section B	4-161
4.9 Appendix A	4-169
5.0 STRUCTURAL ANALYSIS	Book 2 of 3 5-1
5.1 SV Transient Thermal Analysis	5-2
5.2 Transient Shock Analysis	5-2
6.0 ANALYTICAL RESULTS	6-1
6.1 Stress Summary	6-1
6.1.1 Equation C-1 Stresses	6-5
6.1.2 Equation C-2 Stresses	6-16
6.1.3 Equation C-3 Stresses	6-27
6.2 Support Loads	6-38




TABLE OF CONTENTS
(Continued)

	<u>PAGE</u>
6.3 Valve Accelerations	6-79
6.3.1 DBE Seismic Accelerations	6-80
6.3.2 SV Transient Shock Valve Accelerations	6-84
6.4 Nozzle Loads	6-88
6.5 Valve Loads	6-94
7.0 DRAWINGS	7-1
8.0 REFERENCES	8-1
9.0 COMPUTER ANALYSIS	Book 3 of 3
9.1 RELAP Input	
9.2 REPIPE Input	
9.2.1 REPIPE Input Section A	
9.2.2 REPIPE Input Section B	
9.3 Thermal Case 3 Input/Output	
9.4 SV Transient Shock Input	

1.0 INTRODUCTION

American Electric Power Service Corporation (AEPSC), purchase order number 02676-820-1N, authorized Teledyne Engineering Services (TES) to analyze the Pressurizer Safety/Relief Valve Discharge Piping per NRC NUREG-0737, Item II. D.1 for the Donald C. Cook Nuclear Power Plant, Unit #1..


This activity was performed in accordance with the TES Quality Assurance program which meets the requirements of 10CFR50, Appendix B, and ANSI N45.2.11 as interpreted by Regulatory Guide 1.64, Revision 2.

The scope of work for this effort is described in detail in Teledyne Engineering Services Technical Proposal PR-5653 (Reference 9), dated May 14, 1981 and modified as stated in AEPSC letter dated November 29, 1982, from Mr. Sam Ulan (AEPSC) to Mr. L. B. Semprucci (TES); in AEPSC letter from Mr. Sam Ulan (AEPSC) to Mr. P. D. Harrison (TES) dated March 15, 1983 (References 1 and 11) and in TES letter 5364-44 from Mr. P. D. Harrison (TES) to Mr. S. Ulan (AEPSC) dated May 28, 1983 (Reference 10).

The majority of the analysis was performed after the receipt of AEPSC letters dated November 29, 1982 and March 15, 1983 (References 1 and 11), which were issued after more complete information was available from the EPRI data.

This analysis was performed using large digital computer programs supplemented with any necessary hand calculations. The RELAP5 MOD1 Cycle 14 computer program was used to do the thermal fluid transient analysis. The structural analysis, for all loading conditions, was done utilizing the TMRSAP computer program.

The size of the pressurizer safety/relief valve discharge piping system was so large that the computer models, for both RELAP and TMRSAP, strained the limits of the programs. This condition necessitated multiple RELAP runs in order to execute the thermal fluid transient analysis for the appropriate length of time. For the structural analysis it was necessary to expand the core of the TMRSAP program in order to avoid an overconservative overlap analysis.




2.0 CONCLUSIONS

The analysis performed by TES on the Pressurizer Safety/Relief Valve Discharge Piping System with the Safety Valve loop seal drained, indicates that all criteria of NRC NUREG-0737, Item II.D.1 are met, with the following qualifications:

- 1) Valve accelerations due to the SV transient shock condition for valves SV-45A, SV-45B and SV-45C exceed the vertical allowable of 2g's (Reference 14). The accelerations exceed the allowable by less than 1g and, therefore, it is TES's opinion that these valve accelerations are acceptable. However, setting the criteria of acceptance of these accelerations is out of the TES work scope and is, therefore, the responsibility of others.
- 2) The supports listed below exceed the loads given on the As-Built support drawings (see Section 6.2). These support loads, while exceeding the previous loads, do so in most cases by a small percentage. However, acceptance of these loads is out of the TES work scope and is the responsibility of others.

1-GRC-R-585
1-GRC-R-589
1-GRC-R-591
1-GRC-R-601
1-GRC-S-608
1-GRC-R-613
1-GRC-S-614
1-GRC-R-616



This report documents that the safety/relief valve discharge piping for Unit 1 is acceptable for emergency conditions assuming drained loop seals. TES Technical Report TR-5364-1, Revision 0 (Reference 2), which is based on the as-built condition, documents the acceptability of the system for normal and upset conditions. Draining the loop seals will not affect the normal and upset conditions.

The purpose of the loop seals was to protect the safety valves from leaking by keeping free hydrogen and high temperatures away from the valve seats. It should be noted that while draining the loop seals relieves the overwhelming stress on the discharge system; see TES Technical Report TR-5364-1, Revision 0 (Reference 2), it also leaves the valve seats unprotected and, therefore, susceptible to leaking. While it is beyond the responsibility of TES, this condition can result in serious consequences and should be investigated.

Support load summary sheets have been included in this report for all supports and supercede the loads reported in TR-5364-1.

3.0 SYSTEM DESCRIPTION/DISCUSSION

The Pressurizer Safety/Relief Valve Discharge Piping System consists of all of the piping from the pressurizer nozzles, down to the sparger in the quench tank. This information is depicted on-TES drawing E-5763, Revision 3, generated from AEP drawings 1-GRC-6, sheets 1, 2, 3, and 4; 1-GRC-7; 1-GRC-8; 1-GRC-9; 1-5435-8; 1-RC-6, sheets 1, 2, 3 and 4; 1-RC-7; 1-RC-8; and 1-RC-9.

The "Discharge" piping constitutes a very large system resulting in a large computer model. The size and geometrical complexity, which is due mainly to the sweeping curves around the pressurizer, complicates the modification effort in addition to causing longer run times..

Modification of this complex system, to attempt to secure satisfactory "Safety Valve Discharge" results, is limited to draining the SV loop seals. Heating the loop seals is not a viable "fix" because of the size of the loops. These long loops contain sufficient quantity of water such that on SV Discharge, the water seal does not "flash" completely enough to reduce the very high loads caused by the water slug. Modification to the support system is also a poor option because of the very limited space in the annulus around the pressurizer, which makes construction very difficult.

4.0 THERMAL FLUIDS ANALYSIS


4.1 Introduction

The following thermodynamic fluid analysis determines the fluid forces which act on the pressurizer safety valve discharge piping of the American Electric Power Service Corporation (AEPSC) Donald C. Cook Nuclear Power Plant, Unit 1. These forces are generated by the sudden opening of the pressurizer safety valves during one of the pressurizer transients described in the AEP letter of November 29, 1982 to TES (Reference 1).

These fluid forces and the resulting loads and stresses on the piping system became of increased concern as a result of the incident at Three Mile Island. Following this incident, the NRC issued NUREG 0578 and NUREG 0737, which required that each utility determine the effect of safety/ relief valve operation upon the valve and the discharge piping. An elaborate program involving both testing and analysis was established under the general management of the Electric Power Research Institute (EPRI). The EPRI program included intensive testing of safety and relief valves as well as a full scale safety valve test facility, built at Combustion Engineering in Connecticut.

Simultaneously, an analytical program was initiated to choose and test a computer program which would predict the fluid forces; RELAP5 MOD1 was chosen. RELAP5 MOD1 is the latest in the family of RELAP programs developed at the Idaho National Engineering Laboratory.

The D.C. Cook Units 1 and 2 pressurizer safety valves have "Cold Loop Seals". A "Cold Loop Seal" is a subcooled slug of water trapped between the safety valve seat and the pressurizer nozzle by a loop of piping. The function of this slug of water is to prevent the safety valve from leaking, this is accomplished by keeping free hydrogen away from, and maintaining reduced temperatures at the valve seat. While the loop seal provides a benefit, it also has a serious drawback. When the safety valve opens, the loop seal is shot through the discharge piping with tremendous force. In TES Technical Report TR-5364-1, TES performed a fluid analysis to determine the magnitude of the loads applied



to the discharge piping by the propulsion of the cold loop seal. These loads were calculated to be greater than 100,000 lbf for a single safety valve discharge. The simultaneous discharge of the pressurizer's three safety valves with loop seals could result in loads of over 300,000 lbs.

As explained in TR-5364-1, TES also performed a sensitivity study to determine if raising the loop seal temperature (by electrical trace heating) would reduce the loads. Increasing the loop seal temperature did lower the loads somewhat, however, a significant reduction was not obtained. It was then suggested that the loop seals should be drained so that when the safety valves operated, they would discharge steam only.


This report presents the analysis for the steam discharge that was performed for the Unit 1 pressurizer safety valves. The maximum fluid force calculated in this analysis is 24,000 lbf for simultaneous discharge of all three safety valves. It can be seen that draining the loop seals provides a significant force reduction.

In this analysis, as before, TES has used RELAP5 MOD1 version 2.11 as it is made available through Control Data Corp with a post-processor, REPIPE version 3.10, which calculates the fluid forces. This version of RELAP5 MOD1 is identified by the following computer job control language at Control Data Corporation:

```
BEGIN, RELAP5, R5M2, INPUT=INPUTFILE, SCM=377000B
```

The computer analysis procedure for the thermal analysis portion is included in Appendix A.

RELAP5 calculates hydrodynamic data for control volumes in each segment of pipe. REPIPE then takes this data and defines two force time histories for each segment, one set for inlet junction forces and the other for outlet junction forces. A TES generated program, SAP2SAP, adds these force time histories. Finally, one force-time history for each segment of axial, unbalanced loads is analyzed structurally.




4.2 RELAP Model

4.2.1 The D.C. Cook pressurizer was modeled as a single time dependent volume with the following transient condition as specified by the AEPSC, November 29, 1982 letter to Mr. L.B. Semprucci, pages 1-7 (Reference 1):

Safety Valves

Pressure Time History (in the pressurizer)



These are the same safety valve pressure boundary conditions that were used in analyzing the quarter model cold loop seal case of TR-5364-1 (Reference 2).

4.2.2 Safety valves were modeled as RELAP junctions emulating Crosby HB-BP-86 valves (Reference 3) with orifice areas of 0.01897 Ft^2 and a valve opening time of 0.010 seconds.

Valve orifice areas were calculated using the Crosby Valve and Gage Company Drawing No. H-51688, Revision A (Reference 3) provided by AEP, and RELAP (Run ID BAICDRO) implementing rated flows. Calculated values are included in Section 4.6 and Figure 4.6.1.

4.2.3 Discharge piping was modeled from all safety and power operated relief valves to the quench tank. This discharge piping included the following pipe sizes:

3 inch, 12 inch	SCH 40
4 inch, 6 inch	SCH 40S
4 inch	SCH 120
3 inch, 6 inch	SCH 160

Friction factors for long and short radius elbows and reducers were taken from technical paper #410 by Crane (Reference 4). Calculations of these frictional losses are included in Appendix A. The discharge piping is defined in segments of straight sections from; elbow to elbow, valve to elbow, etc.

4.2.4 The Quench Tank was modeled in two parts, the sparger and the tank itself, using cylindrical volumes containing water and air. The quench tank volumes were taken from Westinghouse Dwg. No. 110E272 (Reference 5).

The sparger for D.C. Cook is a perforated pipe submerged in water within the quench tank as indicated in Figure 4.2.1. It is represented in RELAP as a pipe similarly submerged and of equal volume.

4-5

BY SAT DATE 1-12-83
CHKD. BY CJM DATE 3-11-83

DONALD C. COOK
NUCLEAR GEN. STATION UNITS 1 & 2
QUENCH TANK

SHEET NO. 1 OF 6
PROJ. NO. 5364






FIGURE 4.2.1-1

NOM. INTERNAL VOL. = 1800 ft³

QUENCH TANK DRAWING FOR
D.C. COOK UNIT 1 & 2 (NOT SCALE)
(REF: WEST. DRAWG. 110E272; AER.DRAWG. 1-512BA-21)

DETAIL "A"





BY BAT DATE 1-14-83
CHKD. BY CMV DATE 3-11-83

DONALD C. COOK
NUCLEAR GEN. STATION UNITS 1&2
RELAPS QUENCH TANK MODELING

SHEET NO. 2 OF 6
PROJ. NO. 5364

FIGURE 4.2.1-2

RELAP5 MODEL OF THE QUENCH TANK

REMARKS:


1. QUENCH TANK WAS MODELED AS A SERIES OF "PIPE COMPONENTS" WITH APPROPRIATE FLOW AREAS AND LOSS COEFFICIENTS.
2. WATER LEVEL IN THE QUENCH TANK IS AT THE SAME HEIGHT AS THE WATER LEVEL IN THE SPARGER
3. THE SECTION OF THE SPARGER WITH DISCHARGE HOLES WAS MODELED AS A PIPE WITH ITS LENGTH EQUAL TO THE LENGTH OF THE SPARGER WITH THE TOTAL NUMBER OF HOLE AREAS EQUAL TO FLOW AREA OF THE SPARGER (REF. DETAIL DRW "A")
4. RUPTURE DISCS WERE MODELED AS A TRIP VALVE WHICH OPENS AT THE BURST PRESSURE OF 100 psig.
5. VACUUM BREAKER HOLE WITH DIA. = 0.25 - 0.31" AND LOCATED 14 INCHES FROM THE TOP OF THE QUENCH TANK WAS IGNORED IN THE MODELING.

V = NOMINAL INTERNAL VOLUME OF THE TANK = 1800 ft^3 (W.H. DR. 110 E272)

TANK IS 82% FULL OF WATER. . . (REF. TELECON LBS WITH SAM ULAN DATED 1-14-83)

V_1 = WATER VOLUME IN THE QUENCH TANK = 1476 ft^3

V_2 = AIR VOLUME IN THE QUENCH TANK = 324 ft^3




BY BAI DATE 1-17-83
CHKD. BY CMM DATE 3-11-83

DONALD C. COOK
NUCLEAR GEN. STATION UNITS 1&2
KELAP5 QUENCH TANK MODELING


SHEET NO. 3 OF 6
PROJ. NO. 5364

FIGURE 4.2.1-3

IF QUENCH TANK IS A CYLINDER WITH $D = 114$ IN INSIDE DIA.



H - HEIGHT OF THE WATER LEVEL FROM BOTTOM OF THE TANK



$$\text{AREA}(1) = \frac{R^2}{2} (\hat{\alpha} - \sin \alpha) \quad \text{EQN-1}$$

WHERE: $\hat{\alpha}$; IN RADIANS

α ; IN DEGREES

$$\text{AREA}(1) = \frac{\text{AIR VOLUME}}{\text{HEIGHT OF CYL}} = \frac{V_2}{L} = \frac{324}{25.3943}$$

$$\text{AREA}(1) = 12.7588 \text{ ft}^2$$


SUBSTITUTING INTO EQN 1

$$12.7588 = \frac{22.5625}{2} (\hat{\alpha} - \sin \alpha)$$

$$13.1310 = \hat{\alpha} - \sin \alpha$$

BY TRIAL AND ERROR:

$$\underline{\alpha \approx 116.5^\circ}$$



Technical Report
TR-5364-3
Revision 0

TELEDYNE ENGINEERING SERVICES

BY B.A.I DATE 1-17-83
CHKD. BY CMM DATE 3-11-83

DONALD C. COCK
NUCLEAR GEN. STATION UNITS 1 & 2
RELAPS QUENCH TANK MODELING

SHEET NO. 4 OF 6
PROJ. NO. 5364

FIGURE 4.2.1-4

$$h = R \cos \frac{\alpha}{2}$$

$$h = 4.75 \cos \frac{116.5}{2}$$

$$h = 2.4995$$

$$H = h + R = 4.75 + 2.4995$$

$H \approx 87 \text{ in} = 7.25 \text{ ft}$ HEIGHT OF WATER SURFACE FROM THE BOTTOM OF THE QUENCH TANK.

$D - H = 24 \text{ in} = 2.25 \text{ ft}$ FROM THE TOP OF THE QUENCH TANK TO THE WATER SURFACE.

FROM WATER SURFACE TO THE CENTER OF THE HORIZONTAL SECTION OF THE SPARGER $\approx 68 \text{ in} = 5.6667 \text{ ft}$


HEIGHT OF WATER LEVEL IN QUENCH TANK MODEL MUST BE ALSO = 5.6667 ft

VOLUME OF WATER IN QUENCH TANK = 1476 ft^3

SURFACE AREA BETWEEN WATER AND AIR = $\frac{1476}{5.6667} = 260.4706 \text{ ft}^2$


VOLUME OF AIR IN QUENCH TANK = 324 ft^3

HEIGHT OF AIR VOLUME IN RELAP MODEL = $\frac{324}{260.4706} = 1.2439 \text{ ft}$



BY JAT DATE 1-17-83
CHKD. BY CMM DATE 3-11-83DONALD C. COOK
NUCLEAR GEN. STATION UNITS 1&2
RELAPS QUENCH TANK MODELINGSHEET NO. 5 OF 6
PROJ. NO. 5364

FIGURE 4.2.1-5

SPARGER MODELING

$$\text{AREA OF EACH HOLE ON SPARGER SIDE} = 0.1963 \text{ in}^2 = 0.0014 \text{ ft}^2$$

$$\text{TOTAL FLOW AREA OF ALL THE SIDE HOLES} = 1054 \times 0.0014 = 1.4368 \text{ ft}^2$$

$$\text{FLOW AREA OF } 12 \text{ IN SCH 40 PIPE} = 0.7773 \text{ ft}^2$$

ALL THE HOLES ARE DISTRIBUTED EVENLY @ 183 IN LENGTH FROM THE TIP OF THE SPARGER

AREA RATIOS = $\frac{0.7773}{1.4368} = 0.541$ REPRESENTS THE SECTION OF THE SPARGER WHICH INCLUDES ALL THE HOLES WITH THE TOTAL AREAS EQUAL TO THE FLOW AREA OF THE 12 IN SCH 40 PIPE.

$$1 - 0.541 = .459$$

$$183 \times 0.459 = 83.9977 \approx 84.0 \text{ IN} = 7 \text{ ft} \text{ THE LENGTH WHICH MUST BE EXCLUDED FROM THE TIP}$$

$$\text{TOTAL LENGTH OF HORIZONTAL SECTION} = 215.77 \text{ IN} \text{ (REF 3RD IN ON PAGE 1)} \\ \text{THIS LENGTH IN RELAP MODEL} = 215.77 - 84 = 131.77 \approx 11 \text{ ft}$$

Technical Report
TR-5364-3
Revision 0

TELEDYNE ENGINEERING SERVICES


4-10

BY BAT DATE 1-17-83
CHKD. BY C44 DATE 3-11-83


DONALD C. COOK
NUCLEAR GEN. STATION UNITS 1&2
RELAPS QUENCH TANK MODELING

SHEET NO. 6 OF 6
PROJ. NO. 5364

FIGURE 4.2.1-6



RELAPS QUENCH TANK MODEL



4.3 RELAP Model Control Volumes

The "Evaluation of RELAP5/MOD1 for Calculation of Safety/Relief Valve Discharge Piping Hydrodynamic Loads" report prepared by Intermountain Technologies Inc. (Reference 6) recommends using ten or more control volumes per bounded segment when modeling valve discharge piping for RELAP5, while avoiding significant control volume length differences to preserve pressure wave shapes. The ten control volume criteria recommended by ITI was adhered to by TES in all cases, except in piping arcs and in segments less than three feet in length. The D.C. Cook discharge piping is modeled using as few as one control volume per segment (pipe segments with lengths less than 0.5 feet) and up to thirty-two control volumes per segment.

Arc modeling for Unit 1 is represented in Figure 4.3.1. All arcs for Unit 1 were modeled in RELAP as having no fluid losses. Essentially, RELAP calculates these as straight sections of pipe. REPIPE, however, distributes the calculated forces to pre-assigned node points matching the TES structural models.


Average control volume lengths used for the D.C. Cook RELAP Unit 1 model were:

<u>Pipe Size</u>	<u>Average C.V. Length</u>
3 inch SCH 160	0.4644 feet
6 inch SCH 160	0.5264 feet
4 inch SCH 40S	0.4471 feet
6 inch SCH 40S	0.8614 feet
12 inch SCH 40	0.8064 feet
3 inch SCH 40	0.4744 feet
4 inch SCH 120	0.5056 feet

The schematic of the discharge system modeled in RELAP for the SV Unit 1 model is represented in Figure 4.7.1.

Quench Tank modeling was achieved using twenty control volumes and twenty junctions. Eighteen volumes comprise the sparger model while the remaining two are single volumes modeling the water and air spaces of the quench tank. The water and air volumes as determined from Westinghouse Dwg. No. 110E272 (Reference 5) were input to RELAP to insure proper quenching capacity. Eighteen control volumes forming the sparger are initially 88% full of water representing a submerged pipe. The discharge holes were modeled as a single hole with an area of .7773 ft.² at a point on the sparger where the sum of the small hole areas equal the 12 inch schedule 40 discharge area.

Finally, the tank rupture disk is modeled as a pressure actuated valve placed on the air volume and set to blow out at 100 psig discharging to atmosphere. Figure 4.2.1 represents the D.C. Cook Unit 1 and 2 Quench Tanks. Pressure in the air volume of the quench tank never exceeded 30 psia during the Unit 1 SV transient case of steam and drained loop seals RELAP5 run for 0.5 seconds.




BY BAL DATE 2-8-83
CHKD. BY CJC DATE 2-15-83

D. C. COOK UNIT1
ARC 1 GEOMETR) @ ELEV. 669'-2"

SHEET NO. 1 OF 5
PROJ. NO. 5364

FIGURE 4.3.1-1
KELAP5 MODEL OF ARC (@ ELEVATION 669'-2" (ARC 1))




BY BAI DATE 2-8-83
CHKD. BY CJC DATE 2-15-83

D.C. COOK UNIT 1
ARC 2 GEOMETRY @ ELEV. 670'-10"

SHEET NO. 2 OF 5
PROJ. NO. 5364

FIGURE 4.3.1-2

K'ELAPS MODEL OF ARC @ ELEVATION 670'-10" (ARC 2)



REMARKS:

NUMBERS IN INDICATE STRUCTURAL NODES

DIMENSIONS BETWEEN NODES REPRESENT CORRESPONDING ARC LENGTHS.


BY BAI DATE 6-6-83
CHKD. BY CJC DATE 2-15-83

D. C. COOK UNIT 1
AKC 3 GEOMETRY @ ELEV. 672'-6"

SHEET NO. 3 OF 5
PROJ. NO. 5634

FIGURE 4.3.1-3

RELAPS MODEL OF ARC @ ELEVATION 672'-6" (ARC3)



REMARKS:

NUMBER IN INDICATE STRUCTURAL NODES


DIMENSIONS BETWEEN NODES REPRESENT CORRESPONDING ARC LENGTHS.


BY CJC DATE 3-25-83
CHKD. BY CHM DATE 3-28-83

UNIT PORV SECTION
RELAP MODEL (DOWNSTREAM)

SHEET NO. 4 OF 5
PROJ. NO. 5369

FIGURE 4.3.1-4






4-17

BY CJC DATE 3-25-83
CHKD. BY CJM DATE 3-28-83UNIT I MAIN ARC CONNECTIONS
BRANCHES + TEESSHEET NO. 1 OF 2
PROJ. NO. 5364

FIGURE 4.3.1-5






4-18


CJC DATE 3-25-83
 AD. BY CHM DATE 3-26-83
X

UNIT 1 PDRV SECTION
 BRANCHES + TEES

SHEET NO. 2 OF 2
 PROJ. NO. 5364

FIGURE 4.3.1-6





4.4 Valve Flow Rate Calculation

The following values were used in valve modeling considerations:

<u>Valve Type</u>	<u>TES Flow² Rate Calculated LBM/HR</u>	<u>Max Rating¹ For Steam @ 3% Accum.</u>	<u>Actual Bore Area (IN²)</u>	<u>Opening Time (Sec)</u>
Crosby Safety Relief Valve	452,393	435,000	3.6 in ²	0.010 (Ref. 15)

1 The maximum rating for steam at 3% accumulation value is from the Crosby Valve and Gage Safety Valve Drawing No. H-51688, Revision A (Reference 3).

2 Flow rate at 2500 psig plus 3% accumulation.

The valve flow rates normally used by TES in the RELAP analysis of the SVs would be a 15% increase in the ASME rated flow: 10% to consider the ASME underrating of the theoretical flow and 5% to cover tolerances. However, in this particular case, Westinghouse has provided AEPSC with a summary of the EPRI flow rate tests of the Crosby 6M6 safety valve (Reference 7). Also, see Figure 4.4.1-4. A comparison was made in an effort to achieve a more realistic flow rate. The flow rate chosen which most closely bounds the test data is the following ASME flow rate. All calculations are included as Figure 4.4.1.

$$W_T = 51.5 \text{ AP} \quad \text{Napier's Eq.}$$

ASME rated flow:

$$W_R = 51.5A (1.03P + 14.7)(.9)(.966)C \quad (\text{Ref. 8})$$

where:

W_T = theoretical flow

W_R = rated flow

coefficients:

1.03 - applies 3% accumulation

0.966 - valve flow coefficient

0.9 - represents theoretical flow rate reduced 10% to equal ASME rating

C = 1.0771 calculated on Figure 4.4.1-2 following.

4-21

BAI DATE 2-4-83
CHKD. BY CMM DATE 2-10-83

CROSBY GM6 VALVE
RELAPS MODEL FLOW AREA CALCULATIONS

SHEET NO. 1 OF 3
PROJ. NO. 5364

FIGURE 4.4.1-1

- REF: 1. ASME SEC III N.B.-7731.1 & N.B.-7734.2 (1980)
2. CROSBY GM6 MODEL: HB-BP-B6 VALVE DRAWING No: H-51688 REV.A
3. WESTINGHOUSE REPORT WCAP-10105
"REVIEW OF PRESSURIZER SAFETY VALVE PERFORMANCE AS
OBSERVED IN THE EPRI SAFETY AND RELIEF VALVE TEST
PROGRAM"
4. TES TELECON WITH MR. DAVE TIEBAULT FROM CROSBY DATED 2-4-85

CROSBY GM6 VALVE PROPERTIES

MANUFACTURER : CROSBY VALVE & GAGE CO.
TYPE : SPRING LOADED SAFETY VALVE
MODEL NO : HB-BP-B6 GM6
DRAWING NO. : H-51688 REV. A

BORE AREA (A_r) : 3.644 in²
DESIGN SET PRESS. (P_{SET}) : 2485 psig
DISCHARGE COEFF. (K_d) : 0.966

CALCULATION OF MAX. FLOW RATE (w_r)

THE FOLLOWING ASSUMPTIONS AND CONSIDERATIONS ARE MADE
IN DETERMINING w_r FOR RELAPS MODEL

1. IN THE FOLLOWING CALCULATIONS A CONSTANT SET PRESSURE IS
USED TO CALCULATE A FLOW AREA FOR THE RELAPS MODEL AND
DOES NOT NECESSARILY REPRESENT PRESSURIZER INPUT CONDITIONS
2. THERE ARE VARIOUS EQUATIONS AND EXPERIMENTAL
RESULTS YIELDING DIFFERENT FLOW RATES. ALL OF THESE ARE
PRESENTED IN THE PROCEEDING PAGE. A FLOW RATE WAS SELECTED
SUCH THAT IT WOULD BE CONSERVATIVE IF COMPARED WITH TEST
DATA BUT IT WOULD STILL BE REALISTIC.

BAI DATE 2-4-83
 CHKD. BY CMM DATE 2-10-83

CROSBY 6M6 VALVE
 RELAP5 MODEL FLOW AREA CALCULATIONS

SHEET NO. 2 OF 3
 PROJ. NO. 5364

FIGURE 4.4.1-2

VARIOUS FLOW RATES FOR 6M6 CROSBY VALVE FROM DIFFERENT SOURCES

1. FLOW RATE BY USING EQN. $w_R)_1 = 51.5 \times A_R (1.03 P_{SET} + 14.7) K_D$

WHERE $A_R = 3.644 \text{ in}^2$
 $P_{SET} = 2485 \text{ psig}$
 $K_D = 0.966$

$\therefore w_R)_1 = 466.674 \text{ lb/hr}$

2. FLOW RATE BY USING EQN. $w_R)_2 = 51.5 \times A_R (1.03 P_{SET} + 14.7) K_D (0.9)$

FACTOR: 0.9 TAKES INTO ACCOUNT MANUFACTURING TOLERANCES

(ASME. FLOW RATE FROM OLD EQN.) $w_R)_2 = 420.006 \text{ lb/hr}$

3. FLOW RATE BY USING EQN. $w_R)_3 = 51.5 \times A_R (1.03 P_{SET} + 14.7) (0.9)$

HERE $K_D = 1.0$

(THIS IS THE VALUE PRESENTED ON 6M6 DRWG. (REF.2)) $w_R)_3 = 434788 \text{ lb/hr}$
 AS $w_R_3 \approx 435000 \text{ lb/hr}$

4. FLOW RATE BY USING EQN. $w_R)_4 = 51.5 \times A_R (1.03 P_{SET} + 14.7) C \times K_D$

(THIS IS THE NEW ASME EQN. WITHOUT MANUFACTURING TOLERANCES)

$C = \frac{0.1906 P_{SET} - 1000}{0.2292 P_{SET} - 1061}$

$C = 1.07711$

$w_R)_4 = 502.659 \text{ lb/hr}$


5. FLOW RATE BY USING EQN. $w_R)_5 = 51.5 A_R (1.03 P_{SET} + 14.7) C \times K_D \times 0.9$
 $C = 1.07711$

(FACTOR OF 0.9 INCLUDES MANUFACTURING TOLERANCES)

$w_R)_5 = 452.393 \text{ lb/hr}$

6. MAXIMUM TESTED FLOW RATE (REF.3)

$w_R)_6 \approx 444.000 \text{ lb/hr}$



4-23

BAI DATE 2-4-83
MKD. BY CMM DATE 1-10-83

CROSBY GM6 VALVE
RELAP5 MODEL FLOW AREA CALCULATIONS

SHEET NO. 3 OF 3
PROJ. NO. 5364

FIGURE 4.4.1=3

IN RELAP5 MODEL FOR THE GM6 CROSBY VALVE w_R = 452 393 lb/hr
WAS USED BASED ON ASSUMPTION 2 AT PAGE 1.

$$w_R = 452 393 \text{ lb/hr} = 125.66 \text{ lb/sec}$$

USING THE COMPUTER RUN BAI CDRφ

VALVE FULL OPEN AREA IN THE RUN BAI CDRφ = 0.0232 ft²

FLOW RATE @ 80 % OPENING = 122.99 lb/sec

FLOW RATE @ 90 % OPENING = 138.01 lb/sec

RELAP5 FLOW AREA WHICH DELIVERS w_R = 125.66 lb/sec
IS CALCULATED BY INTERPOLATION

$$A_{FLOW} = \left[0.8 + 0.1 \frac{125.66 - 122.99}{138.01 - 122.99} \right] (0.0232)$$

$$A_{FLOW} = 0.01894 \text{ ft}^2$$

CROSBY GM6 RELAP5 MODEL FLOW AREA = 0.01894 ft²





FIGURE 4.4.1-4

FIGURE 3-5

STEAM DISCHARGE CYCLE (STABLE)
CROSBY 6M6



4.5 RELAP Plots


The following plots represent RELAP mass flows, pressures and qualities at various points along the discharge piping. The ordinate axis may not always be correct; many times multipliers will be off (CDC is aware of this problem in RELAP). However, the plots do depict trends accurately and are calculated and reported in RELAP every 0.001 seconds. Correct peaks and times at which they occur are listed with each trace. A RELAP volume schematic precedes the plot set for the transient steam case.


DATE 4-14-83
BY CMM DATE 5-25-83

RELAP MODEL SCHEMATIC
UNIT 1 PORV DOWNSTREAM

SHEET NO. 1 OF 3
PROJ. NO. 5364

FIGURE 4.5.1-1





 TELEDYNE ENGINEERING SERVICES

Technical Report

TR-5364-3

Revision 0


BY CMM DATE 4-14-83
BY CMM DATE 5-23-83

4-27

RELAP MODEL SCHEMATIC
UNIT 1 MAIN ARCS

SHEET NO. 2 OF 3
PROJ. NO. 5364

FIGURE 4.5.1-2



Technical Report
TR-5364-3
Revision 0

TELEDYNE ENGINEERING SERVICES


4-28

RELEI DATE 4-12-85
D. BY CMH DATE 5-25-85

SHEET NO. 2 OF 3
PROJ. NO. 5364

RELAP MODEL SCHEMATIC
UNIT 1 DOWNSTREAM (12IN)

FIGURE 4.5.1-3




4-29

TELEDYNE
ENGINEERING SERVICES

BY KSG DATE 6-21-83
CHKD. BY CMLY DATE 6-29-83

RELAPS/MOD1/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM

D.C.COOK UNIT 1 3 SV'S OPEN 83/06/17.




4-30


BY KJL DATE 6-21-83
CHKD. BY CWY DATE 6-29-83

RELAPS/MOD1/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM

D.C. COOK UNIT 1 3 SV'S OPEN 83/06/17.




4-31



BY KJG DATE 6-21-83
CHKD. BY CWY DATE 6-29-83

4-32

BY KJC DATE 6-21-83
CHKD. BY CMLY DATE 6-29-83





4-33

BY KSTG DATE 6-21-83
CHKD. BY CMLY DATE 6-29-83

RELAPS/HOD/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM

D.C.COOK UNIT 1 3 SV'S OPEN 83/06/17.






4-34

BY KTG DATE 6-21-83
CHKD. BY CML DATE 6-29-83

R6EFS/MOD1/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM
D.C.COOK UNIT 1 3 SV'S OPEN 83/06/17.




4-35

TELEDYNE
ENGINEERING SERVICES


RELAPSS/MOD1/014, REACTOR LOSS OF COOLANT ANALYSIS PROGRAM

D.C.COOK UNIT1 3 SV'S OPEN 83/06/17.




BY KSG DATE 6-21-83
CHKD. BY CMLY DATE 6-29-83

4-36



BY KJC DATE 6-21-83
CHKD. BY CMLY DATE 6-29-83





4-37

BY KTG DATE 6-21-83
CHKD. BY CMLY DATE 6-29-83

RELAPS/MOD1/Q14 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM

D.C.COOK UNIT1 3 SV'S OPEN 63/06/17.






4-38

BY KJG DATE 6-21-83
CHKD. BY QMK DATE 6-29-83

RELAPS/MOD1/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM

D.C.COOK UNIT 1 3 SV'S OPEN 03/06/17.




4-39


BY KJC DATE 6-21-83
CHKD. BY CWY DATE 6-29-83

RELAP5/101/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM

D.C. COOK UNIT 1 3 SV'S OPEN 83/06/17.



4-40




BY KYC DATE 6-21-83
CHKD. BY CWY DATE 6-29-83


4-41

BY KMG DATE 6-21-83
CHKD. BY CWY DATE 6-29-83

RELAPS/MOD1/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM

O.C. COOK UNIT 1 3 SV'S OPEN 83/06/17.






4-42

BY KJG DATE 6-21-83
CHKD. BY CML DATE 6-29-83

R621APS/MOD1/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM

D.C. COOK UNIT1-3 SV'S OPEN 63/05/17,




TELEDYNE
ENGINEERING SERVICES

BY KJG DATE 6-21-83
CHKD. BY CWY DATE 6-29-83

RELAPS/MOD1/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM

D.C. COOK UNIT 1 3 SV'S OPEN 83/06/17.





4-44

BY KSG DATE 6-21-83
CHKD. BY CML DATE 6-29-83

RELAPS/KODI/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM

D.C.COOK UNIT 1 3 SV'S OPEN 63/06/17.







4-45

BY KJG DATE 6-21-83
CHKD. BY CWY DATE 6-29-83

RELAPS/MOD1/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM

D.C. COOK UNIT 1 3 SV'S OPEN 63/06/17.







4-46

BY KTG DATE 6-21-83
CHKD. BY CMM DATE 6-29-83

~~RELAT50/MOD1/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM~~

D.C. COCK UNIT 1 3 SV'S OPEN 03/08/17.






TELEDYNE
ENGINEERING SERVICES

RELAPS/MOD1/D14 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM

D.C.COOK UNIT 1 3 SV'S OPEN 83/06/17.




BY KSG DATE 6-21-83
CHKD. BY CWY DATE 6-29-83

4-48

BY KSG DATE 6-21-83
CHKD. BY CMM DATE 6-29-83

RELAPS/MOD1/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM
D.C.COOK UNIT1 3 SV'S OPEN 83/06/17.




4-49

BY KYC DATE 6-21-83
CHKD. BY CWY DATE 6-29-83

RELAPS/MOD1/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM


D.C. COOK UNIT 1 3 SV'S OPEN 63/06/17.



4-50

BY KJG DATE 6-21-83
CHKD. BY CWY DATE 6-29-83

REL625/MOD1/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM
D.C.COOK UNIT1 3 SV'S OPEN 83/06/17.




4-51

BY KSG DATE 6-21-83
CHKD. BY CWY DATE 6-29-83

RELAP5/MOD1/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM

D.C. COCK UNIT 1 3 SV'S OPEN 83/06/17.




4-52

BY KJG DATE 4-21-83
CHKD. BY CMLY DATE 6-29-83

RELAPS/MOD1/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM

D.C. COOK UNIT 1 3 SV'S OPEN 83/06/17.





4-53

BY KJC DATE 6-21-83
CHKD. BY CWY DATE 6-29-83

RELAPS/MOD1/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM

O.C.COOK UNIT1 3 SV'S OPEN 63/06/17.






4-54

BY KTG DATE 6-21-83
CHKD. BY CWY DATE 6-29-83


RELFS/M001/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM
D.C.COOK UNIT 1 3 SV'S OPEN 83/06/17.




4-55

BY KJG DATE 6-24-83
CHKD. BY CML DATE 6-29-83

RELAPS/MOD1/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM
D.C.COOK UNIT1 3 SV'S OPEN 83/06/17.




4-56




BY KTG DATE 6-21-83
CHKD. BY CMM DATE 6-29-83

4-57



BY KTG DATE 6-21-83
CHKD. BY CML DATE 6-29-83




4-58


BY KSG DATE 6-21-83
CHKD. BY CWY DATE 6-29-83

RELAPS/MOD1/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM

D.C.COOK UNIT1 3 SV'S OPEN 63/06/17.



4-59




BY KSG DATE 6-21-83
CHKD. BY CWY DATE 6-29-83

4-60

BY KJG DATE 6-21-83
CHKD. BY CWY DATE 6-29-83


REL/REF/ANAL/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM
D.C. COOK UNIT 1 3 SV'S OPEN 63/06/17.



4-61

BY KYC DATE 6-21-83
CHKD. BY CWY DATE 6-29-83

RELAPS/MOD1/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM
D.C.COOK UNIT 1 3 SV'S OPEN 83/06/17.





4-62

BY KTG DATE 6-21-83
CHKD. BY CWY DATE 6-29-83

RELAPS/MOD1/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM

D.C.COOK UNIT 3 SV'S OPEN 03/08/17.





4.6 Force Time History Plots

The following are force versus time plots for each pipe segment at a node point described by the structural model. A drawing indicating force placement precedes the set. Since the force time histories were plotted after balancing and merging(i.e. SAP2SAP and MERGE), each plot is unbalanced force versus time from 0.0 to 0.5 seconds. Unit 1 has 67 pipe segments and correspondingly 67 force time histories.


BY LBS DATE 4-14-83
CHG BY LBS DATE 4-14-83

SHEET NO. 1 OF 3
PROJ. NO. 5364

UNIT 1 STRUCTURAL NODE POINTS

PORV SECTION

FIGURE 4.6.1-1



Technical Report
TR-5364-3
Revision 0

TELEDYNE ENGINEERING SERVICES


4-65

BY M DATE 4/14/83
CHK LBS DATE 4/14/83

SHEET NO. 2 OF 3
PROJ. NO. 5364

UNIT 1 STRUCTURAL NODES POINTS
MFAN FRCS

FIGURE 4.6.1-2



Technical Report
TR-5364-3
Revision 0

TELEDYNE ENGINEERING SERVICES


4-66


BY P. S. DATE 4-14-83
CH LBS DATE 4-14-83

SHEET NO. 2 OF 3
PROJ. NO. 5364

UNIT 1 STRUCTURAL NODE POINTS
DOWNSTRT. FM (12 IN)

FIGURE 4.6.1-3






TELEDYNE
ENGINEERING SERVICES

SAP2SAP VERIFICATION 5364 6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 1. MAGNITUDE AT NODE POINT 620



TELEDYNE
ENGINEERING SERVICES


SAP2SAP-VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 2. MAGNITUDE AT NODE POINT

610



TELEDYNE
ENGINEERING SERVICES


6-JUL-83

SAP2SAP VERIFICATION 5364

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 3. MAGNITUDE AT NODE POINT

529




SAP2SAP VERIFICATION 5364 6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 4. MAGNITUDE AT NODE POINT

536



TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 5. MAGNITUDE AT NODE POINT

545



TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 6. MAGNITUDE AT NODE POINT

550




SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 7. MAGNITUDE AT NODE POINT

555



TRIELEDYNE
ENGINEERING SERVICES


6-JUL-83

SAP2SAP VERIFICATION 5364

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 8. MAGNITUDE AT NODE POINT

560




TRIFELDYNE
ENGINEERING SERVICES

SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 9. MAGNITUDE AT NODE POINT



TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364


6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 10. MAGNITUDE AT NODE POINT

375





WIELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 11. MAGNITUDE AT NODE POINT

365



TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 12. MAGNITUDE AT NODE POINT

360



TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 13. MAGNITUDE AT NODE POINT

355




TELEDYNE
ENGINEERING SERVICES

SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 14. MAGNITUDE AT NODE POINT 350



TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 15. MAGNITUDE AT NODE POINT

340




TELEDYNE
ENGINEERING SERVICES

SAP2SAP VERIFICATION 5364 6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 16. MAGNITUDE AT NODE POINT

335




TELEDYNE
ENGINEERING SERVICES

SAP2SAP VERIFICATION 5364 6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 17. MAGNITUDE AT NODE POINT 325



TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 18. MAGNITUDE AT NODE POINT

320



TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 19. MAGNITUDE AT NODE POINT

310




TELEDYNE
ENGINEERING SERVICES

SAP2SAP VERIFICATION 5364
DC COOK-UNIT1, SV MODIFICATION
TIME/FORCE TABLE

6-JUL-83

20. MAGNITUDE AT NODE POINT

300




TELEDYNE
ENGINEERING SERVICES

SAP2SAP VERIFICATION 5364 6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 21. MAGNITUDE AT NODE POINT 136



TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 22. MAGNITUDE AT NODE POINT

134



TELEDYNE
ENGINEERING SERVICES


6-JUL-83

SAP2SAP VERIFICATION 5364

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 23. MAGNITUDE AT NODE POINT

130



TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 24. MAGNITUDE AT NODE POINT

126




TELEDYNE
ENGINEERING SERVICES

SAP2SAP VERIFICATION 5364 6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 25. MAGNITUDE AT NODE POINT

120




APPLIEDYNE
ENGINEERING SERVICES

SAP2SAP VERIFICATION 5364 6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 26. MAGNITUDE AT NODE POINT

115



TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 27. MAGNITUDE AT NODE POINT

109




TELGYNE
ENGINEERING SERVICES

SAP2SAP VERIFICATION 5364 6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 28. MAGNITUDE AT NODE POINT 104



TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 29. MAGNITUDE AT NODE POINT

103



TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 30. MAGNITUDE AT NODE POINT

102



TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 31. MAGNITUDE AT NODE POINT

100




TELEDYNE
ENGINEERING SERVICES

SAP2SAP VERIFICATION 5364 6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 32. MAGNITUDE AT NODE POINT

99




TELEDYNE
ENGINEERING SERVICES

SAP2SAP VERIFICATION 5364 6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 33. MAGNITUDE AT NODE POINT

98




TELEDYNE
ENGINEERING SERVICES

SAP2SAP VERIFICATION 5364 6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 34. MAGNITUDE AT NODE POINT 184



390-1024-12-100257

卷之三

Digitized by srujanika@gmail.com

TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364


6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 35. MAGNITUDE AT NODE POINT

182





Technical Report
TR-5364-3
Revision 0

4-102


TELEDYNE
ENGINEERING SERVICES

SAP2SAP VERIFICATION 5364 6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 36. MAGNITUDE AT NODE POINT

180




TRIFELDYNE
ENGINEERING SERVICES

SAP2SAP VERIFICATION 5364 6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 37. MAGNITUDE AT NODE POINT

176




SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 38. MAGNITUDE AT NODE POINT

170



TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 39. MAGNITUDE AT NODE POINT

163



TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 40. MAGNITUDE AT NODE POINT

157



TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 41. MAGNITUDE AT NODE POINT

150




SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 42. MAGNITUDE AT NODE POINT

148



TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 43, MAGNITUDE AT NODE POINT

146



TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 44. MAGNITUDE AT NODE POINT

144




SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE . 45, MAGNITUDE AT NODE POINT

242



100% of 29900

29900

29900


TELEDYNE
ENGINEERING SERVICES

SAP2SAP VERIFICATION 5364 6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 46. MAGNITUDE AT NODE POINT

240




TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364
DC COOK-UNIT1. SV MODIFICATION
TIME/FORCE TABLE

6-JUL-83

47. MAGNITUDE AT NODE POINT

237





Technical Report
TR-5364-3
Revision 0

4-114

TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 48. MAGNITUDE AT NODE POINT

.235



$$x = \frac{1}{\alpha_1} - \frac{\alpha_1^2}{\alpha_1^2 + 1} \approx \sqrt{\alpha_1} - \frac{1}{2\sqrt{\alpha_1}} \approx \sqrt{\alpha_1} - \frac{1}{2}$$

$$\frac{f''(x)}{g''(x)} = \frac{2x}{\ln x} > 0 \quad \text{for } x > 1.$$

112 *Journal of Health Politics*


TELEDYNE
ENGINEERING SERVICES

SAP2SAP VERIFICATION 5364 6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 49. MAGNITUDE AT NODE POINT

229




SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 50. MAGNITUDE AT NODE POINT

225






TELEDYNE
ENGINEERING SERVICES

SAP2SAP VERIFICATION 5364 6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 51. MAGNITUDE AT NODE POINT

222




TELEDYNE
ENGINEERING SERVICES

SAP2SAP VERIFICATION 5364 6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 52. MAGNITUDE AT NODE POINT

214



Technical Report
TR-5364-3
Revision 0


4-119

TELEDYNE
ENGINEERING SERVICES

SAP2SAP VERIFICATION 5364
DC COOK-UNIT1. SV MODIFICATION
TIME/FORCE TABLE

6-JUL-83

53. MAGNITUDE AT NODE POINT 208.




TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 54 , MAGNITUDE AT NODE POINT 295





TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 55 , MAGNITUDE AT NODE POINT

195




TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 56 , MAGNITUDE AT NODE POINT 88






TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 57 . MAGNITUDE AT NODE POINT 83





Technical Report
TR-5364-3
Revision 0

4-124


TELGYNE
ENGINEERING SERVICES

SAP2SAP VERIFICATION 5364
DC COOK-UNIT1. SV MODIFICATION
TIME/FORCE TABLE

6-JUL-83

58 , MAGNITUDE AT NODE POINT

80




TELEDYNE
ENGINEERING SERVICES

SAP2SAP VERIFICATION 5364 6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 59 . MAGNITUDE AT NODE POINT 68




TELEDYNE
ENGINEERING SERVICES

SAP2SAP VERIFICATION 5364 6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 60 , MAGNITUDE AT NODE POINT 60



TRIELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 61 . MAGNITUDE AT NODE POINT


56



SAP2SAP VERIFICATION 5364 6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 62.. MAGNITUDE AT NODE POINT 48




WIELEDYNE
ENGINEERING SERVICES

SAP2SAP VERIFICATION 5364 6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 63. MAGNITUDE AT NODE POINT

44




6-JUL-83

SAP2SAP VERIFICATION 5364

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 64. MAGNITUDE AT NODE POINT

34



TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1, SV MODIFICATION

TIME/FORCE TABLE 65. MAGNITUDE AT NODE POINT

18



TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE . 66. MAGNITUDE AT NODE POINT

8



TELEDYNE
ENGINEERING SERVICES


SAP2SAP VERIFICATION 5364

6-JUL-83

DC COOK-UNIT1. SV MODIFICATION

TIME/FORCE TABLE 67. MAGNITUDE AT NODE POINT

4





4.7 RELAP Input

Included here is the RELAP5 MOD1 input listing for the transient steam case.

The SV model has:

- 375 volumes
- 374 junctions

Heat structures were not included in the RELAP model because of the program capacity. Including heat structures would have further reduced the number of available control volumes. This is a conservative assumption, ITI (Reference 6) showed higher loads were computed without heat structures.

LISTING OF INPUT DATA FOR CASE 1

1 * D.C. COOK UNIT 1 SV'S OPEN
 2 * DISCHARGE PIPING
 3 * THIS IS THE NUMBERING SYSTEM FOR UNIT 1'S RELAP MODEL
 4 * WHERE COMPONENTS ARE NUMBERED IN THE;
 5 * 100'S ARE VALVE SV-45C AND ARC 1 LEVEL 669'-2"
 6 * 200'S ARE VALVE SV-45B AND ARC 2 LEVEL 670'-10"
 7 * 300'S ARE VALVE SV-45A ARN ARC 3 LEVEL 672'-8"
 8 * 400'S ARE PORV NRV-151 AND ARC "A"
 9 * 500'S ARE PORV NRV-153 AND ARC "B"
 10 * 600'S ARE PORV NRV-152 AND ARC "C"
 11 * 700'S AND 800'S ARE 6" AND 12" MAIN DISCHARGE PIPING
 12 * 900'S QUENCH TANK PORTION
 13 * 999' ATMOSPHERE

14 *

15 *

16 *

17 100 NEW TRANSNT

18 101 RUN

19 102 BRITISH BRITISH

20 104 NOACTION

21 *

22 *****

23 * TIME STEP CONTROL *

24 *****

25 *

26 201 0.500,1,-7.2,-4,11001,5,50,250

27 *

28 *

29 *****

30 * MINOR EDITS *

31 *****

32 *

33 301 MFLOWJ 108000000

34 302 MFLOWJ 205000000

35 303 MFLOWJ 305000000

36 304 MFLOWJ 308000000

37 305 MFLOWJ 208000000

38 306 MFLOWJ 702000000

39 307 MFLOWJ 108000000

40 308 MFLOWJ 977000000

41 *

42 309 QUALS 105200000

43 310 QUALS 107000000

44 311 QUALS 107300000

45 312 QUALS 701000000

46 313 QUALS 811970000

47 314 QUALS 813250000

48 315 QUALS 978180000

49 316 QUALS 205200000

50 317 QUALS 207000000

51 318 QUALS 305200000

52 319 QUALS 207260000

53 320 QUALS 307610000

54 321 QUALS 307180000

55 *

56 323 P 105200000

4-135

TELEDYNE
ENGINEERING SERVICES

Technical Report
TR-5364-3
Revision 0

BY KJG DATE 6-21-83
CHKD. BY CMM DATE 6-27-83



Technical Report
TR-5364-3
Revision 0

4-36

TELEDYNE
ENGINEERING SERVICES

57 324 P 107010000
58 326 P 107330000
59 327 P 701010000
60 328 P 811970000
61 329 P 813260000
62 330 P 978020000
63 331 P 978030000
64 332 P 205200000
65 333 P 207010000
66 334 P 305200000
67 335 P 207260000
68 336 P 307010000
69 337 P 307180000
70
71

* FORCE CARDS FOR REPIPE *

* PIPING DOWNSTREAM OF THE PORV'S *

83 2001 5,215
84 2002 411010000,411020000,411030000,411040000,411050000
85 2003 411060000,411070000,411080000,411090000,411100000
86 2004 411110000,411120000,411130000,411140000,411150000
87 2005 411160000,411170000,411180000,411190000
88
89 2006 511010000,511020000,511030000,511040000,511050000
90 2007 511060000,511070000,511080000,511090000,511100000
91 2008 511110000,511120000,511130000,511140000,511150000
92 2009 511160000,511170000,511180000,511190000
93
94 2010 611010000,611020000,611030000,611040000,611050000
95 2011 611060000,611070000,611080000
96
97 2012 515010000,515020000,515030000,515040000,515050000
98 2014 515060000,515070000,515080000,515090000,515100000
99 2015 515110000,515120000,701010000,513010000
100
101
102
103
104
105
106
107 2018 301010000,303010000,303020000,303030000,303040000
108 2019 305010000,305020000,305030000,305040000,305050000
109 2020 305060000,305070000,305080000,305090000,305100000
110 2021 305110000,305120000,305130000,305140000,305150000
111 2022 305160000,305170000,305180000,305190000,305200000
112 2023 307010000,307020000,307030000,307040000,307050000
113 2024 307060000,307070000,307080000,307090000,307100000
114 2025 307110000,307120000,307130000,307140000,307150000

115 2026 307160000, 307170000, 307180000, 801010000

116 *

117 *

118 *

119 *

120 *

121 * SV ARC FROM VALVE 45B DOWN TO ELEVATION 670' 10"

122 *

123 2029 201010000, 203010000, 203020000, 203030000, 203040000

124 2030 205010000, 205020000, 205030000, 205040000, 205050000

125 2031 205060000, 205070000, 205080000, 205090000, 205100000

126 2032 205110000, 205120000, 205130000, 205140000, 205150000

127 2033 205180000, 205170000, 205180000, 205190000, 205200000

128 2034 207010000, 207020000, 207030000, 207040000, 207050000

129 2035 207080000, 207070000, 207080000, 207090000, 207100000

130 2036 207110000, 207120000, 207130000, 207140000, 207150000

131 2037 207160000, 207170000, 207180000, 207190000, 207200000

132 2038 207210000, 207220000, 207230000, 207240000, 207250000

133 2039 207280000, 805010000

134 *

135 *

136 *

137 *

138 *

139 *

140 * SV ARC FROM VALVE 45C DOWN TO ELEVATION 669' 2"

141 *

142 2042 101010000, 103010000, 103020000, 103030000, 103040000

143 2043 105010000, 105020000, 105030000, 105040000, 105050000

144 2044 105080000, 105070000, 105080000, 105090000, 105100000

145 2045 105110000, 105120000, 105130000, 105140000, 105150000

146 2046 105160000, 105170000, 105180000, 105190000, 105200000

147 2047 107010000, 107020000, 107030000, 107040000, 107050000

148 2048 107080000, 107070000, 107080000, 107090000, 107100000

149 2049 107110000, 107120000, 107130000, 107140000, 107150000

150 2050 107180000, 107170000, 107180000, 107190000, 107200000

151 2051 107210000, 107220000, 107230000, 107240000, 107250000

152 2052 107280000, 107270000, 107280000, 107290000, 107300000

153 2053 107310000, 107320000, 107330000, 809010000

154 *

155 *

156 *

157 *

158 *

159 *****

160 * THIS RUN OF RELAP INCLUDES SAFETY RELIEF VALVE LINES AND MAIN *

161 * DISCHARGE LINES BETWEEN ELEV. 684'-9" TO ELEV. 649'- 1/2" *

162 *

163 *

164 *

165 *

166 *

167 *

168 *****

169 * TRIPS *


170 *

171 *

172 *

4-137

TELEDYNE
ENGINEERING SERVICESTechnical Report
TR-5364-3
Revision 0



RELAP5X 1/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM

173 501 TIME 0 GE NULL 3 0.0 L * VALVE OPENING TRIP
 174 502 TIME 0 GE NULL 1 5.0 L * JOB TERMINATION TRIP
 175 515 P 982010000 GE NULL 0 114.7 L * QUENCH TANK RUPTURE PRESS.
 176 600 502

* HYDRODYNAMIC COMPONENTS *

* SAFETY VALVES DISCHARGE SECTION *

* SAFETY VALVE #1 DISCHARGING AT ELEV. 669.7-2" ARC 1

* PRESSURIZER COMPONENT

1010000 "PRSRZ#1" TMID VOL

1010200 2

1010101 0. 20. 500. 0 0. 0. 0.00005 0. 11

1010201 0. 2500. 1 2514. 1. 3. 2555. 1. 5. 2600. 1. 7. 2667. 1.

1010202 9. 2700. 1 1. 2740. 1. 1. 3. 2745. 1. 1. 5. 2747. 1. 1. 7. 2748. 1.

1010203 1. 9. 2750. 1

1010204 *

* PIPE COMPONENTS

1020000 "PRZ1-EXIT" SNGLJUN

1020101 101000000 0.000000 0.0 0.0 0.0 1000

1020201 1 0.0 0 0.0

* VALVE UPSTREAM

1030000 "LSI IN" SLOPE

* NO. OF VOLS.

1030001 4

* VOL. FLOW AREA

1030101 0.14653 4

* VOL. LENGTHS

1030301 0.3490 5

1030302 0.4238 4

* VOL. CAL. AUTO

1030401 0.0 4

* VERT. ANGLES

1030501 45. 1

1030602 0.0 4

* PIPE ROUGHNESS

1030801 1.513-4 0 4

* UNL. LOSS COEFF

1030901 0.0918 0 1

1030902 0.0 0 3

* 1031001 00 4

1031101 1000 3

4-139

TELEDYNE
ENGINEERING SERVICES

231 *
 232 1031201 2 2500. 1. 0.0 0.0 4
 233 *
 234 * INITIAL JUN FLOWS
 235 1031300 1
 236 1031301 0.0 0.0 0.0 3
 237 *
 238 * LOOP SEAL
 239 1040000 "JUN-LS1" SNGLJUN
 240 1040101 103010000 105000000 0.0 0.1836 0.1836 1000
 241 1040201 1 0.0 0.0 0.0
 242 *
 243 1050000 "LPSL 1" PIPE
 244 1050001 20
 245 1050101 0.14653 220
 246 *
 247 1050301 0.50 10
 248 1050302 0.6203 220
 249 *
 250 1050401 0.0 220
 251 *
 252 1050601 -90. 7
 253 1050602 0.0 10
 254 1050603 90. 220
 255 *
 256 1050801 1.513-4 0.0 20
 257 *
 258 1050901 0.0 0.0 6
 259 1050902 0.1836 0.1836 7
 260 1050903 0.0 0.0 9
 261 1050904 0.1836 0.1836 10
 262 1050905 0.0 0.0 19
 263 *
 264 1051001 00. 20
 265 *
 266 1051101 1000 18
 267 *
 268 1051201 2 2500. 1.0 0.0 0.0 20
 269 *
 270 1051300 1
 271 1051301 0.0 0.0 0.0 19
 272 *
 273 * CROSBY 6MG SAFETY VALVE #1 SV-45C
 274 *
 275 1060000 "SVN01" VALVE * VALVE OPEN WITH PROG. START
 276 1060101 105010000 107000000 0.01897 0.0 0.0 0100 1.0 1.0
 277 1060201 1 0.0 0.0 0.0
 278 1060300 NTRVLV
 279 1060301 501 502 100. 0.0 * VALVE OPENS WITH PROG. START
 280 *
 281 * VALVE DOWNSTREAM PIPING
 282 1070000 "DWNSTRM#1" PIPE
 283 1070001 33
 284 *
 285 1070101 0.20069 33
 286 *
 287 1070301 0.5261 4
 288 1070302 0.9943 15

RELAP5 1/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM

289 1070303 0.9132
 290 1070304 0.8472
 291 1070305 1.085
 292 *
 293 1070401 0.0
 294 *
 295 1070601 0.0
 296 1070602 -90.
 297 1070603 0.0
 298 *
 299 1070801 1.524 0. 32
 300 1070901 0.0 0.0
 301 1070902 0.18 0.18
 302 1070903 0.0 0.0
 303 1070904 0.18 0.18
 304 1070905 0.0 0.0
 305 *
 306 1071001 00 33
 307 1071101 1000 32
 308 *
 309 1071201 4 17.7 120 0.93424 0. 33
 310 *
 311 1071300 1
 312 1071301 0.0 0.0 0.0 0.0 32
 313 *
 314 *
 315 *
 316 *
 317 ***** SAFETY VALVE #2 DISCHARGING AT ELEV. 670'-10" ARC 2 *****
 318 *
 319 *
 320 * PRESSURIZER COMPONENT
 321 2010000 "PRSRZ#2" TMC VOL
 322 *
 323 2010101 0. 20. 500. 0 0. 0. 0.00005 0. 11
 324 2010200 2
 325 2010201 0. 2500. 1. 2514. 1. 3.2555. 1. 5.2600. 1. 7.2667. 1.
 326 2010202 9. 2700. 1. 1. 2740. 1. 3.2745. 1. 5.2747. 1. 7.2748. 1.
 327 2010203 1.9. 2750. 1.
 328 *
 329 * PIPE "COMPONENTS"
 330 2020000 "PRZ2-EXIT" PGLJUN
 331 *
 332 2020101 201000000 201000000 0.0 0.0 0.0 1000
 333 *
 334 2020201 1. 0.0 0.0 0.0
 335 *
 336 * VALVE UPSTREAM
 337 2030000 "LS2 IN" PIPE
 338 * NO OF VOL
 339 2030001 4
 340 * VOL. FLOW AREA
 341 2030101 0.14653 4
 342 * VOL LENGTHS
 343 2030301 0.3490 1
 344 2030302 0.4236 4
 345 * VOL. CAL. AUTO.
 346 2030401 0.0 4

Technical Report
TR-5364-3
Revision 0

347 * VERT. ANGLES
 348 2030601 45. 1
 349 2030602 0. 4
 350 * PIPE ROUGHNESS
 351 2030801 1.513-4 0.0 4
 352 * JUN. LOSS COEFF.
 353 2030901 0.0918 0.0918 1
 354 2030902 0.0 0.0 3
 355 *
 356 2031001 00. 4
 357 *
 358 2031101 1000 3
 359 *
 360 2031201 2 2500. 1. 6 0. 4
 361 * INITIAL JUN. FLOWS
 362 2031300 1
 363 2031301 0.0 0.0 0.0 3
 364 *
 365 * LOOP SEAL
 366 *
 367 2040000 "JUN-LS2" SNG JUN
 368 2040101 203010000 205010000 0.0 0.1836 0.1836 1000
 369 2040201 1 0.0 0.0 1.0
 370 * 4-141
 371 2050000 "LPSL 1" PIPE
 372 2050001 20
 373 *
 374 2050101 0.14653 20
 375 *
 376 2050301 0.50 10
 377 2050302 0.6203 20
 378 *
 379 2050401 0.0 20
 380 *
 381 2050601 -90. 7
 382 2050602 0.0 10
 383 2050603 90. 20
 384 *
 385 2050801 1.513-4 0. 20
 386 *
 387 2050901 0.0 0.0 6
 388 2050902 0.1836 0.1836 7
 389 2050903 0.0 0.0 8
 390 2050904 0.1836 0.1836 10
 391 2050905 0.0 0.0 19
 392 *
 393 2051001 00 20
 394 *
 395 2051101 1000 19
 396 *
 397 2051201 2 2500. 1.0 0.0 0.0 20
 398 * INITIAL JUN. FLOWS
 399 2051300 1
 400 2051301 0.0 0.0 0.0 19
 401 *
 402 * CROSBY 6MB SAFETY VALVE #2 SV-45B
 403 *
 404 2060000 "SV N02" VALVE

TELEDYNE
ENGINEERING SERVICES

RELAY 01/014

REACTOR LOSS OF COOLANT ANALYSIS PROGRAM

PAGE 9

463 3030000 "LS2 IN" PIPE
 464 *
 465 3030001 4
 466 *
 467 3030101 0.14653 4
 468 *
 469 3030301 0.3125 1
 470 3030302 0.4236 4
 471 *
 472 3030401 0.0 4
 473 *
 474 3030601 45. 1
 475 3030602 0.0 4
 476 *
 477 3030801 1.513-4 0.0 4
 478 *
 479 3030901 0.0918 0.0918 1
 480 3030902 0.0 0.0 3
 481 *
 482 3031001 00 4
 483 *
 484 3031101 1000 3
 485 *
 486 3031201 2 2500 1. 0.0 0.0 4
 487 *
 488 3031300 1
 489 3031301 0.0 0.0 0.0 3
 490 *
 491 3040000 "JUN-LS3" SNGLJUN
 492 3040101 303010000 305000000 0.0 0.1838 0.1836 1000
 493 3040201 1 0.0 0.0 0.0
 494 *
 495 3050000 "LPSL 2" PIPE
 496 3050001 20
 497 *
 498 3050101 0.14653 20
 499 *
 500 3050301 0.5 10
 501 3050302 0.6203 20
 502 *
 503 3050401 0.0 20
 504 *
 505 3050601 -90. 7
 506 3050602 0.0 10
 507 3050603 90. 20
 508 *
 509 3050801 1.513-4 0.0 20
 510 *
 511 3050901 0.0 0.0 8
 512 3050902 0.1836 0.1838 7
 513 3050903 0.0 0.0 9
 514 3050904 0.1836 0.1836 10
 515 3050905 0.0 0.0 19
 516 *
 517 3051001 00 20
 518 *
 519 3051101 1000 19
 520 *

 Technical Report
 TR-5364-3
 Revision 0

4-143

 TELEDYNE
 ENGINEERING SERVICES

RELAR 01/014

REACTOR LOSS OF COOLANT ANALYSIS PROGRAM

PAGE 10

521 3051201 2 2500. 1.0 0.0 0.0 20
 522 *
 523 3051300 1
 524 3051301 0.0 0.0 0.0 19
 525 *
 526 * CROSSBY 6MG SAFETY VALVE #3 SV-45A
 527 *
 528 3060000 "SV N03" VALVE * VALVE OPEN WITH PROG. START
 305010000 307000000 0.01897 0.0 0.0 0100 1. 1.
 529 3060101 1 0.0 0.0 0.0
 530 3060201
 531 3060300 MTRVLV
 532 3060301 501 502 100. 0.0 * VALVE OPENS WITH PROG. START
 533 *
 534 * VALVE DOWNSTREAM PIPING
 535 3070000 "DWNSTRM#3" PIPE
 536 3070001 18
 537 *
 538 3070101 0.20089 18
 539 *
 540 3070301 0.5261 4
 541 3070302 1.034 12
 542 3070303 0.801 15
 543 3070304 1.085 18
 544 *
 545 3070401 0.0 18
 546 *
 547 3070601 0.0 4
 548 3070602 -90. 12
 549 3070603 0.0 18
 550 *
 551 3070801 1.52-4 0. 18
 552 *
 553 3070901 0.0 0.0 3
 554 3070902 0.18 0.18 4
 555 3070903 0.0 0.0 11
 556 3070904 0.18 0.18 12
 557 3070905 0.0 0.0 17
 558 *
 559 3071001 00 18
 560 3071101 1000 17
 561 *
 562 3071201 4 17.7 120. 0.93424 0. 18
 563 *
 564 3071300 1
 565 3071301 0.0 0.0 0.0 17
 566 *
 567 *
 568 ***** PORV DISCHARGE SECTION *****
 569 *
 570 *****
 571 *
 572 *
 573 *****
 574 * PORV NRV-151 DISCHARGE LINE ARC "A" *
 575 *****
 576 *
 577 *
 578 4110000 "PORV1" PIPE

 Technical Report
 TR-5364-3
 Revision 0

4-144

TELEDYNE
ENGINEERING SERVICES

Technical Report
TR-5364-3
Revision 0

4-145

TELEDYNE
ENGINEERING SERVICES

```

579 4110001 19
580 *
581 4110101 0.05132 17
582 4110102 0.200869 19
583 +
584 4110301 0.3724 4
585 4110302 0.3659 8
586 4110303 0.561 17
587 4110304 0.349 19
588 +
589 4110401 0.0 19
590 +
591 4110601 0.0 4
592 4110602 -90. 8
593 4110603 0.0 19
594 +
595 4110801 1.53-4 0.17
596 4110802 1.52-4 0.19
597 +
598 4110901 0.0 0.0 3
599 4110902 0.20838 0.2088 4
600 4110903 0.0 0.0 7
601 4110904 0.20838 0.2088 8
602 4110905 0.0 0.0 18
603 4110906 0.37814 0.1565 17
604 4110907 0.0 0.0 18
605 +
606 4111001 00 19
607 4111101 1000 18
608 +
609 4111201 4 17.7 120. 0.93424 0.0 19
610 +
611 4111300 1
612 4111301 0.0 0.0 0.0 18
613 +
614 4120000 "ENTERMAIN" SNGLJUN
615 4120101 411010000 701000000 0.0 0.18 0.18 1000
616 4120201 1 0.0 0.0 0.0
617 +
618 +
619 ****
620 * PORV NRV-153 DISCHARGE LINE ARC "B" *
621 ****
622 +
623 +
624 +
625 5110000 "PORV2LINE" PIPE
626 5110001 19
627 +
628 5110101 0.05132 18
629 5110102 0.08840 19
630 +
631 5110301 0.4303 3
632 5110302 0.3620 7
633 5110303 0.35 9
634 5110304 0.6058 18
635 5110305 0.371 19
636 +

```

4-146

637	5110401	0.0	19
638	*		
639	5110601	0.0	3
640	5110602	-90.	7
641	5110603	0.0	19
642	*		
643	5110801	1.53-4 .0	18
644	5110802	1.34-4 .0	19
645	*		
646	5110901	0.0	0.0 2
647	5110902	0.2088	0.2088 3
648	5110903	0.0	0.0 6
649	5110904	0.2088	0.2088 7
650	5110905	0.0	0.0 17
651	5110906	0.0544	0.0399 18
652	*		
653	5111001	00	19
654	*		
655	5111101	1000	18
656	*		
657	5111201	4 17.7	120. 0.93424 0.0 19
658	*		
659	5111300	1	
660	5111301	0.0 0.0	0.0 18
661	*		
662	5120000	"JUNC."	SNGLJUN
663	5120101	511010000	513000000 0.0 0.0 0.0 1000
664	5120201	1 0.0	00.0 0.0
665	*		
666	*		
667	*		
668	5130000	"4X4X3TEE"	BRANCH
669	5130001	0	
670	5130101	0.08840	0.3524 0.0 0.0 0.0 0.0 1.34-4 0.0 00
671	5130200	4 17.7	120. 0.93424 0.0 0.0
672	*		
673	*		
674	5140000	"4IN JUNC"	SNGLJUN
675	5140101	513010000	515000000 0.0 0.0 0.0 1000
676	5140201	1 0.0	00.0 0.0
677	*		
678	5150000	"4INSCH40"	PIPE
679	5150001		12
680	*		
681	5150101	0.0884	10
682	5150102	0.20069	12
683	*		
684	5150301	0.3524	1
685	5150302	0.6963	10
686	5150303	0.349	12
687	*		
688	5150401	0.0	12
689	*		
690	5150601	0.0	12
691	*		
692	5150801	1.34-4 0.0	10
693	5150802	1.52-4 0.0	12
694	*		



RELAPS

1/01/14 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM

PAGE

13

Technical Report
TR-5364-3
Revision 0

4-147

TELEDYNE
ENGINEERING SERVICES

695 S1509901 0.0 0.0 9
696 S1509902 0.1483 0.0815 10
697 S1509903 0.0 0.0 11
698
699 S151001 00 12
700
701 S1511101 1000 11
702
703 S1512201 4 17.7 120. 0.93424 0.0 12
704
705 S1512300 1
706 S1512301 0.0 0.0 0.0 11
707
708 S1600000 "ENTERMAIN" SNGLJUN
709 S1601101 S15010000 701000000 0.0 0.18 0.18 1000
710 S1602201 1 0.0 0.0 0.0
711
712
713 *****
714 * SPORV NRV-152 DISCHARGE LINE ARC "C"
715 *****
716
717
718
719 S1104000 "PORVDISČ3" PIPE
720 S1104001 8
721
722 S1104101 0.05132 8
723
724 S1104301 0.3723 4
725 S1104302 0.3646 8
726
727 S1104401 0.0 8
728
729 S1104601 0.0 4
730 S1104602 -90. 8
731
732 S1104801 1.53-4 .0 8
733
734 S1104901 0.0 0.0 3
735 S1104902 0.2088 0.2088 4
736 S1104903 0.0 0.0 7
737
738 S1110001 00 8
739 S111101 1000 7
740
741 S1112001 4 17.7 120. 0.93424 0.0 8
742
743 S111300 1
744 S111301 0.0 0.0 0.0 7
745
746 S1200000 "PORVLINE" SNGLJUN
747 S120101 S11010000 S130000000 0.0 0.1932 0.1932 1000
748 S120201 1 0.0 0.0 0.0
749
750 *****
751 * MAIN DISCHARGE LINE SECTION
752 *****




753 *
 754 *
 755 * MAIN DISCHARGE LINE
 756 7010000 "ENTERMAIN" BRANCH
 757 7010001 0
 758 7010101 0.20069 0.7035 0 0 0 0 0 0 0 1.52-4 0.0 00
 759 7010200 4 17.7 120. 0.93424 0.0 0.0
 760 *
 761 7020000 "MAINLINE" SNGLJUN
 762 7020101 701010000 7030000000 0.0 0.0 0.0 1000
 763 7020201 1 0.0 0.0 0.00
 764 *
 765 7030000 "MAINLINE" PIPE
 766 *
 767 7030001 14
 768 *
 769 7030101 0.20069 12
 770 7030102 0.77708 14 * 1;2 IN LINE STARTS HERE
 771 *
 772 7030301 0.7035 1
 773 7030302 1.0076 12
 774 7030303 0.5834 14 * 12 IN LINE STARTS HERE
 775 *
 776 7030401 0.0 14
 777 *
 778 7030601 0.0 1
 779 7030602 -90. 14
 780 *
 781 7030801 1.52-4 0. 12
 782 7030802 1.69-4 0. 14
 783 *
 784 7030901 0.180 0.180 1
 785 7030902 0.0 0.0 11
 786 7030903 0.493 0.2045 12
 787 7030904 0.0 0.0 13
 788 *
 789 7031001 00 14
 790 7031101 1000 13
 791 *
 792 7031201 4 17.7 120. 0.93424 0.0 14
 793 *
 794 7031300 1
 795 7031301 0.0 0.0 0.0 13
 796 *
 797 *
 798 7040000 "MAINLINE" SNGLJUN
 799 7040101 703010000 8010000000 0.0 0.0 0.0 1000
 800 7040201 1 0.0 0.0 0.0
 801 *
 802 3080000 "CON. 1" SNGLJUN
 803 3080101 307010000 8010000000 0.0 0.156 0.156 1000
 804 3080201 1 0.0 0.0 0.0
 805 *
 806 *
 807 *
 808 *
 809 *
 810 * CONNECTION TO MAIN LINE AT ELEV. 872'-6"

Technical Report
TR-5364-3
Revision 0

4-148

**TELEDYNE
ENGINEERING SERVICES**



4-149

TELEDYNE
ENGINEERING SERVICES

811 *
 812 *
 813 80100000 "12-BRANC1" BRANCH
 814 80100011 0
 815 80101001 0.77708 0.8334 0.0 0.0 -90. -0.8334 1.69-4 0.0 00
 816 80102000 4 17.7 120. 0.93424 0.0 0.0
 817 *
 818 80200000 "MAINLINE" SNGLJUN
 819 80201001 801010000 803000000 0.0 0.0 0.0 1000
 820 80202001 1 0.0 0.0 0.0
 821 *
 822 80300000 "MAINLINE" SNGLVOL
 823 80301001 0.77708 0.8334 0.0 0.0 -90. -0.8334 1.69-4 0.0 00
 824 80302000 4 17.7 120. 0.93424 0.0 0.0
 825 *
 826 CONNECTION TO MAIN LINE AT ELEV. 670'-10"
 827 *
 828 *
 829 80400000 "MAINLINE" SNGLJUN
 830 80401001 803010000 805000000 0.0 0.0 0.0 1000
 831 80402001 1 0.0 0.0 0.0
 832 *
 833 20800-00 "CON.2" SNGLJUN
 834 20801001 207010000 805000000 0.0 0.158 0.158 1000
 835 20802001 1 0.0 0.0 0.0
 836 *
 837 80500-00 "MAINBR.3" BRANCH
 838 80500001 0
 839 80501001 0.77708 0.8334 0.0 0.0 -90. -0.8334 1.69-4 0.0 00
 840 80502000 4 17.7 120. 0.93424 0.0 0.0
 841 *
 842 80600000 "MAINLINE" SNGLJUN
 843 80601001 805010000 807000000 0.0 0.0 0.0 1000
 844 80602001 1 0.0 0.0 0.0
 845 *
 846 80700000 "MAINLINE" SNGLVOL
 847 80701001 0.77708 0.8334 0.0 0.0 -90. -0.8334 1.69-4 0.0 00
 848 80702000 4 17.7 120. 0.93424 0.0 0.0
 849 *
 850 *
 851 CONNECTION TO MAIN LINE AT ELEV. 689'-2"
 852 *
 853 *
 854 *
 855 80800000 "MAINLINE" SNGLJUN
 856 80801001 807010000 809000000 0.0 0.0 0.0 1000
 857 80802001 1 0.0 0.0 0.0
 858 *
 859 10800000 "CON.3" SNGLJUN
 860 10801001 107010000 809000000 0.0 0.158 0.158 1000
 861 10802001 1 0.0 0.0 0.0
 862 *
 863 80900000 "MAINBR4" BRANCH
 864 80901001 0
 865 80901001 0.77708 0.8334 0.0 0.0 -90. -0.8334 1.67-4 0.0 00
 866 80902000 4 17.7 120. 0.93424 0.0 0.0
 867 *
 868 81000000 "MAINLINE" SNGLJUN

RELAP

1/014

REACTOR LOSS OF COOLANT ANALYSIS PROGRAM


PAGE 16

		869	8100101	8609010000	811000000	0.0	0.0	0.0	1000
870	*	870	8100201	1	0.0	0.0	0.0		
871	*								
872	*								
873	*		8110000	"MAINLINE" PIPE					
874	*								
875	*		8110001	97					
876	*								
877	*		8110101	0.77708	97				
878	*								
879	*		8110301	0.0149	14				
880	*		8110302	0.5303	18				
881	*		8110303	0.5	22				
882	*		8110304	0.53125	26				
883	*		8110305	0.9908	56				
884	*		8110306	0.5	64				
885	*		8110307	0.8750	72				
886	*		8110308	0.5104	80				
887	*		8110309	0.4993	88				
888	*		8110310	1.0556	97				
889	*								
890	*		8110401	0.0	97				
891	*								
892	*		8110501	-90.	14				
893	*		8110602	-45.	18				
894	*		8110603	-90.	22				
895	*		8110604	-45.	26				
896	*		8110605	-90.	56				
897	*		8110606	0.0	80				
898	*		8110607	-90.	88				
899	*		8110608	0.0	97				
900	*								
901	*		8110801	1.69-4	0. 97				
902	*								
903	*		8110901	0.0	0.0	13			
904	*		8110902	0.078	0.078	14			
905	*		8110903	0.0	0.0	17			
906	*		8110904	0.078	0.078	18			
907	*		8110905	0.0	0.0	21			
908	*		8110906	0.078	0.078	22			
909	*		8110907	0.0	0.0	25			
910	*		8110908	0.078	0.078	26			
911	*		8110909	0.0	0.0	55			
912	*		8110910	0.158	0.158	56			
913	*		8110911	0.0	0.0	63			
914	*		8110912	0.026	0.026	64			
915	*		8110913	0.0	0.0	71			
916	*		8110914	0.13	0.13	72			
917	*		8110915	0.0	0.0	79			
918	*		8110916	0.156	0.156	80			
919	*		8110917	0.0	0.0	87			
920	*		8110918	0.156	0.156	88			
921	*		8110919	0.0	0.0	96			
922	*								
923	*		8111001	00	97				
924	*								
925	*		8111101	1000	98				
926	*								

TELEDYNE
ENGINEERING SERVICES

Technical Report
TR-5364-3;
Revision 0

4-150



RELAP 1/014 REACTOR LOSS OF COOLANT ANALYSIS PROGRAM

PAGE 17

Technical Report
TR-5364-3
Revision 0

4-151

TELEDYNE
ENGINEERING SERVICES


927	8111201	4	17.7	120.	0.93424	0.0
928	*					
929	8111300	1				
930	8111301	0.0	0.0	0.0	0.0	96
931	*					
932	*					
933	8120000	"MAINDISC"	SNGLJUN			
934	8120101	8110100000	813000000	0.0	0.156	0.156
935	8120201	1	0.0	0.0	0.0	1000
936	*					
937	8130000	"MAINLINE"	PIPE			
938	*					
939	8130001		26			
940	*					
941	8130101	0.77708		26		
942	*					
943	8130301	1.0		14		
944	8130302	0.5		24		
945	8130303	1.0208		26		
946	*					
947	8130401	0.0		26		
948	*					
949	8130601	0.0		24		
950	8130602	-90.		26		
951	*					
952	8130801	1.69-4		0.. 28		
953	*					
954	8130901	0.0		0.0 13		
955	8130902	0.156		0.156 14		
956	8130903	0.0		0.0 23		
957	8130904	0.156		0.156 24		
958	8130905	0.0		0.0 25		
959	*					
960	8131001	00		26		
961	*					
962	8131101	1000		25		
963	*					
964	8131201	4	17.7	120.	0.93424	0.0 28
965	*					
966	8131300	1				
967	8131301	0.0	0.0	0.0	25	
968	*					
969	*					
970	*					
971	*****	*****	*****	*****	*****	*****
972	*	QUENCH TANK	*			
973	*****	*****	*****	*****	*****	*****
974	*					
975	*					
976	*					
977	9770000	"QTANK-1"	SNGLJUN			
978	9770101	813010000	978000000	0. 0. 0.	1000	
979	9770201	1	0.	0.	0.	
980	*					
981	*	SPÄRGER	12 IN SCH40	PIPE		
982	*					
983	9780000	"SPÄRGER"	PIPE			
984	*	NO OF VOLUMES				

Technical Report
TR-5364-3
Revision 0

4-152

TELEDYNE
ENGINEERING SERVICES

985	9780001	18
986	*	FLOW AREA
987	9780101	0.7773 18
988	*	VOL. LENGTHS
989	9780301	1.125 2
990	9780302	1.1333 7
991	9780303	1.0 18
992	*	VOL. VOLs.
993	9780401	0.0 18
994	*	
995	*	VERTICAL ANGLES
996	9780601	-90. 7
997	9780602	0.0 18
998	*	PIPE ROUGHNESS
999	9780801	1.69-4 0.0 18
1000	*	JUNCTION LOSS COEFF
1001	9780901	0.0 0.0 6
1002	9780902	0.156 0.152 7
1003	9780903	0.0 0.0 17
1004	*	VOL. CONTROL FLAG
1005	9781001	0.0 18
1006	*	JUN. CONTROL FLAG
1007	9781101	1000 17
1008	*	INITIAL COND.
1009	9781201	4 17.7 120 0.93424 0. 2
1010	9781202	3 17.7 120 0.0 0. 18
1011	*	JUN. INITIAL COND.
1012	9781300	1
1013	9781301	0.0 0.0 0.0 17
1014	*	SPARGER EXIT
1015	9790000	"EXIT" SNGLJUN
1016	9790101	978010000 939000000 0.0 1.0 1.0 1100
1017	9790201	1 0. 0. 0.
1018	*	QUENCH TANK
1019	*	
1020	*	WATER VOL.
1021	9800000	"QT. WATER" SNGL-VOL
1022	9800101	260.4706 5.6687 0.0 0.0 90. 5.6687 0.003 0.0 01
1023	9800200	3 17.7 120.
1024	*	INTERFACE
1025	9810000	"INTERFACE" SNGLJUN
1026	9810101	980010000 982010000 0.0 0.0 0.0 1000
1027	9810201	1 0.0 0.0 0.0
1028	*	AIR VOLUME
1029	9820000	"QT.AIR" SNGL-VOL
1030	9820101	260.4706 1.2439 0.0 0.0 90. 1.2439 0.003 0.0 01
1031	9820200	4 17.7 120 0.93424
1032	*	RUPTURE DISC
1033	9830000	"RUP.DISC" VAL-YE
1034	9830101	982010000 983000000 1.77 0. 0. 1100
1035	9830201	1 0. 0. 0.
1036	9830300	TRPVLV
1037	9830301	515
1038	*	VALVE OPENING TRIP
1039	*	
1040	*	
1041	*****	*****
1042	*	PIPE OUTSIDE ENVIRONMENT



1043 ****
1044 *
1045 *
1046 9990000 "ATMOSPHERE" THNDPVOL
1047 9990101 10000. 10000. 0.0 0.0 0.0 0.0 .00001 0.0 11
1048 9990200 4
1049 9990201 0.0 14.7 120. 0.9284
1050 *
1051 *
1052 * PLOT CARDS
1053 *
1054 *
1055 *
1056 *
1057 20300100 MFLOWJ 106000000K
1058 20300200 MFLOWJ 206000000K
1059 20300300 MFLOWJ 306000000K
1060 20300400 MFLOWJ 308000000K
1061 20300500 MFLOWJ 208000000K
1062 20300600 MFLOWJ 702000000K
1063 20300700 MFLOWJ 108000000K
1064 20300800 MFLOWJ 977000000K
1065 20300900 QUALS 105200000K
1066 20301000 QUALS 107010000K
1067 20301100 QUALS 107330000K
1068 20301200 QUALS 701010000K
1069 20301300 QUALS 811970000K
1070 20301400 QUALS 813260000K
1071 20301500 QUALS 978180000K
1072 20301600 QUALS 205200000K
1073 20301700 QUALS 207010000K
1074 20301800 QUALS 305200000K
1075 20301900 QUALS 207260000K
1076 20302000 QUALS 307010000K
1077 20302100 QUALS 307180000K
1078 20302300 P 105200000K
1079 20302400 P 107010000K
1080 20302600 P 107330000K
1081 20302700 P 701010000K
1082 20303100 P 811970000K
1083 20303200 P 813260000K
1084 20303300 P 978020000K
1085 20303400 P 978030000K
1086 20303500 P 205200000K
1087 20303600 P 207010000K
1088 20303700 P 305200000K
1089 20303800 P 207260000K
1090 20303900 P 307010000K
1091 20304000 P 307180000K
1092 *
1093 *
1094 *
1095 *
1096 END OF CASE

4-153

TELEDYNE
ENGINEERING SERVICES

4.8 REPIPE Input

These are input listings of Control Data Corporation's RELAP post-processor, REPIPE. Each set represents direction cosines of the RELAP model as well as structural node assignments. On the Unit 1 SV model, it was necessary to break up the model in two sections, of approximately equal size, because of REPIPE's size limitations.

<u>Input Set</u>	<u>Model Section</u>
4.8.1	A
4.8.2	B



Technical Report
TR-5364-3
Revision 0

 TELEDYNE
ENGINEERING SERVICES

4-155

4.8.1 REPIPE Input - Section A




4-156

TELEDYNE
ENGINEERING SERVICES

\$PIPES
INLINE=3,KBLOCK=300,KPIPE=13,KPLOTT(1)=0,KWAVE=1,
KPRINT=-1,KPNV=1,KSTEP=3,
NDROPV=411190000,515120000,307180000,207260000,107330000,978080000\$
2951 515000000 -0.648 0.0 -7611/
2951 412000000 -0.648 0.0 -7611/
2951 702000000 -0.648 0.0 -7611/
290 -702000000 -0.648 0.0 -7611/
290 -703010000 -0.648 0.0 -7611/
285 703010000 0. 0 -1.0 0./
285 703020000 0. 0 -1.0 0./
285 703030000 0. 0 -1.0 0./
285 703040000 0. 0 -1.0 0./
285 703050000 0. 0 -1.0 0./
285 703060000 0. 0 -1.0 0./
285 703070000 0. 0 -1.0 0./
285 703080000 0. 0 -1.0 0./
285 703090000 0. 0 -1.0 0./
285 703100000 0. 0 -1.0 0./
285 703110000 0. 0 -1.0 0./
285 703120000 0. 0 -1.0 0./
285 703130000 0. 0 -1.0 0./
285 704000000 0. 0 -1.0 0./
285 308000000 0.0 -1.0 0.0/
285 802000000 0. 0 -1.0 0./
285 804000000 0. 0 -1.0 0./
285 208000000 0.0 -1.0 0.0/
285 806000000 0. 0 -1.0 0./
285 808000000 0. 0 -1.0 0.0/
285 108000000 0.0 -1.0 0.0/
285 810000000 0. 0 -1.0 0./
285 811010000 0. 0 -1.0 0./
285 811020000 0. 0 -1.0 0./
285 811030000 0. 0 -1.0 0./
285 811040000 0. 0 -1.0 0./
285 811050000 0. 0 -1.0 0./
285 811060000 0. 0 -1.0 0./
285 811070000 0. 0 -1.0 0./
285 811080000 0. 0 -1.0 0./
285 811090000 0. 0 -1.0 0./
285 811100000 0. 0 -1.0 0./
285 811110000 0. 0 -1.0 0./
285 811120000 0. 0 -1.0 0./
285 811130000 0. 0 -1.0 0./
90 -703020000 0. 0 -1.0 0./
90 -703030000 0. 0 -1.0 0./
90 -703040000 0. 0 -1.0 0./
90 -703050000 0. 0 -1.0 0./
90 -703060000 0. 0 -1.0 0./
90 -703070000 0. 0 -1.0 0./
90 -703080000 0. 0 -1.0 0./
90 -703090000 0. 0 -1.0 0./
90 -703100000 0. 0 -1.0 0./
90 -703110000 0. 0 -1.0 0./
90 -703120000 0. 0 -1.0 0./
90 -703130000 0. 0 -1.0 0./
90 -704000000 0. 0 -1.0 0./
90 -802000000 0. 0 -1.0 0./
90 -804000000 0. 0 -1.0 0./
90 -806000000 0. 0 -1.0 0./
90 -808000000 0. 0 -1.0 0./
90 -810000000 0. 0 -1.0 0./
90 -811010000 0. 0 -1.0 0./

BY KJG DATE 6-22-83
CHKD. BY CML DATE 6-27-83

90	1020000	0.	-1.0	0./
90	811030000	0.	-1.0	0./
90	-811040000	0.	-1.0	0./
90	-811050000	0.	-1.0	0./
90	-811060000	0.	-1.0	0./
90	-811070000	0.	-1.0	0./
90	-811080000	0.	-1.0	0./
90	-811090000	0.	-1.0	0./
90	-811100000	0.	-1.0	0./
90	-811110000	0.	-1.0	0./
90	-811120000	0.	-1.0	0./
90	-811130000	0.	-1.0	0./
90	-811140000	0.	-1.0	0./
88	811140000	0.2356	-0.7071	0.6667/
88	811150000	0.2356	-0.7071	0.6667/
88	811160000	0.2356	-0.7071	0.6667/
88	811170000	0.2356	-0.7071	0.6667/
86	-811150000	0.2356	-0.7071	0.6667/
86	-811160000	0.2356	-0.7071	0.6667/
86	-811170000	0.2356	-0.7071	0.6667/
86	-811180000	0.2356	-0.7071	0.6667/
84	811180000	0.	-1.0	0./
84	811190000	0.	-1.0	0./
84	811200000	0.	-1.0	0./
84	811210000	0.	-1.0	0./
82	-811190000	0.	-1.0	0./
82	-811200000	0.	-1.0	0./
82	-811210000	0.	-1.0	0./
82	-811220000	0.	-1.0	0./
80	811220000	-0.2356	-0.7071	-0.6667/
80	811230000	-0.2356	-0.7071	-0.6667/
80	811240000	-0.2356	-0.7071	-0.6667/
80	811250000	-0.2356	-0.7071	-0.6667/
76	-811230000	-0.2356	-0.7071	-0.6667/
76	-811240000	-0.2356	-0.7071	-0.6667/
76	-811250000	-0.2356	-0.7071	-0.6667/
76	-811260000	-0.2356	-0.7071	-0.6667/
74	811260000	0.0	-1.0	0.0/
74	811270000	0.0	-1.0	0.0/
74	811280000	0.0	-1.0	0.0/
74	811290000	0.0	-1.0	0.0/
74	811300000	0.0	-1.0	0.0/
74	811310000	0.0	-1.0	0.0/
74	811320000	0.0	-1.0	0.0/
74	811330000	0.0	-1.0	0.0/
74	811340000	0.0	-1.0	0.0/
74	811350000	0.0	-1.0	0.0/
74	811360000	0.0	-1.0	0.0/
74	811370000	0.0	-1.0	0.0/
74	811380000	0.0	-1.0	0.0/
74	811390000	0.0	-1.0	0.0/
74	811400000	0.0	-1.0	0.0/
74	811410000	0.0	-1.0	0.0/
74	811420000	0.0	-1.0	0.0/
74	811430000	0.0	-1.0	0.0/
74	811440000	0.0	-1.0	0.0/
74	811450000	0.0	-1.0	0.0/
74	811460000	0.0	-1.0	0.0/
74	811470000	0.0	-1.0	0.0/
74	811480000	0.0	-1.0	0.0/
74	811490000	0.0	-1.0	0.0/
74	811500000	0.0	-1.0	0.0/
74	811510000	0.0	-1.0	0.0/



4-158

TELEDYNE
ENGINEERING SERVICES

74	811520000	0.0	-1.0	0.0/
74	811530000	0.0	-1.0	0.0/
74	811540000	0.0	-1.0	0.0/
74	811550000	0.0	-1.0	0.0/
62	-811270000	0.0	-1.0	0.0/
62	-811280000	0.0	-1.0	0.0/
62	-811290000	0.0	-1.0	0.0/
62	-811300000	0.0	-1.0	0.0/
62	-811310000	0.0	-1.0	0.0/
62	-811320000	0.0	-1.0	0.0/
62	-811330000	0.0	-1.0	0.0/
62	-811340000	0.0	-1.0	0.0/
62	-811350000	0.0	-1.0	0.0/
62	-811360000	0.0	-1.0	0.0/
62	-811370000	0.0	-1.0	0.0/
62	-811380000	0.0	-1.0	0.0/
62	-811390000	0.0	-1.0	0.0/
62	-811400000	0.0	-1.0	0.0/
62	-811410000	0.0	-1.0	0.0/
62	-811420000	0.0	-1.0	0.0/
62	-811430000	0.0	-1.0	0.0/
62	-811440000	0.0	-1.0	0.0/
62	-811450000	0.0	-1.0	0.0/
62	-811460000	0.0	-1.0	0.0/
62	-811470000	0.0	-1.0	0.0/
62	-811480000	0.0	-1.0	0.0/
62	-811490000	0.0	-1.0	0.0/
62	-811500000	0.0	-1.0	0.0/
62	-811510000	0.0	-1.0	0.0/
62	-811520000	0.0	-1.0	0.0/
62	-811530000	0.0	-1.0	0.0/
62	-811540000	0.0	-1.0	0.0/
62	-811550000	0.0	-1.0	0.0/
62	-811560000	0.0	-1.0	0.0/
60	811560000	0.0	0.0	-1.0/
60	811570000	0.0	0.0	-1.0/
60	811580000	0.0	0.0	-1.0/
60	811590000	0.0	0.0	-1.0/
60	811600000	0.0	0.0	-1.0/
60	811610000	0.0	0.0	-1.0/
60	811620000	0.0	0.0	-1.0/
60	811630000	0.0	0.0	-1.0/
58	-811570000	0.0	0.0	-1.0/
58	-811580000	0.0	0.0	-1.0/
58	-811590000	0.0	0.0	-1.0/
58	-811600000	0.0	0.0	-1.0/
58	-811610000	0.0	0.0	-1.0/
58	-811620000	0.0	0.0	-1.0/
58	-811630000	0.0	0.0	-1.0/
58	-811640000	0.0	0.0	-1.0/
58	811640000	-259	0.0	-966/
58	811650000	-259	0.0	-966/
58	811660000	-259	0.0	-966/
58	811670000	-259	0.0	-966/
56	811680000	-259	0.0	-966/
58	811690000	-259	0.0	-966/
56	811700000	-259	0.0	-966/
58	811710000	-259	0.0	-966/
52	-811650000	-259	0.0	-966/
52	-811660000	-259	0.0	-966/
52	-811670000	-259	0.0	-966/
52	-811680000	-259	0.0	-966/
52	-811690000	-259	0.0	-966/



4-159

TELEDYNE
ENGINEERING SERVICES

52 811700000 - .259 0.0 811700000 /
52 -811710000 - .259 0.0 811710000 /
52 -811720000 - .259 0.0 811720000 /
50 811720000 -1.0 0.0 1.0 /
50 811730000 -1.0 0.0 1.0 /
50 811740000 -1.0 0.0 1.0 /
50 811750000 -1.0 0.0 1.0 /
50 811760000 -1.0 0.0 1.0 /
50 811770000 -1.0 0.0 1.0 /
50 811780000 -1.0 0.0 1.0 /
50 811790000 -1.0 0.0 1.0 /
46 -811730000 -1.0 0.0 1.0 /
46 -811740000 -1.0 0.0 1.0 /
46 -811750000 -1.0 0.0 1.0 /
46 -811760000 -1.0 0.0 1.0 /
46 -811770000 -1.0 0.0 1.0 /
46 -811780000 -1.0 0.0 1.0 /
46 -811790000 -1.0 0.0 1.0 /
46 -811800000 -1.0 0.0 1.0 /
44 811800000 0.0 -1.0 1.0 /
44 811810000 0.0 -1.0 1.0 /
44 811820000 0.0 -1.0 1.0 /
44 811830000 0.0 -1.0 1.0 /
44 811840000 0.0 -1.0 1.0 /
44 811850000 0.0 -1.0 1.0 /
44 811860000 0.0 -1.0 1.0 /
44 811870000 0.0 -1.0 1.0 /
40 -811810000 0.0 -1.0 1.0 /
40 -811820000 0.0 -1.0 1.0 /
40 -811830000 0.0 -1.0 1.0 /
40 -811840000 0.0 -1.0 1.0 /
40 -811850000 0.0 -1.0 1.0 /
40 -811860000 0.0 -1.0 1.0 /
40 -811870000 0.0 -1.0 1.0 /
40 -811880000 0.0 -1.0 1.0 /
38 811880000 -1.0 0.0 1.0 /
38 811890000 -1.0 0.0 1.0 /
38 811900000 -1.0 0.0 1.0 /
38 811910000 -1.0 0.0 1.0 /
38 811920000 -1.0 0.0 1.0 /
38 811930000 -1.0 0.0 1.0 /
38 811940000 -1.0 0.0 1.0 /
38 811950000 -1.0 0.0 1.0 /
38 811960000 -1.0 0.0 1.0 /
32 -811970000 -1.0 0.0 1.0 /
32 -811980000 -1.0 0.0 1.0 /
32 -811990000 -1.0 0.0 1.0 /
32 -811910000 -1.0 0.0 1.0 /
32 -811920000 -1.0 0.0 1.0 /
32 -811930000 -1.0 0.0 1.0 /
32 -811940000 -1.0 0.0 1.0 /
32 -811950000 -1.0 0.0 1.0 /
32 -811960000 -1.0 0.0 1.0 /
32 -812000000 -1.0 0.0 1.0 /
30 812000000 0.0 0.0 1.0 /
30 813010000 0.0 0.0 1.0 /
30 813020000 0.0 0.0 1.0 /
30 813030000 0.0 0.0 1.0 /
30 813040000 0.0 0.0 1.0 /
30 813050000 0.0 0.0 1.0 /
30 813060000 0.0 0.0 1.0 /
30 813070000 0.0 0.0 1.0 /
30 813080000 0.0 0.0 1.0 /
30 813090000 0.0 0.0 1.0 /

30	8100000	0.0	0.0	1.0/
30	813110000	0.0	0.0	1.0/
30	813120000	0.0	0.0	1.0/
30	813130000	0.0	0.0	1.0/
12	-813010000	0.0	0.0	1.0/
12	-813020000	0.0	0.0	1.0/
12	-813030000	0.0	0.0	1.0/
12	-813040000	0.0	0.0	1.0/
12	-813050000	0.0	0.0	1.0/
12	-813060000	0.0	0.0	1.0/
12	-813070000	0.0	0.0	1.0/
12	-813080000	0.0	0.0	1.0/
12	-813090000	0.0	0.0	1.0/
12	-813100000	0.0	0.0	1.0/
12	-813110000	0.0	0.0	1.0/
12	-813120000	0.0	0.0	1.0/
12	-813130000	0.0	0.0	1.0/
12	-813140000	0.0	0.0	1.0/
10	813140000	1.0	0.0	0.0/
10	813150000	1.0	0.0	0.0/
10	813160000	1.0	0.0	0.0/
10	813170000	1.0	0.0	0.0/
10	813180000	1.0	0.0	0.0/
10	813190000	1.0	0.0	0.0/
10	813200000	1.0	0.0	0.0/
10	813210000	1.0	0.0	0.0/
10	813220000	1.0	0.0	0.0/
10	813230000	1.0	0.0	0.0/
6	-813150000	1.0	0.0	0.0/
6	-813160000	1.0	0.0	0.0/
6	-813170000	1.0	0.0	0.0/
6	-813180000	1.0	0.0	0.0/
6	-813190000	1.0	0.0	0.0/
6	-813200000	1.0	0.0	0.0/
6	-813210000	1.0	0.0	0.0/
6	-813220000	1.0	0.0	0.0/
6	-813230000	1.0	0.0	0.0/
6	-813240000	1.0	0.0	0.0/
4	813240000	0.0	-1.0	0.0/
4	813250000	0.0	-1.0	0.0/
4	977000000	0.0	-1.0	0.0/
4	978010000	0.0	-1.0	0.0/
4	978020000	0.0	-1.0	0.0/
4	978030000	0.0	-1.0	0.0/
4	978040000	0.0	-1.0	0.0/
4	978050000	0.0	-1.0	0.0/
4	978060000	0.0	-1.0	0.0/
1	-813250000	0.0	-1.0	0.0/
1	-977000000	0.0	-1.0	0.0/
1	-978010000	0.0	-1.0	0.0/
1	-978020000	0.0	-1.0	0.0/
1	-978030000	0.0	-1.0	0.0/
1	-978040000	0.0	-1.0	0.0/
1	-978050000	0.0	-1.0	0.0/
1	-978060000	0.0	-1.0	0.0/
1	-978070000	0.0	-1.0	0.0/

99999/
\$STEPS TSTEP(1)=0.001,0.500,-1,-1\$



Technical Report
TR-5364-3
Revision 0

TELEDYNE
ENGINEERING SERVICES

4-161

4.8.2 REPIPE Input - Section B

\$PIPE
INLINE, KBLOCK=300, KPIPE=13, KPLOT(1)=0, KWAVE=1,
KPRINT=-1, KPNV=1, KSTEP=3.
NDROPV=100010000, 200010000, 300010000, 801010000, 805010000,
809010000, 701010000,

625	610000000	-0.9272	0.0	0.375/
625	611010000	-0.9272	0.0	0.375/
625	611020000	-0.9272	0.0	0.375/
625	611030000	-0.9272	0.0	0.375/
615	-611010000	-0.9272	0.0	0.375/
615	-611020000	-0.9272	0.0	0.375/
815	-611030000	-0.9272	0.0	0.375/
615	-611040000	-0.9272	0.0	0.375/
610	611040000	0.0	-1.0	0.0/
610	611050000	0.0	-1.0	0.0/
610	611060000	0.0	-1.0	0.0/
610	611070000	0.0	-1.0	0.0/
335	-611050000	0.0	-1.0	0.0/
335	-611060000	0.0	-1.0	0.0/
335	-611070000	0.0	-1.0	0.0/
335	-612000000	0.0	-1.0	0.0/
525	410000000	0.9272	0.0	-0.3746/
525	411010000	0.9272	0.0	-0.3746/
525	411020000	0.9272	0.0	-0.3746/
525	411030000	0.9272	0.0	-0.3746/
530	-411010000	0.9272	0.0	-0.3746/
530	-411020000	0.9272	0.0	-0.3746/
530	-411030000	0.9272	0.0	-0.3746/
530	-411040000	0.9272	0.0	-0.3746/
533	411040000	0.0	-1.0	0.0/
533	411050000	0.0	-1.0	0.0/
533	411060000	0.0	-1.0	0.0/
533	411070000	0.0	-1.0	0.0/
540	-411050000	0.0	-1.0	0.0/
540	-411060000	0.0	-1.0	0.0/
540	-411070000	0.0	-1.0	0.0/
540	-411080000	0.0	-1.0	0.0/
545	411080000	.235	0.0	-0.9585/
545	411090000	.235	0.0	-0.9585/
545	411100000	.235	0.0	-0.9585/
55001	-411090000	.235	0.0	-0.9585/
55001	-411100000	.235	0.0	-0.9585/
55001	-411110000	.235	0.0	-0.9585/
55002	411110000	-.107	0.0	-0.9943/
55002	-411120000	-.107	0.0	-0.9943/
55002	-411130000	-.107	0.0	-0.8943/
55501	-411120000	-.107	0.0	-0.9943/
55501	-411130000	-.107	0.0	-0.9943/
55501	-411140000	-.107	0.0	-0.9943/
55502	411140000	-.423	0.0	-0.876/
55502	411150000	-.423	0.0	-0.876/
55502	411160000	-.423	0.0	-0.876/
56001	-411150000	-.423	0.0	-0.876/
56001	-411160000	-.423	0.0	-0.876/
56001	-411170000	-.423	0.0	-0.876/
56002	411170000	-.7054	0.0	-0.7078/
56002	411180000	-.7054	0.0	-0.7078/
295	-411180000	-.7054	0.0	-0.7078/
295	-412000000	-.7054	0.0	-0.7078/
385	510000000	0.3705	0.0	0.9272/
385	511010000	0.3705	0.0	0.9272/
385	511020000	0.3705	0.0	0.9272/
380	-511010000	0.3705	0.0	0.9272/

BY KJG DATE 6-22-83CHKD. BY CW DATE 6-27-83

4-162

4-163

380	10200000	0.3708	0.0	0.9272/	
380	511030000	0.3706	0.0	0.9272/	
375	511030000	0.0	-1.0	0.0/	
375	511040000	0.0	-1.0	0.0/	
375	511050000	0.0	-1.0	0.0/	
375	511060000	0.0	-1.0	0.0/	
370	-511040000	0.0	-1.0	0.0/	
370	-511050000	0.0	-1.0	0.0/	
370	-511060000	0.0	-1.0	0.0/	
370	-511070000	0.0	-1.0	0.0/	
385	511070000	.826	0.0	.563/	
385	511080000	.826	0.0	.583/	
36001	-511080000	.826	0.0	.563/	
36001	-511090000	.826	0.0	.563/	
36002	511090000	.833	0.0	.7745/	
36002	511100000	.633	0.0	.7745/	
36002	511110000	.633	0.0	.7745/	
35501	-511100000	.633	0.0	.7745/	
35501	-511110000	.633	0.0	.7745/	
35501	-511120000	.633	0.0	.7745/	
35502	511120000	.254	0.0	.967/	
35502	511130000	.254	0.0	.967/	
35502	511140000	.254	0.0	.967/	
35001	-511130000	.254	0.0	.967/	
35001	-511140000	.254	0.0	.967/	
35001	-511150000	.254	0.0	.967/	
35002	511150000	.169	0.0	.9856/	
35002	511160000	.169	0.0	.9856/	
35002	511170000	.169	0.0	.9856/	
34001	-511160000	.169	0.0	.9856/	
34001	-511170000	.169	0.0	.9856/	
34001	-511180000	.169	0.0	.9856/	
34002	511180000	.415	0.0	.9099/	
33501	-512000000	.415	0.0	.9099/	
33502	512000000	.525	0.0	.851/	
33502	812000000	0.525	0.0	-0.851/	
33502	514000000	.525	0.0	.851/	
32501	-514000000	.525	0.0	.851/	
32501	-515010000	.525	0.0	.851/	
32502	515010000	.773	0.0	.835/	
32502	515020000	.773	0.0	.835/	
32502	515030000	.773	0.0	.835/	
32001	-515020000	.773	0.0	.835/	
32001	-515030000	.773	0.0	.835/	
32001	-515040000	.773	0.0	.835/	
32002	515040000	.981	0.0	.195/	
32002	515050000	.981	0.0	.195/	
32002	515060000	.981	0.0	.195/	
31001	-515050000	.981	0.0	.195/	
31001	-515080000	.981	0.0	.195/	
31001	-515070000	.981	0.0	.195/	
31002	515070000	.957	0.0	.290/	
31002	515080000	.957	0.0	.290/	
30001	-515080000	.957	0.0	.290/	
30001	-515090000	.957	0.0	.290/	
30001	-515100000	.957	0.0	.290/	
30002	515100000	.812	0.0	.583/	
30002	515110000	.812	0.0	.583/	
2952	-515110000	.812	0.0	.583/	
2952	-516000000	.812	0.0	.583/	
138	102000000	-0.694	0.707	-0.135/	
138	-103010000	-0.694	0.707	-0.135/	

134	10000	-0.9816	0.0	-0.1908/
134	-103020000	-0.9816	0.0	-0.1908/
134	103030000	-0.9816	0.0	-0.1908/
132	-103020000	-0.9816	0.0	-0.1908/
132	-103030000	-0.9816	0.0	-0.1908/
132	104000000	0.0	-1.0	0.0/
130	105010000	0.0	-1.0	0.0/
130	105020000	0.0	-1.0	0.0/
130	105030000	0.0	-1.0	0.0/
130	105040000	0.0	-1.0	0.0/
130	105050000	0.0	-1.0	0.0/
130	105060000	0.0	-1.0	0.0/
128	-105010000	0.0	-1.0	0.0/
128	-105020000	0.0	-1.0	0.0/
128	-105030000	0.0	-1.0	0.0/
128	-105040000	0.0	-1.0	0.0/
128	-105050000	0.0	-1.0	0.0/
128	-105060000	0.0	-1.0	0.0/
128	-105070000	0.0	-1.0	0.0/
126	105070000	-0.0652	0.0	0.98979/
126	105080000	-0.0652	0.0	0.98979/
126	105090000	-0.0652	0.0	0.98979/
124	-105080000	-0.0652	0.0	0.98979/
124	-105090000	-0.0652	0.0	0.98979/
124	-105100000	-0.0652	0.0	0.98979/
122	105100000	0.	1.0	0./
122	105110000	0.	1.0	0./
122	105120000	0.	1.0	0./
122	105130000	0.	1.0	0./
122	105140000	0.	1.0	0./
122	105150000	0.	1.0	0./
122	105160000	0.	1.0	0./
122	105170000	0.	1.0	0./
122	105180000	0.	1.0	0./
122	105190000	0.	1.0	0./
118	-105110000	0.	1.0	0./
118	-105120000	0.	1.0	0./
118	-105130000	0.	1.0	0./
118	-105140000	0.	1.0	0./
118	-105150000	0.	1.0	0./
118	-105160000	0.	1.0	0./
118	-105170000	0.	1.0	0./
118	-105180000	0.	1.0	0./
118	-105190000	0.	1.0	0./
118	-106000000	0.	1.0	0./
115	106000000	0.3498	0.	0.9368/
115	107010000	0.3498	0.	0.9368/
115	107020000	0.3498	0.	0.9368/
115	107030000	0.3498	0.	0.9368/
114	-107010000	0.3498	0.	0.9368/
114	-107020000	0.3498	0.	0.9368/
114	-107030000	0.3498	0.	0.9368/
114	-107040000	0.3498	0.	0.9368/
112	107040000	0.	-1.0	0./
112	107050000	0.	-1.0	0./
112	107060000	0.	-1.0	0./
112	107070000	0.	-1.0	0./
112	107080000	0.	-1.0	0./
112	107090000	0.	-1.0	0./
112	107100000	0.	-1.0	0./
112	107110000	0.	-1.0	0./
112	107120000	0.	-1.0	0./

112	-07130000	0.	-1.0	0./
112	-107140000	0.	-1.0	0./
106	-107050000	0.	-1.0	0./
106	-107060000	0.	-1.0	0./
106	-107070000	0.	-1.0	0./
106	-107080000	0.	-1.0	0./
106	-107090000	0.	-1.0	0./
106	-107100000	0.	-1.0	0./
106	-107110000	0.	-1.0	0./
106	-107120000	0.	-1.0	0./
106	-107130000	0.	-1.0	0./
106	-107140000	0.	-1.0	0./
106	-107150000	0.	-1.0	0./
104	107150000	0.7723	0.	0.8353/
104	107160000	0.7723	0.	0.8353/
104	107170000	0.7723	0.	0.8353/
10301	-107160000	0.7723	0.	0.8353/
10301	-107170000	0.7723	0.	0.8353/
10301	-107180000	0.7723	0.	0.8353/
10302	107180000	0.9948	0.	0.1018/
10302	107190000	0.9948	0.	0.1018/
10302	107200000	0.9948	0.	0.1018/
10201	-107190000	0.9948	0.	0.1018/
10201	-107200000	0.9948	0.	0.1018/
10201	-107210000	0.9948	0.	0.1018/
10202	107210000	0.8945	0.	-0.4470/
10202	107220000	0.8945	0.	-0.4470/
10202	107230000	0.8945	0.	-0.4470/
10001	-107220000	0.8945	0.	-0.4470/
10001	-107230000	0.8945	0.	-0.4470/
10001	-107240000	0.8945	0.	-0.4470/
10002	107240000	0.534	0.	-0.8453/
10002	107250000	0.534	0.	-0.8453/
10002	107260000	0.534	0.	-0.8453/
9901	-107250000	0.534	0.	-0.8453/
9901	-107260000	0.534	0.	-0.8453/
9901	-107270000	0.534	0.	-0.8453/
9902	107270000	0.0195	0.	-0.9988/
9902	107280000	0.0195	0.	-0.998/
9902	107290000	0.0195	0.	-0.998/
9801	-107280000	0.0195	0.	-0.998/
9801	-107290000	0.0195	0.	-0.998/
9801	-107300000	0.0195	0.	-0.998/
9802	107300000	-0.2497	0.	-0.9883/
9802	107310000	-0.2497	0.	-0.9883/
9802	107320000	-0.2497	0.	-0.9883/
97	-107310000	-0.2497	0.	-0.9883/
97	-107320000	-0.2497	0.	-0.9883/
97	-108000000	-0.2497	0.	-0.9883/
185	202000000	0.4056	0.7071	0.5792/
184	-203010000	0.4056	0.7071	0.5792/
182	203010000	-0.5736	0.0	0.8192/
182	203020000	-0.5736	0.0	0.8192/
182	203030000	-0.5736	0.	0.8192/
181	-203020000	-0.5736	0.	0.8192/
181	-203030000	-0.5736	0.	0.8192/
181	-204000000	-0.5736	0.	0.8192/
180	204000000	0.	-1.0	0./
180	205010000	0.	-1.0	0./
180	205020000	0.	-1.0	0./
180	205030000	0.	-1.0	0./
180	205040000	0.	-1.0	0./
180	205050000	0.	-1.0	0./

180	5060000	0.	-1.0	0./
178	-205010000	0.	-1.0	0./
178	-205020000	0.	-1.0	0./
178	-205030000	0.	-1.0	0./
178	-205040000	0.	-1.0	0./
178	-205050000	0.	-1.0	0./
178	-205060000	0.	-1.0	0./
178	-205070000	0.	-1.0	0./
178	205070000	0.9006	0.	0.4348/
178	205080000	0.9006	0.	0.4348/
178	205090000	0.9006	0.	0.4348/
174	-205080000	0.9006	0.	0.4348/
174	-205090000	0.9006	0.	0.4348/
174	-205100000	0.9006	0.	0.4348/
172	205100000	0.	1.0	0./
172	205110000	0.	1.0	0./
172	205120000	0.	1.0	0./
172	205130000	0.	1.0	0./
172	205140000	0.	1.0	0./
172	205150000	0.	1.0	0./
172	205160000	0.	1.0	0./
172	205170000	0.	1.0	0./
172	205180000	0.	1.0	0./
172	205190000	0.	1.0	0./
168	-205110000	0.	1.0	0./
168	-205120000	0.	1.0	0./
168	-205130000	0.	1.0	0./
168	-205140000	0.	1.0	0./
168	-205150000	0.	1.0	0./
168	-205160000	0.	1.0	0./
168	-205170000	0.	1.0	0./
168	-205180000	0.	1.0	0./
168	-205190000	0.	1.0	0./
168	-206000000	0.	1.0	0./
164	206000000	0.9968	0.	0.0828/
164	207010000	0.9968	0.	0.0828/
164	207020000	0.9968	0.	0.0828/
164	207030000	0.9968	0.	0.0828/
162	-207010000	0.9968	0.	0.0828/
162	-207020000	0.9968	0.	0.0828/
162	-207030000	0.9968	0.	0.0828/
162	-207040000	0.9968	0.	0.0828/
160	207040000	0.	-1.0	0./
160	207050000	0.	-1.0	0./
160	207060000	0.	-1.0	0./
160	207070000	0.	-1.0	0./
160	207080000	0.	-1.0	0./
160	207090000	0.	-1.0	0./
160	207100000	0.	-1.0	0./
160	207110000	0.	-1.0	0./
160	207120000	0.	-1.0	0./
160	207130000	0.	-1.0	0./
152	-207050000	0.	-1.0	0./
152	-207060000	0.	-1.0	0./
152	-207070000	0.	-1.0	0./
152	-207080000	0.	-1.0	0./
152	-207090000	0.	-1.0	0./
152	-207100000	0.	-1.0	0./
152	-207110000	0.	-1.0	0./
152	-207120000	0.	-1.0	0./
152	-207130000	0.	-1.0	0./
152	-207140000	0.	-1.0	0./
150	207140000	0.9202	0.	-0.3915/

4-167

150	1500000	0.9202	0.	-0.3915/
150	-107160000	0.9202	0.	-0.3915/
14801	-207150000	0.9202	0.	-0.3915/
14801	-207160000	0.9202	0.	-0.3915/
14801	-207170000	0.9202	0.	-0.3915/
14802	207170000	0.5647	0.	-0.8253/
14802	207180000	0.5647	0.	-0.8253/
14802	207190000	0.5647	0.	-0.8253/
14601	-207180000	0.5647	0.	-0.8253/
14601	-207190000	0.5647	0.	-0.8253/
14601	-207200000	0.5647	0.	-0.8253/
14602	207200000	0.0318	0.	-0.9995/
14602	207210000	0.0318	0.	-0.9995/
14602	207220000	0.0318	0.	-0.9995/
14401	-207210000	0.0318	0.	-0.9995/
14401	-207220000	0.0318	0.	-0.9995/
14401	-207230000	0.0318	0.	-0.9995/
14402	207230000	-0.2497	0.	-0.9683/
14402	207240000	-0.2497	0.	-0.9683/
14402	207250000	-0.2497	0.	-0.9683/
142	-207240000	-0.2497	0.	-0.9683/
142	-207250000	-0.2497	0.	-0.9683/
142	-208000000	-0.2497	0.	-0.9683/
244	302000000	0.3641	0.7071	0.606/
242	-303010000	0.3641	0.7071	0.606/
240	303010000	0.5150	0.0	0.8524/
240	303020000	0.5150	0.	0.8524/
240	303030000	0.5150	0.	0.8524/
238	-303020000	0.5150	0.	0.8572/
238	-303030000	0.5150	0.	0.8572/
238	-304000000	0.5150	0.	0.8572/
237	304000000	0.	-1.0	0./
237	305010000	0.	-1.0	0./
237	305020000	0.	-1.0	0./
237	305030000	0.	-1.0	0./
237	305040000	0.	-1.0	0./
237	305050000	0.	-1.0	0./
237	305060000	0.	-1.0	0./
236	-305010000	0.	-1.0	0./
238	-305020000	0.	-1.0	0./
236	-305030000	0.	-1.0	0./
238	-305040000	0.	-1.0	0./
238	-305050000	0.	-1.0	0./
238	-305060000	0.	-1.0	0./
238	-305070000	0.	-1.0	0./
235	305070000	0.7633	0.	-0.6460/
235	305080000	0.7633	0.	-0.6460/
235	305090000	0.7633	0.	-0.6460/
234	-305080000	0.7633	0.	-0.6460/
234	-305090000	0.7633	0.	-0.6460/
234	-305100000	0.7633	0.	-0.6460/
233	305100000	0.	1.0	0./
233	305110000	0.	1.0	0./
233	305120000	0.	1.0	0./
233	305130000	0.	1.0	0./
233	305140000	0.	1.0	0./
233	305150000	0.	1.0	0./
233	305160000	0.	1.0	0./
233	305170000	0.	1.0	0./
233	305180000	0.	1.0	0./
233	305190000	0.	1.0	0./
228	-305110000	0.	1.0	0./
228	-305120000	0.	1.0	0./

228 5130000 0. 1.0 0./
228 -305140000 0. 1.0 0./
228 -305150000 0. 1.0 0./
228 -305160000 0. 1.0 0./
228 -305170000 0. 1.0 0./
228 -305180000 0. 1.0 0./
228 -305190000 0. 1.0 0./
228 -306000000 0. 1.0 0./
224 306000000 0.4621 0. -0.8868/
224 307010000 0.4621 0. -0.8868/
224 307020000 0.4621 0. -0.8868/
224 307030000 0.4621 0. -0.8868/
223 -307010000 0.4621 0. -0.8868/
223 -307020000 0.4621 0. -0.8868/
223 -307030000 0.4621 0. -0.8868/
223 -307040000 0.4621 0. -0.8868/
222 307040000 0. -1.0 0./
222 307050000 0. -1.0 0./
222 307060000 0. -1.0 0./
222 307070000 0. -1.0 0./
222 307080000 0. -1.0 0./
222 307090000 0. -1.0 0./
222 307100000 0. -1.0 0./
222 307110000 0. -1.0 0./
216 -307050000 0. -1.0 0./
216 -307060000 0. -1.0 0./
216 -307070000 0. -1.0 0./
216 -307080000 0. -1.0 0./
216 -307090000 0. -1.0 0./
216 -307100000 0. -1.0 0./
216 -307110000 0. -1.0 0./
216 -307120000 0. -1.0 0./
214 307120000 0.0047 0. -0.99999/
214 307130000 0.0047 0. -0.99999/
214 307140000 0.0047 0. -0.99999/
20801 -307130000 0.0047 0. -0.99999/
20801 -307140000 0.0047 0. -0.99999/
20801 -307150000 0.0047 0. -0.99999/
20802 307150000 -0.2497 0. -0.9683/
20802 307160000 -0.2497 0. -0.9683/
20802 307170000 -0.2497 0. -0.9683/
206 -307160000 -0.2497 0. -0.9683/
206 -307170000 -0.2497 0. -0.9683/
206 -308000000 -0.2497 0. -0.9683/
99999/
\$STEPS TSTEP(1)=0.001,0.500,-1,-1\$

Technical Report
TR-5364-3
Revision 0

 TELEDYNE
ENGINEERING SERVICES

4- 169

4.9 APPENDIX A


TELEDYNE ENGINEERING SERVICES

BY JRM DATE 8-24-82
 CHKD. BY SGC DATE 8-25-82
JK 6-1-83

AMERICAN ELECTRIC POWER
 D.C. COOK UNITS 1 & 2
 PIPE PROPERTIES

SHEET NO. 1 OF 1
 PROJ. NO. 5364

PIPE PROPERTIES

SIZE	SCHEDULE	I.D. (in.)	FLOW AREA (ft ²)	FRICITION FACTOR f	ϵ/d	ROUGHNESS ϵ (ft)	* K_{ELBOW} 125
3"	40	3.068	.05132	.0174	.0006	1.53×10^{-4}	.2088
3"	160	2.624	.03757	.0181	.0007	1.53×10^{-4}	.2172
4"	40	4.026	.08840	.0161	.0004	1.34×10^{-4}	.1932
4"	120	3.624	.07160	.0162	.00044	1.33×10^{-4}	.1944
6"	40	6.065	.20069	.015	.0003	1.52×10^{-4}	.1800
6"	160	5.189	.14653	.0153	.00035	1.51×10^{-4}	.1836
12"	40	11.938	.77708	.013	.00017	1.69×10^{-4}	.1560


* RESISTANCE DUE TO BEND ONLY FOR 1.5d BENDS

REF: CRANE TECHNICAL PAPER NO. 410.

JBM DATE 12-8-82
CHKD. BY J.E.Y. DATE 12-8-82
LJF 6-1-83

AMERICAN ELECTRIC POWER
D.C. COOK UNITS 1 & 2
LOSSES IN REDUCERS

SHEET NO. 1 OF 1
PROJ. NO. 5364



IF: $\theta \leq 45^\circ$

FORWARD LOSS COEFFICIENTS

$$K = 0.8 (\sin \frac{\theta}{2}) (1 - \beta^2)$$

REVERSE LOSS COEFFICIENTS

$$K = 2.6 (\sin \frac{\theta}{2}) (1 - \beta^2)^2$$

SIZE	d_1	d_2	β	θ	K, FORWARD	K, REVERSE
12" SCH 40 x 6" SCH 40S	6.065"	11.938"	.5080	10.3°	.2045	.4930
6" SCH 40S x 4" SCH 40S	4.026"	6.065"	.6638	21°	.0815	.1483
4" SCH 40S x 3" SCH 40	3.068"	4.026"	.7620	13.66°	.0399	.0544
3" SCH 160 x 4" SCH 160	2.624"	3.624"	.7241	14.25°	.0472	.0730
4" SCH 120 x 6" SCH 160	3.624"	5.189"	.6984	16.19°	.0577	.0961
6" SCH 40S x 3" SCH 40	3.068"	6.065"	.5659	30.48°	.1565	.3784

REFERENCE: CRANE TECHNICAL PAPER 410 p. A-26

K IS TAKEN WITH RESPECT TO THE SMALLER DIAMETER PIPE.

TELEDYNE ENGINEERING SERVICES

CMH DATE 5-21-83
CHKD. BY ~~SG~~ DATE 5-24-83

NON-CONDENSIBLE GAS QUALITY
CALCULATION FOR INITIAL COND.
UNITS 1/2

SHEET NO. 1 OF 1
PROJ. NO. 5364

FOR INITIAL CONDITIONS OF:

$$P_f = 17.7 \text{ PSIA}$$

$$T = 1200^{\circ} \text{ F} \quad P_v = 1.6924 \text{ PSIA}$$

SPECIFIC HUMIDITY

$$\gamma = \frac{M_w}{M_a} = \frac{\text{MASS OF WATER VAPOR}}{\text{MASS OF AIR}} = \frac{V_w}{V_a}$$

$$\gamma = \frac{R_a T / P_a}{R_w T / P_w} = 0.622 \frac{P_w}{P_a}$$

$$\gamma = 0.622 \frac{1.6924 \text{ PSIA}}{16.008 \text{ PSIA}}$$

$$\gamma = 0.06576$$

$$\text{NONCONDENSABLE GAS(AIR) QUALITY} = 1 - \gamma = 0.93424$$

CLM DATE 7-14-83
CHKD. BY LBS DATE 7-14-83

UNIT 1 TEMPERATURE
DISTRIBUTION SV 4100

SHEET NO. 1 OF 5
PROJ. NO. 5364

THE FOLLOWING TEMPERATURE DISTRIBUTION (PAGE 5 OF 5) IS EXTRACTED FROM THE RELAP RUN FOR STRUCTURAL PURPOSES. THE PRECEDING PLOTS (1-3) SHOW TEMPERATURE VERSUS TIME AT SOME POINTS ON THE DISCHARGE TO CONFER THE TIME AT WHICH MAXIMUM TEMPERATURE VALUES OCCURRED. THAT TIME WAS USED TO ESTIMATE MAXIMUMS FOR ALL OTHER POINTS ON THE DISCHARGE PIPING YIELDING THE VALUES ON PAGE 4.

THE FOLLOWING CONDITIONS APPLY TO THESE TEMPERATURES:

1. THESE ARE STEAM TEMPERATURES NOT PIPE WALL TEMPERATURES.
2. THE PIPE WALL TEMPERATURES WILL LAG THESE TEMPS. BY SEVERAL SECONDS.
3. THE PIPE WALL TEMPS MAY EQUAL THE STEAM TEMPS. IN MAGNITUDE BUT WILL NEVER EXCEED THESE TEMPS.
4. THE RELAP ANALYSIS ASSUMED THE PIPE WALL TO BE ADIASTATIC THEREFORE THESE STEAM TEMPS. REPRESENT CONSERVATIVE UPPER BOUND.


Technical Report
TR-5364-3
Revision 0

TELEDYNE ENGINEERING SERVICES

BY KJB DATE 6-30-83
CHKD. BY CMW DATE 7-13-83

UNIT 1 SV MODIFICATION
TEMP DISTRIBUTION

SHEET NO. 2 OF 5
PROJ. NO. 5364



Technical Report
TR-5364-3
Revision 0


4-175

TELEDYNE ENGINEERING SERVICES

KTG DATE 6-30-83
CHKD. BY CMM DATE 7-13-83

UNIT I SV MODIFICATION
TEMP DISTRIBUTION


SHEET NO. 3 OF 5
PROJ. NO. 5364



CMM DATE 6-29-83
CHKD. BY KJG DATE 6-30-83

UNIT 5V MODIFICATION
TEMP. DISTRIBUTION

SHEET NO. 4 OF 5
PROJ. NO. 5364



TELEDYNE ENGINEERING SERVICES

CMY DATE 6-29-83
CHKD. BY KTG DATE 7-6-83


UNIT MODIFICATION SV
TEMP DISTRIBUTION.

SHEET NO. 5 OF 5.
PROJ. NO. 5364

THE PRECEDING PLOT SETS DETERMINED THE 400 MSEC DATA POINT AS THE OCCURANCE OF PEAK TEMPERATURES

NODE POINT	RELAPS CONTROL VOLUME	EQUILIBRIUM TEMP. (OF) EXTRACTED FROM RUN @ 400 MSEC ID=BHFRIFK
234	30509	671.60
225	30901	464.08
208	30715	444.72
174	20510	671.59
165	20701	466.90
146	20719	445.98
126	10509	671.60
115	10701	467.99
102	10721	447.27
525	41101	923.21 *
550	41112	566.63
625	61101	923.45 *
385	51101	959.93 *
355	51112	815.89 *
320	51505	495.24
285	70302	453.60
200	80101	451.63
84	81119	440.23
60	81158	428.34
46	81180	422.39
33	81195	413.89
18	81311	406.31
1	81326	393.78

* THESE TEMPS APPRESENT THE EFFECT OF ADIABATIC COMPRESSION OF THE N₂ IN THE DISCHARGE LINE WHICH IS TRAPPED AGAINST THE CLOSED PORV'S. THE RELAP'S PROGRAM DOES NOT ADEQUATELY REPRESENT THE MIXING BETWEEN THE STEAM AND N₂ AT THESE POINTS THEREFORE THIS IS AN UPPER BOUND OF THE ACTUAL TEMPERATURE. IN THE PHYSICAL SYSTEM MORE MIXING WOULD OCCUR AND THESE TEMPERATURES WOULD BE QUICKLY DISSIPATED.



PIPE SIZE	PIPE SCHEDULE	FLOW AREA (FT ²)
3"	40	.0513
3"	160	.0376
4"	40	.0884
4"	120	.0716
8"	40	.2007
6"	160	.1465
12"	40	.7771

PRC
APERTU
CARD

8312210225-01

REV	DATE	D.C.O.	ZONE	DESCRIPTION	DRAWN	CHKD	ANAL	ENGR	DWG. CON.
REVISIONS									
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOLERANCES ON FRACTIONS DECIMALS ANGLES ± ± ±				DESIGNED	DATE	 TELEDYNE ENGINEERING SERVICES WALTHAM, MASS.			
				DRAWN <i>G, K</i>	7.12.83				
				CHECKED <i>CYM</i>	7.13.83				
				ANALYZED <i>KJG</i>	7-13-83	TITLE <i>RELAP MODEL-SV</i>			
				ENGR APPR. <i>LBS</i>	7-13-83	<i>DISCHARGE - DRAINED</i>			
FINISH <i>✓</i>				DWG. CON. <i>SOL</i>	7-14-83	<i>LOOPSEAL MOD.</i>			
SCALE						<i>D.C. COOK NUC. POWER PLANT UNIT 1</i>			
USED ON/NEXT ASSY						PROJECT NO	DRAWING NO	REV	
						<i>5364</i>	<i>E -8596</i>	<i>O</i>	

