

ACCESSION NO: 05000315 DOC DATE: 86/01/29 NOTARIFIED: NO DCKET
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316
 AUTH. NAME AUTHOR AFFILIATION
 ALEXICH, M. P. Indiana & Michigan Electric Co.
 RECIP. NAME RECIPIENT AFFILIATION
 DENTON, H. R. Office of Nuclear Reactor Regulation, Director (post 851125)

SUBJECT: Forwards Rev 1 to WCAP-10230, "Evaluation of Acceptability of Reactor Vessel Head Life Rig, ... to Requirements of NUREG-0612..." & requests relief from requirements of NUREG-0612 Table 3.1-1 re load block.

SEE SUBJECT FILE FOR ENCLOSURE

DISTRIBUTION CODE: A033D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 7+168
 TITLE: OR Submittal: USI A-36 Control of Heavy Load Near Spent Fuel-NUREG-06

NOTES: 05000315
 OL: 10/25/74 05000316
 OL: 12/23/72

RECIPIENT		COPIES		RECIPIENT		COPIES	
ID CODE/NAME		LTTR	ENCL	ID CODE/NAME		LTTR	ENCL
PWR-A PD4 PD		5	1*	NRR SINGH, A 01		4	1*
WIGGINGTON, D		1	1*				
INTERNAL: ACRS	13	6	1	ADM/LFMB		1	1
NRR BWR ADTS		1	1	NRR NEIGHBORS09		1	1
NRR PWR-A ADTS		1	1	NRR PWR-B ADTS		1	1
NRR/DRAS	12	1	1	NRR/TAMB		1	1
<u>REG FILE</u>	04	1	1*	RGN3		1	1
EXTERNAL: 24X		1	1*	LPDR	03	2	2*
NRC PDR	02	1	1*	NSIC	06	1	1*

Add: EB(Ballard)* * - w/Encl
 RSB(Berlinger)* Limited Dist
 PSB(Gammil)*

10 Encl

1000

БЗВ (С. 1000) *

БЗВ (С. 1000) *

1000

БЗВ: БЗВ (С. 1000) *

1000

1000

1000

1000

INDIANA & MICHIGAN ELECTRIC COMPANY

P.O. BOX 16631
COLUMBUS, OHIO 43216

January 29, 1986
AEP:NRC:0514N

Donald C. Cook Nuclear Plant Nos. 1 and 2
Docket Nos. 50-315 and 50-316
License Nos. DPR-58 and DPR-74
NUREG-0612, "CONTROL OF HEAVY LOADS"
ADDITIONAL INFORMATION

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Reference: Letter No. AEP:NRC:0514M, dated September 11, 1985.

Dear Mr. Denton:

Pursuant to a request made by members of your staff, this letter and its attachments are being submitted in order to clarify the intent of the above-referenced letter, in which we modified Table 2.1.3.c.1 to restrict movement of the crane load block over the spent fuel pool only when the main hoist is deenergized. The second item of this submittal corrects a discrepancy in our Phase II submittal. The third item addresses and transmits the Revision 1 to WCAP-10230 that was noted in the above-referenced letter.

We request relief from the requirement of NUREG-0612 Table 3.1-1, Footnote 1, which states that the load block should be considered a heavy load even if it is not carrying a load. As an alternative requirement, we propose that whenever load-handling activities are being performed over, or adjacent to, the spent fuel pool utilizing the auxiliary hook, the main load block will be deenergized and unloaded. The word "adjacent" refers to the area between the designated load path and the edge of the spent fuel pool.

Some of the typical load-handling activities that are currently being performed using the auxiliary hook are listed below.

8602060195 860129
PDR ADOCK 05000315
P PDR

A-093
11

Add: EB (Ballard)
RSB (Berlinger)
RSB (Gammil)



Handwritten marks and characters in the top right corner.

Faint, illegible text or markings in the upper left area.

Faint, illegible text or markings in the upper center area.

Faint, illegible text or markings in the middle right area.

Faint, illegible text or markings in the middle right area, lower down.

Large block of extremely faint, illegible text or markings covering the lower middle section of the page.

Faint, illegible text or markings at the bottom center of the page.

<u>Activity Using the Auxiliary Hook</u>	<u>Position of the Main Hook</u>
1) Loading the new fuel using the auxiliary hook.	Main hook will be unloaded and will travel close to the edge or over the spent fuel pool. Electrical interlocks must be bypassed.
2) Maintenance activities on the weir gate which separates the transfer canal and spent fuel pool.	Main hook will be unloaded and will travel close to the edge or over the spent fuel pool. Electrical interlocks must be bypassed.
3) Relamping of the ceiling above spent fuel pool using the trolley.	Both hooks will be unloaded and will be over the spent fuel pool. Electrical interlocks must be bypassed.
4) Maintenance work while carrying components from the Unit No. 1 equipment room located in the N-W corner of the pool area using the auxiliary hook.	Main hook will be unloaded and will travel close to the edge or over the spent fuel pool. Electrical interlocks must be bypassed.
5) Removing/installing the spent fuel handling tools which are stored inside the spent fuel pool (along the wall).	Main hook will be unloaded and will travel over the spent fuel pool. Electrical interlocks must be bypassed.
6) Installation of the superstructure of the new and spent fuel pool (N&SFP) crane prior to its usage. The installation is done using the auxiliary hook.	Main hook will be unloaded and will travel close to the edge of the spent fuel pool. Electrical interlocks must be bypassed.
7) Checking the hoist height interlock limit switches of N&SFP crane with a man-lift attached to the auxiliary hook.	Main hook will be unloaded and will travel close to the edge of the pool. Electrical interlocks must be bypassed.

In earlier conversations with your staff, we identified five activities that involve moving the load block over the spent fuel pool. We subsequently identified two additional activities. These are designated as items (6) and (7) above.

When the main hoist is deenergized and there are no loads on the main hook, the load block will be a passive component of the trolley rather than an active component and will be an integral part of the crane. We believe that our procedures will meet the intent of NUREG-0612. Upon receiving NRC approval, we will be revising the plant procedures to deenergize the main hoist prior to the trolley being moved over the spent fuel pool. The area of the spent fuel pool is defined as that area of the pool which contains the spent fuel racks.

The attachment to this letter contains Table 2.1.3.c.1, which includes the above clarification in the footnote for the load block, i.e., the main hook not carrying any load for the case when the main hoist is deenergized. This table supersedes the version of Table 2.1.3.c.1 submitted to your office with the above-referenced letter. For your convenience, the revisions to the table are noted by a vertical line in the right-hand margin.

The second item serves to correct a discrepancy in one of the Phase II submittals. In the Phase I submittal (AEP:NRC:0514C), dated June 18, 1982, we committed that the "...Component specific safe load paths remain within the indicated load handling area and are based on the general concept of handling heavy loads as close to the operating floor as is feasible, in order to minimize the potential load drop impact energy, and with the maximum possible horizontal separation from the spent fuel." The Safety Evaluation Report (SER) for Phase I issued by the NRC, dated September 20, 1983, approved the above criterion as consistent with the requirements of Guideline 1 of NUREG-0612.

The NRC SER, dated June 28, 1985, issued for the Phase II of the Control of Heavy Loads at Nuclear Power Plants noted in part that "Based on the improvements in heavy loads handling obtained from implementation of NUREG-0612 (Phase I), further action is not required to reduce the risks associated with the handling of heavy loads (See enclosed NUREG-0612 Phase II). Therefore, a detailed Phase II review of heavy loads is not necessary and Phase II is considered completed. However, while not a requirement, we encourage the implementation of any actions you identified in Phase II regarding the handling of heavy loads that you consider appropriate."

Currently we are performing a review of all our Phase II submittals to identify the action items, and in that process we have identified a discrepancy. In our submittal AEP:NRC:0514A, dated August 27, 1982, we committed to maintain a 15.0-foot horizontal separation from the pool, as per NUREG-0612 guidelines for movement of heavy loads near the spent fuel pool using the Auxiliary Building Crane. This was a discrepancy in our submittal, which we would like to correct. Based on our Phase I commitment of maximum horizontal separation, the maximum separation we can maintain is 9'-10½" on the south side and 5'-7" on the west side. The drawing showing the load path was submitted to your office as an attachment to letter AEP:NRC:0514C. It is being resubmitted for clarification.

As a third item, we are transmitting Revision 1 to WCAP-10230, which was received from Westinghouse Electric Corporation. The major revision to the report is due to using the correct weight of the reactor internals, which was changed from 260,000 lbs. to 325,000 lbs. In accordance with the Westinghouse conclusion, three specific items do not meet the design criteria of Section 3.2.1.1 of ANSI 14.6 requiring application of stress design factors of three and five with the accompanying allowable stress limits of yield and ultimate, respectively. However, all three items meet the AISC Code allowable limits and thus are considered acceptable. It should be noted that during this load handling sequence, all the fuel has been removed from the core and the containment building. We therefore

The first part of the document discusses the general situation of the country and the role of the government. It mentions the need for a strong and stable government to ensure the development and progress of the nation. The text emphasizes the importance of maintaining law and order and promoting economic growth.

In the second part, the author talks about the social and cultural aspects of the country. It highlights the need for a united and harmonious society where all citizens are treated equally. The text also mentions the importance of education and the role of the family in shaping the character of the young generation.

The third part of the document focuses on the economic development of the country. It discusses the various challenges faced by the economy and the need for a comprehensive economic policy. The text mentions the importance of investing in infrastructure and promoting small and medium-sized enterprises.


In the fourth part, the author talks about the international relations of the country. It mentions the need for a peaceful and cooperative international environment. The text also discusses the role of the country in the global community and the importance of maintaining friendly relations with all nations.

The final part of the document is a conclusion. It summarizes the main points discussed in the previous sections and reiterates the author's vision for the future of the country. The text ends with a call to action for all citizens to work together for the betterment of the nation.

agree with the Westinghouse conclusion that the lift equipment is acceptable for use. The other corrections are considered minor and will not alter the content of the report significantly. Three copies of the WCAP report are attached.

This document has been prepared following Corporate procedures which incorporate a reasonable set of controls to insure its accuracy and completeness prior to signature by the undersigned.

Very truly yours,


M. P. Alexich ⁹⁸⁵
Vice President 11/27/86

cm

Attachments

cc: John E. Dolan
W. G. Smith, Jr. - Bridgman
R. C. Callen
G. Bruchmann
G. Charnoff
NRC Resident Inspector - Bridgman

The first part of the report deals with the general situation in the country. It is noted that the economy is showing signs of recovery, but that there are still many difficulties. The government is working to improve the situation and to provide for the needs of the people.

CONCLUSION

It is hoped that the measures taken by the government will lead to a more stable and prosperous future for the country.

The second part of the report deals with the specific measures being taken by the government. It is noted that the government is working to improve the situation in the rural areas, to provide for the needs of the people, and to improve the economy.


TABLE 2.1.3.C.1
SURVEY OF HEAVY LOADS*
AEP:NRC:0514C

AREA	CRANE A = AUX. BLDG. CRANE FHC = NEW & SPENT FUEL HANDLING CRANE	LOADS HANDLED	OVER (O) OR ONLY PROXIMITY (P) TO SPENT FUEL	APPROXIMATE WEIGHT	FREQUENCY HANDLED	LIFTING DEVICE	HANDLING PROCEDURE
AUXILIARY BUILDING	A	1. Spent Fuel Shipping Cask	(P)	110 Tons	(Future)	(Future)	(Future)
	A	2. Radiation Protection Shields	(P)	55 Tons	As required during refueling outages	Slings	12 MHP 5021.001.036
	A	3. Irradiated Specimen Shipping Cask	(P)	1-2 Tons	8 times in 20 yrs. (2 Units)	Slings	12 MHP-SP-006
	A	4. Plant Equipment (e.g. pumps, motors, valves, heat exchangers)	(P)	Max 4 Tons	As required for Mod- ification or replace- ment	Slings	12 MHP 5001.001.036
	A	5. New Fuel Shipping Containers with Assembly	(P)	1-1/2 Tons	50/year	Slings	12 MHP 4050 FDF .001 12 MHP 4050 FDF .002
	FHC	6. Spent Fuel Assembly	(O)	1850#/1890#	100-150 per refueling	Handling Tool	12 MHP 4050 FDF .008
	A	7a. Crane Load Block	(P)	4.25 T	Integral to Crane	Crane Ropes	12 MHP 4050 FDF .011
		7b. Crane Load Block	(O)†	4.25 T	Integral to Crane	Crane Ropes	12 MHP 5021.082.020 12 MHP 5021.001.036
	A & FHC	8. New Fuel Assembly	(P)	1850#/ 1890#**	100-150 per refueling	Handling Tool	12 MHP 4050 FDF .008
	A	9. Superstructure New & Spent Fuel Handling Crane	(P)	25 Tons	Approx. every 18 mos.	Slings	Instruction Book #105671 Dwight Foote, Inc. 12 MHP 5021.001.032
	A	10. Equipment Hatch	(P)	45 Tons	As required during refueling	Slings	12 MHP 5021.001.036
	A	11. Reactor Coolant Pump Rotating Assembly	(P)	28 Tons	As required during Maintenance	Slings	12 MHP 5021.001.036
	A	12. Reactor Coolant Pump Motor	(P)	38 Tons	As required during Maintenance	Slings	12 MHP 5021.001.036
	A	13. LSA Waste Boxes	(P)	2 Tons	52/year	Slings	12 MHP 5021.001.036
	A	14. Waste Container Metal Bin	(P)	2 Tons	52/year	Slings	12 MHP 5021.001.036
	A	15. Glycol Tank	(P)	5 Tons	12/year	Slings	12 MHP 5021.001.036
A	16. Reactor Stud Rack (12 Studs/Rack)	(P)	4-5 Tons	4/year	Slings	12 MHP 5021.001.036	

* Heavy loads are defined as "any load, carried in a given area after a plant becomes operational, that weighs more than the combined weight of a single spent fuel assembly and its associated handling tool for the specific plant in question."

** Unit No. 1 1850#, Unit No. 2 1890#

† The load block is over or adjacent to the pool; with main hoist deenergized and no load on the Main Hook



ITEM NO.	DESCRIPTION
1	STEAM GENERATOR
2	REACTOR COOLANT PUMP ACCUMULATOR
3	REGENERATIVE HEAT EXCHANGER
4	EXCESS LET-DOWN HEAT EXCHANGER
5	SEAL TABLE
6	PRESSURIZER RELIEF TANK
7	INSTRUMENTATION ROOM PURGE SYS.
8	REFUELING EQUIPMENT
9	SEC. CHAMBER, FIGURE
10	VESEL FLS. PROTECTION RING IT FLOOD STOP
11	REACTOR UPPER INTERNALS STORAGE
12	REACTOR LOWER INTERNALS STORAGE
13	VENTILATING UNIT
14	BLOWER
15	PERSONNEL LOCK
16	FUEL TRANSFER SYSTEM
17	CVCS MIXED BED DEMINERALIZER
18	CVCS MIXED BED DEMINERALIZER
19	B.A. EVAPORATOR FEED ION EXCHANGER
20	B.A. EVAPORATOR CONDENSATE DEMIN.
21	DEBORATING DEMINERALIZER
22	CVCS CATION BED DEMINERALIZER
23	DRY CLEANER MACHINE ROOM
24	SPENT FUEL PIT DEMINERALIZER
25	CONDENSATE HEAT EXCHANGER
26	RESIDUAL HEAT EXCHANGER
27	BLOWDOWN HEAT EXCHANGER
28	BODIUM INJECTION TANK
29	VOLUME CONTROL TANK
30	SEAL WATER HEAT EXCHANGER
31	WASTE GAS COMPRESSORS
32	CONCENTRATE HOLDING TANK
33	CONCENTRATE HOLDING TANK
34	DORIC ACID BATCHING TANK
35	COMPONENT COOLING HEAT EXCHANGER
36	MONTHLY TANKS
37	PLANT AIR RECEIVER
38	PLANT AIR AFTERCOOLER
39	PLANT AIR COMPRESSOR
40	CONTROL AIR DEHUMIDIFIER
41	CONTROL AIR RECEIVERS
42	CONTROL AIR AFTERCOOLER
43	CONTROL AIR COMPRESSOR
44	COMPONENT COOLING PUMPS
45	BLOWDOWN PURIFICATION DEMIN.
46	SPENT FUEL PIT FILTER
47	SPENT FUEL PIT SKIMMER FILTER
48	SPENT FUEL PIT SKIMMER PUMP
49	SPENT FUEL PIT HEAT EXCHANGERS
50	SPENT FUEL PIT PUMPS
51	HEAD LIFTING DEVICE SYS. AREA
52	CASK
53	CASK HEAD
54	CASK LIFTING DEVICE SYS. AREA
55	ELEC. PILASTERS
56	VESTIBULE EL. 612'-0"
57	EXTERIOR PIPEWAY
58	NON-ESSENTIAL SERVICE WATER CONTROL ISOLATION VALVE AREA
59	PIPE CHASE
60	ALTEREX CABINET
61	RECTIFIER CUBICLE
62	ESS SERV. WTR. PIPE CHASE, WITH MISCELL. PROTECTION BARRIER
63	ENV. CONDENSATE FILTER
64	LOCAL SHUTDOWN PIPING PANS
65	CASK DROP PROTECTION SYSTEM
66	EQUIPMENT HATCH OPENING 26'-60"
67	EQUIPMENT HATCH

NOTE: 1/2, 3/4
FLOOR ATTACHMENTS FOR L.P. ROTOR UP-LIFTING DEVICE TO BE ADDED IN THE TRACK BAY

NO.	REVISIONS	DATE	BY	CHKD.
1	GENERAL REVISION	12/15/66	J.E. Dolan	
2	GENERAL REVISION	12/15/66	J.E. Dolan	
3	GENERAL REVISION	12/15/66	J.E. Dolan	
4	GENERAL REVISION	12/15/66	J.E. Dolan	
5	GENERAL REVISION	12/15/66	J.E. Dolan	
6	GENERAL REVISION	12/15/66	J.E. Dolan	
7	GENERAL REVISION	12/15/66	J.E. Dolan	
8	GENERAL REVISION	12/15/66	J.E. Dolan	
9	GENERAL REVISION	12/15/66	J.E. Dolan	
10	GENERAL REVISION	12/15/66	J.E. Dolan	
11	GENERAL REVISION	12/15/66	J.E. Dolan	
12	GENERAL REVISION	12/15/66	J.E. Dolan	
13	GENERAL REVISION	12/15/66	J.E. Dolan	
14	GENERAL REVISION	12/15/66	J.E. Dolan	
15	GENERAL REVISION	12/15/66	J.E. Dolan	
16	GENERAL REVISION	12/15/66	J.E. Dolan	
17	GENERAL REVISION	12/15/66	J.E. Dolan	
18	GENERAL REVISION	12/15/66	J.E. Dolan	
19	GENERAL REVISION	12/15/66	J.E. Dolan	
20	GENERAL REVISION	12/15/66	J.E. Dolan	
21	GENERAL REVISION	12/15/66	J.E. Dolan	
22	GENERAL REVISION	12/15/66	J.E. Dolan	
23	GENERAL REVISION	12/15/66	J.E. Dolan	
24	GENERAL REVISION	12/15/66	J.E. Dolan	
25	GENERAL REVISION	12/15/66	J.E. Dolan	
26	GENERAL REVISION	12/15/66	J.E. Dolan	
27	GENERAL REVISION	12/15/66	J.E. Dolan	
28	GENERAL REVISION	12/15/66	J.E. Dolan	
29	GENERAL REVISION	12/15/66	J.E. Dolan	
30	GENERAL REVISION	12/15/66	J.E. Dolan	
31	GENERAL REVISION	12/15/66	J.E. Dolan	
32	GENERAL REVISION	12/15/66	J.E. Dolan	
33	GENERAL REVISION	12/15/66	J.E. Dolan	
34	GENERAL REVISION	12/15/66	J.E. Dolan	
35	GENERAL REVISION	12/15/66	J.E. Dolan	
36	GENERAL REVISION	12/15/66	J.E. Dolan	
37	GENERAL REVISION	12/15/66	J.E. Dolan	
38	GENERAL REVISION	12/15/66	J.E. Dolan	
39	GENERAL REVISION	12/15/66	J.E. Dolan	
40	GENERAL REVISION	12/15/66	J.E. Dolan	
41	GENERAL REVISION	12/15/66	J.E. Dolan	
42	GENERAL REVISION	12/15/66	J.E. Dolan	
43	GENERAL REVISION	12/15/66	J.E. Dolan	
44	GENERAL REVISION	12/15/66	J.E. Dolan	
45	GENERAL REVISION	12/15/66	J.E. Dolan	
46	GENERAL REVISION	12/15/66	J.E. Dolan	
47	GENERAL REVISION	12/15/66	J.E. Dolan	
48	GENERAL REVISION	12/15/66	J.E. Dolan	
49	GENERAL REVISION	12/15/66	J.E. Dolan	
50	GENERAL REVISION	12/15/66	J.E. Dolan	
51	GENERAL REVISION	12/15/66	J.E. Dolan	
52	GENERAL REVISION	12/15/66	J.E. Dolan	
53	GENERAL REVISION	12/15/66	J.E. Dolan	
54	GENERAL REVISION	12/15/66	J.E. Dolan	
55	GENERAL REVISION	12/15/66	J.E. Dolan	
56	GENERAL REVISION	12/15/66	J.E. Dolan	
57	GENERAL REVISION	12/15/66	J.E. Dolan	
58	GENERAL REVISION	12/15/66	J.E. Dolan	
59	GENERAL REVISION	12/15/66	J.E. Dolan	
60	GENERAL REVISION	12/15/66	J.E. Dolan	
61	GENERAL REVISION	12/15/66	J.E. Dolan	
62	GENERAL REVISION	12/15/66	J.E. Dolan	
63	GENERAL REVISION	12/15/66	J.E. Dolan	
64	GENERAL REVISION	12/15/66	J.E. Dolan	
65	GENERAL REVISION	12/15/66	J.E. Dolan	
66	GENERAL REVISION	12/15/66	J.E. Dolan	
67	GENERAL REVISION	12/15/66	J.E. Dolan	

INDIANA & MICHIGAN ELECTRIC CO.
DONALD C. COOK
NUCLEAR PLANT

BRIDGMAN MICHIGAN

PLANT ARRANGEMENT
MEZZANINE FLOOR EL. 609'-0"
UNITS 1 & 2

DR. NO. 12-5168-6

AREA: 100' x 100' (approx)
DATE: 12/15/66
BY: J.E. Dolan
CHKD: [Signature]

AMERICAN ELECTRIC POWER SERVICE CORP.
2 BROADWAY NEW YORK

TI
APERTURE
CARD

Also Available On
Aperture Card

8602060195-01

