

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9603110426 DOC.DATE: 96/02/28 NOTARIZED: NO DOCKET #
FACIL:50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana M 05000315
50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana M 05000316
AUTH.NAME AUTHOR AFFILIATION
FITZPATRICK,E. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
RECIP.NAME RECIPIENT AFFILIATION
Document Control. Branch (Document Control Desk)

SUBJECT: Forwards "DC Cook Nuclear Plant 1995 Annual Operating Rept," ^{See} including summary of SG inservice insp results & SG insps & ^{Reports} repairs performed during 1995.

DISTRIBUTION CODE: IE47D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 3+500
TITLE: 50.59 Annual Report of Changes, Tests or Experiments Made W/out Approv

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	PD3-1 PD	1 0	HICKMAN,J	1 1
INTERNAL:	<u>ELLE CENTER</u>	1 1	RGN3 FILE 01	1 1
EXTERNAL:	NOAC	1 1	NRC PDR	1 1

NOTE TO ALL "RIDS" RECIPIENTS:
PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
ROOM OWFN SD-5 (EXT. 415-2083) TO ELIMINATE YOUR NAME FROM
DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 6 ENCL 5

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T



Indiana Michigan
Power Company
P.O. Box 16631
Columbus, OH 43216



February 28, 1996

AEP:NRC:1147F

Docket Nos. 50-315
50-316

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Donald C. Cook Nuclear Plant Units 1 and 2
1995 ANNUAL OPERATING REPORT

Paragraph 6.9.1.5 of the Donald C. Cook Nuclear Plant Technical Specifications requires that an annual report be submitted to address personnel exposure, steam generator in-service inspection results, challenges to power-operated relief and safety valves, and information regarding I-131 reactor coolant activity. In addition, 10 CFR 50.59(b)(2) requires submittal of an annual report describing changes, tests, and experiments made in the preceding year. Consistent with these requirements, a copy of the Cook Nuclear Plant 1995 Annual Operating Report is contained in attachments 1 and 2. Attachment 1 contains only a summary of the steam generator in-service inspection results, while attachment 2 provides further details of the steam generator tube inspections and repairs that were performed in 1995.

We would like to correct the Annual Operating Report for 1994. On page 14, in Table 2 reporting the annual exposures the values listed in the "Grand Total" line were in error. The correct values are as follows.

	<u># Personnel > 100mR</u>			<u>Total Person Rem</u>		
	Stat.	Util.	Cont.	Stat.	Util.	Cont.
Grand Total	0242	0006	0740	104.142	001.536	328.639

060028

9603110426 960228
PDR ADOCK 05000315
R PDR

JEH



11-11-11

There were no safety concerns with this error. The error was created during the preparation of the 1994 Annual Operating Report and the data was not used for the operation of the plant.

Sincerely,

for 
E. E. Fitzpatrick
Vice President

eh

Attachments

cc: A. A. Blind - Bridgman
J. R. Padgett
G. Charnoff
NFEM Section Chief
H. J. Miller - Region III
NRC Resident Inspector - Bridgman

...9603110426

ATTACHMENT 1 TO AEP:NRC:1147F

DONALD C. COOK NUCLEAR PLANT

1995 ANNUAL OPERATING REPORT

MAIN REPORT

