CATEGORY 2

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

FACIL:5	0-315 Donald C. Co 0-316 Donald C. Co	ook Nuclear Po ook Nuclear Po	8/07/15 NOTARIZEI wer Plant, Unit 1, wer Plant, Unit 2,	Indiana M	DOCKET # 05000315 05000316
BURGESS	,B.L. Region 3 NAME RECIPIE	AFFILIATION (Post 820201 ENT AFFILIATIO LELectric Pow	N	. See	Meeting Summaries
				_	, C
SUBJECT	resolving issues	necessary fo	ting w/util re pro r startup.Summary t of attendees end	version of	rd . A
				,	72 T
DISTRIB	UTION CODE: IE45D Summary of Signifi	COPIES RECEI cant Meeting	VED:LTR <u></u> ENCL _ with Licensee (Par	t 50)	· E
NOTES:			•		G
-	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENC	o L
•		1 1	STANG, J	1 1	R
INTERNAL:	DEDRO NRR/DRPM/PERB RES/DET/EIB	1 1 1 1 1 1 1	EILE GENTER OGC/ROED RGN3 FILE 01	1 1 1 1 1 1	¥
	KES/DEI/EIB	. . ,	RGRS FIRE OF	<u> </u>	2
EXTERNAL:	NOAC	1 1	NRC PDR	1 1	•

NOTE TO ALL "RIDS" RECIPIENTS:
PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

JAR;

N

T



UNITED STATES NUCLEAR REGULATORY COMMISSION

REGION III 801 WARRENVILLE ROAD LISLE, ILLINOIS 60532-4351

July 15, 1998

Mr. John Sampson Site Vice President Nuclear Generation Group American Electric Power Company 500 Circle Drive Buchanan, MI 49107-1395

SUBJECT:

SUMMARY OF THE JULY 9, 1998, PUBLIC MEETING TO DISCUSS D. C. COOK

RESTART ACTIVITIES

Dear Mr. Sampson:

This letter refers to a meeting held between the NRC and Donald C. Cook plant staff to discuss your progress toward resolving those issues necessary for plant startup conducted on July 9, 1998. This meeting was open to public observation. The meeting started with a presentation of the restart plan master schedule. You indicated that changes may be necessary to the master schedule as lower tier schedules are finalized or as additional information is received from restart plant activities. The NRC requested a complete set of schedules when available. A summary version of the restart plan master schedule is contained in Enclosure 2 to this letter.



During the meeting, your staff discussed the status of the startup plan and reiterated that the discovery phase or Phase 1 of the restart plan is complete. This phase involved system readiness reviews of 21 safety systems and programmatic and functional assessments of selected areas, including corrective action, design, design change impact, operations, and maintenance. The results of functional and area assessments continue to be reviewed by the Restart Oversight Committee for determination of plant restart items.

The status of Phase 2 of the restart plan was discussed. Phase 2 consists of the actual work activities needed for plant restart. To date, approximately 447 items have been assessed as restart issues, with additional items expected from the completion of the functional and programmatic assessments. During the meeting, a new aspect of the restart plan was introduced as Phase 3. Phase 3 involves a compilation of all of the documentation generated by the completion of activities performed to close a restart issue. Your staff indicated that restart closure packages will be contained in a central file location that will provide access for inspection and review activities. Phase 4 has now been designated for those activities that comprise actual plant startup.

D. C. Cook licensing and engineering personnel also discussed those activities requiring NRC licensing or review prior to plant restart. To date, only two items involved Technical Specification amendments. These amendments involved wording changes to the specification for the hydrogen recombiners and the reinstatement of the specifications for the boric acid concentration reduction initiative. Both amendments have been submitted for NRC review. Other issues discussed that may involve Technical Specification amendments include diesel generator cable routing, containment spray pump vibration, containment sump pH, and reanalysis of containment post accident conditions, including hydrogen analysis by Westinghouse.

220069

9807220151 980715 PDR ADDCK 05000315 P PDR

J. Sampson

A status of ice condenser work was also presented and the issues associated with the independent review of the containment spray system were also discussed. Your staff indicated that the use of operability evaluations performed in accordance with Generic Letter 91-18 or the completion of a 10 CFR 50.59 safety evaluation may be needed. The NRC requested and you committed to provide the NRC with documentation for any operability or safety evaluations completed prior to plant startup.

Enclosure 1 is a list of meeting attendees. Enclosure 2 contains the handout provided to the NRC during the meeting.

In accordance with 10 CFR 2.790 of the NRC's "Rules of Practice," a copy of this letter and its enclosures will be placed in the NRC Public Document Room.

Sincerely,

Bruce L. Burgess, Chief Reactor Projects Branch 6

Druce I Surger

Docket Nos.: 50-315; 50-316 License Nos.: DPR-58; DPR-74

Enclosures:

1. Meeting Attendees

2. Meeting Handout

cc w/encls:

Don Hafer, Acting Chief

Nuclear Engineer

Douglas Cooper, Plant Manager Richard Whale, Michigan Public

Service Commission
Michigan Department of
Environmental Quality
Emergency Management
Division, MI Department

of State Police

David A. Lochbaum, Union of Concerned Scientists

J. Sampson

A status of ice condenser work was also presented and the issues associated with the independent review of the containment spray system were also discussed. Your staff indicated that the use of operability evaluations performed in accordance with Generic Letter 91-18 or the completion of a 10 CFR 50.59 safety evaluation may be needed. The NRC requested and you committed to provide the NRC with documentation for any operability or safety evaluations completed prior to plant startup.

Enclosure 1 is a list of meeting attendees. Enclosure 2 contains the handout provided to the NRC during the meeting.

In accordance with 10 CFR 2.790 of the NRC's "Rules of Practice," a copy of this letter and its enclosures will be placed in the NRC Public Document Room.

Sincerely,

Original signed by

Bruce L. Burgess, Chief Reactor Projects Branch 6

Docket Nos.: 50-315; 50-316 License Nos.: DPR-58; DPR-74

Enclosures:

1. Meeting Attendees

2. Meeting Handout

cc w/encls:

Don Hafer, Acting Chief

Nuclear Engineer

Douglas Cooper, Plant Manager Richard Whale, Michigan Public

Service Commission
Michigan Department of
Environmental Quality
Emergency Management
Division, MI Department

of State Police

David A. Lochbaum, Union of Concerned Scientists

DOCUMENT NAME: G:\COOK\DCC07098.SUM


o receive a copy of this document, indicate in the box "C" = Copy w/o attach/enci "E" = Copy w/attach/enci "N" = No cop

		sex o - depy modules come to - depy management in - indeepy	
OFFICE	RIII	NRR v	
NAME	Burgess/mi	Bellamy////	
DATE	7/15/98	7/15/1989	

J. Sampson

Distribution:
RRB1 (E-Mail)
Project Mgr., NRR w/encls
C. Paperiello, Rill w/encls
J. Caldwell, RIII w/encls
B. Clayton, RIII w/encls
SRI DC Cook w/encls
DRP w/encls
TSS w/encls
DRS (2) w/encls
RIII PRR w/encls
PUBLIC IE-01 w/encls
Docket File w/encls
GREENS
IEO (E-Mail)

DOCDESK (E-Mail)



COOK NUCLEAR PLANT RESTART MEETING ATTENDANCE LIST JUNE 9, 1998

NRC

James Caldwell Ron Bellamy Bruce Burgess Bruce Bartlett Brian Fuller

PUBLIC

Joseph Gallo (Gallo and Ross) Dan Salter (HGP) Gene Poletto (DES)

AEP

Doug Cooper Steve Brewer Don Hafer Paul Barrett John Boesch Ken Baker Dave Powell Paul Schoepf Phil Gora Mark Ackerman Mark Kelly Jeremy Euto Tom Kratt Bill Schalk Jeb Kingseed **Gary Weber** Roger Rickman Bo Smith **Denny Willemin** Kathy McLaughlin


John Sampson

Mike Finissi
Doug Malin
Gordon Allen
Jim Tyler
John Schrader
Byron Bradley


Mark Mitch Gary Proulx Joel Gebbie Dan Boston



Bob Heathcote Jay Kovarik David Walker **Brent Auer** David Bublick Bart Benjamin Darryl Lynch Tim Schlimpert **Bob Smith Guy Tollas** Doug Burris Doug Mason Jack Rutkowski Wayne Walschof **Terry Postlewait** Steve DeLong Frank Pisarsky Scott Kelley Dave Kosonovich Richard Strasser Thomas Craven Rod Simms Mickey Bellville Keith Steinmetz Gordon Arent Tom Quaka



Maintenance:Rule:Risk Significant/System (sorted by risk)	Also SERB:	
significance)		
ESW .	X	
ccw	x	
RPS & ESFAS (counts as 2)	x	
RHR .	x	
EDG/EDGS	X	
OFFSITE POWER	Not reviewed	
AFW .	. x	
CTS	, x	
CONTROL AIR & PLANT AIR (counts as 2)	x	
250 VDC	x	
ACCUMULATORS	×	
sı	x	
RCS PRESSURE RELIEF	x	
CHARGING	· x	
4 kV	, x	
NESW	x	
120 VAC	x (also CRIDs)	
MAIN STEAM	x	
600 VAC	· x	
Not reviewed	AIR Recirc / Hydrogen Skimmers	
Not reviewed	Containment	
Not reviewed	Ice Condenser	



Restart Meeting

July 9, 1998.



AEP: America's Energy Partner




PRESENTATIONS

- Restart plan status (P. Gora)
- NRC submittals (M. Kelly)
- Ice condenser status (P. Schoepf)
- Containment spray status (D. Powell)
- Programmatic assessment
 - calculations (K. Baker)
- Functional area assessments
 - production engineering (K. Baker)
 - maintenance (J. Boesch)




RESTART PLAN STATUS

Phillip Gora




RESTART VISION

- •Develop the "right picture" for our people, programs, and plant
- •Leverage the lessons learned and values acquired during restart to succeed in the future
- •Instill a culture of individual accountability and teamwork for identifying and addressing problems
- •Perform the corrective and preventive maintenance activities and surveillances required to effectively operate the plant through the next fuel cycle
- •Develop a thorough understanding of the importance of maintaining and controlling our design and licensing basis
- •Maintain a healthy workforce that is committed to the future success of Cook Nuclear Plant
- •Make effective use of our financial and time resources





RESTART PROCESS



PHASE 1 - DISCOVERY

TYPICAL FUNCTIONAL AREA ASSESSMENT







PHASE 2 - RESTART WORK


ŗч

13





Total restart issues ·	447
Regulatory	3
Functional assessments	93
Programmatic assessments	15
System and containment assessments	336



Perform Restart Work

RESTART FOCUS ITEMS


- •Ice condenser
- •Containment spray
- •Cable issues




2.1 Restart Manager

Perform Restart Work

PHASE 2 - RESTART WORK









NRC SUBMITTALS

Mark L. Kelly Licensing Engineer



NRC SUBMITTALS

- Hydrogen recombiner
 - removes the term "immediately"
 - submitted March 3, 1998
- Boric acid concentration reduction
 - reinstates previous technical specifications
 - submitted June 10, 1998



NRC SUBMITTALS

- Surveillance interval extensions
 - steam generator eddy current testing
 - other surveillances
- Response to 2.206/50.54(f) letter
 - docketed revised submittal date
 - July 22, 1998

POTENTIAL SUBMITTALS

- Issues that may result in submittals
 - cable routing issues
 - containment spray pump vibration
 - · sump pH
 - hydrogen analysis
 - Westinghouse safety evaluation (SECL)

 Sably word Charle lish 50.55



ICE CONDENSER STATUS

Paul Schoepf
Mechanical Systems Manager

ICE CONDENSER STATUS

- History
- Scope


13

- Schedule logic
- Project status

HISTORY

ICE CONDENSER INSPECTION

- Surveillance program
- Maintenance program
- Design basis maintenance
- Corrective action



HISTORY


DECISION TO THAW

- Ice weights
- Basket integrity
 - basket damage
 - coupling screws
 - hold down bar welds
- Flow passages
- Debris

HISTORY


BROAD CORRECTIVE ACTION

- Thaw ice condenser
 - remove debris, inspect, repair, refurbish, refill
 - baseline materiel condition
 - baseline surveillances
- Reconstitute requirements and bases and incorporate into procedures and practices



BASKET COUPLING SCREWS

- Problem
 - missing or damaged screws
- Action
 - metallurgical evaluation
 - inspections and reinstallation
 - surveillance and maintenance techniques
 - future inspections
- Result
 - screws installed per design, acceptability
 confirmed




BASKET DAMAGE

- Problem.
 - dents, folds, ligaments, top rim
- Action
 - "detrimental damage" definition
 - (50.59, design change)
 - inspect, repair, and replace
 - techniques, contractor oversight, training, inspections following future maintenance
- Result
 - basket condition within approved design


DEBRIS

- Problem
 - foreign material in ice bed
- Action
 - thaw ice condensers, remove debris
 - strict QC on ice production
 - standards, training
 - pre-fill basket inspections
 - oversight
- Result
 - ice beds free of debris



GLYCOL HANGERS

- Problem
 - design non-conformances
- Action
 - capture as-built information
 - revisit design criteria
 - design change to redefine design criteria
 - potential hanger modifications
- Result
 - glycol support system installed per design




HOLD DOWN BAR WELDS

- Problem
 - weld failures, latent defects
- Action
 - visual inspections
 - · remove basket bottoms
 - non-destructive exams
 - inspection, repair, replacement
- Result
 - hold down bars per design

FLOOR SLAB

- Problem
 - possibility of water in slab
- Action
 - defrosts
 - examine water content
 - drainage modification
- Result
 - floor ready for freeze




SHOCK ABSORBERS

- Problem
 - damaged bags, foam, and mesh
- Action
 - removed bags for complete inspection
 - replacing shock absorbers with air boxes (except entrance end wall)
 - future protection, inspection
- Result
 - shock absorbers replaced with later generation design air boxes

SCHEDULE LOGIC

- Containment preps and temporary systems
- Thaw and clean
- Inspections, refurbishments, and technical issue resolution
- Revisit surveillance basis and procedures
- Chill ice condenser and reload ice
- Final installations and as-left surveillances
- Operability



SCHEDULE CHALLENGES

- Floor slab
- Glycol hangers
- Ice production
- Ice reload efficiency
 - Repair / refurbishment production

PROJECT STATUS


- Unit 1 ice condenser thawed
 - inspections
 - issue resolution
 - refurbishments
- Ice production and storage
- Surveillance basis research / procedures
- Preparations for unit 2 thaw




CONTAINMENT SPRAY (CTS) ISSUES RESOLUTION PROJECT

David F. Powell


CTS Issues Resolution Project Manager




- Problem: issues challenged CTS design basis
- Sources
 - containment spray SSFI
 - SERB walkdowns and readiness reviews
 - safety analysis upgrades
 - DBD and UFSAR review processes
 - EOP and NOP review processes



- Action: assemble interdisciplinary project team
 - source listing of known CTS issues
 - review and prioritize
 - identify potential resolution paths and key decision points
 - identify design change or regulatory involvement required




- Status: developed decision trees for key CTS issues to aid in resolution and planning
 - project management and communication tool
 - potential long lead items for restart (e.g. design changes or NRC submittals) identified
 - first step towards project plan and schedule when resolution paths are established
- Expected Result: CTS in conformance with design basis



CTS Pump Vibration


ĹJ


M



CTS Header Debris Removal

ורן






П


Hydrogen Analysis Issues

ĹΊ

1.3



Other Safety Analysis Issues .






- Future actions
 - establish resolution paths on each issue
 - optimize logic, advance key decision points
 - develop resource loaded project schedule
 - monitor progress, track commitments and remove obstacles



CALCULATIONS PROGRAMMATIC ASSESSMENT


Kenneth R. Baker

Director of Production Engineering



INTRODUCTION


- Short term assessment item
- Establish confidence
- Interim actions
- Improvements



OLD CALCULATIONS


- Problem
 - calculation deficiencies
- Action
 - independent review of 81 calculations
- Result
 - no inoperable conditions

OLD CALCULATIONS



CURRENT CALCULATIONS


- Problem
 - maintaining quality
- Action
 - focus on quality
 - peer review
 - contractor review
- Result
 - quality improved




CURRENT CALCULATIONS

14

lud






FUTURE CALCULATIONS

- Problem
 - expectations and standards
 - accuracy
 - review thoroughness
 - uniformity
 - assumption validity


ACTIONS

- Established clear program ownership
 - responsibilities
 - accountabilities
- Revising procedure
- Conducting training
 - management involvement
 - standards and expectations




ACTIONS

- Establishing effectiveness monitoring program
- Program improvements



EXPECTED RESULTS

- Design and licensing basis maintained
- Quality improvements
- Indicators to monitor calculations and provide feedback





PRODUCTION ENGINEERING FUNCTIONAL AREA ASSESSMENT


Kenneth R. Baker

Director of Production Engineering

. • •

SIX FUNCTIONAL AREAS

- •Reactor engineering
- •Preventive maintenance engineering
- •Instrument and controls engineering
- •Mechanical component engineering
- •Performance test engineering
- •Materials management



FUNCTIONAL AREA ASSESSMENT

Area 1 Area 2 Area 3 Area 4 Area 5

Staffing


! 4

Training

Commitments


Future

Other




FUNCTIONAL AREA ASSESSMENT RESULTS

Reactor Engineering



(examples)

- Problem
 - time critical information
- Action
 - assess and improve process
- Result
 - design and licensing basis maintained




(examples) .

• Problem

13

- low power physics training
- Action
 - provide familiarization training
- Result
 - event free startup



(examples)

- Problem
 - flux map data transfer changes
- Action
 - practice flux map data transfer
- Result
 - efficient flux map data transfer

(examples)

- Problem
 - reactivity management program document
- Action
 - formalize and roll out program
- Result
 - improved knowledge
 - event free startup
 - procedure based program


(examples).

- Problem
 - startups after extended outages
- Action
 - utilize experience from other utilities
- Result
 - event free startup

NON-RESTART ISSUES

(examples)

- Additional self assessments
- Training
 - codes used in core design and licensing
 - continuing education program





MAINTENANCE FUNCTIONAL AREA ASSESSMENT

John Boesch Maintenance Superintendent


ASSESSMENT AREAS

- Conduct of maintenance
- Work control process
- Corrective action process
- Procedures
- Training

CONDUCT OF MAINTENANCE

AREA SUB-TOPICS

- Pre-job briefs
- Procedure use and adherence
- Logs and records
- Shift turnovers
- Control of contractors
- Staffing adequacy



- Problem
 - formal procedure for shift turnover
- Action
 - develop a formal procedure
 - conduct briefings
- Result
 - improved shift turnover communication


WORK CONTROL PROCESS

AREA SUBTOPICS

- Planning effectiveness
- Scheduling effectiveness
- Materiel condition


NON-RESTART ITEM

- Problem
 - planning process issues
- Action
 - develop planner training program
 - track, trend, and assess performance
- Result
 - improved efficiency



NON-RESTART ITEM

- Problem
 - scheduling process issues
- Action
 - improve the process and procedures
 - tracking and trending
- Result
 - improved effectiveness



NON-RESTART ITEM

Problem

aggregate impact of minor equipment deficiencies

Action

- increased effort to reduce minor deficiencies
- training
- - tracking and trending

• Result

- improved materiel condition

