

CATEGORY 2

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9810050072 DOC DATE: 98/09/25 NOTARIZED: NO DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana M 05000315
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana M 05000316
 AUTH. NAME AUTHOR AFFILIATION
 GROBE, J.A. Region 3 (Post 820201)
 RECIP. NAME RECIPIENT AFFILIATION
 POWERS, R.P. American Electric Power Co., Inc.

SUBJECT: Forwards insp repts 50-315/98-19 & 50-316/98-19 on 980831-0903. No violations noted. Insp exam of activities conducted under license as they relate to radiation safety & to compliance with Commission rules & regulations.

DISTRIBUTION CODE: IE06F COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+11
 TITLE: Environ & Radiological (50 DKT) - Insp Rept/Notice of Violation Respons

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD3-3 PD	1 1	STANG, J	1 1
INTERNAL:	AEOD/TTC	1 1	FILE CENTER	1 1
	NMSS/SFPO 06F18	1 1	NRR/DRPM/PERB	1 1
	NUDOCS-ABSTRACT	1 1	OE DIR	1 1
	OGC/HDS3	1 1	RGN3 FILE 01	1 1
INTERNAL:	NOAC	1 1	NRC PDR	1 1
	NUDOCS FULLTEXT	1 1		

LOADED FROM
ELECTRONIC FILE

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LIST OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 13 ENCL 13

September 25, 1998

Mr. R. P. Powers
Senior Vice President
Nuclear Generation Group
American Electric Power Company
500 Circle Drive
Buchanan, MI 49107-1395

SUBJECT: NRC ROUTINE RADIATION PROTECTION INSPECTION REPORTS
50-315/98019(DRS); 50-316/98019(DRS)

Dear Mr. Powers:

On September 3, 1998, the NRC completed an inspection at your D. C. Cook, Units 1 and 2 reactor facility. The enclosed report presents the results of that inspection.

The inspection was an examination of activities conducted under your license as they relate to radiation safety and to compliance with the Commission's rules and regulations and with the conditions of your license. Areas specifically reviewed included the implementation of the radiological environmental monitoring program, maintenance of effluent monitors, and radiation protection department self-assessment activities. Station corrective actions for previously identified NRC violations were also reviewed. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observation of activities in progress.

No violations of NRC requirements were identified. The radiological environmental monitoring program was properly implemented, and the effluent radiation monitors were well maintained. We noted that you had taken corrective actions to address previously identified NRC violations; including self-assessments to measure performance. However, these assessments and our inspection findings indicate that radiation worker problems continue to exist at your facility. Therefore, two of the items reviewed will remain open so that your efforts to improve performance can be reviewed in subsequent inspections.

11

9810050072 980925
PDR ADDCK 05000315
G PDR



R. Powers

2

In accordance with 10 CFR 2.790 of the NRC'S "Rules of Practice," a copy of this letter and the enclosure will be placed in the NRC Public Document Room (PDR).

Sincerely,

Original Signed by Steven A. Reynolds (for)

John A. Grobe, Director
Division of Reactor Safety

Docket Nos.: 50-315; 50-316
License Nos.: DPR-58; DPR-74

Enclosure: Inspection Reports 50-315/98019(DRS); 50-316/98019(DRS)

cc w/encl: J. Sampson, Site Vice President
R. Eckstein, Chief Nuclear Engineer
D. Cooper, Plant Manager
R. Whale, Michigan Public Service Commission
Michigan Department of Environmental Quality
Emergency Management Division
MI Department of State Police
D. Lochbaum, Union of Concerned Scientists

Distribution:

RRB1 (E-Mail)
Project Mgr., NRR w/encl
J. Caldwell, RIII w/encl
C. Pederson, RIII w/encl
B. Clayton, RIII w/encl
SRI DC Cook w/encl
DRP w/encl
TSS w/encl
DRS (2) w/encl
RIII PRR w/encl
PUBLIC IE-01 w/encl
Docket File w/encl
GREENS
IEO (E-Mail)
DOCDESK (E-Mail)
DOCUMENT NAME: G:DRS\DCC98019.DRS

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RIII	<input checked="" type="checkbox"/>	RIII	<input checked="" type="checkbox"/>	RIII	<input checked="" type="checkbox"/>	RIII	<input checked="" type="checkbox"/>
NAME	Nissen:jp	<i>Shear</i>	<i>Walden</i>	<i>Bugess</i>	<i>Grobe</i>	<i>in</i>		
DATE	09/17/98	09/18/98	09/21/98	09/21/98	09/25/98			

OFFICIAL RECORD COPY
U.S. NUCLEAR REGULATORY COMMISSION

020009

