NRC FORM 366 (7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | LICENSEE CODE: F L T P S 4 (2) | LICENSE NUMBER: 0 0 - 0 0 0 0 0 - 0 0 (3) | LICENSE TYPE: 4 1 1 1 1 (4) | CAT (5)

CON'T 01 | REPORT SOURCE: L (6) | DOCKET NUMBER: 0 5 0 0 0 2 5 1 (7) | EVENT DATE: 0 9 0 3 7 9 (8) | REPORT DATE: 1 0 0 3 7 9 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 For a period of about 8 hours during dual unit shutdown, the Condensate
03 Storage Tank (CST) contained less than the 185,000 gallons required by T.S.
04 3.8.1.c. Operation in this mode is allowed by T.S. 3.8.3. The minimum
05 inventory during this interval was approximately 111,000 gallons. Public
06 health and safety was not affected. The only effect of having a reduced
07 volume in the tank is illustrated in FSAR Figure 9.11-1. Reference
08 similar occurrence: LER-251-78-14.

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
09	W F (11)	X (12)	Z (13)	Z Z Z Z Z Z (14)	Z (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	7 9	—	0 1 7	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
X (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	N (24)	Z (25)	Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Increased water demand for steam generator blowdown combined with reduced
11 water treatment plant output (as a result of resin bed regeneration)
12 resulted in CST level decreasing to less than the T.S. 3.8.1.c limit.
13 Filling of the CST began following resin bed regeneration.
14

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
15	G (28)	0 0 0 (29)	NA	A (31)	Operator Observation

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
16	Z (33)	Z (34)	NA	NA

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
17	0 0 0 (37)	Z (38)	NA

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
18	0 0 0 (40)	NA

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
19	Z (42)	NA

PUBLICITY

	ISSUED	DESCRIPTION (45)	NRC USE ONLY
20	N (44)	NA	

NAME OF PREPARER M. A. Schoppman PHONE: (305) 552-3802

7910190 47?0