3.7 PLANT SYSTEMS

3.7.2 Diesel Generator Cooling Water (DGCW) System

LCO 3.7.2 The following DGCW subsystems shall be OPERABLE:

a. Three DGCW subsystems; and

b. The opposite unit Division 2 DGCW subsystem.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

---NOTE---
Separate Condition entry is allowed for each DGCW subsystem.

DRAFT

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. --------NOTES-------- 1. Not applicable to Division 1 during installation of the Division 1 CSCS isolation valves during Unit 1 Refueling 18 while Unit 1 is in MODE 4,5, or defueled and during Unit 2 Refueling 18 while Unit 2 is in MODE 4,5, or defueled. 2. Not applicable to Division 2 during installation of the Division 2 CSCS isolation valves during Unit 2 Refueling 17 while Unit 2 is in MODE 4,5, or defueled and during Unit 1 Refueling 19 while Unit 1 is in MODE 4,5, or defueled. ---------- One or more DGCW subsystems inoperable.	A.1 Declare supported component(s) inoperable.	Immediately

(continued)

DRAFT

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. --------NOTES-------- 1. Only applicable to Division 1 during installation of the Division 1 CSCS isolation valves during Unit 1 Refueling 18 while Unit 1 is in Mode 4,5, or defueled and during Unit 2 Refueling 18 while Unit 2 is in Mode 4,5, or defueled. 2. Only applicable to Division 2 during installation of the Division 2 CSCS isolation valves during Unit 2 Refueling 17 while Unit 2 is in MODE 4,5, or defueled and during Unit 1 Refueling 19 while Unit 1 is in MODE 4,5, or defueled. ---------- One or more DGCW subsystems inoperable.	B.1 Restore DGCW subsystem to OPERABLE status.	7 days
C. Required Action and associated Completion Time of Condition B not met.	C.1 Be in MODE 3. AND C.2 Be in MODE 4.	12 hours 36 hours

DRAFT