

### 3.7 PLANT SYSTEMS

#### 3.7.2 Diesel Generator Cooling Water (DGCW) System

LC0 3.7.2 The following DGCW subsystems shall be OPERABLE:

- a. Three DGCW subsystems; and
- b. The opposite unit Division 2 DGCW subsystem.

APPLICABILITY: MODES 1, 2, and 3.

#### ACTIONS

-----NOTE-----  
Separate Condition entry is allowed for each DGCW subsystem.  
-----

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. <u>-----NOTES-----</u>  <u>1. Not applicable to Division 1 during installation of the Division 1 CSCS isolation valves during Unit 1 Refueling 18 while Unit 1 is in MODE 4,5, or defueled and during Unit 2 Refueling 18 while Unit 2 is in MODE 4,5, or defueled.</u>   <u>2. Not applicable to Division 2 during installation of the Division 2 CSCS isolation valves during Unit 2 Refueling 17 while Unit 2 is in MODE 4,5, or defueled and during Unit 1 Refueling 19 while Unit 1 is in MODE 4,5, or defueled.</u>  <u>-----</u>            One or more DGCW subsystems inoperable.</p>	<p>A.1 Declare supported component(s) inoperable.</p>	<p>Immediately</p>

(continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p><u>B. -----NOTES-----</u>  <u>1. Only applicable to Division 1 during installation of the Division 1 CSCS isolation valves during Unit 1 Refueling 18 while Unit 1 is in Mode 4,5, or defueled and during Unit 2 Refueling 18 while Unit 2 is in Mode 4,5, or defueled.</u>   <u>2. Only applicable to Division 2 during installation of the Division 2 CSCS isolation valves during Unit 2 Refueling 17 while Unit 2 is in MODE 4,5, or defueled and during Unit 1 Refueling 19 while Unit 1 is in MODE 4,5, or defueled.</u>  <u>-----</u>  <u>One or more DGCW subsystems inoperable.</u></p>	<p><u>B.1     Restore DGCW subsystem to OPERABLE status.</u></p>	<p><u>7 days</u></p>
<p><u>C. Required Action and associated Completion Time of Condition B not met.</u></p>	<p><u>C.1     Be in MODE 3.</u>  <u>AND</u>  <u>C.2     Be in MODE 4.</u></p>	<p><u>12 hours</u>  <u>36 hours</u></p>