

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | FIL | TP | S | 3 | ② | 0 | 0 | 1 | - | 10 | 10 | 10 | 10 | 0 | 0 | d | - | 10 | 10 | ③ | 4 | h | | | | | | | ④ | | | | ⑤

CONT

01 | REPORT SOURCE | L | ⑥ | 0 | 5 | 1 | 0 | 0 | 10 | 12 | 15 | 10 | ⑦ | 0 | 11 | 10 | B | 18 | 10 | ⑧ | 0 | 2 | 1 | 0 | 1 | 1 | 8 | 10 | ⑨

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES ⑩

02 | During a routine system walkthrough, the east fire pump was found to be inoperable. An investigation revealed that the pump may have been inoperable for 17 days due to its power supply breaker not being closed following periodic maintenance. The breaker was closed and the pump declared operable on 01/04/80. Inoperability of a fire pump in excess of 7 days is reportable pursuant to TS 3.14.2.b.1. Redundant pump was operable throughout this period.

09 | SYSTEM CODE | A | B | ⑪ | CAUSE CODE | A | ⑫ | CAUSE SUBCODE | A | ⑬ | COMPONENT CODE | P | U | M | P | X | X | ⑭ | COMP. SUBCODE | B | ⑮ | VALVE SUBCODE | Z | ⑯

17 | LER/RO REPORT NUMBER | 8 | 0 | ⑰ | SEQUENTIAL REPORT NO. | 0 | 0 | 1 | ⑱ | OCCURRENCE CODE | 0 | 1 | 3 | ⑲ | REPORT TYPE | L | ⑳ | REVISION NO. | 0 | ㉑

ACTION TAKEN | X | ⑳ | FUTURE ACTION | G | ㉑ | EFFECT ON PLANT | Z | ㉒ | SHUTDOWN METHOD | Z | ㉓ | HOURS | 0 | 0 | 0 | ⑳ | ATTACHMENT SUBMITTED | Y | ㉔ | NPRO-4 FORM SUB. | N | ㉕ | PRIME COMP. SUPPLIER | A | ㉖ | COMPONENT MANUFACTURER | F | 0 | 1 | 1 | 0 | ㉗

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS ㉘

10 | The cause of this event was improper operator action following a maintenance clearance. Long term corrective action is a procedure change to require a daily check and log entry confirming that power is available to both fire pumps.

15 | FACILITY STATUS | H | ㉘ | % POWER | 0 | 0 | 0 | ㉙ | OTHER STATUS | NA | ㉚ | METHOD OF DISCOVERY | C | ㉛ | DISCOVERY DESCRIPTION | Shift Technical Advisor Observation | ㉜

15 | ACTIVITY CONTENT RELEASED OF RELEASE | Z | ㉝ | Z | ㉞ | AMOUNT OF ACTIVITY | NA | ㉟ | LOCATION OF RELEASE | NA | ㊱

17 | PERSONNEL EXPOSURES NUMBER | 0 | 0 | 0 | ㊲ | TYPE | Z | ㊳ | DESCRIPTION | NA | ㊴

18 | PERSONNEL INJURIES NUMBER | 0 | 0 | 0 | ㊵ | DESCRIPTION | NA | ㊶

19 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | ㊷ | DESCRIPTION | NA | ㊸

20 | PUBLICITY ISSUED DESCRIPTION | N | ㊹ | DESCRIPTION | NA | ㊺

NAME OF PREPARER M. A. Schoppman

PHONE: (305) 552-3802

80 09220 370

NRC USE ONLY

REPORTABLE OCCURRENCE 250-80-001

LICENSEE EVENT REPORT

PAGE TWO

Additional Event Description and Probable Consequences

During a routine system walk through a shift technical advisor found the East fire pump to be inoperable. Subsequent investigation revealed that the pump may have been inoperable for 17 days due to its power supply breaker not having been closed following periodic maintenance on the breaker. The breaker was closed and the pump declared operable on 01/04/80. Inoperability of a Fire pump in excess of 7 days is reportable pursuant to TS 3.14.2.b.1. The redundant fire pump was operable throughout this period. Similar occurrences have been reported on LER 250-79-001, LER 250-79-024, and LER 250-79-027