

480V MOTOR CONTROL CENTER NO. 2B5 (SB) (CONTINUED)



- NOTES:
- FOR GENERAL NOTES, SYMBOLS AND ABBREVIATIONS SEE INDEX DRAWING 2998-G-275SH.A
  - SECOND PROTECTIVE DEVICE IS REQUIRED TO ASSURE CIRCUIT IS IN CONFORMANCE WITH NRC REG. GUIDES 1.63 OR 1.75.

RECEIVED  
 STATE OF FLORIDA  
 ALAN L. SCHILDKRAUT  
 Registered PE  
 Approval Date: 04/03/84

**NUCLEAR SAFETY RELATED**  
 THE ORIGINAL DRAWING WITH APPROVAL SIGNATURES AND THE PE SEAL AND SUBSEQUENT REVISIONS THEREOF WITH APPROVAL NAMES AND INITIALS ARE MAINTAINED IN THE FILES OF EBASCO SERVICES INCORPORATED.

THIS DOCUMENT IS THE PROPERTY OF EBASCO SERVICES INCORPORATED. ITS USE IS EXPRESSLY RESTRICTED BY THE TERMS OF THE CONTRACT, DATED AS OF SEPT. 1, 1975 BETWEEN EBASCO SERVICES INCORPORATED AND FLORIDA POWER & LIGHT COMPANY.

FLORIDA POWER & LIGHT COMPANY  
 ST. LUCIE PLANT  
 1983-890MW (e) EXTENSION-UNIT NO. 2

480V MOTOR CONTROL CENTER NO. 2B5 SH.2  
 ONE LINE DIAGRAM

EBASCO SERVICES INCORPORATED

SCALE NONE APPROVED DATE 04-03-84  
 DIV. ELECTRICAL A SCHILDKRAUT 2998-G-275  
 DR. J McKNIGHT KENNETH HANCOCK SHEET 36  
 CH. R. ENGESSER WHL

INFORMATION ONLY  
 VERIFY WITH A CONTROLLED COPY BEFORE USE.

SI APERTURE CARD

NO	DATE	REVISION	BY	CH	APPROVED
3	7-7-86	REVISED: COMPT KR4 (H2) PER PCM 028-284	AP	R	[Signature]
2	8-6-85	REVISED: DWS TITLE (N.D.) NOTES (U18), DWS NO. (A2, N10), PER GENERAL AS BUILT	J.V.C.	R.C.	[Signature]
1	5-28-85	REVISED: COMPT. CR4 (H1) PER K&A; TABLE SIZE (C14); NOTE (J18) PER PCM-015-282	R.C.	[Signature]	[Signature]
4	4-17-87	REVISED: MCC 2B5 COMPT. LF4 PER PCM 02-286	AP	R	[Signature]

ATTENTION: ANY REVISION TO THIS DRAWING MUST BE MADE BY COMPUTER AIDED DESIGN DRAFTING

054-1116 11/15/80  
 17 46888 8/23/81  
 012345 / 12345