NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01	FLTPS3 (2)	00-00000-00 (3)	41111 (4)	(5)	
	LICENSEE CODE	LICENSE NUMBER	LICENSE TYPE	CAT	

CON'T

01	REPORT SOURCE X (6)	05000250 (7)	062480 (8)	070880 (9)
		DOCKET NUMBER	EVENT DATE	REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 Notification was received from our NSSS vendor that a potential safety
03 concern could exist regarding intermittent contact operation of the Westing-
04 house "W-2" switch in the neutral position. The applicable switch has a
05 spring return to the neutral position. FPL has tentatively identified this
06 as reportable pursuant to 10 CFR 21 based on the preliminary information
07 from the vendor. (Refer to Westinghouse letter NS-TMA-2264 dated June 18,
08 1980 to V. Stello, Director, OI&E.

09	SYSTEM CODE SB (11)	CAUSE CODE X (12)	CAUSE SUBCODE X (13)	COMPONENT CODE INSTRU (14)	COMP. SUBCODE S (15)	VALVE SUBCODE Z (16)	
(17) LER/RO REPORT NUMBER	EVENT YEAR 80	—	SEQUENTIAL REPORT NO. 013	/	OCCURRENCE CODE 09	REPORT TYPE X	REVISION NO. 0
	ACTION TAKEN X (18)	FUTURE ACTION X (19)	EFFECT ON PLANT Z (20)	SHUTDOWN METHOD Z (21)	HOURS (22) 0000	ATTACHMENT SUBMITTED N (23)	NPRO-4 FORM SUB. N (24)	PRIME COMP. SUPPLIER N (25)	COMPONENT MANUFACTURER W120 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 No failures of this type have been observed on either unit. A program
11 has been established to (1) tabulate quantity and function, and (2) test
12 safety related W-2 switches. The applicability of this occurrence to
13 St. Lucie Units 1 and 2 will be addressed.
14

15	FACILITY STATUS E (28)	% POWER 100 (29)	OTHER STATUS (30) NA	METHOD OF DISCOVERY D (31)	DISCOVERY DESCRIPTION (32) Notification from vendor
16	ACTIVITY RELEASED Z (33)	CONTENT OF RELEASE Z (34)	AMOUNT OF ACTIVITY (35) NA		LOCATION OF RELEASE (36) NA
17	PERSONNEL EXPOSURES NUMBER 000 (37)	TYPE Z (38)	DESCRIPTION (39) NA		
18	PERSONNEL INJURIES NUMBER 000 (40)	DESCRIPTION (41) NA			
19	LOSS OF OR DAMAGE TO FACILITY TYPE Z (42)	DESCRIPTION (43) NA			
20	PUBLICITY ISSUED N (44)	DESCRIPTION (45) NA			NRC USE ONLY

NAME OF PREPARER M. A. SCHOPPMAN PHONE: (305)552-3802

8008210384