

APPENDIX A

NOTICE OF VIOLATION

Florida Power and Light Company
Turkey Point

License Nos. DPR-31
& DPR-41

Based on the NRC inspection June 4-6, 1980, certain of your activities were apparently not conducted in full compliance with NRC requirements as indicated below. These items have been categorized as described in correspondence to you dated December 31, 1974.

As required by Section 6.4.2 of the Technical Specifications, a fire brigade training program which meets or exceeds the requirements of National Fire Protection Association Manual No. 27 (NFPA-27), Private Fire Brigades, is required to be maintained except training sessions are required to be conducted quarterly. Sections 41 and 42 of NFPA-27 requires a schedule of training to be established and to be adopted to the needs of the brigade and to include actual fire fighting operations. Section 51 of NFPA-27 requires practice drills to be conducted to check the ability of the brigade members to perform the operations that they are expected to carry out.

Contrary to the above, records available do not indicate that all members of the brigade, primarily members from operations, routinely attend the quarterly fire brigade training drills, participate in actual fire fighting practice sessions, participate in quarterly scheduled classroom training sessions, and, that fire brigade team leaders are given advanced training in fire protection and fire fighting.

This is an infraction.

8009120531

2
3

