

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8010010549    DOC. DATE: 80/09/26    NOTARIZED: NO    DOCKET #  
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C    05000250  
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C    05000251  
 AUTH. NAME    AUTHOR AFFILIATION  
 UHRIG, R.E.    Florida Power & Light Co.  
 RECIP. NAME    RECIPIENT AFFILIATION  
 EISENHUT, D.G.    Division of Licensing

SUBJECT: Forwards supplemental info re 790131 request for amend to Tech Spec, allowing deletion of interim fuel residence time limits. Requests NRC approval by 801130. Attachments A & B encl.

DISTRIBUTION CODE: A001S    COPIES RECEIVED: LTR    ENCL    SIZE:     
 TITLE: General Distribution for after Issuance of Operating Lic

NOTES:

ACTION:	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTR	ENCL		LTR	ENCL
	VARGA, S.    04	13	13			
INTERNAL:	D/DIR, HUM FAC08	1	1	I&E	06	2
	NRC PDR    02	1	1	OELD	11	0
	OR ASSESS BR 10	1	0	<u>REG FILE</u>	01	1
EXTERNAL:	ACRS    09	16	16	LPDR	03	1
	NSIC    05	1	1			

OCT 2 1980

TOTAL NUMBER OF COPIES REQUIRED: LTR 39 ENCL 37  
~~38~~    ~~36~~



1951 10 3



September 26, 1980  
L-80-322

Office of Nuclear Reactor Regulation  
Attention: Mr. Darrell G. Eisenhut, Director  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dear Mr. Eisenhut:

Re: Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
Fuel Residence Time Limit

This letter supplements our request of January 31, 1979 (L-79-25) to amend the subject Technical Specification. Attachment A responds to the NRC Staff verbal questions. Attachment B provides the requested information on primary coolant activity.

The interim fuel residence time limits in the Turkey Point Technical Specifications no longer apply to the fuel in Turkey Point Units 3 and 4. The limits were established for specific regions of unpressurized fuel in early fuel cycles (Region 2 for Unit 3, Cycle 4 and Region 3 for Unit 4, Cycle 2) to assure that fuel clad flattening would not be expected to occur. The limits of 27,000 EFPH for Unit 3 and 30,000 EFPH for Unit 4 are now predicted to be in excess of 50,000 EFPH for both units.


A fuel residence time Technical Specification limit is not necessary. A reload safety evaluation is conducted prior to each reload. The effects of the reload on the design basis and postulated accidents analyzed in the FSAR are examined. Each fuel region is checked during the reload design process to assure that clad flattening is not expected to occur. Further, for each reload cycle our Turkey Point Plant Nuclear Safety Committee and Florida Power & Light Company Nuclear Review Board review and approve the Reload Safety Evaluation (RSE) report. It is noted that most operating plants do not have fuel residence time limitations based on clad flattening, but these plants do assure that a no-clad flattening design basis is satisfied as a result of the reload design process and review.

The limit for Unit 3 will be exceeded during the current fuel cycle, i.e., Cycle 7. The limit for Unit 4 will be exceeded during the next fuel cycle,

A001  
5  
1/1

8001010 549


P



Office of Nuclear Reactor Regulation  
Page Two

i.e., Cycle 7. Accordingly, approval of our request to delete the interim fuel residence time limits, as proposed on January 30, 1979, is required by November 30, 1980.

Very truly yours,




Robert E. Uhrig  
Vice President  
Advanced Systems & Technology

REU/RAK/ah

Attachments

cc: J. P. O'Reilly, Region II  
Harold F. Reis, Esquire



ATTACHMENT A

Re: Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
Fuel Residence Time Limit

1. If the restriction on residence time is lifted, what is the potential increase in fuel assembly burnup (MWD/MTU)?

Response:

The projected increase in the maximum fuel assembly burnup with the deletion of the fuel residence time limit is expected to be less than 3,500 MWD/MTU. Expected burnups for current fuel cycles, i.e., Unit 3 Cycle 7 and Unit 4 Cycle 6, and future cycles are shown below.

With respect to Unit 3 Cycle 7, Batch 5A (10 assemblies) will exceed the 27,000 EFPH limit before the end of the cycle. The burnup of these Batch 5A assemblies projected for EOC will be:

35,000 MWD/MTU Batch Average  
37,700 MWD/MTU Maximum Assembly  
28,500 MWD/MTU Minimum Assembly

The average burnup of all the fuel (Batches 5A and 6), that will be discharged from Cycle 7 is 35,000 MWD/MTU. The maximum assembly burnup of the discharged fuel is 37,700, which is a Batch 6 assembly that does not exceed the residence time limit.

Although the fuel in Unit 4 Cycle 6 will not exceed the 30,000 EFPH limit, the end of cycle burnups for comparison purposes are expected to be: 33,200 MWD/MTU discharge average and 36,000 MWD/MTU for the maximum assembly.

Although an increase in fuel residence time is expected in future fuel cycles, a decrease in maximum assembly burnup (less than 37,000 MWD/MTU is expected for Unit 3, Cycles 8 and 9. For Unit 4 Cycle 7, the maximum assembly burnup will remain essentially the same (37,900 MWD/MTU).

Florida Power & Light Company may consider fuel cycles in the mid 1980's with maximum assembly burnups of up to 41,000 MWD/MTU for Unit 3 and 39,000 MWD/MTU for Unit 4. However, we have not yet made decisions regarding these fuel cycles and fuel cycles beyond the mid 1980's.

2. Have the radiological consequences of accidents where fuel failure is predicted by calculation (e.g., locked rotor incident, fuel handling accident, and others) been examined to assure that the FSAR evaluation is still conservative?



Handwritten text, possibly bleed-through from the reverse side of the page. The text is faint and mostly illegible due to the quality of the scan. It appears to be organized into several lines or paragraphs, with some characters resembling numbers and letters. The text is located in the upper right quadrant of the page.



Response:


The radiological consequences of accidents are analyzed for iodine and noble gas releases only. All of the important radioactive iodine and noble gas nuclides are of short half-life compared to the fuel cycle time, with the exception of Kr-85. Thus, except for Kr-85, all reach equilibrium inventories in the fuel so that the release of fission products from fuel failures is independent of burnup. In the case of Kr-85, both the small inventory present and the small biological effects of Kr-85 radiation result in insignificant changes in radiological consequences of accidents involving fuel failures as a result of changes in fuel assembly burnup.

3. What mechanism would the licensee propose to assure that, in addition to clad flattening, radiological consequences of postulated accidents are reviewed on a cycle-by-cycle basis?

Response:

The Reload Safety Evaluation identifies any changes in potential consequences of accidents from a core performance standpoint (e.g., differences in number of rods with minimum DNBR<1.3). These changes would be reviewed by the appropriate radiation specialists within Westinghouse to determine the impact of these changes on the radiological consequences of postulated accidents. Thus, there would be assurance that the radiological consequences of accidents are assessed on a cycle-by-cycle basis.

Furthermore, Florida Power & Light Company reviews the results of the Reload Safety Evaluation and concurs with the conclusions prior to each reload.




ATTACHMENT B

Re: Turkey Point Units 3 & 4  
Docket Nos. 50-250 & 50-251  
Fuel Residence Time Limit

Unit 3, Cycle 7  
Monthly Radiochemical Surveillance  
Primary Coolant Iodine Activity

<u>Month/Year</u>	<u>I-131 (<math>\mu\text{Ci/ml}</math>)</u>	<u>I-133 (<math>\mu\text{Ci/ml}</math>)</u>
Feb. 1980	$2.1 \times 10^{-3}$	$2.3 \times 10^{-2}$
Mar. 1980	$1.6 \times 10^{-3}$	$1.9 \times 10^{-2}$
April 1980	$2.2 \times 10^{-3}$	$2.1 \times 10^{-2}$
May 1980	$9.8 \times 10^{-4}$	$1.2 \times 10^{-2}$
June 1980	$2.7 \times 10^{-3}$	$1.9 \times 10^{-2}$
July 1980	$2.5 \times 10^{-3}$	$2.9 \times 10^{-2}$
Aug. 1980	$3.5 \times 10^{-3}$	$2.4 \times 10^{-2}$



Re: Turkey Point Units 3 & 4  
Docket Nos. 50-250 & 50-251  
Fuel Residence Time Limit

Unit 4, Cycle 6  
Monthly Radiochemical Surveillance  
Primary Coolant Iodine Activity

<u>Month/Year</u>	<u>I-131 (<math>\mu\text{Ci/ml}</math>)</u>	<u>I-133 (<math>\mu\text{Ci/ml}</math>)</u>
July 1979	$1.6 \times 10^{-3}$	$5.9 \times 10^{-3}$
Aug. 1979	$1.2 \times 10^{-3}$	$6.7 \times 10^{-3}$
Sept. 1979	$1.7 \times 10^{-3}$	$7.0 \times 10^{-3}$
Oct. 1979	$1.4 \times 10^{-3}$	$7.7 \times 10^{-3}$
Nov. 1979	$1.2 \times 10^{-2}$	$1.1 \times 10^{-2}$
Dec. 1979	$3.1 \times 10^{-3}$	$9.4 \times 10^{-3}$
Jan. 1980	$2.2 \times 10^{-3}$	$8.0 \times 10^{-3}$
Feb. 1980	$6.1 \times 10^{-3}$	$1.5 \times 10^{-2}$
Mar. 1980	$2.5 \times 10^{-3}$	$1.2 \times 10^{-2}$
April 1980	$3.0 \times 10^{-3}$	$1.3 \times 10^{-2}$
May 1980	Shutdown	Shutdown
June 1980	Shutdown	Shutdown
July 1980	$3.4 \times 10^{-3}$	$1.7 \times 10^{-2}$
Aug. 1980	$2.6 \times 10^{-3}$	$1.2 \times 10^{-2}$

1000

