

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | F | L | T | P | S | 3 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 4 | 1 | 1 | 1 | 1 | 1 | 4 | 9

CON'T 01 | L | 0 | 5 | 0 | 0 | 0 | 2 | 5 | 0 | 0 | 1 | 0 | 3 | 8 | 1 | 0 | 1 | 1 | 6 | 8 | 1 | 9

02 | While performing a planned unit shutdown, the boric acid flowpath from
03 | the boric acid tanks as described in TS 3.6.b.4 was found to be obstructed.
04 | The flow path was re-established in 1 hr. 33 min. Public health and
05 | safety was not affected. The alternate flow path from the Refueling
06 | Water Storage Tank was operable throughout this period. Reference FSAR
07 | Sec. 9.2.2 Similar occurrences were reported as AO 251-74-08, and LERs
08 | 251-77-11, 251-77-12, and 251-79-1.

09 | SYSTEM CODE: P C | CAUSE CODE: E | CAUSE SUBCODE: A | COMPONENT CODE: E L E C O N | COMP. SUBCODE: Z | VALVE SUBCODE: Z
17 | LER/RO REPORT NUMBER: 8 1 | SEQUENTIAL REPORT NO.: 0 0 2 | OCCURRENCE CODE: 0 1 | REPORT TYPE: T | REVISION NO.: 0
18 | ACTION TAKEN: X | FUTURE ACTION: Z | EFFECT ON PLANT: Z | SHUTDOWN METHOD: Z | HOURS: 0 0 0 | ATTACHMENT SUBMITTED: N | NPD-4 FORM SUB.: N | PRIME COMP. SUPPLIER: L | COMPONENT MANUFACTURER: C 3 3 2

10 | The apparent cause of the obstruction was reduced temperature resulting
11 | from failure of one channel of heat tracing circuit no. 21. The circuit
12 | was found to have 4 open sections and a partial ground. The root cause
13 | could not be determined. The temperature set point on the remaining
14 | channel was increased to re-establish flow. Damaged channel was repaired.

15 | FACILITY STATUS: D | % POWER: 0 9 2 | OTHER STATUS: NA | METHOD OF DISCOVERY: A | DISCOVERY DESCRIPTION: Operator Observation

16 | ACTIVITY CONTENT RELEASED OF RELEASE: Z | AMOUNT OF ACTIVITY: NA | LOCATION OF RELEASE: NA

17 | PERSONNEL EXPOSURES NUMBER: 0 | TYPE: Z | DESCRIPTION: NA

18 | PERSONNEL INJURIES NUMBER: 0 | DESCRIPTION: NA

19 | LOSS OF OR DAMAGE TO FACILITY TYPE: Z | DESCRIPTION: NA

20 | PUBLICITY ISSUED: N | DESCRIPTION: NA

NAME OF PREPARER: P.L. Pace PHONE: (305) 552-3801

40