



DISTRIBUTION  
 Docket Files  
 NRC PDR  
 Local PDR  
 ORB 1 File  
 D. Eisenhut  
 OELD  
 OI&E (3)  
 S. Varga  
 M. Grotenhuis  
 C. Parrish  
 J. Olshinski  
 W. Marsh, Res. Insp. Turkey Point  
 NSIC  
 TERA  
 ACRS (10)

MAY 8 1981

Docket Nos. 50-250  
 and 50-251

Dr. Robert E. Uhrig, Vice President  
 Advanced Systems and Technology  
 Florida Power and Light Company  
 Post Office Box 529100  
 Miami, Florida 33152

Dear Dr. Uhrig:

On April 7, 1980 we sent you a copy of the staff evaluation of the TMI Lessons Learned Category "A" items on the Turkey Point Plant Unit Nos. 3 and 4. On November 10, 1980 (L-80-378) you responded regarding a clarification of your compliance with items 2.1.4 Containment Isolation, which required "a dedicated person will be assigned to close it [the normally closed manually operated isolation valves] immediately in the event of an emergency or when the operation is complete." Your clarification indicated that the Nuclear Control Center Operator would be required to "close the appropriate valves under specified accident conditions."

Your clarification apparently overlooks the second essential requirement of the dedicated person, namely, to close the isolation valves in question "when the operation is complete." Further, your clarification did not mention that the normally closed manual isolation valves would be locked closed.

We cannot agree to your clarification unless the second essential requirement of the dedicated person is included and the valves are normally locked in the closed position. Please respond in 30 days and indicate your compliance with these requirements.

Sincerely,

Original Signed By:

Steven A. Varga, Chief  
 Operating Reactors Branch No. 1  
 Division of Licensing

**REGULATORY DOCKET FILE COPY**

P 9105130102

OFFICE	ORB	ORB	ORB				
SURNAME	MGrotenhuis	JOlshinski	SVarga				
DATE	5/6/81	5/7/81	5/7/81				

MAY 6 1981

16  
17

18

Robert E. Uhrig  
Florida Power and Light Company

MAY .8 1981

cc: Mr. Robert Lowenstein, Esquire  
Lowenstein, Newman, Reis and Axelrad  
1025 Connecticut Avenue, N.W.  
Suite 1214  
Washington, D. C. 20036

Environmental and Urban Affairs Library  
Florida International University  
Miami, Florida 33199

Mr. Norman A. Coll, Esquire  
Steel, Hector and Davis  
1400 Southeast First National  
Bank Building  
Miami, Florida 33131

Mr. Henry Yaeger, Plant Manager  
Turkey Point Plant  
Florida Power and Light Company  
P. O. Box 013100  
Miami, Florida 33101

Mr. Jack Shreve  
Office of the Public Counsel  
Room 4, Holland Building  
Tallahassee, Florida 32304

Administrator  
Department of Environmental Regulation  
Power Plant Siting Section  
State of Florida  
2600 Blair Stone Road  
Tallahassee, Florida 32301

Resident Inspector  
Turkey Point Nuclear Generating Station  
U. S. Nuclear Regulatory Commission  
Post Office Box 1207  
Homestead, Florida 33030

MAY 07 1981